

J. Bernie Beasley, Jr., P.E.
Vice President
Vogtle Project

**Southern Nuclear
Operating Company, Inc.**
40 Inverness Center Parkway
P.O. Box 1295
Birmingham, Alabama 35201

Tel 205.992.7110
Fax 205.992.0403



November 2, 2001

Docket Nos. 50-424
50-425

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

VOGTLE ELECTRIC GENERATING PLANT
EMERGENCY RESPONSE DATA SYSTEM (ERDS)
DATA POINT LIBRARY MODIFICATIONS


Ladies and Gentlemen:

In accordance with the requirements of 10 CFR 50, Appendix E, Section VI, Item 3a, Southern Nuclear Operating Company is submitting changes to the Vogtle Electric Generating Plant Unit 1 and Unit 2 Emergency Response Data System (ERDS) data point library. The changes were implemented on October 15, 2001.

Data point R6980 (Radwaste Processing Facility Exhaust Particulates) has been added to provide the NRC with the particulate radiation value from the new facility.

If you have any questions, please contact this office.

Sincerely,

A handwritten signature in dark ink, appearing to be "JBB/TEW", is written over the typed name.

JBB/TEW

Attachments (2): New pages to the Unit 1 and Unit 2 ERDS Data Point Library

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser
Mr. M. Sheibani
SNC Document Management
U. S. Nuclear Regulatory Commission, Washington, DC
Mr. R. R. Assa, Project Manager, NRR
Mr. L. A. Reyes, Regional Administrator
Mr. J. Zeiler, NRC Senior Resident Inspector, Vogtle

A026

Date	: 10/02/01
Reactor Unit	: VO1
Data Feeder	: N/A
NRC ERDS Parameter	: Not Listed
Point ID	: R6980
Plant Spec. Point	: ARE-16980A RW PROC FAC EXH PARTICULATE
Generic/Cond.	: RW PROC FAC EXH PARTICULATE
Analog/Digital	: A
Engr. Units/Dig	: uCI/CC
Engr. Units	: 1.0E-13 to 1.0E-07 uCI/CC
Minimum Instr.	: 1.0E-13
Maximum Instr.	: 1.0E-07
Zero Point	: N/A
Reference Point	: N/A
Proc or Sens.	: S
Number of Sensors	: N/A
How Processed	: N/A - THIS IS A DIRECT SENSOR INPUT
Sensor Locations	: RPF VENTILATION STACK
Alarm/Trip Setpoints	: VARIABLE
NI Power Cut Off	: N/A
NI Power Turn On	: N/A
Instrument Failure	: N/A
Temp. Comp.	: N
Level Reference	: N/A

Unique System

This point provides indication of radioactivity releases through the Radwaste Processing Facility (RPF) vent. It is located in the stack beyond the last point of gaseous radioactivity addition to the effluent path. The RPF is common to Unit 1 and Unit 2.

Date	: 10/02/01
Reactor Unit	: VO2
Data Feeder	: N/A
NRC ERDS Parameter	: Not Listed
Point ID	: R6980
Plant Spec. Point	: ARE-16980A RW PROC FAC EXH PARTICULATE
Generic/Cond.	: RW PROC FAC EXH PARTICULATE
Analog/Digital	: A
Engr. Units/Dig	: uCI/CC
Engr. Units	: 1.0E-13 to 1.0E-07 uCI/CC
Minimum Instr.	: 1.0E-13
Maximum Instr.	: 1.0E-07
Zero Point	: N/A
Reference Point	: N/A
Proc or Sens.	: S
Number of Sensors	: N/A
How Processed	: N/A - THIS IS A DIRECT SENSOR INPUT
Sensor Locations	: RPF VENTILATION STACK
Alarm/Trip Setpoints	: VARIABLE
NI Power Cut Off	: N/A
NI Power Turn On	: N/A
Instrument Failure	: N/A
Temp. Comp.	: N
Level Reference	: N/A

Unique System

This point provides indication of radioactivity releases through the Radwaste Processing Facility (RPF) vent. It is located in the stack beyond the last point of gaseous radioactivity addition to the effluent path. The RPF is common to Unit 1 and Unit 2.