

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**RICHMOND, VIRGINIA 23261**

January 2, 2002

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No.:	01- 751
CM/RAB	R0
Docket Nos.:	50-338
	50-339
License Nos.:	NPF-4
	NPF-7

Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)**  
**NORTH ANNA POWER STATION UNITS 1 AND 2**  
**PROPOSED IMPROVED TECHNICAL SPECIFICATIONS (ITS)**  
**REQUEST FOR ADDITIONAL INFORMATION (RAI)**  
**ITS 3.3.1, FUNCTION 6, DOC L.21 (TAC Nos. MB 1437 and MB 1432)**

This letter transmits our response to the NRC's request for additional information (RAI) regarding the North Anna Power Station (NAPS) Units 1 and 2 proposed Improved Technical Specifications (ITS). The North Anna ITS license amendment request was submitted to the NRC in a December 11, 2000 letter (Serial No. 00-606). The NRC requested additional information regarding the proposed allowable value for the overtemperature delta temperature (OT $\Delta$ T) function in a NRC letter dated December 7, 2001 (TAC Nos. MB 1437 and MB 1432).

After evaluating the NRC's request, Dominion has decided that the additional costs that would be required to obtain the NRC's approval of the proposed change are not warranted. Therefore, Dominion is withdrawing the proposed change. The ITS submittal will be revised to reflect the value in the current Technical Specifications, which is more conservative than the value originally proposed in the ITS.

If you have any further questions or require additional information, please contact us.

Very truly yours,



Leslie N. Hartz  
Vice President - Nuclear Engineering

Commitments made in this letter: None

A001

cc: U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth Street, SW  
Suite 23T85  
Atlanta, Georgia 30303-8931

Mr. Tommy Le  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Mail Stop 12 H4  
Rockville, MD 20852-2738

Mr. M. J. Morgan  
NRC Senior Resident Inspector  
North Anna Power Station

Commissioner  
Bureau of Radiological Health  
1500 East Main Street  
Suite 240  
Richmond, VA 23218

Mr. J. E. Reasor, Jr.  
Old Dominion Electric Cooperative  
Innsbrook Corporate Center  
4201 Dominion Blvd.  
Suite 300  
Glen Allen, Virginia 23060