

January 18, 2002

Mr. J. A. Price
Vice President - Nuclear Technical Services - Millstone
c/o Mr. David A. Smith
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3 - CORRECTION TO
AMENDMENT NO. 198 (TAC NO. MB1389)

Dear Mr. Price:

On November 5, 2001, the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 198 to Facility Operating License No. NPF-49. Amendment No. 198 revised the Technical Specifications to extend the surveillance interval for certain engineered safety features actuation system slave relays from 90 days to 18 months.

Inadvertently, page 3/4 3-40 was included on the errata page as an updated page, but was not included with the updated pages. No changes were made to this page and it should not have been included on the errata page for the amendment. Please update your copy of Amendment No. 198 with the enclosed corrected errata page.

The NRC regrets any inconvenience this may have caused.

Sincerely,

/RA/

Victor Nerses, Sr. Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: Errata page

cc w/encl: See next page

ATTACHMENT TO LICENSE AMENDMENT NO. 198

FACILITY OPERATING LICENSE NO. NPF-49

DOCKET NO. 50-423

Replace the following pages of the Appendix A Technical Specifications, with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3/4 3-36	3/4 3-36
3/4 3-37	3/4 3-37
3/4 3-38	3/4 3-38
3/4 3-39	3/4 3-39
3/4 3-41	3/4 3-41
B 3/4 3-2a	B 3/4 3-2a

January 18, 2002

Mr. J. A. Price
Vice President - Nuclear Technical Services - Millstone
c/o Mr. David A. Smith
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NO. 3 - CORRECTION TO
AMENDMENT NO. 198 (TAC NO. MB1389)

Dear Mr. Price:

On November 5, 2001, the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 198 to Facility Operating License No. NPF-49. Amendment No. 198 revised the Technical Specifications to extend the surveillance interval for certain engineered safety features actuation system slave relays from 90 days to 18 months.

Inadvertently, page 3/4 3-40 was included on the errata page as an updated page, but was not included with the updated pages. No changes were made to this page and it should not have been included on the errata page for the amendment. Please update your copy of Amendment No. 198 with the enclosed corrected errata page.

The NRC regrets any inconvenience this may have caused.

Sincerely,

/RA/

Victor Nerses, Sr. Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: Errata page

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	GHill(2)	JClifford	GTracy	ACRS
PDI-2 R/F	LLois	WBeckner	EMarinos	SSheng
EAdensam	TClark	CCowgill, RI	VNerses	

ADAMS ACCESSION NUMBER: ML020090596

OFFICE	PDI-2:PM	PDI-2:LA	PDI-2:SC	
NAME	VNerses	TClark	JClifford	
DATE	01/14/02	01/14/02	01/17/02	

OFFICIAL RECORD COPY

Millstone Nuclear Power Station
Unit 3

cc:

Ms. L. M. Cuoco
Senior Nuclear Counsel
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.
Director, Division of Radiation
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

First Selectmen
Town of Waterford
15 Rope Ferry Road
Waterford, CT 06385

Mr. P. J. Parulis
Process Owner - Oversight
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Mr. W. R. Matthews
Vice President and Senior
Nuclear Executive - Millstone
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Ernest C. Hadley, Esquire
P.O. Box 1104
West Falmouth, MA 02574-1104

Mr. John Markowicz
Co-Chair
Nuclear Energy Advisory Council
9 Susan Terrace
Waterford, CT 06385

Mr. Evan W. Woollacott
Co-Chair
Nuclear Energy Advisory Council
128 Terry's Plain Road
Simsbury, CT 06070

Mr. D. A. Christian
Senior Vice President - Nuclear Operations
and Chief Nuclear Officer
Innsbrook Technical Center - 2SW
5000 Dominion Boulevard
Waterford, CT 06385

Mr. C. J. Schwarz
Master Process Owner - Operate the Asset
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Senior Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
P. O. Box 513
Niantic, CT 06357

Mr. G. D. Hicks
Master Process Owner - Training
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Mr. R. P. Necci
Vice President - Nuclear Operations - Millstone
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Mr. D. A. Smith
Process Owner - Regulatory Affairs
Dominion Nuclear Connecticut, Inc.
Rope Ferry Road
Waterford, CT 06385

Millstone Nuclear Power Station
Unit 3

cc:

Ms. Nancy Burton
147 Cross Highway
Redding Ridge, CT 00870

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056