

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.9 REPORTING REQUIREMENTS</u>	
6.9.1 ROUTINE REPORTS	6-16
STARTUP REPORTS	6-16
ANNUAL REPORTS	6-17
ANNUAL RADIOLOGICAL REPORTS	6-18
MONTHLY OPERATING REPORT	6-18
CORE OPERATING LIMITS REPORT	6-18
6.9.2 SPECIAL REPORTS	6-19
<u>6.10 DELETED</u>	
<u>6.11 RADIATION PROTECTION PROGRAM</u>	6-22
<u>6.12 HIGH RADIATION AREA</u>	6-22
<u>6.13 SYSTEMS INTEGRITY</u>	6-23
<u>6.14 IODINE MONITORING</u>	6-23
<u>6.15 RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE</u> <u>CALCULATION MANUAL (REMODCM)</u>	6-24
<u>6.16 RADIOACTIVE WASTE TREATMENT</u>	6-24
<u>6.17 SECONDARY WATER CHEMISTRY</u>	6-25
<u>6.18 DELETED</u>	
<u>6.19 CONTAINMENT LEAKAGE RATE TESTING PROGRAM</u>	6-26
<u>6.20 RADIOACTIVE EFFLUENT CONTROLS PROGRAM</u>	6-26
<u>6.21 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM</u>	6-27

ADMINISTRATIVE CONTROLS

6.16 RADIOACTIVE WASTE TREATMENT

Procedures for liquid and gaseous radioactive effluent discharges from the Unit shall be prepared, approved, maintained, and adhered to for all operations involving offsite releases of radioactive effluents. These procedures shall specify the use of appropriate* waste treatment utilizing the guidance provided in the REMODCM.

6.17 SECONDARY WATER CHEMISTRY

A program shall be maintained for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

1. Identification of a sampling schedule for the critical variables and control points for these variables.
2. Identification of the procedures used to measure the values of the critical variables,
3. Identification of process sampling points, which shall include monitoring the discharge of the condensate pumps for evidence of condenser in-leakage.
4. Procedures for the recording and management of data.
5. Procedures defining corrective actions for all off-control point chemistry conditions, and
6. A procedure identifying: (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

6.18 Deleted

*The Solid Radioactive Waste Treatment System shall be operated in accordance with the Process Control Program to process wet radioactive wastes to meet shipping and burial ground requirements.