



Palo Verde Nuclear  
Generating Station

William E. Ide  
Vice President  
Nuclear Production

TEL (623) 393-6116  
FAX (623) 393-6077

Mail Station 7602  
P.O. Box 52034  
Phoenix, AZ 85072-2034

Technical Specification 5.6.8

192-01094-WEI/DGM/DFH  
October 31, 2001

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-37  
Washington, D.C. 20555-0001

Dear Sirs:

**Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Unit 3  
Docket No. STN 50-530  
Special Report 3-SR-2001-001**

Attached please find Special Report 3-SR-2001-001 prepared and submitted pursuant to Technical Specifications (TS) Reporting Requirement 5.6.8. This report discusses steam generator tube plugging in Unit 3. Pursuant to Technical Specification 5.6.8, the complete results of the steam generator tube inservice inspection will be submitted by October 19, 2002. Copies of the Special Report are being forwarded to the Regional Administrator, NRC Region IV and the PVNGS Resident Inspector.

No commitments are being made to the NRC by this letter.

If you have any questions, please contact Daniel G. Marks, Section Leader, Regulatory Affairs, Compliance, at (623) 393-6492.

Sincerely,

WEI/DGM/DFH

Attachment

cc: E. W. Merschoff (all with attachment)  
L. R. Wharton  
J. H. Moorman

IE22

# **ATTACHMENT**

**Special Report No. 3-SR-2001-001**

**Palo Verde Nuclear Generating Station Unit 3**

**Steam Generator Tube Plugging**

**Docket No. STN 50-530**

**Special Report No. 3-SR-2001-001**

This Special Report is being provided pursuant to Palo Verde Unit 3 Technical Specifications (TS) Reporting Requirement 5.6.8 to report the number of steam generator tubes plugged and/or repaired as a result of inservice inspection activities. On October 19, 2001, Unit 3 was defueled during a refueling outage when an inservice inspection of both steam generators was completed. The inspection resulted in the plugging of 51 tubes in Steam Generator No. 1 and 84 tubes in Steam Generator No. 2.

Pursuant to Technical Specification 5.6.8, the complete results of the steam generator tube inservice inspection will be submitted by October 19, 2002.