



Scott A. Bauer
Department Leader
Regulatory Affairs
Palo Verde Nuclear
Generating Station

Tel: 623/393-5978
Fax: 623/393-5442
e-mail: sbauer@apsc.com

Mail Station 7636
P.O. Box 52034
Phoenix, AZ 85072-2034

102-04637-SAB/TNW/JAP
December 14, 2001

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-37
Washington, DC 20555-0001

Dear Sirs:

Subject: **Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2, and 3
Docket Nos. STN 50-528/529/530
Core Operating Limits Reports (COLR), Unit 1- Revision 5,
Unit 2- Revision 4, and Unit 3- Revision 7**

Pursuant to PVNGS Technical Specifications, Section 5.6.5.d, enclosed is Unit 1- Revision 5, Unit 2-Revision 4, and Unit 3-Revision 7 COLRs, which were made effective on December 6, 2001. These revisions of the COLRs consist of adding the complete revision data for topical reports listed in Technical Specification 5.6.5.b used to determine the core operating limits. These changes are associated with the implementation of PVNGS Technical Specification amendment #137. These revisions replace the previous Unit 1 (Revision 4), Unit 2 (Revision 3), and Unit 3 (Revision 6) COLRs.

By copy of this letter and the enclosure, these COLR revisions are being provided to the NRC Region IV Administrator and the PVNGS Senior Resident Inspector.

This letter does not make any commitments to the NRC.

Please contact Thomas N. Weber at (623) 393-5764 if you have any questions or require additional information.

Sincerely,

SAB/TNW/JAP/kg

Enclosure

cc: E. W. Merschoff
L. R. Wharton
J. M. Moorman

A001

Enclosure

**Core Operating Limits Reports for
PVNGS Unit 1- Revision 5, Unit 2- Revision 4,
and Unit 3- Revision 7**

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 1

Revision 5

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Cover Page	5	1
Table of Contents	5	2
List of Figures	5	3
List of Tables	5	4
Affected Technical Specifications	5	5
Analytical Methods	5	6
CORE Operating Limits		
3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open	5	8
3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed	5	8
3.1.4 Moderator Temperature Coefficient (MTC)	5	8
3.1.5 Control Element Assembly (CEA) Alignment	5	8
3.1.7 Regulating CEA Insertion Limits	5	8
3.1.8 Part Length CEA Insertion Limits	5	9
3.2.1 Linear Heat Rate (LHR)	5	9
3.2.3 Azimuthal Power Tilt (Tq)	5	9
3.2.4 Departure From Nucleate Boiling Ratio (DNBR)	5	9
3.2.5 Axial Shape Index (ASI)	5	9
3.3.12 Boron Dilution Alarm System (BDAS)	5	10
3.9.1 Boron Concentration	5	10

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

List of Figures

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	5	11
Figure 3.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	5	12
Figure 3.1.4-1 MTC Acceptable Operation, Modes 1 and 2	5	13
Figure 3.1.5-1 Core Power Limit After CEA Deviation	5	14
Figure 3.1.7-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	5	15
Figure 3.1.7-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	5	16
Figure 3.1.8-1 Part Length CEA Insertion Limits Versus Thermal Power	5	17
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	5	18
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable	5	19
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Operable)	5	20
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)	5	21

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT**List of Tables**

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Table 3.3.12-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	5	22
Table 3.3.12-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	5	23
Table 3.3.12-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	5	24
Table 3.3.12-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	5	25
Table 3.3.12-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	5	26

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

This Report has been prepared in accordance with the requirements of Technical Specification 5.6.5. The Core Operating Limits have been developed using the NRC approved methodologies specified in Section 5.6.5 b of the Palo Verde Unit 1 Technical Specifications.

AFFECTED PVNGS TECHNICAL SPECIFICATIONS

- 3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open
- 3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed
- 3.1.4 Moderator Temperature Coefficient (MTC)
- 3.1.5 Control Element Assembly (CEA) Alignment
- 3.1.7 Regulating CEA Insertion Limits
- 3.1.8 Part Length CEA Insertion Limits
- 3.2.1 Linear Heat Rate (LHR)
- 3.2.3 Azimuthal Power Tilt (T_q)
- 3.2.4 Departure From Nucleate Boiling Ratio (DNBR)
- 3.2.5 Axial Shape Index (ASI)
- 3.3.12 Boron Dilution Alarm System (BDAS)
- 3.9.1 Boron Concentration

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

ANALYTICAL METHODS

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
1) CE Method for Control Element Assembly Ejection Analysis	CENPD-0190-A	N.A.	January 1976	N.A.
2) The ROCS and DIT Computer Codes for Nuclear Design	CENPD-266-P-A	N.A.	April 1983	N.A.
3) Modified Statistical Combination of Uncertainties	CEN-356(V)-P-A	01-P-A	May 1988	N.A.
4) System 80 TM Inlet Flow Distribution	Enclosure 1-P to LD-82-054	N.A.	February 1993	1-P
5) Calculative Methods for the CE Large Break LOCA Evaluation Model for the Analysis of CE and W Designed NSSS	CENPD-132	N.A.	June 1985	3-P-A
6) Calculative Methods for the CE Small Break LOCA Evaluation Model	CENPD-137-P	N.A.	January 1977	1-P
7) Fuel Rod Maximum Allowable Pressure	CEN-372-P-A	N.A.	May 1990	N.A.
8) Arizona Public Service Company PWR Reactor Physics Methodology Using CASMO-4/SIMULATE-3	NFM002	0	September 1999	N.A.

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
9) Technical Manual for the CENTS Code	CE-NPD 282-P-A Vols. 1-3	N.A.	June 1993	1-P

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

The cycle-specific operating limits for the specifications listed are presented below.

3.1.1 - Shutdown Margin (SDM) - Reactor Trip Breakers Open

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1-1.

3.1.2 - Shutdown Margin (SDM) - Reactor Trip Breakers Closed

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.2-1.

3.1.4 - Moderator Temperature Coefficient (MTC)

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.4-1.

3.1.5 - Control Element Assembly (CEA) Alignment

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.5-1.

3.1.7 - Regulating CEA Insertion Limits

One or more CEACs OPERABLE: With COLSS IN SERVICE, regulating CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-2.

¹ A reactor power cutback will cause either (Case 1) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with no sequential insertion of additional Regulating Groups (Groups 1, 2, 3, and 4) or (Case 2) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with all or part of the remaining Regulating Groups (Groups 1, 2, 3, and 4) being sequentially inserted. In either case, the Transient Insertion Limit and withdrawal sequence specified in the CORE OPERATING LIMITS REPORT can be exceeded for up to 2 hours.

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT**3.1.8 - Part Length CEA Insertion Limits**

One or more CEACs OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.8-1.

3.2.1 - Linear Heat Rate (LHR)

The linear heat rate limit of 13.1 kW/ft shall be maintained.

3.2.3 - Azimuthal Power Tilt (T_q)

The AZIMUTHAL POWER TILT (T_q) shall be less than or equal to the limit in Figure 3.2.3-1 with COLSS IN SERVICE.

3.2.4 - Departure From Nucleate Boiling Ratio (DNBR)

COLSS IN SERVICE and Both CEACs INOPERABLE - Maintaining COLSS calculated core power less than or equal to COLSS calculated core power operation limit based on DNBR decreased by the allowance shown in Figure 3.2.4-1.

COLSS OUT OF SERVICE and Either One or Both CEACs are OPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-2 using any operable CPC channel.

COLSS OUT OF SERVICE and CEACs INOPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-3 using any operable CPC channel.

3.2.5 - Axial Shape Index (ASI)

The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

COLSS OPERABLE

$-0.18 \leq \text{ASI} \leq 0.16$ for power $\geq 50\%$

$-0.28 \leq \text{ASI} \leq 0.16$ for power $< 50\%$

COLSS OUT OF SERVICE (CPC)

$-0.10 \leq \text{ASI} \leq 0.10$

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

3.3.12 - Boron Dilution Alarm System (BDAS)

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.3.12-1 through 3.3.12-5.

3.9.1 - Boron Concentration

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration ≥ 3000 ppm.

FIGURE 3.1.1-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS OPEN




FIGURE 3.1.2-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS CLOSED




FIGURE 3.1.4-1
MTC ACCEPTABLE OPERATION, MODES 1 AND 2





FIGURE 3.1.5-1
CORE POWER LIMIT AFTER CEA DEVIATION*



* WHEN CORE POWER IS REDUCED TO 55% OF RATED THERMAL POWER PER THIS LIMIT CURVE, FURTHER REDUCTION IS NOT REQUIRED.

FIGURE 3.1.7-1

CEA INSERTION LIMITS VERSUS THERMAL POWER
(COLSS IN SERVICE)




FIGURE 3.1.7-2

CEA INSERTION LIMITS VERSUS THERMAL POWER (COLSS OUT OF SERVICE)




FIGURE 3.1.8-1
PART LENGTH CEA INSERTION LIMITS
VERSUS THERMAL POWER




FIGURE 3.2.3-1
AZIMUTHAL POWER TILT VERSUS THERMAL POWER
(COLSS IN SERVICE)




FIGURE 3.2.4-1
COLSS DNBR OPERATING LIMIT
ALLOWANCE FOR BOTH CEAC's INOPERABLE




FIGURE 3.2.4-2
DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's OPERABLE)





FIGURE 3.2.4-3
DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's INOPERABLE)



PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table 3.3.12-1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{\text{eff}} > 0.98$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	0.5 hours	ONA	ONA
4 not on SCS	12 hours	0.5 hours	ONA	ONA
5 not on SCS	8 hours	0.5 hours	ONA	ONA
4 & 5 on SCS	ONA	ONA	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table 3.3.12-2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.98 \geq K_{\text{eff}} > 0.97$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	1 hour	0.5 hours	ONA
4 not on SCS	12 hours	1.5 hours	0.5 hours	ONA
5 not on SCS	8 hours	1.5 hours	0.5 hours	ONA
4 & 5 on SCS	8 hours	0.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table 3.3.12-3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.97 \geq K_{\text{eff}} > 0.96$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	2.5 hours	1 hour	ONA
4 not on SCS	12 hours	2.5 hours	1 hour	0.5 hours
5 not on SCS	8 hours	2.5 hours	1 hour	0.5 hours
4 & 5 on SCS	8 hours	1 hour	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table 3.3.12-4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.96 \geq K_{eff} > 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	3 hours	1 hour	0.5 hours
4 not on SCS	12 hours	3.5 hours	1.5 hours	0.75 hours
5 not on SCS	8 hours	3.5 hours	1.5 hours	0.75 hours
4 & 5 on SCS	8 hours	1.5 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 1 CORE OPERATING LIMITS REPORT

Table 3.3.12-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{\text{eff}} \leq 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	4 hours	1.5 hours	1 hour
4 not on SCS	12 hours	4.5 hours	2 hours	1 hour
5 not on SCS	8 hours	4.5 hours	2 hours	1 hour
4 & 5 on SCS	8 hours	2 hours	0.75 hours	ONA
6	24 hours	1.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS REPORT
PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 2

Revision 4

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Cover Page	4	1
Table of Contents	4	2
List of Figures	4	3
List of Tables	4	4
Affected Technical Specifications	4	5
Analytical Methods	4	6
CORE Operating Limits		
3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open	4	8
3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed	4	8
3.1.4 Moderator Temperature Coefficient (MTC)	4	8
3.1.5 Control Element Assembly (CEA) Alignment	4	8
3.1.7 Regulating CEA Insertion Limits	4	8
3.1.8 Part Length CEA Insertion Limits	4	9
3.2.1 Linear Heat Rate (LHR)	4	9
3.2.3 Azimuthal Power Tilt (Tq)	4	9
3.2.4 Departure From Nucleate Boiling Ratio (DNBR)	4	9
3.2.5 Axial Shape Index (ASI)	4	9
3.3.12 Boron Dilution Alarm System (BDAS)	4	10
3.9.1 Boron Concentration	4	10

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

List of Figures

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	4	11
Figure 3.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	4	12
Figure 3.1.4-1 MTC Acceptable Operation, Modes 1 and 2	4	13
Figure 3.1.5-1 Core Power Limit After CEA Deviation	4	14
Figure 3.1.7-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	4	15
Figure 3.1.7-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	4	16
Figure 3.1.8-1 Part Length CEA Insertion Limits Versus Thermal Power	4	17
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	4	18
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable	4	19
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Operable)	4	20
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)	4	21

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT**List of Tables**

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Table 3.3.12-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	4	22
Table 3.3.12-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	4	23
Table 3.3.12-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	4	24
Table 3.3.12-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	4	25
Table 3.3.12-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	4	26

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

This Report has been prepared in accordance with the requirements of Technical Specification 5.6.5. The Core Operating Limits have been developed using the NRC approved methodologies specified in Section 5.6.5 b of the Palo Verde Unit 2 Technical Specifications.

AFFECTED PVNGS TECHNICAL SPECIFICATIONS

- 3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open
- 3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed
- 3.1.4 Moderator Temperature Coefficient (MTC)
- 3.1.5 Control Element Assembly (CEA) Alignment
- 3.1.7 Regulating CEA Insertion Limits
- 3.1.8 Part Length CEA Insertion Limits
- 3.2.1 Linear Heat Rate (LHR)
- 3.2.3 Azimuthal Power Tilt (T_q)
- 3.2.4 Departure From Nucleate Boiling Ratio (DNBR)
- 3.2.5 Axial Shape Index (ASI)
- 3.3.12 Boron Dilution Alarm System (BDAS)
- 3.9.1 Boron Concentration

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

ANALYTICAL METHODS

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
1) CE Method for Control Element Assembly Ejection Analysis	CENPD-0190-A	N.A.	January 1976	N.A.
2) The ROCS and DIT Computer Codes for Nuclear Design	CENPD-266-P-A	N.A.	April 1983	N.A.
3) Modified Statistical Combination of Uncertainties	CEN-356(V)-P-A	01-P-A	May 1988	N.A.
4) System 80 TM Inlet Flow Distribution	Enclosure 1-P to LD-82-054	N.A.	February 1993	1-P
5) Calculative Methods for the CE Large Break LOCA Evaluation Model for the Analysis of CE and W Designed NSSS	CENPD-132	N.A.	June 1985	3-P-A
6) Calculative Methods for the CE Small Break LOCA Evaluation Model	CENPD-137-P	N.A.	January 1977	1-P
7) Fuel Rod Maximum Allowable Pressure	CEN-372-P-A	N.A.	May 1990	N.A.
8) Arizona Public Service Company PWR Reactor Physics Methodology Using CASMO-4/SIMULATE-3	NFM002	0	September 1999	N.A.

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
9) Technical Manual for the CENTS Code	CE-NPD 282-P-A Vols. 1-3	N.A.	June 1993	1-P

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

The cycle-specific operating limits for the specifications listed are presented below.

3.1.1 - Shutdown Margin (SDM) - Reactor Trip Breakers Open

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1-1.

3.1.2 - Shutdown Margin (SDM) - Reactor Trip Breakers Closed

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.2-1.

3.1.4 - Moderator Temperature Coefficient (MTC)

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.4-1.

3.1.5 - Control Element Assembly (CEA) Alignment

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.5-1.

3.1.7 - Regulating CEA Insertion Limits

One or more CEACs OPERABLE: With COLSS IN SERVICE, regulating CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-2.

¹ A reactor power cutback will cause either (Case 1) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with no sequential insertion of additional Regulating Groups (Groups 1, 2, 3, and 4) or (Case 2) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with all or part of the remaining Regulating Groups (Groups 1, 2, 3, and 4) being sequentially inserted. In either case, the Transient Insertion Limit and withdrawal sequence specified in the CORE OPERATING LIMITS REPORT can be exceeded for up to 2 hours.

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT**3.1.8 - Part Length CEA Insertion Limits**

One or more CEACs OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.8-1.

3.2.1 - Linear Heat Rate (LHR)

The linear heat rate limit of 13.1 kW/ft shall be maintained.

3.2.3 - Azimuthal Power Tilt (T_q)

The AZIMUTHAL POWER TILT (T_q) shall be less than or equal to the limit in Figure 3.2.3-1 with COLSS IN SERVICE.

3.2.4 - Departure From Nucleate Boiling Ratio (DNBR)

COLSS IN SERVICE and Both CEACs INOPERABLE - Maintaining COLSS calculated core power less than or equal to COLSS calculated core power operation limit based on DNBR decreased by the allowance shown in Figure 3.2.4-1.

COLSS OUT OF SERVICE and Either One or Both CEACs are OPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-2 using any operable CPC channel.

COLSS OUT OF SERVICE and CEACs INOPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-3 using any operable CPC channel.

3.2.5 - Axial Shape Index (ASI)

The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

COLSS OPERABLE

$-0.18 \leq \text{ASI} \leq 0.16$ for power $\geq 50\%$

$-0.28 \leq \text{ASI} \leq 0.16$ for power $< 50\%$

COLSS OUT OF SERVICE (CPC)

$-0.10 \leq \text{ASI} \leq 0.10$

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

3.3.12 - Boron Dilution Alarm System (BDAS)

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.3.12-1 through 3.3.12-5.

3.9.1 - Boron Concentration

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration ≥ 3000 ppm.

FIGURE 3.1.1-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS OPEN




FIGURE 3.1.2-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS CLOSED




FIGURE 3.1.4-1
MTC ACCEPTABLE OPERATION, MODES 1 AND 2





FIGURE 3.1.5-1
CORE POWER LIMIT AFTER CEA DEVIATION*



* WHEN CORE POWER IS REDUCED TO 55% OF RATED THERMAL POWER PER THIS LIMIT CURVE, FURTHER REDUCTION IS NOT REQUIRED.

FIGURE 3.1.7-1

CEA INSERTION LIMITS VERSUS THERMAL POWER (COLSS IN SERVICE)




FIGURE 3.1.7-2

CEA INSERTION LIMITS VERSUS THERMAL POWER (COLSS OUT OF SERVICE)




FIGURE 3.1.8-1
PART LENGTH CEA INSERTION LIMITS
VERSUS THERMAL POWER




FIGURE 3.2.3-1
AZIMUTHAL POWER TILT VERSUS THERMAL POWER
(COLSS IN SERVICE)




FIGURE 3.2.4-1

COLSS DNBR OPERATING LIMIT
ALLOWANCE FOR BOTH CEAC'S INOPERABLE




FIGURE 3.2.4-2

DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's OPERABLE)





FIGURE 3.2-4-3

DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS

(COLSS OUT OF SERVICE, CEAC'S INOPERABLE)



PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table 3.3.12-1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} > 0.98$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	0.5 hours	ONA	ONA
4 not on SCS	12 hours	0.5 hours	ONA	ONA
5 not on SCS	8 hours	0.5 hours	ONA	ONA
4 & 5 on SCS	ONA	ONA	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table 3.3.12-2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.98 \geq K_{\text{eff}} > 0.97$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	1 hour	0.5 hours	ONA
4 not on SCS	12 hours	1.5 hours	0.5 hours	ONA
5 not on SCS	8 hours	1.5 hours	0.5 hours	ONA
4 & 5 on SCS	8 hours	0.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table 3.3.12-3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.97 \geq K_{\text{eff}} > 0.96$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	2.5 hours	1 hour	ONA
4 not on SCS	12 hours	2.5 hours	1 hour	0.5 hours
5 not on SCS	8 hours	2.5 hours	1 hour	0.5 hours
4 & 5 on SCS	8 hours	1 hour	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table 3.3.12-4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.96 \geq K_{eff} > 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	3 hours	1 hour	0.5 hours
4 not on SCS	12 hours	3.5 hours	1.5 hours	0.75 hours
5 not on SCS	8 hours	3.5 hours	1.5 hours	0.75 hours
4 & 5 on SCS	8 hours	1.5 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 2 CORE OPERATING LIMITS REPORT

Table 3.3.12-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} \leq 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	4 hours	1.5 hours	1 hour
4 not on SCS	12 hours	4.5 hours	2 hours	1 hour
5 not on SCS	8 hours	4.5 hours	2 hours	1 hour
4 & 5 on SCS	8 hours	2 hours	0.75 hours	ONA
6	24 hours	1.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

CORE OPERATING LIMITS REPORT

PALO VERDE NUCLEAR GENERATING STATION (PVNGS)

UNIT 3

Revision 7

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table of Contents

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Cover Page	7	1
Table of Contents	7	2
List of Figures	7	3
List of Tables	7	4
Affected Technical Specifications	7	5
Analytical Methods	7	6
CORE Operating Limits		
3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open	7	8
3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed	7	8
3.1.4 Moderator Temperature Coefficient (MTC)	7	8
3.1.5 Control Element Assembly (CEA) Alignment	7	8
3.1.7 Regulating CEA Insertion Limits	7	8
3.1.8 Part Length CEA Insertion Limits	7	9
3.2.1 Linear Heat Rate (LHR)	7	9
3.2.3 Azimuthal Power Tilt (Tq)	7	9
3.2.4 Departure From Nucleate Boiling Ratio (DNBR)	7	9
3.2.5 Axial Shape Index (ASI)	7	9
3.3.12 Boron Dilution Alarm System (BDAS)	7	10
3.9.1 Boron Concentration	7	10

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

List of Figures

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Figure 3.1.1-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Open	7	11
Figure 3.1.2-1 Shutdown Margin Versus Cold Leg Temperature Reactor Trip Breakers Closed	7	12
Figure 3.1.4-1 MTC Acceptable Operation, Modes 1 and 2	7	13
Figure 3.1.5-1 Core Power Limit After CEA Deviation	7	14
Figure 3.1.7-1 CEA Insertion Limits Versus Thermal Power (COLSS in Service)	7	15
Figure 3.1.7-2 CEA Insertion Limits Versus Thermal Power (COLSS Out of Service)	7	16
Figure 3.1.8-1 Part Length CEA Insertion Limits Versus Thermal Power	7	17
Figure 3.2.3-1 Azimuthal Power Tilt Versus Thermal Power (COLSS in Service)	7	18
Figure 3.2.4-1 COLSS DNBR Operating Limit Allowance for Both CEACs Inoperable	7	19
Figure 3.2.4-2 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Operable)	7	20
Figure 3.2.4-3 DNBR Margin Operating Limit Based on the Core Protection Calculators (COLSS Out of Service, CEACs Inoperable)	7	21

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT**List of Tables**

<u>Description</u>	<u>Revision #</u>	<u>Page</u>
Table 3.3.12-1 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} > 0.98$	7	22
Table 3.3.12-2 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.98 \geq K_{eff} > 0.97$	7	23
Table 3.3.12-3 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.97 \geq K_{eff} > 0.96$	7	24
Table 3.3.12-4 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $0.96 \geq K_{eff} > 0.95$	7	25
Table 3.3.12-5 Required Monitoring Frequencies for Backup Boron Dilution Detection as a Function of Operating Charging Pumps and Plant Operational Modes for $K_{eff} \leq 0.95$	7	26

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

This Report has been prepared in accordance with the requirements of Technical Specification 5.6.5. The Core Operating Limits have been developed using the NRC approved methodologies specified in Section 5.6.5 b of the Palo Verde Unit 3 Technical Specifications.

AFFECTED PVNGS TECHNICAL SPECIFICATIONS

- 3.1.1 Shutdown Margin (SDM) - Reactor Trip Breakers Open
- 3.1.2 Shutdown Margin (SDM) - Reactor Trip Breakers Closed
- 3.1.4 Moderator Temperature Coefficient (MTC)
- 3.1.5 Control Element Assembly (CEA) Alignment
- 3.1.7 Regulating CEA Insertion Limits
- 3.1.8 Part Length CEA Insertion Limits
- 3.2.1 Linear Heat Rate (LHR)
- 3.2.3 Azimuthal Power Tilt (T_q)
- 3.2.4 Departure From Nucleate Boiling Ratio (DNBR)
- 3.2.5 Axial Shape Index (ASI)
- 3.3.12 Boron Dilution Alarm System (BDAS)
- 3.9.1 Boron Concentration

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

ANALYTICAL METHODS

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
1) CE Method for Control Element Assembly Ejection Analysis	CENPD-0190-A	N.A.	January 1976	N.A.
2) The ROCS and DIT Computer Codes for Nuclear Design	CENPD-266-P-A	N.A.	April 1983	N.A.
3) Modified Statistical Combination of Uncertainties	CEN-356(V)-P-A	01-P-A	May 1988	N.A.
4) System 80 TM Inlet Flow Distribution	Enclosure 1-P to LD-82-054	N.A.	February 1993	1-P
5) Calculative Methods for the CE Large Break LOCA Evaluation Model for the Analysis of CE and W Designed NSSS	CENPD-132	N.A.	June 1985	3-P-A
6) Calculative Methods for the CE Small Break LOCA Evaluation Model	CENPD-137-P	N.A.	January 1977	1-P
7) Fuel Rod Maximum Allowable Pressure	CEN-372-P-A	N.A.	May 1990	N.A.
8) Arizona Public Service Company PWR Reactor Physics Methodology Using CASMO-4/SIMULATE-3	NFM002	0	September 1999	N.A.

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

<u>Title</u>	<u>Report No.</u>	<u>Rev</u>	<u>Date</u>	<u>Supplement</u>
9) Technical Manual for the CENTS Code	CE-NPD 282-P-A Vols. 1-3	N.A.	June 1993	1-P

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

The cycle-specific operating limits for the specifications listed are presented below.

3.1.1 - Shutdown Margin (SDM) - Reactor Trip Breakers Open

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.1-1.

3.1.2 - Shutdown Margin (SDM) - Reactor Trip Breakers Closed

The Shutdown Margin shall be greater than or equal to that shown in Figure 3.1.2-1.

3.1.4 - Moderator Temperature Coefficient (MTC)

The moderator temperature coefficient (MTC) shall be within the area of Acceptable Operation shown in Figure 3.1.4-1.

3.1.5 - Control Element Assembly (CEA) Alignment

With one or more full-length or part-length CEAs misaligned from any other CEAs in its group by more than 6.6 inches, the minimum required MODES 1 and 2 core power reduction is specified in Figure 3.1.5-1.

3.1.7 - Regulating CEA Insertion Limits

One or more CEACs OPERABLE: With COLSS IN SERVICE, regulating CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-1; with COLSS OUT OF SERVICE, regulation CEA groups shall be limited to the withdrawal sequence and to the insertion limits¹ shown in Figure 3.1.7-2.

¹ A reactor power cutback will cause either (Case 1) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with no sequential insertion of additional Regulating Groups (Groups 1, 2, 3, and 4) or (Case 2) Regulating Group 5 or Regulating Group 4 and 5 to be dropped with all or part of the remaining Regulating Groups (Groups 1, 2, 3, and 4) being sequentially inserted. In either case, the Transient Insertion Limit and withdrawal sequence specified in the CORE OPERATING LIMITS REPORT can be exceeded for up to 2 hours.

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

3.1.8 - Part Length CEA Insertion Limits

One or more CEACs OPERABLE: The part length CEA groups shall be limited to the insertion limits shown in Figure 3.1.8-1.

3.2.1 - Linear Heat Rate (LHR)

The linear heat rate limit of 13.1 kW/ft shall be maintained.

3.2.3 - Azimuthal Power Tilt (T_q)

The AZIMUTHAL POWER TILT (T_q) shall be less than or equal to the limit in Figure 3.2.3-1 with COLSS IN SERVICE.

3.2.4 - Departure From Nucleate Boiling Ratio (DNBR)

COLSS IN SERVICE and Both CEACs INOPERABLE - Maintaining COLSS calculated core power less than or equal to COLSS calculated core power operation limit based on DNBR decreased by the allowance shown in Figure 3.2.4-1.

COLSS OUT OF SERVICE and Either One or Both CEACs are OPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-2 using any operable CPC channel.

COLSS OUT OF SERVICE and CEACs INOPERABLE - Operating within the region of acceptable operation of Figure 3.2.4-3 using any operable CPC channel.

3.2.5 - Axial Shape Index (ASI)

The core average AXIAL SHAPE INDEX (ASI) shall be maintained within the following limits:

COLSS OPERABLE

$-0.18 \leq \text{ASI} \leq 0.16$ for power $\geq 50\%$

$-0.28 \leq \text{ASI} \leq 0.16$ for power $< 50\%$

COLSS OUT OF SERVICE (CPC)

$-0.10 \leq \text{ASI} \leq 0.10$

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

3.3.12 - Boron Dilution Alarm System (BDAS)

With one or both start-up channel high neutron flux alarms inoperable, the RCS boron concentration shall be determined at the applicable monitoring frequency specified in Tables 3.3.12-1 through 3.3.12-5.

3.9.1 - Boron Concentration

The boron concentration of all filled portions of the Reactor Coolant System and the refueling canal shall be maintained at a uniform concentration ≥ 3000 ppm.

FIGURE 3.1.1-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS OPEN




FIGURE 3.1.2-1
SHUTDOWN MARGIN VERSUS COLD LEG TEMPERATURE
REACTOR TRIP BREAKERS CLOSED




FIGURE 3.1.4-1
MTC ACCEPTABLE OPERATION, MODES 1 AND 2





FIGURE 3.1.5-1
CORE POWER LIMIT AFTER CEA DEVIATION*



* WHEN CORE POWER IS REDUCED TO 55% OF RATED THERMAL POWER PER THIS LIMIT CURVE, FURTHER REDUCTION IS NOT REQUIRED.

FIGURE 3.1.7-1

CEA INSERTION LIMITS VERSUS THERMAL POWER (COLSS IN SERVICE)




FIGURE 3.1.7-2

CEA INSERTION LIMITS VERSUS THERMAL POWER (COLSS OUT OF SERVICE)




FIGURE 3.1.8-1
PART LENGTH CEA INSERTION LIMITS
VERSUS THERMAL POWER




FIGURE 3.2.3-1
AZIMUTHAL POWER TILT VERSUS THERMAL POWER
(COLSS IN SERVICE)




FIGURE 3.2.4-1
COLSS DNBR OPERATING LIMIT
ALLOWANCE FOR BOTH CEAC's INOPERABLE




FIGURE 3.2.4-2

DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's OPERABLE)





FIGURE 3.2.4-3

DNBR MARGIN OPERATING LIMIT BASED ON
THE CORE PROTECTION CALCULATORS
(COLSS OUT OF SERVICE, CEAC's INOPERABLE)



PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table 3.3.12-1

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} > 0.98$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	0.5 hours	ONA	ONA
4 not on SCS	12 hours	0.5 hours	ONA	ONA
5 not on SCS	8 hours	0.5 hours	ONA	ONA
4 & 5 on SCS	ONA	ONA	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table 3.3.12-2

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.98 \geq K_{\text{eff}} > 0.97$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	1 hour	0.5 hours	ONA
4 not on SCS	12 hours	1.5 hours	0.5 hours	ONA
5 not on SCS	8 hours	1.5 hours	0.5 hours	ONA
4 & 5 on SCS	8 hours	0.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table 3.3.12-3

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.97 \geq K_{eff} > 0.96$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	2.5 hours	1 hour	ONA
4 not on SCS	12 hours	2.5 hours	1 hour	0.5 hours
5 not on SCS	8 hours	2.5 hours	1 hour	0.5 hours
4 & 5 on SCS	8 hours	1 hour	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table 3.3.12-4

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $0.96 \geq K_{\text{eff}} > 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	3 hours	1 hour	0.5 hours
4 not on SCS	12 hours	3.5 hours	1.5 hours	0.75 hours
5 not on SCS	8 hours	3.5 hours	1.5 hours	0.75 hours
4 & 5 on SCS	8 hours	1.5 hours	0.5 hours	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed

PVNGS UNIT 3 CORE OPERATING LIMITS REPORT

Table 3.3.12-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR $K_{eff} \leq 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps			
	0	1	2	3
3	12 hours	4 hours	1.5 hours	1 hour
4 not on SCS	12 hours	4.5 hours	2 hours	1 hour
5 not on SCS	8 hours	4.5 hours	2 hours	1 hour
4 & 5 on SCS	8 hours	2 hours	0.75 hours	ONA
6	24 hours	1.5 hours	ONA	ONA

Notes: SCS = Shutdown Cooling System
ONA = Operation Not Allowed