

---

**Industry/TSTF Standard Technical Specification Change Traveler**

---

**P-7 Surveillance**

---

Classification: 3) Improve Specifications

NUREGs Affected: ☐ 1430 ☒ 1431 ☐ 1432 ☐ 1433 ☐ 1434

## Description:

Delete SR 3.3.1.11 and SR 3.3.1.13 from Table 3.3.1-1, Function 18.b and insert SR 3.3.1.5.

## Justification:

COTs and CHANNEL CALIBRATIONS apply to the P-10 and P-13 inputs, not to the P-7 logic function. Logic functions are tested under SR 3.3.1.5. This change is an administrative clarification to address the relationships between these interlocks. This change has been approved for Vogtle and the FLOG plants (Callaway, Comanche Peak, Diablo Canyon, and Wolf Creek).

Industry Contact: Buschbaum, Denny

(254) 897-5851

dbuschb1@tuelectric.com

NRC Contact: Schulten, Carl

301-314-1192

css1@nrc.gov

---

**Revision History****OG Revision 0****Revision Status: Active****Next Action: EXCEL**

---

Revision Proposed by: Callaway

Revision Description:  
Original Issue

---

**Owners Group Review Information**

Date Originated by OG: 17-Mar-99

Owners Group Comments  
(No Comments)

Owners Group Resolution: Approved Date: 17-Mar-99

---

**TSTF Review Information**

TSTF Received Date: 17-Jun-99

Date Distributed for Review 17-Jun-99

OG Review Completed: ☒ BWOG ☒ WOG ☒ CEOG ☒ BWROG

TSTF Comments:

WOG only.

TSTF Resolution: Approved Date: 07-Jul-99

---

**Incorporation Into the NUREGs**

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

7/12/99

---

**Affected Technical Specifications**

---

LCO 3.3.1

RTS Instrumentation

Change Description: Table 3.3.1-1, Function 18.b SRs

SR 3.3.1.5 Bases

RTS Instrumentation

---

7/12/99

Table 3.3.1-1 (page 5 of 8)  
Reactor Trip System Instrumentation

TSTF-347

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	TRIP SETPOINT <sup>(a)</sup>
16. Turbine Trip						
a. Low Fluid Oil Pressure	1(j)	3	P	SR 3.3.1.10 SR 3.3.1.15	≥ [750] psig	≥ [800] psig
b. Turbine Stop Valve Closure	1(j)	4	P	SR 3.3.1.10 SR 3.3.1.15	≥ [11% open	≥ [11% open
17. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1,2	2 trains	Q	SR 3.3.1.14	NA	NA
18. Reactor Trip System Interlocks						
a. Intermediate Range Neutron Flux, P-6	2(e)	2	S	SR 3.3.1.11 SR 3.3.1.13	≥ [6E-11] amp	≥ [1E-10] amp
b. Low Power Reactor Trips Block, P-7	1	1 per train	T	<del>SR 3.3.1.11</del> <del>SR 3.3.1.13</del>	NA	NA
c. Power Range Neutron Flux, P-8	1	4	T	SR 3.3.1.11 SR 3.3.1.13	≤ [50.2%] RTP	≤ [48%] RTP
d. Power Range Neutron Flux, P-9	1	4	T	SR 3.3.1.11 SR 3.3.1.13	≤ [52.2%] RTP	≤ [50%] RTP
e. Power Range Neutron Flux, P-10	1,2	4	S	SR 3.3.1.11 SR 3.3.1.13	≥ [7.8%] RTP and ≤ [12.2%] RTP	≥ [10%] RTP
f. Turbine Impulse Pressure, P-13	1	2	T	[SR 3.3.1.1] SR 3.3.1.10 SR 3.3.1.13	≤ [12.2%] turbine power	≤ [10%] turbine power

(continued)

(a) Reviewer's Note: Unit specific implementations may contain only Allowable Value depending on Setpoint Study methodology used by the unit.

(e) Below the P-6 (Intermediate Range Neutron Flux) interlocks.

(j) Above the P-9 (Power Range Neutron Flux) interlock.

TSTF-347

BASES

SURVEILLANCE  
REQUIREMENTS  
(continued)

SR 3.3.1.4

SR 3.3.1.4 is the performance of a TADOT every 31 days on a STAGGERED TEST BASIS. This test shall verify OPERABILITY by actuation of the end devices.

The RTB test shall include separate verification of the undervoltage and shunt trip mechanisms. Independent verification of RTB undervoltage and shunt trip Function is not required for the bypass breakers. No capability is provided for performing such a test at power. The independent test for bypass breakers is included in SR 3.3.1.14. The bypass breaker test shall include a local shunt trip. A Note has been added to indicate that this test must be performed on the bypass breaker prior to placing it in service.

The Frequency of every 31 days on a STAGGERED TEST BASIS is adequate. It is based on industry operating experience, considering instrument reliability and operating history data.

SR 3.3.1.5

SR 3.3.1.5 is the performance of an ACTUATION LOGIC TEST. The SSPS is tested every 31 days on a STAGGERED TEST BASIS, using the semiautomatic tester. The train being tested is placed in the bypass condition, thus preventing inadvertent actuation. Through the semiautomatic tester, all possible logic combinations, with and without applicable permissives, are tested for each protection function. The Frequency of every 31 days on a STAGGERED TEST BASIS is adequate. It is based on industry operating experience, considering instrument reliability and operating history data.

SR 3.3.1.6

SR 3.3.1.6 is a calibration of the excore channels to the incore channels. If the measurements do not agree, the excore channels are not declared inoperable but must be calibrated to agree with the incore detector measurements. If the excore channels cannot be adjusted, the channels are declared inoperable. This Surveillance is performed to verify the  $f(\Delta I)$  input to the overtemperature  $\Delta T$  Function.

including operation of the  
P-7 permissive which is a logic  
function only.

(continued)