

**NOV 15 2001**

**LRN-01-0380**



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 1  
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **October 2001** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow", written over the typed name.

D. F. Garchow  
Vice President - Operations

RAR  
Attachments

C Distribution

TE24

## INDEX

<u>SECTION</u>	<u>NUMBER OF PAGES</u>
Operating Data Report .....	1
Monthly Operating Summary .....	1

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 11/09/01  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period October 2001

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1130		
1096		
Month	Year-to-date	Cumulative
390	5755	132764
374	5652	128231
0	0	0
403169	6095184	129669159

### UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
3	10/1/01 - 10/16/01	F	371 hrs.	A	4	Loss of #2 Station Power Transformer

#### (1) Reason

A - Equipment Failure (Explain)  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training/License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other

#### (2) Method

1 - Manual  
 2 - Manual Trip/Scram  
 3 - Automatic Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 11/09/01  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

**Summary Of Monthly Operating Experience**

- Salem 1 began the month in a forced shutdown.
- Salem 1 went online on October 16 and returned to 100% power on October 17.
- At the end of the month, Salem 1 completed 15 days of consecutive on-line operation.