

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 1 of 311

TABLE 4

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6883 *	* .5912 *	* .5379 *	* .6023 *	* .5363 *	* .5747 *	* .4728 *	* .4007 *
	* 2.3821 *	* 3.0210 *	* 3.3791 *	* 2.9841 *	* 3.3407 *	* 3.0848 *	* 3.7301 *	* 4.3436 *
9	* .5912 *	* .5456 *	* .6000 *	* .5381 *	* .5914 *	* .5353 *	* .5087 *	* .3360 *
	* 3.0210 *	* 3.3739 *	* 3.0461 *	* 3.3670 *	* 3.0293 *	* 3.3241 *	* 3.5019 *	* 5.2412 *
10	* .5380 *	* .6005 *	* .5559 *	* .5147 *	* .5236 *	* .5696 *	* .5206 *	* .3212 *
	* 3.3791 *	* 3.0458 *	* 3.3048 *	* 3.5468 *	* 3.4687 *	* 3.2030 *	* 3.4710 *	* 5.5086 *
11	* .6023 *	* .5382 *	* .5140 *	* .4831 *	* .5482 *	* .5072 *	* .4696 *	* .2827 *
	* 2.9841 *	* 3.3663 *	* 3.5521 *	* 3.5149 *	* 3.1699 *	* 3.5428 *	* 3.8905 *	* 6.4435 *
12	* .5363 *	* .5913 *	* .5235 *	* .5481 *	* .4660 *	* .4663 *	* .3761 *	
	* 3.3407 *	* 3.0298 *	* 3.4691 *	* 3.1701 *	* 3.3616 *	* 3.4140 *	* 4.6198 *	
13	* .5747 *	* .5352 *	* .5695 *	* .5072 *	* .4662 *	* .4151 *	* .4081 *	
	* 3.0848 *	* 3.3243 *	* 3.2031 *	* 3.5431 *	* 3.4141 *	* 3.7613 *	* 4.1172 *	
14	* .4728 *	* .5090 *	* .5207 *	* .4696 *	* .3763 *	* .4079 *		
	* 3.7301 *	* 3.5002 *	* 3.4704 *	* 3.8905 *	* 4.6173 *	* 4.1186 *		
15	* .4007 *	* .3362 *	* .3213 *	* .2828 *	F-SUB-Q			
	* 4.3436 *	* 5.2372 *	* 5.5064 *	* 6.4430 *	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8833 *	* 1.2801 *	* 1.0420 *	* 1.2646 *	* 1.0312 *	* 1.2124 *	* .9124 *	* .5290 *
	* 1.9269 *	* 1.4371 *	* 1.7852 *	* 1.4549 *	* 1.7699 *	* 1.4939 *	* 1.9760 *	* 3.3585 *
9	* 1.2801 *	* 1.0453 *	* 1.3031 *	* 1.0343 *	* 1.2461 *	* 1.0631 *	* 1.1769 *	* .6689 *
	* 1.4371 *	* 1.7960 *	* 1.4344 *	* 1.7866 *	* 1.4686 *	* 1.7101 *	* 1.5468 *	* 2.6819 *
10	* 1.0420 *	* 1.3030 *	* 1.0395 *	* 1.0697 *	* 1.0749 *	* 1.1865 *	* 1.1599 *	* .6389 *
	* 1.7852 *	* 1.4348 *	* 1.7958 *	* 1.7423 *	* 1.7385 *	* 1.5720 *	* 1.5900 *	* 2.8273 *
11	* 1.2646 *	* 1.0341 *	* 1.0678 *	* .9639 *	* 1.1588 *	* 1.0118 *	* 1.0870 *	* .5594 *
	* 1.4549 *	* 1.7873 *	* 1.7455 *	* 1.8521 *	* 1.5383 *	* 1.7992 *	* 1.7007 *	* 3.3253 *
12	* 1.0312 *	* 1.2458 *	* 1.0747 *	* 1.1586 *	* 1.0036 *	* 1.1223 *	* .7566 *	
	* 1.7699 *	* 1.4689 *	* 1.7389 *	* 1.5384 *	* 1.6430 *	* 1.5036 *	* 2.3561 *	
13	* 1.2124 *	* 1.0631 *	* 1.1864 *	* 1.0116 *	* 1.1223 *	* 1.0179 *	* .5382 *	
	* 1.4939 *	* 1.7101 *	* 1.5721 *	* 1.7992 *	* 1.5036 *	* 1.6488 *	* 3.2148 *	
14	* .9124 *	* 1.1773 *	* 1.1601 *	* 1.0870 *	* .7565 *			
	* 1.9760 *	* 1.5463 *	* 1.5897 *	* 1.7007 *	* 2.3564 *	* 3.2150 *		
15	* .5290 *	* .6692 *	* .6391 *	* .5595 *	F-SUB-Q			
	* 3.3585 *	* 2.6806 *	* 2.8264 *	* 3.3252 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 2 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0377	* 1.3361	* 1.2158	* 1.3282	* 1.1862	* 1.2807	* 1.0288	* .6037 *
	* 1.7807	* 1.4357	* 1.5590	* 1.4141	* 1.5609	* 1.4371	* 1.7720	* 2.9722 *
9	* 1.3361	* 1.2139	* 1.3417	* 1.2066	* 1.3099	* 1.2048	* 1.2571	* .7487 *
	* 1.4357	* 1.5822	* 1.4136	* 1.5554	* 1.4222	* 1.5328	* 1.4670	* 2.4317 *
10	* 1.2158	* 1.3415	* 1.1623	* 1.2721	* 1.2465	* 1.2685	* 1.2160	* .7087 *
	* 1.5590	* 1.4153	* 1.6279	* 1.4892	* 1.5268	* 1.4915	* 1.5394	* 2.5875 *
11	* 1.3282	* 1.2057	* 1.2693	* 1.1512	* 1.2685	* 1.1509	* 1.2454	* .6335 *
	* 1.4141	* 1.5566	* 1.4925	* 1.6431	* 1.4526	* 1.6116	* 1.5078	* 2.9849 *
12	* 1.1862	* 1.3092	* 1.2458	* 1.2680	* 1.2161	* 1.2209	* .8881	*
	* 1.5609	* 1.4224	* 1.5276	* 1.4526	* 1.4701	* 1.4684	* 2.0606	*
13	* 1.2807	* 1.2047	* 1.2682	* 1.1508	* 1.2209	* 1.2137	* .6133	*
	* 1.4371	* 1.5330	* 1.4918	* 1.6117	* 1.4684	* 1.4587	* 2.9100	*
14	* 1.0288	* 1.2574	* 1.2160	* 1.2454	* .8880	* .6133	*	
	* 1.7720	* 1.4667	* 1.5394	* 1.5078	* 2.0610	* 2.9099	*	
15	* .6037	* .7489	* .7088	* .6335	* F-SUB-Q			
	* 2.9722	* 2.4309	* 2.5870	* 2.9849	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1159	* 1.4593	* 1.3404	* 1.4455	* 1.3017	* 1.3896	* 1.1290	* .6446 *
	* 1.7388	* 1.3493	* 1.4430	* 1.3220	* 1.4455	* 1.3455	* 1.6388	* 2.8265 *
9	* 1.4593	* 1.3375	* 1.4636	* 1.3351	* 1.4294	* 1.3009	* 1.3660	* .7845 *
	* 1.3493	* 1.4724	* 1.3164	* 1.4316	* 1.3292	* 1.4411	* 1.3687	* 2.3571 *
10	* 1.3404	* 1.4632	* 1.2348	* 1.3903	* 1.3489	* 1.3732	* 1.3051	* .7278 *
	* 1.4430	* 1.3182	* 1.5617	* 1.3860	* 1.4388	* 1.4024	* 1.4582	* 2.5603 *
11	* 1.4455	* 1.3325	* 1.3869	* 1.2788	* 1.3969	* 1.2524	* 1.3719	* .6558 *
	* 1.3220	* 1.4330	* 1.3894	* 1.5239	* 1.3637	* 1.5218	* 1.3958	* 2.9366 *
12	* 1.3017	* 1.4285	* 1.3480	* 1.3963	* 1.3362	* 1.3530	* .9581	*
	* 1.4455	* 1.3299	* 1.4398	* 1.3638	* 1.3958	* 1.3780	* 1.9626	*
13	* 1.3896	* 1.3007	* 1.3728	* 1.2522	* 1.3529	* 1.3611	* .6630	*
	* 1.3455	* 1.4414	* 1.4028	* 1.5220	* 1.3781	* 1.3493	* 2.7786	*
14	* 1.1290	* 1.3661	* 1.3051	* 1.3718	* .9577	* .6629	*	
	* 1.6388	* 1.3686	* 1.4583	* 1.3959	* 1.9634	* 2.7786	*	
15	* .6446	* .7847	* .7279	* .6558	* F-SUB-Q			
	* 2.8265	* 2.3566	* 2.5600	* 2.9368	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 3 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1375	* 1.5180	* 1.3817	* 1.5028	* 1.3586	* 1.4442	* 1.1625	* .6514 *
	* 1.7636	* 1.3322	* 1.4312	* 1.2973	* 1.4128	* 1.3199	* 1.6220	* 2.8513 *
9	* 1.5180	* 1.3775	* 1.5219	* 1.3741	* 1.4866	* 1.3458	* 1.4178	* .7973 *
	* 1.3322	* 1.4683	* 1.2928	* 1.4186	* 1.3038	* 1.4198	* 1.3434	* 2.3641 *
10	* 1.3817	* 1.5214	* 1.2615	* 1.4352	* 1.3902	* 1.4263	* 1.3572	* .7398 *
	* 1.4312	* 1.2947	* 1.5589	* 1.3702	* 1.4244	* 1.3771	* 1.4289	* 2.5676 *
11	* 1.5028	* 1.3732	* 1.4315	* 1.3322	* 1.4580	* 1.3032	* 1.4354	* .6676 *
	* 1.2973	* 1.4196	* 1.3738	* 1.4996	* 1.3398	* 1.5019	* 1.3667	* 2.9403 *
12	* 1.3586	* 1.4856	* 1.3892	* 1.4573	* 1.3939	* 1.4206	* .9969	*
	* 1.4128	* 1.3046	* 1.4255	* 1.3398	* 1.3812	* 1.3540	* 1.9401	*
13	* 1.4442	* 1.3454	* 1.4258	* 1.3029	* 1.4205	* 1.4406	* .6843	*
	* 1.3199	* 1.4201	* 1.3775	* 1.5021	* 1.3542	* 1.3160	* 2.7781	*
14	* 1.1625	* 1.4178	* 1.3570	* 1.4352	* .9965	* .6843	*	
	* 1.6220	* 1.3434	* 1.4291	* 1.3668	* 1.9410	* 2.7781	*	
15	* .6514	* .7974	* .7398	* .6676	* F-SUB-Q			
	* 2.8513	* 2.3637	* 2.5676	* 2.9407	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1500	* 1.5473	* 1.4038	* 1.5323	* 1.3825	* 1.4736	* 1.1782	* .6546 *
	* 1.7886	* 1.3352	* 1.4432	* 1.3016	* 1.4215	* 1.3235	* 1.6369	* 2.9029 *
9	* 1.5473	* 1.3961	* 1.5513	* 1.3945	* 1.5159	* 1.3719	* 1.4469	* .8044 *
	* 1.3352	* 1.4802	* 1.2990	* 1.4315	* 1.3081	* 1.4242	* 1.3455	* 2.3951 *
10	* 1.4038	* 1.5508	* 1.2805	* 1.4582	* 1.4135	* 1.4565	* 1.3882	* .7505 *
	* 1.4432	* 1.3009	* 1.5723	* 1.3799	* 1.4319	* 1.3779	* 1.4265	* 2.5865 *
11	* 1.5323	* 1.3935	* 1.4543	* 1.3577	* 1.4909	* 1.3338	* 1.4731	* .6772 *
	* 1.3016	* 1.4325	* 1.3836	* 1.5019	* 1.3398	* 1.5042	* 1.3597	* 2.9467 *
12	* 1.3825	* 1.5149	* 1.4124	* 1.4901	* 1.4298	* 1.4604	* 1.0237	*
	* 1.4215	* 1.3085	* 1.4331	* 1.3399	* 1.3843	* 1.3556	* 1.9397	*
13	* 1.4736	* 1.3716	* 1.4560	* 1.3335	* 1.4602	* 1.4888	* .6989	*
	* 1.3235	* 1.4246	* 1.3784	* 1.5045	* 1.3557	* 1.3148	* 2.8071	*
14	* 1.1782	* 1.4468	* 1.3880	* 1.4729	* 1.0233	* .6989	*	
	* 1.6369	* 1.3456	* 1.4267	* 1.3599	* 1.9405	* 2.8071	*	
15	* .6546	* .8045	* .7505	* .6770	* F-SUB-Q			
	* 2.9029	* 2.3949	* 2.5866	* 2.9472	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 4 of 311

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.1649	* 1.5856	* 1.4315	* 1.5710	* 1.4106	* 1.5130	* 1.1994	* .6621
	* 1.8021	* 1.3200	* 1.4530	* 1.3038	* 1.4319	* 1.3241	* 1.6510	* 2.9474
9	* 1.5856	* 1.4205	* 1.5902	* 1.4212	* 1.5552	* 1.4056	* 1.4873	* .8177
	* 1.3200	* 1.4738	* 1.3011	* 1.4428	* 1.3091	* 1.4268	* 1.3429	* 2.4163
10	* 1.4315	* 1.5897	* 1.2964	* 1.4889	* 1.4447	* 1.4968	* 1.4271	* .7568
	* 1.4530	* 1.3031	* 1.5942	* 1.3860	* 1.4289	* 1.3729	* 1.4199	* 2.6284
11	* 1.5710	* 1.4202	* 1.4849	* 1.3875	* 1.5351	* 1.3709	* 1.5195	* .6850
	* 1.3038	* 1.4439	* 1.3899	* 1.4910	* 1.3342	* 1.4954	* 1.3402	* 2.9584
12	* 1.4106	* 1.5540	* 1.4435	* 1.5350	* 1.4711	* 1.5083	* 1.0446	*
	* 1.4319	* 1.3094	* 1.4301	* 1.3343	* 1.3814	* 1.3472	* 1.9514	*
13	* 1.5130	* 1.4052	* 1.4962	* 1.3706	* 1.5081	* 1.5427	* .7182	*
	* 1.3241	* 1.4271	* 1.3734	* 1.4958	* 1.3474	* 1.3020	* 2.8057	*
14	* 1.1994	* 1.4871	* 1.4268	* 1.5191	* 1.0439	* .7182	*	
	* 1.6510	* 1.3430	* 1.4202	* 1.3405	* 1.9525	* 2.8057	*	
15	* .6621	* .8177	* .7567	* .6849	* F-SUB-Q			
	* 2.9474	* 2.4161	* 2.6286	* 2.9591	* M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* 1.1638	* 1.6094	* 1.4505	* 1.5958	* 1.4302	* 1.5391	* 1.2144	* .6619
	* 1.8404	* 1.3324	* 1.4737	* 1.3228	* 1.4566	* 1.3419	* 1.6802	* 3.0384
9	* 1.6094	* 1.4363	* 1.6149	* 1.4396	* 1.5811	* 1.4291	* 1.5146	* .8225
	* 1.3324	* 1.4939	* 1.3186	* 1.4673	* 1.3264	* 1.4456	* 1.3568	* 2.4707
10	* 1.4505	* 1.6144	* 1.3086	* 1.5110	* 1.4674	* 1.5241	* 1.4537	* .7616
	* 1.4737	* 1.3207	* 1.6242	* 1.4017	* 1.4406	* 1.3786	* 1.4294	* 2.6832
11	* 1.5958	* 1.4386	* 1.5068	* 1.4101	* 1.5675	* 1.3970	* 1.5522	* .6893
	* 1.3228	* 1.4684	* 1.4057	* 1.5038	* 1.3331	* 1.4976	* 1.3400	* 3.0066
12	* 1.4302	* 1.5799	* 1.4661	* 1.5674	* 1.5023	* 1.5417	* 1.0623	*
	* 1.4566	* 1.3272	* 1.4418	* 1.3332	* 1.3825	* 1.3474	* 1.9540	*
13	* 1.5391	* 1.4287	* 1.5234	* 1.3966	* 1.5415	* 1.5813	* .7270	*
	* 1.3419	* 1.4459	* 1.3792	* 1.4980	* 1.3476	* 1.3028	* 2.8370	*
14	* 1.2144	* 1.5144	* 1.4534	* 1.5518	* 1.0616	* .7269	*	
	* 1.6802	* 1.3570	* 1.4298	* 1.3403	* 1.9552	* 2.8370	*	
15	* .6619	* .8225	* .7615	* .6891	* F-SUB-Q			
	* 3.0384	* 2.4707	* 2.6836	* 3.0073	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 5 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1752	* 1.6366	* 1.4708	* 1.6242	* 1.4516	* 1.5686	* 1.2308	* .6699 *
	* 1.8900	* 1.3515	* 1.4979	* 1.3447	* 1.4862	* 1.3629	* 1.7152	* 3.1082 *
9	* 1.6366	* 1.4538	* 1.6432	* 1.4601	* 1.6110	* 1.4544	* 1.5450	* .8318 *
	* 1.3515	* 1.5224	* 1.3375	* 1.4959	* 1.3460	* 1.4689	* 1.3733	* 2.5217 *
10	* 1.4708	* 1.6426	* 1.3218	* 1.5367	* 1.4926	* 1.5545	* 1.4824	* .7668 *
	* 1.4979	* 1.3382	* 1.6587	* 1.4207	* 1.4566	* 1.3897	* 1.4418	* 2.7471 *
11	* 1.6242	* 1.4590	* 1.5323	* 1.4348	* 1.6025	* 1.4246	* 1.5869	* .6948 *
	* 1.3447	* 1.4970	* 1.4249	* 1.5259	* 1.3476	* 1.5152	* 1.3511	* 3.0566 *
12	* 1.4516	* 1.6097	* 1.4913	* 1.6024	* 1.5348	* 1.5775	* 1.0781	*
	* 1.4862	* 1.3470	* 1.4578	* 1.3476	* 1.4007	* 1.3593	* 1.9840	*
13	* 1.5686	* 1.4539	* 1.5538	* 1.4241	* 1.5772	* 1.6207	* .7409	*
	* 1.3629	* 1.4693	* 1.3904	* 1.5156	* 1.3595	* 1.3092	* 2.8654	*
14	* 1.2308	* 1.5446	* 1.4819	* 1.5864	* 1.0773	* .7409	*	*
	* 1.7152	* 1.3736	* 1.4421	* 1.3515	* 1.9853	* 2.8655	*	*
15	* .6699	* .8317	* .7666	* .6946	* F-SUB-Q			
	* 3.1082	* 2.5217	* 2.7476	* 3.0574	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1623	* 1.6272	* 1.4683	* 1.6167	* 1.4504	* 1.5634	* 1.2301	* .6620 *
	* 1.9833	* 1.4057	* 1.5566	* 1.4037	* 1.5474	* 1.4217	* 1.7831	* 3.2635 *
9	* 1.6272	* 1.4493	* 1.6349	* 1.4581	* 1.6054	* 1.4532	* 1.5412	* .8318 *
	* 1.4057	* 1.5800	* 1.3941	* 1.5561	* 1.4027	* 1.5275	* 1.4260	* 2.6133 *
10	* 1.4683	* 1.6343	* 1.3328	* 1.5369	* 1.4941	* 1.5508	* 1.4804	* .7763 *
	* 1.5566	* 1.3948	* 1.7078	* 1.4742	* 1.5077	* 1.4421	* 1.4939	* 2.8088 *
11	* 1.6167	* 1.4570	* 1.5325	* 1.4369	* 1.6037	* 1.4248	* 1.5869	* .7035 *
	* 1.4037	* 1.5572	* 1.4784	* 1.5760	* 1.4021	* 1.5689	* 1.3927	* 3.1145 *
12	* 1.4504	* 1.6041	* 1.4927	* 1.6036	* 1.5413	* 1.5779	* 1.0913	*
	* 1.5474	* 1.4038	* 1.5091	* 1.4021	* 1.4535	* 1.4141	* 2.0345	*
13	* 1.5634	* 1.4527	* 1.5501	* 1.4243	* 1.5776	* 1.6247	* .7393	*
	* 1.4217	* 1.5279	* 1.4428	* 1.5694	* 1.4143	* 1.3578	* 2.9831	*
14	* 1.2301	* 1.5408	* 1.4799	* 1.5865	* 1.0907	* .7393	*	*
	* 1.7831	* 1.4263	* 1.4943	* 1.3931	* 2.0356	* 2.9832	*	*
15	* .6620	* .8318	* .7761	* .7033	* F-SUB-Q			
	* 3.2635	* 2.6134	* 2.8094	* 3.1154	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 6 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1774	* 1.6658	* 1.4940	* 1.6563	* 1.4776	* 1.6043	* 1.2509	* .6737 *
	* 1.9837	* 1.3951	* 1.5549	* 1.4016	* 1.5682	* 1.4438	* 1.8290	* 3.3468 *
9	* 1.6658	* 1.4720	* 1.6747	* 1.4840	* 1.6466	* 1.4869	* 1.5830	* .8413 *
	* 1.3951	* 1.5791	* 1.3867	* 1.5638	* 1.4094	* 1.5574	* 1.4467	* 2.6887 *
10	* 1.4940	* 1.6741	* 1.3416	* 1.5697	* 1.5266	* 1.5924	* 1.5187	* .7751 *
	* 1.5549	* 1.3872	* 1.7314	* 1.4786	* 1.5208	* 1.4583	* 1.5131	* 2.9242 *
11	* 1.6563	* 1.4829	* 1.5651	* 1.4689	* 1.6490	* 1.4605	* 1.6330	* .7033 *
	* 1.4016	* 1.5650	* 1.4830	* 1.5826	* 1.4149	* 1.5888	* 1.4046	* 3.2349 *
12	* 1.4776	* 1.6453	* 1.5252	* 1.6490	* 1.5810	* 1.6248	* 1.1034	*
	* 1.5682	* 1.4106	* 1.5222	* 1.4150	* 1.4728	* 1.4261	* 2.0834	*
13	* 1.6043	* 1.4864	* 1.5916	* 1.4600	* 1.6246	* 1.6754	* .7564	*
	* 1.4438	* 1.5578	* 1.4591	* 1.5893	* 1.4264	* 1.3697	* 3.0257	*
14	* 1.2509	* 1.5825	* 1.5182	* 1.6324	* 1.1026	* .7563	*	
	* 1.8290	* 1.4471	* 1.5136	* 1.4050	* 2.0849	* 3.0257	*	
15	* .6737	* .8413	* .7749	* .7030	* F-SUB-Q			
	* 3.3468	* 2.6888	* 2.9248	* 3.2359	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1743	* 1.6769	* 1.5024	* 1.6686	* 1.4875	* 1.6188	* 1.2586	* .6738 *
	* 2.0011	* 1.3957	* 1.5564	* 1.4000	* 1.5673	* 1.4392	* 1.8466	* 3.4386 *
9	* 1.6769	* 1.4778	* 1.6868	* 1.4926	* 1.6609	* 1.5003	* 1.5990	* .8447 *
	* 1.3957	* 1.5835	* 1.3858	* 1.5647	* 1.4064	* 1.5536	* 1.4578	* 2.7523 *
10	* 1.5024	* 1.6862	* 1.3489	* 1.5827	* 1.5401	* 1.6079	* 1.5340	* .7783 *
	* 1.5564	* 1.3865	* 1.7334	* 1.4772	* 1.5190	* 1.4547	* 1.5226	* 2.9927 *
11	* 1.6686	* 1.4915	* 1.5780	* 1.4820	* 1.6688	* 1.4757	* 1.6531	* .7067 *
	* 1.4000	* 1.5658	* 1.4816	* 1.5816	* 1.4145	* 1.5929	* 1.4193	* 3.3091 *
12	* 1.4875	* 1.6595	* 1.5386	* 1.6687	* 1.6008	* 1.6451	* 1.1142	*
	* 1.5673	* 1.4076	* 1.5204	* 1.4146	* 1.4770	* 1.4367	* 2.1139	*
13	* 1.6188	* 1.4997	* 1.6070	* 1.4752	* 1.6448	* 1.6997	* .7612	*
	* 1.4392	* 1.5541	* 1.4555	* 1.5935	* 1.4369	* 1.3921	* 3.1038	*
14	* 1.2586	* 1.5985	* 1.5335	* 1.6525	* 1.1133	* .7611	*	
	* 1.8466	* 1.4583	* 1.5232	* 1.4198	* 2.1155	* 3.1040	*	
15	* .6738	* .8446	* .7780	* .7064	* F-SUB-Q			
	* 3.4386	* 2.7526	* 2.9936	* 3.3104	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 7 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1638	* 1.6637	* 1.4951	* 1.6571	* 1.4818	* 1.6102	* 1.2549	* .6679 *
	* 2.0335	* 1.4170	* 1.5751	* 1.4193	* 1.5836	* 1.4560	* 1.8634	* 3.4896 *
9	* 1.6637	* 1.4689	* 1.6747	* 1.4858	* 1.6513	* 1.4954	* 1.5928	* .8424 *
	* 1.4170	* 1.6046	* 1.4057	* 1.5825	* 1.4239	* 1.5681	* 1.4718	* 2.7736 *
10	* 1.4951	* 1.6738	* 1.3530	* 1.5777	* 1.5366	* 1.6008	* 1.5303	* .7841 *
	* 1.5751	* 1.4064	* 1.7402	* 1.4927	* 1.5334	* 1.4709	* 1.5366	* 2.9840 *
11	* 1.6571	* 1.4847	* 1.5730	* 1.4770	* 1.6658	* 1.4725	* 1.6503	* .7118 *
	* 1.4193	* 1.5836	* 1.4972	* 1.5990	* 1.4292	* 1.6089	* 1.4323	* 3.3030 *
12	* 1.4818	* 1.6499	* 1.5352	* 1.6657	* 1.6024	* 1.6421	* 1.1225	* .7589 *
	* 1.5836	* 1.4251	* 1.5349	* 1.4293	* 1.4887	* 1.4520	* 2.1145	* .7589 *
13	* 1.6102	* 1.4948	* 1.5999	* 1.4719	* 1.6418	* 1.7005	* 1.4385	* 2.7243 *
	* 1.4560	* 1.5687	* 1.4717	* 1.6095	* 1.4523	* 1.4027	* 3.1381	* .7588 *
14	* 1.2549	* 1.5922	* 1.5297	* 1.6497	* 1.1218	* .7588	* 3.1383	* 3.1383 *
	* 1.8634	* 1.4723	* 1.5372	* 1.4329	* 2.1159	* 3.1383	* 3.1383	* 3.1383 *
15	* .6679	* .8423	* .7838	* .7115	* F-SUB-Q			
	* 3.4896	* 2.7740	* 2.9850	* 3.3043	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1705	* 1.6916	* 1.5113	* 1.6860	* 1.4996	* 1.6415	* 1.2690	* .6755 *
	* 2.0132	* 1.3884	* 1.5512	* 1.3891	* 1.5582	* 1.4232	* 1.8329	* 3.4167 *
9	* 1.6916	* 1.4823	* 1.7039	* 1.5019	* 1.6819	* 1.5202	* 1.6265	* .8512 *
	* 1.3884	* 1.5827	* 1.3763	* 1.5586	* 1.3939	* 1.5382	* 1.4385	* 2.7243 *
10	* 1.5113	* 1.7030	* 1.3540	* 1.5996	* 1.5595	* 1.6328	* 1.5623	* .7810 *
	* 1.5512	* 1.3770	* 1.7312	* 1.4696	* 1.5106	* 1.4401	* 1.5042	* 2.9739 *
11	* 1.6860	* 1.5008	* 1.5948	* 1.4993	* 1.7013	* 1.4994	* 1.6885	* .7106 *
	* 1.3891	* 1.5597	* 1.4739	* 1.5742	* 1.4068	* 1.5846	* 1.4042	* 3.2913 *
12	* 1.4996	* 1.6805	* 1.5583	* 1.7012	* 1.6323	* 1.6801	* 1.1289	* .7728 *
	* 1.5582	* 1.3950	* 1.5120	* 1.4069	* 1.4718	* 1.4270	* 2.1064	* .7728 *
13	* 1.6415	* 1.5196	* 1.6319	* 1.4987	* 1.6798	* 1.7437	* .7729	* 3.0859 *
	* 1.4232	* 1.5388	* 1.4409	* 1.5853	* 1.4273	* 1.3780	* 3.0859	* 3.0859 *
14	* 1.2690	* 1.6259	* 1.5616	* 1.6878	* 1.1280	* .7728	* 3.0861	* 3.0861 *
	* 1.8329	* 1.4391	* 1.5049	* 1.4048	* 2.1080	* 3.0861	* 3.0861	* 3.0861 *
15	* .6755	* .8511	* .7807	* .7103	* F-SUB-Q			
	* 3.4167	* 2.7247	* 2.9750	* 3.2928	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 8 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1616	* 1.6984	* 1.5139	* 1.6938	* 1.5037	* 1.6522	* 1.2726	* .6728 *
	* 1.9749	* 1.3463	* 1.5074	* 1.3464	* 1.5134	* 1.3775	* 1.7801	* 3.3395 *
9	* 1.6984	* 1.4828	* 1.7117	* 1.5047	* 1.6925	* 1.5292	* 1.6402	* .8514 *
	* 1.3463	* 1.5401	* 1.3339	* 1.5146	* 1.3498	* 1.4897	* 1.3899	* 2.6515 *
10	* 1.5139	* 1.7108	* 1.3516	* 1.6058	* 1.5675	* 1.6445	* 1.5759	* .7790 *
	* 1.5074	* 1.3346	* 1.6879	* 1.4252	* 1.4642	* 1.3927	* 1.4536	* 2.9017 *
11	* 1.6938	* 1.5036	* 1.6009	* 1.5062	* 1.7163	* 1.5101	* 1.7061	* .7090 *
	* 1.3464	* 1.5156	* 1.4295	* 1.5252	* 1.3599	* 1.5329	* 1.3534	* 3.2087 *
12	* 1.5037	* 1.6911	* 1.5662	* 1.7163	* 1.6464	* 1.6969	* 1.1332	*
	* 1.5134	* 1.3509	* 1.4656	* 1.3600	* 1.4259	* 1.3788	* 2.0413	*
13	* 1.6522	* 1.5286	* 1.6436	* 1.5096	* 1.6966	* 1.7657	* .7749	*
	* 1.3775	* 1.4903	* 1.3935	* 1.5335	* 1.3790	* 1.3298	* 2.9918	*
14	* 1.2726	* 1.6395	* 1.5753	* 1.7054	* 1.1323	* .7749	*	
	* 1.7801	* 1.3905	* 1.4542	* 1.3540	* 2.0430	* 2.9919	*	
15	* .6728	* .8512	* .7787	* .7087	* F-SUB-Q			
	* 3.3395	* 2.6519	* 2.9028	* 3.2101	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1540	* 1.6935	* 1.5086	* 1.6901	* 1.4998	* 1.6509	* 1.2697	* .6699 *
	* 1.9406	* 1.3179	* 1.4765	* 1.3172	* 1.4811	* 1.3458	* 1.7417	* 3.2761 *
9	* 1.6935	* 1.4760	* 1.7077	* 1.5003	* 1.6917	* 1.5280	* 1.6409	* .8488 *
	* 1.3179	* 1.5100	* 1.3051	* 1.4832	* 1.3190	* 1.4550	* 1.3560	* 2.5958 *
10	* 1.5086	* 1.7068	* 1.3494	* 1.6037	* 1.5668	* 1.6443	* 1.5779	* .7778 *
	* 1.4765	* 1.3057	* 1.6498	* 1.3922	* 1.4296	* 1.3589	* 1.4172	* 2.8359 *
11	* 1.6901	* 1.4986	* 1.5987	* 1.5041	* 1.7193	* 1.5117	* 1.7100	* .7080 *
	* 1.3172	* 1.4842	* 1.3964	* 1.4893	* 1.3229	* 1.4936	* 1.3159	* 3.1336 *
12	* 1.4998	* 1.6903	* 1.5655	* 1.7192	* 1.6501	* 1.7006	* 1.1353	*
	* 1.4811	* 1.3201	* 1.4310	* 1.3229	* 1.3859	* 1.3401	* 1.9847	*
13	* 1.6509	* 1.5274	* 1.6434	* 1.5112	* 1.7002	* 1.7728	* .7741 *	
	* 1.3458	* 1.4555	* 1.3597	* 1.4942	* 1.3404	* 1.2890	* 2.9156	*
14	* 1.2697	* 1.6401	* 1.5772	* 1.7093	* 1.1343	* .7741 *		
	* 1.7417	* 1.3565	* 1.4179	* 1.3165	* 1.9863	* 2.9157	*	
15	* .6699	* .8486	* .7775	* .7077	* F-SUB-Q			
	* 3.2761	* 2.5963	* 2.8370	* 3.1351	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 9 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1390	* 1.6722	* 1.4929	* 1.6697	* 1.4853	* 1.6330	* 1.2587	* .6609 *
	* 1.9233	* 1.3060	* 1.4600	* 1.3050	* 1.4638	* 1.3316	* 1.7195	* 3.2512 *
9	* 1.6722	* 1.4597	* 1.6869	* 1.4859	* 1.6742	* 1.5141	* 1.6256	* .8439 *
	* 1.3060	* 1.4941	* 1.2929	* 1.4662	* 1.3046	* 1.4368	* 1.3389	* 2.5548 *
10	* 1.4929	* 1.6860	* 1.3466	* 1.5895	* 1.5543	* 1.6275	* 1.5647	* .7802 *
	* 1.4600	* 1.2936	* 1.6175	* 1.3739	* 1.4099	* 1.3428	* 1.3984	* 2.7662 *
11	* 1.6697	* 1.4839	* 1.5846	* 1.4912	* 1.7052	* 1.5003	* 1.6967	* .7103 *
	* 1.3050	* 1.4673	* 1.3780	* 1.4692	* 1.3014	* 1.4694	* 1.2951	* 3.0537 *
12	* 1.4853	* 1.6728	* 1.5530	* 1.7051	* 1.6407	* 1.6863	* 1.1355	*
	* 1.4638	* 1.3056	* 1.4112	* 1.3015	* 1.3592	* 1.3180	* 1.9367	*
13	* 1.6330	* 1.5135	* 1.6265	* 1.4997	* 1.6860	* 1.7618	* .7671	*
	* 1.3316	* 1.4373	* 1.3435	* 1.4701	* 1.3183	* 1.2638	* 2.8699	*
14	* 1.2587	* 1.6248	* 1.5639	* 1.6959	* 1.1347	* .7671	*	
	* 1.7195	* 1.3395	* 1.3990	* 1.2957	* 1.9381	* 2.8700	*	
15	* .6609	* .8437	* .7799	* .7099	F-SUB-Q			
	* 3.2512	* 2.5553	* 2.7673	* 3.0552	M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1432	* 1.6945	* 1.5023	* 1.6921	* 1.4955	* 1.6572	* 1.2659	* .6660 *
	* 1.8634	* 1.2558	* 1.4144	* 1.2565	* 1.4208	* 1.2840	* 1.6769	* 3.1663 *
9	* 1.6945	* 1.4671	* 1.7100	* 1.4958	* 1.6982	* 1.5316	* 1.6517	* .8461 *
	* 1.2558	* 1.4486	* 1.2438	* 1.4222	* 1.2562	* 1.3898	* 1.2908	* 2.4998 *
10	* 1.5023	* 1.7091	* 1.3414	* 1.6047	* 1.5694	* 1.6521	* 1.5881	* .7706 *
	* 1.4144	* 1.2444	* 1.5865	* 1.3274	* 1.3627	* 1.2928	* 1.3486	* 2.7473 *
11	* 1.6921	* 1.4938	* 1.5997	* 1.5054	* 1.7318	* 1.5192	* 1.7258	* .7022 *
	* 1.2565	* 1.4233	* 1.3315	* 1.4179	* 1.2460	* 1.4179	* 1.2441	* 3.0270 *
12	* 1.4955	* 1.6969	* 1.5680	* 1.7317	* 1.6612	* 1.7152	* 1.1325	*
	* 1.4208	* 1.2572	* 1.3638	* 1.2461	* 1.3027	* 1.2605	* 1.8956	*
13	* 1.6572	* 1.5310	* 1.6511	* 1.5186	* 1.7148	* 1.7945	* .7745	*
	* 1.2840	* 1.3903	* 1.2936	* 1.4184	* 1.2608	* 1.2076	* 2.7752	*
14	* 1.2659	* 1.6509	* 1.5874	* 1.7250	* 1.1315	* .7745	*	
	* 1.6769	* 1.2914	* 1.3493	* 1.2447	* 1.8972	* 2.7754	*	
15	* .6660	* .8459	* .7702	* .7018	F-SUB-Q			
	* 3.1663	* 2.5002	* 2.7485	* 3.0285	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 10 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1354	* 1.6878	* 1.4948	* 1.6855	* 1.4888	* 1.6521	* 1.2599	* .6621 *
	* 1.8141	* 1.2227	* 1.3788	* 1.2243	* 1.3854	* 1.2505	* 1.6366	* 3.1038 *
9	* 1.6878	* 1.4592	* 1.7037	* 1.4898	* 1.6938	* 1.5266	* 1.6482	* .8421 *
	* 1.2227	* 1.4125	* 1.2112	* 1.3854	* 1.2219	* 1.3535	* 1.2558	* 2.4450 *
10	* 1.4948	* 1.7028	* 1.3366	* 1.6011	* 1.5659	* 1.6478	* 1.5837	* .7656 *
	* 1.3788	* 1.2118	* 1.5447	* 1.2901	* 1.3235	* 1.2576	* 1.3117	* 2.6913 *
11	* 1.6855	* 1.4878	* 1.5962	* 1.5006	* 1.7289	* 1.5150	* 1.7230	* .6977 *
	* 1.2242	* 1.3873	* 1.2941	* 1.3786	* 1.2063	* 1.3757	* 1.2076	* 2.9612 *
12	* 1.4888	* 1.6925	* 1.5646	* 1.7288	* 1.6596	* 1.7125	* 1.1270	*
	* 1.3854	* 1.2228	* 1.3246	* 1.2064	* 1.2578	* 1.2200	* 1.8451	*
13	* 1.6521	* 1.5260	* 1.6469	* 1.5145	* 1.7121	* 1.7926	* .7701	*
	* 1.2505	* 1.3541	* 1.2583	* 1.3762	* 1.2202	* 1.1682	* 2.7025	*
14	* 1.2599	* 1.6474	* 1.5829	* 1.7222	* 1.1259	* .7700	*	
	* 1.6366	* 1.2564	* 1.3123	* 1.2082	* 1.8467	* 2.7027	*	
15	* .6621	* .8420	* .7652	* .6973	* F-SUB-Q			
	* 3.1038	* 2.4455	* 2.6925	* 2.9627	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1126	* 1.6443	* 1.4665	* 1.6414	* 1.4608	* 1.6101	* 1.2373	* .6462 *
	* 1.8032	* 1.2231	* 1.3700	* 1.2258	* 1.3770	* 1.2516	* 1.6261	* 3.1056 *
9	* 1.6443	* 1.4324	* 1.6595	* 1.4632	* 1.6530	* 1.4933	* 1.6067	* .8293 *
	* 1.2231	* 1.4024	* 1.2122	* 1.3750	* 1.2204	* 1.3493	* 1.2562	* 2.4235 *
10	* 1.4665	* 1.6587	* 1.3300	* 1.5728	* 1.5391	* 1.6073	* 1.5437	* .7647 *
	* 1.3700	* 1.2127	* 1.5128	* 1.2799	* 1.3115	* 1.2568	* 1.3111	* 2.6295 *
11	* 1.6414	* 1.4613	* 1.5680	* 1.4726	* 1.6880	* 1.4820	* 1.6792	* .6965 *
	* 1.2258	* 1.3768	* 1.2838	* 1.3700	* 1.2015	* 1.3680	* 1.2065	* 2.8930 *
12	* 1.4608	* 1.6518	* 1.5378	* 1.6879	* 1.6297	* 1.6697	* 1.1166	*
	* 1.3770	* 1.2214	* 1.3126	* 1.2016	* 1.2446	* 1.2164	* 1.8128	*
13	* 1.6101	* 1.4927	* 1.6064	* 1.4815	* 1.6694	* 1.7457	* .7503	*
	* 1.2516	* 1.3499	* 1.2575	* 1.3685	* 1.2166	* 1.1655	* 2.6991	*
14	* 1.2373	* 1.6060	* 1.5429	* 1.6784	* 1.1157	* .7503	*	
	* 1.6261	* 1.2568	* 1.3117	* 1.2070	* 1.8142	* 2.6993	*	
15	* .6462	* .8291	* .7644	* .6961	* F-SUB-Q			
	* 3.1056	* 2.4239	* 2.6307	* 2.8944	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 11 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1135	* 1.6379	* 1.4604	* 1.6318	* 1.4542	* 1.6032	* 1.2296	* .6430 *
	* 1.7653	* 1.2029	* 1.3479	* 1.2083	* 1.3559	* 1.2320	* 1.6043	* 3.0625 *
9	* 1.6379	* 1.4282	* 1.6509	* 1.4556	* 1.6452	* 1.4872	* 1.6014	* .8234 *
	* 1.2029	* 1.3779	* 1.1939	* 1.3546	* 1.2014	* 1.3277	* 1.2349	* 2.3941 *
10	* 1.4604	* 1.6502	* 1.3120	* 1.5650	* 1.5352	* 1.6030	* 1.5330	* .7500 *
	* 1.3479	* 1.1944	* 1.5027	* 1.2601	* 1.2875	* 1.2345	* 1.2929	* 2.6296 *
11	* 1.6318	* 1.4537	* 1.5604	* 1.4603	* 1.6798	* 1.4747	* 1.6678	* .6818 *
	* 1.2083	* 1.3563	* 1.2639	* 1.3552	* 1.1812	* 1.3450	* 1.1889	* 2.8969 *
12	* 1.4542	* 1.6440	* 1.5340	* 1.6797	* 1.6275	* 1.6639	* 1.0956	*
	* 1.3559	* 1.2023	* 1.2885	* 1.1813	* 1.2187	* 1.1938	* 1.8085	*
13	* 1.6032	* 1.4865	* 1.6021	* 1.4742	* 1.6635	* 1.7303	* .7450	*
	* 1.2320	* 1.3283	* 1.2352	* 1.3454	* 1.1941	* 1.1492	* 2.6608	*
14	* 1.2296	* 1.6007	* 1.5323	* 1.6671	* 1.0946	* .7449	*	
	* 1.6043	* 1.2355	* 1.2935	* 1.1894	* 1.8100	* 2.6610	*	
15	* .6430	* .8233	* .7496	* .6814	* F-SUB-Q			
	* 3.0625	* 2.3946	* 2.6308	* 2.8984	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0957	* 1.5787	* 1.4043	* 1.5684	* 1.3899	* 1.5455	* 1.1865	* .6161 *
	* 1.7673	* 1.2289	* 1.3809	* 1.2382	* 1.3974	* 1.2588	* 1.6384	* 3.1528 *
9	* 1.5787	* 1.3858	* 1.5859	* 1.3960	* 1.5803	* 1.4340	* 1.5424	* .7972 *
	* 1.2289	* 1.3987	* 1.2239	* 1.3899	* 1.2316	* 1.3561	* 1.2627	* 2.4375 *
10	* 1.4043	* 1.5856	* 1.2604	* 1.4838	* 1.4738	* 1.5505	* 1.4907	* .7331 *
	* 1.3809	* 1.2240	* 1.5403	* 1.3092	* 1.3205	* 1.2567	* 1.3074	* 2.6523 *
11	* 1.5684	* 1.3947	* 1.4798	* 1.3929	* 1.6195	* 1.4217	* 1.5855	* .6601 *
	* 1.2382	* 1.3911	* 1.3127	* 1.3987	* 1.2054	* 1.3727	* 1.2304	* 2.9487 *
12	* 1.3899	* 1.5792	* 1.4727	* 1.6195	* 1.5814	* 1.6055	* 1.0473	*
	* 1.3974	* 1.2325	* 1.3215	* 1.2055	* 1.2337	* 1.2170	* 1.8624	*
13	* 1.5455	* 1.4334	* 1.5496	* 1.4212	* 1.6051	* 1.6478	* .7170	*
	* 1.2588	* 1.3567	* 1.2574	* 1.3732	* 1.2172	* 1.1864	* 2.7219	*
14	* 1.1865	* 1.5417	* 1.4900	* 1.5847	* 1.0465	* .7170	*	
	* 1.6384	* 1.2633	* 1.3080	* 1.2310	* 1.8638	* 2.7222	*	
15	* .6161	* .7971	* .7327	* .6597	* F-SUB-Q			
	* 3.1528	* 2.4380	* 2.6536	* 2.9502	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 12 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9974	* 1.5302	* 1.1831	* 1.4875	* 1.1763	* 1.4576	* 1.0220	* .5344
	* 1.9226	* 1.2536	* 1.6222	* 1.2916	* 1.6348	* 1.3205	* 1.8828	* 3.6032
9	* 1.5302	* 1.1631	* 1.5340	* 1.1583	* 1.5027	* 1.2617	* 1.4440	* .6981
	* 1.2536	* 1.6497	* 1.2515	* 1.6590	* 1.2810	* 1.5257	* 1.3342	* 2.7580
10	* 1.1831	* 1.5337	* 1.1246	* 1.2537	* 1.2707	* 1.4578	* 1.4321	* .6616
	* 1.6222	* 1.2517	* 1.7064	* 1.5343	* 1.5165	* 1.3222	* 1.3459	* 2.9116
11	* 1.4875	* 1.1580	* 1.2509	* 1.2050	* 1.5048	* 1.2569	* 1.3792	* .5775
	* 1.2916	* 1.6595	* 1.5377	* 1.6000	* 1.2823	* 1.5359	* 1.3996	* 3.3387
12	* 1.1763	* 1.5019	* 1.2699	* 1.5045	* 1.3944	* 1.5536	* .9119	*
	* 1.6348	* 1.2816	* 1.5174	* 1.2825	* 1.3842	* 1.2435	* 2.1171	*
13	* 1.4576	* 1.2611	* 1.4571	* 1.2565	* 1.5533	* 1.4186	* .6303	*
	* 1.3205	* 1.5264	* 1.3228	* 1.5364	* 1.2437	* 1.3629	* 3.0655	*
14	* 1.0220	* 1.4434	* 1.4314	* 1.3786	* .9113	* .6302	*	*
	* 1.8828	* 1.3348	* 1.3465	* 1.4002	* 2.1185	* 3.0660	*	*
15	* .5344	* .6979	* .6612	* .5773	* F-SUB-Q			
	* 3.6032	* 2.7588	* 2.9131	* 3.3404	* M-SUB-Q			

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7555	* .6473	* .5682	* .6423	* .5627	* .6285	* .4926	* .3790
	* 2.5251	* 2.9482	* 3.3600	* 2.9767	* 3.3995	* 3.0474	* 3.8899	* 5.0616
9	* .6473	* .5635	* .6423	* .5586	* .6462	* .5786	* .5683	* .3361
	* 2.9482	* 3.3879	* 2.9745	* 3.4215	* 2.9643	* 3.3088	* 3.3740	* 5.7090
10	* .5682	* .6425	* .5728	* .5456	* .5745	* .6392	* .5877	* .3275
	* 3.3600	* 2.9733	* 3.3354	* 3.5104	* 3.3388	* 3.0000	* 3.2641	* 5.8578
11	* .6423	* .5586	* .5452	* .5852	* .6577	* .5790	* .5392	* .2879
	* 2.9767	* 3.4213	* 3.5131	* 3.2788	* 2.9184	* 3.3172	* 3.5615	* 6.6726
12	* .5627	* .6459	* .5743	* .6577	* .6160	* .6162	* .4323	*
	* 3.3995	* 2.9657	* 3.3403	* 2.9188	* 3.1174	* 3.1191	* 4.4469	*
13	* .6285	* .5785	* .6389	* .5788	* .6161	* .5590	* .4491	*
	* 3.0474	* 3.3098	* 3.0014	* 3.3180	* 3.1197	* 3.4405	* 4.2845	*
14	* .4926	* .5681	* .5874	* .5389	* .4324	* .4490	*	*
	* 3.8899	* 3.3756	* 3.2657	* 3.5631	* 4.4459	* 4.2856	*	*
15	* .3790	* .3359	* .3274	* .2878	* F-SUB-Q			
	* 5.0616	* 5.7114	* 5.8606	* 6.6759	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 13 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6398 *	* .5413 *	* .4857 *	* .5417 *	* .4785 *	* .5178 *	* .4238 *	* .3618 *
	* 2.6837 *	* 3.3651 *	* 3.7904 *	* 3.3227 *	* 3.7392 *	* 3.4186 *	* 4.1532 *	* 4.7992 *
9	* .5413 *	* .4930 *	* .5426 *	* .4810 *	* .5321 *	* .4789 *	* .4596 *	* .3046 *
	* 3.3651 *	* 3.7818 *	* 3.3922 *	* 3.7717 *	* 3.3663 *	* 3.7110 *	* 3.8761 *	* 5.7852 *
10	* .4857 *	* .5431 *	* .4985 *	* .4629 *	* .4710 *	* .5145 *	* .4704 *	* .2912 *
	* 3.7904 *	* 3.3920 *	* 3.7092 *	* 3.9606 *	* 3.8884 *	* 3.5611 *	* 3.8506 *	* 6.0780 *
11	* .5417 *	* .4813 *	* .4622 *	* .4368 *	* .5021 *	* .4595 *	* .4289 *	* .2576 *
	* 3.3227 *	* 3.7700 *	* 3.9664 *	* 3.9472 *	* 3.5346 *	* 3.9704 *	* 4.2958 *	* 7.1078 *
12	* .4785 *	* .5320 *	* .4709 *	* .5020 *	* .4417 *	* .4400 *	* .3455 *	
	* 3.7392 *	* 3.3669 *	* 3.8888 *	* 3.5347 *	* 3.7363 *	* 3.7965 *	* 5.1412 *	
13	* .5178 *	* .4789 *	* .5144 *	* .4595 *	* .4399 *	* .3975 *	* .3784 *	
	* 3.4186 *	* 3.7112 *	* 3.5612 *	* 3.9708 *	* 3.7966 *	* 4.1683 *	* 4.5790 *	
14	* .4238 *	* .4598 *	* .4705 *	* .4289 *	* .3457 *	* .3783 *		
	* 4.1532 *	* 3.8743 *	* 3.8499 *	* 4.2957 *	* 5.1386 *	* 4.5805 *		
15	* .3618 *	* .3047 *	* .2913 *	* .2576 *	F-SUB-Q			
	* 4.7992 *	* 5.7810 *	* 6.0757 *	* 7.1073 *	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8398 *	* 1.1961 *	* .9791 *	* 1.1646 *	* .9589 *	* 1.1168 *	* .8357 *	* .4887 *
	* 2.0941 *	* 1.5680 *	* 1.9154 *	* 1.5820 *	* 1.9008 *	* 1.6197 *	* 2.1537 *	* 3.6270 *
9	* 1.1961 *	* .9807 *	* 1.1972 *	* .9619 *	* 1.1452 *	* .9804 *	* 1.0829 *	* .6166 *
	* 1.5680 *	* 1.9284 *	* 1.5699 *	* 1.9207 *	* 1.5985 *	* 1.8557 *	* 1.6809 *	* 2.9071 *
10	* .9791 *	* 1.1971 *	* .9506 *	* .9805 *	* .9904 *	* 1.0979 *	* 1.0699 *	* .5887 *
	* 1.9154 *	* 1.5702 *	* 1.9727 *	* 1.9084 *	* 1.8947 *	* 1.7045 *	* 1.7273 *	* 3.0689 *
11	* 1.1646 *	* .9615 *	* .9787 *	* .9009 *	* 1.0814 *	* .9398 *	* 1.0087 *	* .5178 *
	* 1.5820 *	* 1.9213 *	* 1.9119 *	* 2.0295 *	* 1.6802 *	* 1.9563 *	* 1.8487 *	* 3.6074 *
12	* .9589 *	* 1.1450 *	* .9902 *	* 1.0812 *	* .9616 *	* 1.0727 *	* .7062 *	
	* 1.9008 *	* 1.5988 *	* 1.8950 *	* 1.6802 *	* 1.7948 *	* 1.6440 *	* 2.5721 *	
13	* 1.1168 *	* .9804 *	* 1.0979 *	* .9398 *	* 1.0727 *	* .9696 *	* .5077 *	
	* 1.6197 *	* 1.8559 *	* 1.7046 *	* 1.9564 *	* 1.6440 *	* 1.8001 *	* 3.4975 *	
14	* .8357 *	* 1.0833 *	* 1.0701 *	* 1.0087 *	* .7062 *	* .5076 *		
	* 2.1537 *	* 1.6804 *	* 1.7270 *	* 1.8487 *	* 2.5724 *	* 3.4977 *		
15	* .4887 *	* .6169 *	* .5889 *	* .5178 *	F-SUB-Q			
	* 3.6270 *	* 2.9058 *	* 3.0680 *	* 3.6072 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 14 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0141	* 1.3006	* 1.1845	* 1.2823	* 1.1486	* 1.2373	* .9921	* .5698
	* 1.8740	* 1.4896	* 1.6119	* 1.4664	* 1.6116	* 1.4868	* 1.8347	* 3.1457
9	* 1.3006	* 1.1831	* 1.2972	* 1.1623	* 1.2562	* 1.1568	* 1.2132	* .7125
	* 1.4896	* 1.6369	* 1.4770	* 1.6157	* 1.4749	* 1.5955	* 1.5202	* 2.5542
10	* 1.1845	* 1.2970	* 1.0871	* 1.1813	* 1.1690	* 1.2161	* 1.1746	* .6770
	* 1.6119	* 1.4773	* 1.7543	* 1.6093	* 1.6331	* 1.5564	* 1.5982	* 2.7101
11	* 1.2823	* 1.1614	* 1.1788	* 1.0824	* 1.2088	* 1.1116	* 1.2003	* .6039
	* 1.4664	* 1.6166	* 1.6126	* 1.7341	* 1.5343	* 1.6922	* 1.5802	* 3.1437
12	* 1.1486	* 1.2561	* 1.1685	* 1.2088	* 1.1770	* 1.2001	* .8516	*
	* 1.6116	* 1.4751	* 1.6339	* 1.5343	* 1.5618	* 1.5313	* 2.1784	*
13	* 1.2373	* 1.1567	* 1.2159	* 1.1115	* 1.2000	* 1.1798	* .5913	*
	* 1.4868	* 1.5956	* 1.5567	* 1.6923	* 1.5313	* 1.5372	* 3.0748	*
14	* .9921	* 1.2135	* 1.1746	* 1.2003	* .8515	* .5913	*	*
	* 1.8347	* 1.5199	* 1.5981	* 1.5802	* 2.1788	* 3.0747	*	*
15	* .5698	* .7128	* .6771	* .6039	F-SUB-Q			
	* 3.1457	* 2.5534	* 2.7096	* 3.1437	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1024	* 1.4536	* 1.3085	* 1.4296	* 1.2853	* 1.3802	* 1.1034	* .6201
	* 1.7798	* 1.3634	* 1.4877	* 1.3370	* 1.4640	* 1.3545	* 1.6756	* 2.9352
9	* 1.4536	* 1.3093	* 1.4489	* 1.2868	* 1.4012	* 1.2819	* 1.3560	* .7666
	* 1.3634	* 1.5131	* 1.3463	* 1.4849	* 1.3442	* 1.4615	* 1.3813	* 2.4127
10	* 1.3085	* 1.4486	* 1.1636	* 1.3059	* 1.2826	* 1.3524	* 1.3017	* .7153
	* 1.4877	* 1.3467	* 1.6630	* 1.4799	* 1.5137	* 1.4220	* 1.4646	* 2.6067
11	* 1.4296	* 1.2861	* 1.3030	* 1.1995	* 1.3551	* 1.2367	* 1.3511	* .6401
	* 1.3370	* 1.4856	* 1.4833	* 1.6040	* 1.4049	* 1.5547	* 1.4257	* 3.0143
12	* 1.2853	* 1.4010	* 1.2819	* 1.3550	* 1.3031	* 1.3510	* .9330	*
	* 1.4640	* 1.3444	* 1.5145	* 1.4050	* 1.4489	* 1.3967	* 2.0333	*
13	* 1.3802	* 1.2817	* 1.3521	* 1.2365	* 1.3509	* 1.3429	* .6489	*
	* 1.3545	* 1.4617	* 1.4223	* 1.5549	* 1.3968	* 1.3860	* 2.8719	*
14	* 1.1034	* 1.3561	* 1.3017	* 1.3510	* .9327	* .6489	*	*
	* 1.6756	* 1.3812	* 1.4647	* 1.4258	* 2.0341	* 2.8718	*	*
15	* .6201	* .7668	* .7154	* .6401	F-SUB-Q			
	* 2.9352	* 2.4121	* 2.6064	* 3.0145	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 15 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1392	* 1.5355	* 1.3678	* 1.5099	* 1.3442	* 1.4605	* 1.1524	* .6392
	* 1.7717	* 1.3231	* 1.4548	* 1.2909	* 1.4288	* 1.3059	* 1.6365	* 2.9118
9	* 1.5355	* 1.3647	* 1.5300	* 1.3427	* 1.4818	* 1.3515	* 1.4376	* .7946
	* 1.3231	* 1.4887	* 1.3018	* 1.4530	* 1.2969	* 1.4135	* 1.3276	* 2.3738
10	* 1.3678	* 1.5297	* 1.2034	* 1.3624	* 1.3396	* 1.4300	* 1.3823	* .7423
	* 1.4548	* 1.3022	* 1.6382	* 1.4476	* 1.4779	* 1.3708	* 1.4057	* 2.5617
11	* 1.5099	* 1.3420	* 1.3591	* 1.2602	* 1.4394	* 1.3035	* 1.4375	* .6636
	* 1.2909	* 1.4536	* 1.4512	* 1.5650	* 1.3571	* 1.5060	* 1.3713	* 2.9613
12	* 1.3442	* 1.4815	* 1.3387	* 1.4394	* 1.3750	* 1.4379	* .9844	*
	* 1.4288	* 1.2972	* 1.4788	* 1.3571	* 1.4096	* 1.3468	* 1.9764	*
13	* 1.4605	* 1.3512	* 1.4296	* 1.3033	* 1.4378	* 1.4387	* .6786	*
	* 1.3059	* 1.4137	* 1.3712	* 1.5062	* 1.3469	* 1.3282	* 2.8213	*
14	* 1.1524	* 1.4376	* 1.3821	* 1.4373	* .9839	* .6786	*	
	* 1.6365	* 1.3276	* 1.4059	* 1.3715	* 1.9773	* 2.8213	*	
15	* .6392	* .7948	* .7423	* .6636	* F-SUB-Q			
	* 2.9118	* 2.3734	* 2.5617	* 2.9616	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1654	* 1.5848	* 1.4059	* 1.5585	* 1.3824	* 1.5111	* 1.1846	* .6531
	* 1.7737	* 1.3097	* 1.4509	* 1.2804	* 1.4240	* 1.2927	* 1.6304	* 2.9251
9	* 1.5848	* 1.3992	* 1.5788	* 1.3778	* 1.5319	* 1.3973	* 1.4909	* .8142
	* 1.3097	* 1.4840	* 1.2920	* 1.4508	* 1.2850	* 1.3995	* 1.3090	* 2.3707
10	* 1.4059	* 1.5784	* 1.2339	* 1.3966	* 1.3768	* 1.4801	* 1.4360	* .7650
	* 1.4509	* 1.2924	* 1.6366	* 1.4456	* 1.4703	* 1.3538	* 1.3826	* 2.5423
11	* 1.5585	* 1.3770	* 1.3933	* 1.3023	* 1.4945	* 1.3466	* 1.4941	* .6828
	* 1.2804	* 1.4515	* 1.4492	* 1.5510	* 1.3404	* 1.4882	* 1.3466	* 2.9315
12	* 1.3824	* 1.5316	* 1.3759	* 1.4944	* 1.4249	* 1.4953	* 1.0232	*
	* 1.4240	* 1.2853	* 1.4713	* 1.3405	* 1.3957	* 1.3300	* 1.9494	*
13	* 1.5111	* 1.3970	* 1.4796	* 1.3463	* 1.4951	* 1.5022	* .7008	*
	* 1.2927	* 1.3997	* 1.3542	* 1.4884	* 1.3301	* 1.3095	* 2.8127	*
14	* 1.1846	* 1.4908	* 1.4358	* 1.4939	* 1.0228	* .7008	*	
	* 1.6304	* 1.3091	* 1.3828	* 1.3468	* 1.9502	* 2.8127	*	
15	* .6531	* .8143	* .7649	* .6827	* F-SUB-Q			
	* 2.9251	* 2.3704	* 2.5424	* 2.9319	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 16 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1918	* 1.6402	* 1.4466	* 1.6134	* 1.4236	* 1.5684	* 1.2192	* .6694 *
	* 1.7722	* 1.2845	* 1.4499	* 1.2717	* 1.4234	* 1.2815	* 1.6295	* 2.9370 *
9	* 1.6402	* 1.4365	* 1.6341	* 1.4161	* 1.5885	* 1.4475	* 1.5504	* .8372 *
	* 1.2845	* 1.4679	* 1.2819	* 1.4520	* 1.2748	* 1.3891	* 1.2922	* 2.3682 *
10	* 1.4466	* 1.6337	* 1.2585	* 1.4357	* 1.4184	* 1.5369	* 1.4942	* .7804 *
	* 1.4499	* 1.2824	* 1.6492	* 1.4440	* 1.4630	* 1.3365	* 1.3619	* 2.5573 *
11	* 1.6134	* 1.4153	* 1.4322	* 1.3457	* 1.5543	* 1.3959	* 1.5568	* .6982 *
	* 1.2717	* 1.4527	* 1.4477	* 1.5388	* 1.3241	* 1.4719	* 1.3146	* 2.9173 *
12	* 1.4236	* 1.5882	* 1.4175	* 1.5542	* 1.4782	* 1.5589	* 1.0528	*
	* 1.4234	* 1.2751	* 1.4639	* 1.3242	* 1.3821	* 1.3102	* 1.9448	*
13	* 1.5684	* 1.4472	* 1.5363	* 1.3956	* 1.5587	* 1.5704	* .7262	*
	* 1.2815	* 1.3894	* 1.3370	* 1.4722	* 1.3104	* 1.2859	* 2.7891	*
14	* 1.2192	* 1.5503	* 1.4939	* 1.5564	* 1.0522	* .7262	*	
	* 1.6295	* 1.2924	* 1.3621	* 1.3149	* 1.9459	* 2.7891	*	
15	* .6694	* .8372	* .7804	* .6980	* F-SUB-Q			
	* 2.9370	* 2.3680	* 2.5575	* 2.9179	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2012	* 1.6780	* 1.4761	* 1.6514	* 1.4541	* 1.6093	* 1.2451	* .6760 *
	* 1.7987	* 1.2893	* 1.4646	* 1.2829	* 1.4406	* 1.2904	* 1.6481	* 3.0029 *
9	* 1.6780	* 1.4629	* 1.6721	* 1.4440	* 1.6286	* 1.4841	* 1.5937	* .8498 *
	* 1.2893	* 1.4801	* 1.2864	* 1.4700	* 1.2844	* 1.3988	* 1.2955	* 2.4048 *
10	* 1.4761	* 1.6717	* 1.2778	* 1.4644	* 1.4496	* 1.5776	* 1.5366	* .7928 *
	* 1.4646	* 1.2869	* 1.6745	* 1.4562	* 1.4657	* 1.3381	* 1.3612	* 2.5917 *
11	* 1.6514	* 1.4433	* 1.4606	* 1.3796	* 1.5984	* 1.4332	* 1.6029	* .7085 *
	* 1.2829	* 1.4708	* 1.4600	* 1.5343	* 1.3159	* 1.4633	* 1.3071	* 2.9408 *
12	* 1.4541	* 1.6283	* 1.4486	* 1.5984	* 1.5196	* 1.6056	* 1.0785	*
	* 1.4406	* 1.2846	* 1.4667	* 1.3160	* 1.3761	* 1.3024	* 1.9374	*
13	* 1.6093	* 1.4838	* 1.5770	* 1.4329	* 1.6054	* 1.6212	* .7403	*
	* 1.2904	* 1.3992	* 1.3386	* 1.4636	* 1.3025	* 1.2788	* 2.8029	*
14	* 1.2451	* 1.5934	* 1.5363	* 1.6025	* 1.0779	* .7403	*	
	* 1.6481	* 1.2957	* 1.3615	* 1.3074	* 1.9385	* 2.8029	*	
15	* .6760	* .8498	* .7927	* .7083	* F-SUB-Q			
	* 3.0029	* 2.4048	* 2.5920	* 2.9415	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 17 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2201	* 1.7165	* 1.5045	* 1.6903	* 1.4839	* 1.6509	* 1.2700	* .6888 *
	* 1.8413	* 1.3009	* 1.4812	* 1.3000	* 1.4660	* 1.3058	* 1.6764	* 3.0554 *
9	* 1.7165	* 1.4885	* 1.7111	* 1.4716	* 1.6696	* 1.5199	* 1.6370	* .8652 *
	* 1.3009	* 1.5022	* 1.2974	* 1.4957	* 1.2998	* 1.4166	* 1.3053	* 2.4444 *
10	* 1.5045	* 1.7107	* 1.2956	* 1.4943	* 1.4809	* 1.6190	* 1.5783	* .8039 *
	* 1.4812	* 1.2978	* 1.7075	* 1.4743	* 1.4795	* 1.3451	* 1.3661	* 2.6416 *
11	* 1.6903	* 1.4709	* 1.4904	* 1.4124	* 1.6429	* 1.4691	* 1.6486	* .7187 *
	* 1.3000	* 1.4964	* 1.4782	* 1.5520	* 1.3262	* 1.4763	* 1.3124	* 2.9785 *
12	* 1.4839	* 1.6692	* 1.4798	* 1.6429	* 1.5602	* 1.6524	* 1.1008	*
	* 1.4660	* 1.3001	* 1.4805	* 1.3262	* 1.3906	* 1.3094	* 1.9607	*
13	* 1.6509	* 1.5194	* 1.6183	* 1.4688	* 1.6522	* 1.6709	* .7585	*
	* 1.3058	* 1.4171	* 1.3456	* 1.4766	* 1.3096	* 1.2809	* 2.8226	*
14	* 1.2700	* 1.6367	* 1.5779	* 1.6482	* 1.1001	* .7584	*	
	* 1.6764	* 1.3056	* 1.3665	* 1.3127	* 1.9619	* 2.8226	*	
15	* .6888	* .8652	* .8038	* .7185	* F-SUB-Q			
	* 3.0554	* 2.4444	* 2.6420	* 2.9793	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2126	* 1.7148	* 1.5084	* 1.6901	* 1.4894	* 1.6539	* 1.2760	* .6853 *
	* 1.9256	* 1.3508	* 1.5349	* 1.3549	* 1.5240	* 1.3592	* 1.7389	* 3.1980 *
9	* 1.7148	* 1.4902	* 1.7102	* 1.4756	* 1.6719	* 1.5260	* 1.6430	* .8705 *
	* 1.3508	* 1.5568	* 1.3499	* 1.5544	* 1.3531	* 1.4703	* 1.3524	* 2.5255 *
10	* 1.5084	* 1.7097	* 1.3111	* 1.4984	* 1.4878	* 1.6233	* 1.5858	* .8184 *
	* 1.5349	* 1.3502	* 1.7560	* 1.5293	* 1.5299	* 1.3931	* 1.4106	* 2.6942 *
11	* 1.6901	* 1.4748	* 1.4946	* 1.4238	* 1.6516	* 1.4802	* 1.6564	* .7317 *
	* 1.3549	* 1.5551	* 1.5333	* 1.6014	* 1.3766	* 1.5258	* 1.3486	* 3.0270 *
12	* 1.4894	* 1.6715	* 1.4867	* 1.6515	* 1.5731	* 1.6608	* 1.1206	*
	* 1.5240	* 1.3534	* 1.5310	* 1.3767	* 1.4403	* 1.3588	* 2.0014	*
13	* 1.6539	* 1.5256	* 1.6226	* 1.4798	* 1.6606	* 1.6825	* .7609	*
	* 1.3592	* 1.4707	* 1.3936	* 1.5262	* 1.3590	* 1.3256	* 2.9295	*
14	* 1.2760	* 1.6426	* 1.5853	* 1.6559	* 1.1201	* .7609	*	
	* 1.7389	* 1.3527	* 1.4110	* 1.3490	* 2.0024	* 2.9295	*	
15	* .6853	* .8705	* .8182	* .7315	* F-SUB-Q			
	* 3.1980	* 2.5255	* 2.6947	* 3.0279	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 18 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2318	* 1.7604	* 1.5378	* 1.7357	* 1.5204	* 1.7025	* 1.3015	* .6990 *
	* 1.9235	* 1.3395	* 1.5333	* 1.3563	* 1.5457	* 1.3796	* 1.7840	* 3.2760 *
9	* 1.7604	* 1.5167	* 1.7563	* 1.5041	* 1.7197	* 1.5658	* 1.6935	* .8833 *
	* 1.3395	* 1.5557	* 1.3418	* 1.5648	* 1.3670	* 1.5000	* 1.3705	* 2.5975 *
10	* 1.5378	* 1.7558	* 1.3206	* 1.5308	* 1.5215	* 1.6712	* 1.6333	* .8204 *
	* 1.5333	* 1.3422	* 1.7853	* 1.5403	* 1.5494	* 1.4098	* 1.4271	* 2.8019 *
11	* 1.7357	* 1.5033	* 1.5268	* 1.4570	* 1.7021	* 1.5189	* 1.7098	* .7336 *
	* 1.3563	* 1.5656	* 1.5444	* 1.6242	* 1.3884	* 1.5452	* 1.3598	* 3.1434 *
12	* 1.5204	* 1.7193	* 1.5203	* 1.7021	* 1.6168	* 1.7153	* 1.1351	*
	* 1.5457	* 1.3674	* 1.5506	* 1.3884	* 1.4585	* 1.3686	* 2.0516	*
13	* 1.7025	* 1.5652	* 1.6705	* 1.5185	* 1.7150	* 1.7402	* .7799	*
	* 1.3796	* 1.5005	* 1.4104	* 1.5455	* 1.3688	* 1.3353	* 2.9703	*
14	* 1.3015	* 1.6930	* 1.6328	* 1.7092	* 1.1343	* .7799	*	
	* 1.7840	* 1.3709	* 1.4275	* 1.3601	* 2.0529	* 2.9703	*	
15	* .6990	* .8832	* .8202	* .7334	* F-SUB-Q			
	* 3.2760	* 2.5977	* 2.8025	* 3.1443	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2309	* 1.7747	* 1.5478	* 1.7508	* 1.5322	* 1.7212	* 1.3119	* .7007 *
	* 1.9329	* 1.3353	* 1.5301	* 1.3509	* 1.5398	* 1.3697	* 1.7931	* 3.3487 *
9	* 1.7747	* 1.5241	* 1.7712	* 1.5136	* 1.7374	* 1.5822	* 1.7150	* .8889 *
	* 1.3353	* 1.5551	* 1.3366	* 1.5619	* 1.3587	* 1.4909	* 1.3764	* 2.6472 *
10	* 1.5478	* 1.7707	* 1.3277	* 1.5426	* 1.5353	* 1.6905	* 1.6543	* .8258 *
	* 1.5301	* 1.3370	* 1.7837	* 1.5355	* 1.5432	* 1.4009	* 1.4303	* 2.8546 *
11	* 1.7508	* 1.5129	* 1.5384	* 1.4736	* 1.7248	* 1.5376	* 1.7338	* .7386 *
	* 1.3509	* 1.5627	* 1.5397	* 1.6189	* 1.3867	* 1.5532	* 1.3707	* 3.2057 *
12	* 1.5322	* 1.7370	* 1.5342	* 1.7247	* 1.6386	* 1.7397	* 1.1480	*
	* 1.5398	* 1.3590	* 1.5444	* 1.3868	* 1.4623	* 1.3764	* 2.0783	*
13	* 1.7212	* 1.5816	* 1.6897	* 1.5372	* 1.7394	* 1.7683	* .7861	*
	* 1.3697	* 1.4915	* 1.4015	* 1.5536	* 1.3766	* 1.3559	* 3.0440	*
14	* 1.3119	* 1.7145	* 1.6538	* 1.7332	* 1.1472	* .7861	*	
	* 1.7931	* 1.3768	* 1.4308	* 1.3712	* 2.0798	* 3.0441	*	
15	* .7007	* .8888	* .8256	* .7383	* F-SUB-Q			
	* 3.3487	* 2.6474	* 2.8553	* 3.2069	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 19 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2196	* 1.7610	* 1.5401	* 1.7387	* 1.5265	* 1.7131	* 1.3090	* .6960 *
	* 1.9590	* 1.3518	* 1.5443	* 1.3658	* 1.5522	* 1.3819	* 1.8042	* 3.3839 *
9	* 1.7610	* 1.5147	* 1.7582	* 1.5063	* 1.7282	* 1.5785	* 1.7109	* .8876 *
	* 1.3518	* 1.5717	* 1.3523	* 1.5758	* 1.3713	* 1.5000	* 1.3840	* 2.6589 *
10	* 1.5401	* 1.7577	* 1.3308	* 1.5354	* 1.5310	* 1.6841	* 1.6518	* .8327 *
	* 1.5443	* 1.3526	* 1.7865	* 1.5491	* 1.5540	* 1.4119	* 1.4377	* 2.8379 *
11	* 1.7387	* 1.5056	* 1.5313	* 1.4740	* 1.7222	* 1.5381	* 1.7317	* .7448 *
	* 1.3658	* 1.5766	* 1.5532	* 1.6270	* 1.3968	* 1.5615	* 1.3790	* 3.1878 *
12	* 1.5265	* 1.7278	* 1.5298	* 1.7222	* 1.6401	* 1.7375	* 1.1585	*
	* 1.5522	* 1.3716	* 1.5552	* 1.3969	* 1.4699	* 1.3866	* 2.0701	*
13	* 1.7131	* 1.5780	* 1.6833	* 1.5377	* 1.7372	* 1.7701	* .7846	*
	* 1.3819	* 1.5004	* 1.4126	* 1.5619	* 1.3869	* 1.3629	* 3.0664	*
14	* 1.3090	* 1.7103	* 1.6511	* 1.7311	* 1.1577	* .7846	*	
	* 1.8042	* 1.3845	* 1.4382	* 1.3795	* 2.0714	* 3.0666	*	
15	* .6960	* .8875	* .8325	* .7445	* F-SUB-Q			
	* 3.3839	* 2.6591	* 2.8387	* 3.1890	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2247	* 1.7873	* 1.5528	* 1.7652	* 1.5411	* 1.7438	* 1.3216	* .7024 *
	* 1.9315	* 1.3186	* 1.5146	* 1.3305	* 1.5207	* 1.3446	* 1.7663	* 3.2981 *
9	* 1.7873	* 1.5247	* 1.7850	* 1.5183	* 1.7580	* 1.6003	* 1.7456	* .8959 *
	* 1.3186	* 1.5439	* 1.3181	* 1.5452	* 1.3351	* 1.4671	* 1.3475	* 2.5984 *
10	* 1.5528	* 1.7845	* 1.3270	* 1.5505	* 1.5477	* 1.7149	* 1.6844	* .8290 *
	* 1.5146	* 1.3185	* 1.7695	* 1.5189	* 1.5254	* 1.3765	* 1.4015	* 2.8124 *
11	* 1.7652	* 1.5175	* 1.5463	* 1.4915	* 1.7554	* 1.5614	* 1.7697	* .7424 *
	* 1.3305	* 1.5459	* 1.5229	* 1.6039	* 1.3722	* 1.5385	* 1.3463	* 3.1629 *
12	* 1.5411	* 1.7576	* 1.5465	* 1.7554	* 1.6671	* 1.7754	* 1.1622	*
	* 1.5207	* 1.3355	* 1.5265	* 1.3723	* 1.4516	* 1.3605	* 2.0578	*
13	* 1.7438	* 1.5996	* 1.7140	* 1.5609	* 1.7751	* 1.8133	* .7974	*
	* 1.3446	* 1.4677	* 1.3771	* 1.5389	* 1.3607	* 1.3356	* 3.0096	*
14	* 1.3216	* 1.7449	* 1.6838	* 1.7691	* 1.1613	* .7974	*	
	* 1.7663	* 1.3480	* 1.4021	* 1.3468	* 2.0594	* 3.0097	*	
15	* .7024	* .8957	* .8287	* .7421	* F-SUB-Q			
	* 3.2981	* 2.5987	* 2.8134	* 3.1642	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 20 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2112	* 1.7880	* 1.5491	* 1.7668	* 1.5393	* 1.7497	* 1.3213	* .6975 *
	* 1.8931	* 1.2773	* 1.4712	* 1.2886	* 1.4759	* 1.2994	* 1.7134	* 3.2219 *
9	* 1.7880	* 1.5190	* 1.7863	* 1.5146	* 1.7628	* 1.6033	* 1.7557	* .8937 *
	* 1.2773	* 1.5017	* 1.2765	* 1.5013	* 1.2909	* 1.4196	* 1.2987	* 2.5262 *
10	* 1.5491	* 1.7858	* 1.3185	* 1.5483	* 1.5477	* 1.7216	* 1.6944	* .8249 *
	* 1.4712	* 1.2768	* 1.7258	* 1.4738	* 1.4780	* 1.3290	* 1.3505	* 2.7407 *
11	* 1.7668	* 1.5139	* 1.5439	* 1.4943	* 1.7649	* 1.5672	* 1.7829	* .7386 *
	* 1.2886	* 1.5019	* 1.4778	* 1.5506	* 1.3233	* 1.4854	* 1.2953	* 3.0805 *
12	* 1.5393	* 1.7624	* 1.5464	* 1.7649	* 1.6752	* 1.7878	* 1.1630	*
	* 1.4759	* 1.2912	* 1.4791	* 1.3234	* 1.4028	* 1.3106	* 1.9909	*
13	* 1.7497	* 1.6026	* 1.7207	* 1.5667	* 1.7874	* 1.8310	* .7970	*
	* 1.2994	* 1.4202	* 1.3296	* 1.4858	* 1.3108	* 1.2849	* 2.9135	*
14	* 1.3213	* 1.7549	* 1.6937	* 1.7822	* 1.1621	* .7970	*	*
	* 1.7134	* 1.2993	* 1.3511	* 1.2958	* 1.9925	* 2.9136	*	*
15	* .6975	* .8935	* .8246	* .7383	* F-SUB-Q			
	* 3.2219	* 2.5266	* 2.7417	* 3.0818	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1962	* 1.7725	* 1.5343	* 1.7524	* 1.5264	* 1.7390	* 1.3114	* .6910 *
	* 1.8632	* 1.2524	* 1.4437	* 1.2631	* 1.4471	* 1.2713	* 1.6787	* 3.1634 *
9	* 1.7725	* 1.5028	* 1.7713	* 1.5003	* 1.7513	* 1.5934	* 1.7485	* .8867 *
	* 1.2524	* 1.4752	* 1.2512	* 1.4733	* 1.2634	* 1.3885	* 1.2675	* 2.4759 *
10	* 1.5343	* 1.7708	* 1.3077	* 1.5358	* 1.5366	* 1.7123	* 1.6879	* .8198 *
	* 1.4437	* 1.2515	* 1.6911	* 1.4437	* 1.4464	* 1.2986	* 1.3176	* 2.6814 *
11	* 1.7524	* 1.4996	* 1.5315	* 1.4861	* 1.7584	* 1.5605	* 1.7779	* .7340 *
	* 1.2631	* 1.4740	* 1.4476	* 1.5135	* 1.2891	* 1.4474	* 1.2610	* 3.0120 *
12	* 1.5264	* 1.7509	* 1.5353	* 1.7583	* 1.6695	* 1.7825	* 1.1594	*
	* 1.4471	* 1.2637	* 1.4475	* 1.2891	* 1.3656	* 1.2752	* 1.9378	*
13	* 1.7390	* 1.5927	* 1.7114	* 1.5600	* 1.7821	* 1.8293	* .7924	*
	* 1.2713	* 1.3891	* 1.2993	* 1.4478	* 1.2755	* 1.2467	* 2.8422	*
14	* 1.3114	* 1.7478	* 1.6871	* 1.7771	* 1.1584	* .7923	*	*
	* 1.6787	* 1.2681	* 1.3181	* 1.2615	* 1.9394	* 2.8423	*	*
15	* .6910	* .8865	* .8195	* .7337	* F-SUB-Q			
	* 3.1634	* 2.4763	* 2.6825	* 3.0134	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 21 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1705	* 1.7354	* 1.5055	* 1.7166	* 1.4993	* 1.7065	* 1.2902	* .6770 *
	* 1.8540	* 1.2459	* 1.4333	* 1.2566	* 1.4358	* 1.2628	* 1.6634	* 3.1491 *
9	* 1.7354	* 1.4736	* 1.7348	* 1.4726	* 1.7180	* 1.5678	* 1.7196	* .8752 *
	* 1.2459	* 1.4654	* 1.2447	* 1.4627	* 1.2552	* 1.3752	* 1.2556	* 2.4450 *
10	* 1.5055	* 1.7344	* 1.2942	* 1.5087	* 1.5109	* 1.6818	* 1.6609	* .8161 *
	* 1.4333	* 1.2450	* 1.6649	* 1.4315	* 1.4325	* 1.2878	* 1.3039	* 2.6254 *
11	* 1.7166	* 1.4720	* 1.5045	* 1.4645	* 1.7306	* 1.5381	* 1.7504	* .7312 *
	* 1.2566	* 1.4633	* 1.4354	* 1.4931	* 1.2724	* 1.4268	* 1.2457	* 2.9446 *
12	* 1.4993	* 1.7176	* 1.5097	* 1.7305	* 1.6468	* 1.7545	* 1.1522	*
	* 1.4358	* 1.2556	* 1.4336	* 1.2725	* 1.3442	* 1.2583	* 1.8954	*
13	* 1.7065	* 1.5671	* 1.6809	* 1.5376	* 1.7543	* 1.8043	* .7798	*
	* 1.2628	* 1.3758	* 1.2885	* 1.4273	* 1.2585	* 1.2264	* 2.8053	*
14	* 1.2902	* 1.7188	* 1.6602	* 1.7496	* 1.1514	* .7798	*	
	* 1.6634	* 1.2562	* 1.3045	* 1.2462	* 1.8967	* 2.8054	*	
15	* .6770	* .8750	* .8158	* .7308	* F-SUB-Q			
	* 3.1491	* 2.4455	* 2.6265	* 2.9460	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1604	* 1.7372	* 1.4960	* 1.7186	* 1.4912	* 1.7116	* 1.2826	* .6739 *
	* 1.8057	* 1.2048	* 1.3975	* 1.2173	* 1.4026	* 1.2240	* 1.6302	* 3.0908 *
9	* 1.7372	* 1.4625	* 1.7371	* 1.4630	* 1.7223	* 1.5642	* 1.7275	* .8675 *
	* 1.2048	* 1.4297	* 1.2044	* 1.4287	* 1.2164	* 1.3400	* 1.2153	* 2.4062 *
10	* 1.4960	* 1.7367	* 1.2706	* 1.5034	* 1.5057	* 1.6873	* 1.6670	* .7974 *
	* 1.3975	* 1.2047	* 1.6444	* 1.3931	* 1.3943	* 1.2457	* 1.2616	* 2.6195 *
11	* 1.7186	* 1.4624	* 1.4992	* 1.4591	* 1.7374	* 1.5365	* 1.7610	* .7146 *
	* 1.2173	* 1.4293	* 1.3969	* 1.4475	* 1.2212	* 1.3791	* 1.1993	* 2.9316 *
12	* 1.4912	* 1.7219	* 1.5046	* 1.7373	* 1.6479	* 1.7653	* 1.1354	*
	* 1.4026	* 1.2167	* 1.3955	* 1.2213	* 1.2911	* 1.2048	* 1.8600	*
13	* 1.7116	* 1.5635	* 1.6864	* 1.5360	* 1.7651	* 1.8183	* .7782	*
	* 1.2240	* 1.3406	* 1.2464	* 1.3796	* 1.2050	* 1.1718	* 2.7168	*
14	* 1.2826	* 1.7267	* 1.6662	* 1.7602	* 1.1344	* .7781	*	
	* 1.6302	* 1.2159	* 1.2622	* 1.1998	* 1.8616	* 2.7169	*	
15	* .6739	* .8673	* .7971	* .7142	* F-SUB-Q			
	* 3.0908	* 2.4067	* 2.6206	* 2.9331	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 22 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1335	* 1.7025	* 1.4648	* 1.6848	* 1.4614	* 1.6799	* 1.2570	* .6598 *
	* 1.7842	* 1.1899	* 1.3818	* 1.2028	* 1.3868	* 1.2086	* 1.6127	* 3.0632 *
9	* 1.7025	* 1.4312	* 1.7031	* 1.4332	* 1.6902	* 1.5355	* 1.6977	* .8505 *
	* 1.1899	* 1.4140	* 1.1894	* 1.4128	* 1.2010	* 1.3227	* 1.1981	* 2.3808 *
10	* 1.4648	* 1.7026	* 1.2453	* 1.4766	* 1.4793	* 1.6573	* 1.6372	* .7804 *
	* 1.3818	* 1.1897	* 1.6251	* 1.3733	* 1.3748	* 1.2283	* 1.2443	* 2.5962 *
11	* 1.6848	* 1.4326	* 1.4725	* 1.4331	* 1.7087	* 1.5098	* 1.7321	* .6995 *
	* 1.2028	* 1.4134	* 1.3771	* 1.4242	* 1.1983	* 1.3558	* 1.1797	* 2.9028 *
12	* 1.4614	* 1.6898	* 1.4783	* 1.7086	* 1.6214	* 1.7365	* 1.1134	*
	* 1.3868	* 1.2013	* 1.3759	* 1.1984	* 1.2640	* 1.1817	* 1.8343	*
13	* 1.6799	* 1.5348	* 1.6564	* 1.5093	* 1.7362	* 1.7902	* .7625	*
	* 1.2086	* 1.3233	* 1.2289	* 1.3563	* 1.1820	* 1.1483	* 2.6804	*
14	* 1.2570	* 1.6969	* 1.6364	* 1.7313	* 1.1124	* .7625	*	
	* 1.6127	* 1.1987	* 1.2449	* 1.1802	* 1.8359	* 2.6805	*	
15	* .6598	* .8503	* .7800	* .6991	* F-SUB-Q			
	* 3.0632	* 2.3813	* 2.5973	* 2.9043	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0856	* 1.6233	* 1.4073	* 1.6071	* 1.4052	* 1.6034	* 1.2097	* .6316 *
	* 1.8121	* 1.2144	* 1.3998	* 1.2279	* 1.4045	* 1.2333	* 1.6327	* 3.1208 *
9	* 1.6233	* 1.3756	* 1.6244	* 1.3783	* 1.6138	* 1.4744	* 1.6216	* .8209 *
	* 1.2144	* 1.4317	* 1.2138	* 1.4304	* 1.2253	* 1.3411	* 1.2214	* 2.4043 *
10	* 1.4073	* 1.6240	* 1.2157	* 1.4232	* 1.4264	* 1.5843	* 1.5633	* .7635 *
	* 1.3998	* 1.2141	* 1.6208	* 1.3867	* 1.3878	* 1.2508	* 1.2685	* 2.5864 *
11	* 1.6071	* 1.3777	* 1.4193	* 1.3820	* 1.6362	* 1.4533	* 1.6544	* .6850 *
	* 1.2279	* 1.4309	* 1.3905	* 1.4355	* 1.2156	* 1.3688	* 1.2011	* 2.8874 *
12	* 1.4052	* 1.6131	* 1.4254	* 1.6361	* 1.5612	* 1.6591	* 1.0831	*
	* 1.4045	* 1.2256	* 1.3890	* 1.2157	* 1.2744	* 1.2008	* 1.8334	*
13	* 1.6034	* 1.4738	* 1.5834	* 1.4528	* 1.6588	* 1.7095	* .7296	*
	* 1.2333	* 1.3417	* 1.2515	* 1.3692	* 1.2010	* 1.1671	* 2.7236	*
14	* 1.2097	* 1.6209	* 1.5626	* 1.6536	* 1.0823	* .7295	*	
	* 1.6327	* 1.2219	* 1.2691	* 1.2016	* 1.8348	* 2.7238	*	
15	* .6316	* .8207	* .7631	* .6847	* F-SUB-Q			
	* 3.1208	* 2.4048	* 2.5875	* 2.8889	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 23 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0524 *	* 1.5697 *	* 1.3618 *	* 1.5533 *	* 1.3607 *	* 1.5513 *	* 1.1690 *	* .6114 *
	* 1.8297 *	* 1.2290 *	* 1.4158 *	* 1.2444 *	* 1.4203 *	* 1.2482 *	* 1.6548 *	* 3.1602 *
9	* 1.5697 *	* 1.3319 *	* 1.5704 *	* 1.3336 *	* 1.5622 *	* 1.4262 *	* 1.5688 *	* .7924 *
	* 1.2290 *	* 1.4472 *	* 1.2290 *	* 1.4474 *	* 1.2401 *	* 1.3574 *	* 1.2358 *	* 2.4407 *
10	* 1.3618 *	* 1.5701 *	* 1.1688 *	* 1.3823 *	* 1.3869 *	* 1.5359 *	* 1.5096 *	* .7281 *
	* 1.4158 *	* 1.2293 *	* 1.6506 *	* 1.3978 *	* 1.3973 *	* 1.2628 *	* 1.2858 *	* 2.6574 *
11	* 1.5533 *	* 1.3331 *	* 1.3785 *	* 1.3396 *	* 1.5851 *	* 1.4085 *	* 1.5993 *	* .6524 *
	* 1.2444 *	* 1.4479 *	* 1.4016 *	* 1.4483 *	* 1.2266 *	* 1.3804 *	* 1.2151 *	* 2.9697 *
12	* 1.3607 *	* 1.5615 *	* 1.3860 *	* 1.5851 *	* 1.5170 *	* 1.6071 *	* 1.0342 *	
	* 1.4203 *	* 1.2404 *	* 1.3983 *	* 1.2267 *	* 1.2817 *	* 1.2111 *	* 1.8782 *	
13	* 1.5513 *	* 1.4257 *	* 1.5351 *	* 1.4081 *	* 1.6068 *	* 1.6500 *	* .7052 *	
	* 1.2482 *	* 1.3579 *	* 1.2634 *	* 1.3808 *	* 1.2113 *	* 1.1812 *	* 2.7561 *	
14	* 1.1690 *	* 1.5680 *	* 1.5088 *	* 1.5985 *	* 1.0333 *	* .7052 *		
	* 1.6548 *	* 1.2363 *	* 1.2864 *	* 1.2156 *	* 1.8797 *	* 2.7563 *		
15	* .6114 *	* .7923 *	* .7278 *	* .6520 *	* F-SUB-Q			
	* 3.1602 *	* 2.4412 *	* 2.6586 *	* 2.9712 *	* M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9924 *	* 1.4498 *	* 1.2677 *	* 1.4345 *	* 1.2670 *	* 1.4349 *	* 1.0870 *	* .5666 *
	* 1.9101 *	* 1.3096 *	* 1.4971 *	* 1.3270 *	* 1.5015 *	* 1.3283 *	* 1.7527 *	* 3.3617 *
9	* 1.4498 *	* 1.2426 *	* 1.4483 *	* 1.2392 *	* 1.4479 *	* 1.3203 *	* 1.4490 *	* .7392 *
	* 1.3096 *	* 1.5269 *	* 1.3116 *	* 1.5335 *	* 1.3169 *	* 1.4432 *	* 1.3166 *	* 2.5777 *
10	* 1.2677 *	* 1.4482 *	* 1.0948 *	* 1.2764 *	* 1.2939 *	* 1.4270 *	* 1.4068 *	* .6840 *
	* 1.4971 *	* 1.3117 *	* 1.7346 *	* 1.4904 *	* 1.4740 *	* 1.3373 *	* 1.3573 *	* 2.7866 *
11	* 1.4345 *	* 1.2388 *	* 1.2732 *	* 1.2512 *	* 1.4708 *	* 1.3051 *	* 1.4652 *	* .6095 *
	* 1.3270 *	* 1.5339 *	* 1.4942 *	* 1.5256 *	* 1.3000 *	* 1.4652 *	* 1.3045 *	* 3.1306 *
12	* 1.2670 *	* 1.4473 *	* 1.2931 *	* 1.4707 *	* 1.4198 *	* 1.4879 *	* .9553 *	
	* 1.5015 *	* 1.3174 *	* 1.4749 *	* 1.3000 *	* 1.3463 *	* 1.2861 *	* 2.0008 *	
13	* 1.4349 *	* 1.3198 *	* 1.4263 *	* 1.3047 *	* 1.4876 *	* 1.5125 *	* .6555 *	
	* 1.3283 *	* 1.4438 *	* 1.3380 *	* 1.4656 *	* 1.2864 *	* 1.2665 *	* 2.9183 *	
14	* 1.0870 *	* 1.4483 *	* 1.4062 *	* 1.4645 *	* .9545 *	* .6554 *		
	* 1.7527 *	* 1.3172 *	* 1.3579 *	* 1.3051 *	* 2.0024 *	* 2.9186 *		
15	* .5666 *	* .7390 *	* .6837 *	* .6093 *	* F-SUB-Q			
	* 3.3617 *	* 2.5782 *	* 2.7878 *	* 3.1321 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 24 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8624 *	* 1.3218 *	* 1.0154 *	* 1.2863 *	* 1.0160 *	* 1.2795 *	* .8941 *	* .4747 *
	* 2.1758 *	* 1.4201 *	* 1.8497 *	* 1.4629 *	* 1.8531 *	* 1.4732 *	* 2.1084 *	* 3.9769 *
9	* 1.3218 *	* .9983 *	* 1.3147 *	* .9898 *	* 1.3065 *	* 1.0988 *	* 1.2774 *	* .6204 *
	* 1.4201 *	* 1.8809 *	* 1.4291 *	* 1.9015 *	* 1.4428 *	* 1.7157 *	* 1.4775 *	* 3.0424 *
10	* 1.0154 *	* 1.3145 *	* .9505 *	* 1.0485 *	* 1.0855 *	* 1.2805 *	* 1.2704 *	* .5889 *
	* 1.8497 *	* 1.4293 *	* 1.9758 *	* 1.7958 *	* 1.7389 *	* 1.4741 *	* 1.4863 *	* 3.2060 *
11	* 1.2863 *	* .9897 *	* 1.0463 *	* 1.0286 *	* 1.3066 *	* 1.0912 *	* 1.2134 *	* .5124 *
	* 1.4629 *	* 1.9016 *	* 1.7995 *	* 1.8357 *	* 1.4468 *	* 1.7328 *	* 1.5583 *	* 3.6883 *
12	* 1.0160 *	* 1.3060 *	* 1.0850 *	* 1.3063 *	* 1.2000 *	* 1.3563 *	* .7963 *	
	* 1.8531 *	* 1.4434 *	* 1.7398 *	* 1.4471 *	* 1.5754 *	* 1.3952 *	* 2.3750 *	
13	* 1.2795 *	* 1.0984 *	* 1.2799 *	* 1.0909 *	* 1.3561 *	* 1.2403 *	* .5535 *	
	* 1.4732 *	* 1.7164 *	* 1.4748 *	* 1.7333 *	* 1.3954 *	* 1.5269 *	* 3.4210 *	
14	* .8941 *	* 1.2768 *	* 1.2699 *	* 1.2129 *	* .7958 *	* .5534 *		
	* 2.1084 *	* 1.4782 *	* 1.4869 *	* 1.5589 *	* 2.3766 *	* 3.4215 *		
15	* .4747 *	* .6202 *	* .5886 *	* .5122 *	F-SUB-Q			
	* 3.9769 *	* 3.0432 *	* 3.2076 *	* 3.6901 *	M-SUB-Q			

AT 100% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6269 *	* .5435 *	* .4719 *	* .5391 *	* .4718 *	* .5358 *	* .4199 *	* .3280 *
	* 2.9781 *	* 3.4361 *	* 3.9594 *	* 3.4720 *	* 3.9742 *	* 3.5009 *	* 4.4705 *	* 5.7337 *
9	* .5435 *	* .4681 *	* .5371 *	* .4650 *	* .5466 *	* .4880 *	* .4898 *	* .2921 *
	* 3.4361 *	* 3.9916 *	* 3.4810 *	* 4.0276 *	* 3.4323 *	* 3.8429 *	* 3.8356 *	* 6.4388 *
10	* .4719 *	* .5373 *	* .4743 *	* .4534 *	* .4825 *	* .5442 *	* .5066 *	* .2845 *
	* 3.9594 *	* 3.4795 *	* 3.9423 *	* 4.1365 *	* 3.8938 *	* 3.4507 *	* 3.7095 *	* 6.6119 *
11	* .5391 *	* .4651 *	* .4531 *	* .4867 *	* .5533 *	* .4871 *	* .4646 *	* .2499 *
	* 3.4720 *	* 4.0271 *	* 4.1393 *	* 3.8615 *	* 3.3978 *	* 3.8624 *	* 4.0487 *	* 7.5371 *
12	* .4718 *	* .5463 *	* .4823 *	* .5532 *	* .5173 *	* .5243 *	* .3683 *	
	* 3.9742 *	* 3.4337 *	* 3.8955 *	* 3.3982 *	* 3.6361 *	* 3.5907 *	* 5.1147 *	
13	* .5358 *	* .4878 *	* .5440 *	* .4870 *	* .5242 *	* .4774 *	* .3838 *	
	* 3.5009 *	* 3.8440 *	* 3.4522 *	* 3.8632 *	* 3.5913 *	* 3.9465 *	* 4.9141 *	
14	* .4199 *	* .4896 *	* .5063 *	* .4644 *	* .3684 *	* .3837 *		
	* 4.4705 *	* 3.8374 *	* 3.7111 *	* 4.0504 *	* 5.1134 *	* 4.9153 *		
15	* .3280 *	* .2920 *	* .2843 *	* .2497 *	F-SUB-Q			
	* 5.7337 *	* 6.4414 *	* 6.6148 *	* 7.5407 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 25 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5808 *	* .5069 *	* .4503 *	* .5092 *	* .4530 *	* .4967 *	* .4038 *	* .3535 *
	* 3.0015 *	* 3.6654 *	* 4.1115 *	* 3.5657 *	* 3.9861 *	* 3.6084 *	* 4.4146 *	* 4.9750 *
9	* .5069 *	* .4551 *	* .5080 *	* .4454 *	* .5054 *	* .4517 *	* .4464 *	* .2981 *
	* 3.6654 *	* 4.1228 *	* 3.6616 *	* 4.0900 *	* 3.5817 *	* 3.9853 *	* 4.0425 *	* 5.9929 *
10	* .4503 *	* .5085 *	* .4583 *	* .4358 *	* .4480 *	* .4929 *	* .4545 *	* .2850 *
	* 4.1115 *	* 3.6612 *	* 4.0854 *	* 4.2668 *	* 4.1526 *	* 3.7624 *	* 4.0372 *	* 6.2924 *
11	* .5092 *	* .4454 *	* .4355 *	* .4137 *	* .4805 *	* .4338 *	* .4194 *	* .2529 *
	* 3.5657 *	* 4.0896 *	* 4.2705 *	* 4.2669 *	* 3.7581 *	* 4.2561 *	* 4.4735 *	* 7.3278 *
12	* .4530 *	* .5054 *	* .4480 *	* .4805 *	* .4167 *	* .4263 *	* .3330 *	
	* 3.9861 *	* 3.5818 *	* 4.1530 *	* 3.7582 *	* 3.9535 *	* 3.9972 *	* 5.4431 *	
13	* .4967 *	* .4517 *	* .4928 *	* .4337 *	* .4263 *	* .3880 *	* .3664 *	
	* 3.6084 *	* 3.9855 *	* 3.7623 *	* 4.2562 *	* 3.9972 *	* 4.3564 *	* 4.8315 *	
14	* .4038 *	* .4466 *	* .4546 *	* .4194 *	* .3332 *	* .3663 *		
	* 4.4146 *	* 4.0406 *	* 4.0364 *	* 4.4733 *	* 5.4405 *	* 4.8331 *		
15	* .3535 *	* .2982 *	* .2851 *	* .2529 *	F-SUB-Q			
	* 4.9750 *	* 5.9885 *	* 6.2899 *	* 7.3271 *	M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7790 *	* 1.1096 *	* .9438 *	* 1.0932 *	* .9362 *	* 1.0674 *	* .8133 *	* .4823 *
	* 2.2633 *	* 1.7143 *	* 2.0068 *	* 1.6989 *	* 1.9694 *	* 1.7156 *	* 2.2318 *	* 3.7230 *
9	* 1.1096 *	* .9423 *	* 1.1086 *	* .9293 *	* 1.0840 *	* .9532 *	* 1.0408 *	* .6023 *
	* 1.7143 *	* 2.0338 *	* 1.7161 *	* 2.0015 *	* 1.7058 *	* 1.9305 *	* 1.7711 *	* 3.0148 *
10	* .9438 *	* 1.1087 *	* .8824 *	* .9209 *	* .9450 *	* 1.0527 *	* 1.0253 *	* .5736 *
	* 2.0068 *	* 1.7164 *	* 2.1508 *	* 2.0576 *	* 2.0107 *	* 1.7984 *	* 1.8251 *	* 3.1908 *
11	* 1.0932 *	* .9289 *	* .9194 *	* .8681 *	* 1.0343 *	* .9170 *	* .9761 *	* .5065 *
	* 1.6989 *	* 2.0021 *	* 2.0610 *	* 2.1361 *	* 1.7881 *	* 2.0470 *	* 1.9452 *	* 3.7313 *
12	* .9362 *	* 1.0840 *	* .9449 *	* 1.0342 *	* .9240 *	* 1.0281 *	* .6821 *	
	* 1.9694 *	* 1.7059 *	* 2.0109 *	* 1.7881 *	* 1.9028 *	* 1.7489 *	* 2.7134 *	
13	* 1.0674 *	* .9532 *	* 1.0526 *	* .9170 *	* 1.0281 *	* .9374 *	* .4965 *	
	* 1.7156 *	* 1.9304 *	* 1.7984 *	* 2.0471 *	* 1.7490 *	* 1.9043 *	* 3.6498 *	
14	* .8133 *	* 1.0411 *	* 1.0255 *	* .9761 *	* .6820 *	* .4964 *		
	* 2.2318 *	* 1.7705 *	* 1.8248 *	* 1.9451 *	* 2.7137 *	* 3.6500 *		
15	* .4823 *	* .6026 *	* .5737 *	* .5065 *	F-SUB-Q			
	* 3.7230 *	* 3.0133 *	* 3.1897 *	* 3.7310 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 26 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9752 *	* 1.2704 *	* 1.1462 *	* 1.2587 *	* 1.1459 *	* 1.2419 *	* 1.0028 *	* .5730 *
	* 1.9756 *	* 1.5332 *	* 1.6834 *	* 1.4950 *	* 1.6338 *	* 1.4980 *	* 1.8366 *	* 3.1798 *
9	* 1.2704 *	* 1.1496 *	* 1.2656 *	* 1.1289 *	* 1.2516 *	* 1.1591 *	* 1.2242 *	* .7143 *
	* 1.5332 *	* 1.7050 *	* 1.5309 *	* 1.6769 *	* 1.4971 *	* 1.6094 *	* 1.5244 *	* 2.5798 *
10	* 1.1462 *	* 1.2656 *	* 1.0284 *	* 1.1105 *	* 1.1221 *	* 1.2109 *	* 1.1853 *	* .6812 *
	* 1.6834 *	* 1.5316 *	* 1.8770 *	* 1.7330 *	* 1.7221 *	* 1.5785 *	* 1.6080 *	* 2.7270 *
11	* 1.2587 *	* 1.1286 *	* 1.1085 *	* 1.0572 *	* 1.1921 *	* 1.1176 *	* 1.2010 *	* .6048 *
	* 1.4950 *	* 1.6770 *	* 1.7361 *	* 1.8011 *	* 1.5754 *	* 1.7115 *	* 1.6071 *	* 3.1723 *
12	* 1.1459 *	* 1.2515 *	* 1.1217 *	* 1.1921 *	* 1.1530 *	* 1.2024 *	* .8431 *	
	* 1.6338 *	* 1.4972 *	* 1.7227 *	* 1.5754 *	* 1.6214 *	* 1.5529 *	* 2.2381 *	
13	* 1.2419 *	* 1.1590 *	* 1.2108 *	* 1.1175 *	* 1.2023 *	* 1.1696 *	* .5921 *	
	* 1.4980 *	* 1.6095 *	* 1.5787 *	* 1.7116 *	* 1.5529 *	* 1.5798 *	* 3.1280 *	
14	* 1.0028 *	* 1.2245 *	* 1.1853 *	* 1.2010 *	* .8429 *	* .5922 *		
	* 1.8366 *	* 1.5241 *	* 1.6079 *	* 1.6071 *	* 2.2385 *	* 3.1279 *		
15	* .5730 *	* .7145 *	* .6813 *	* .6048 *	F-SUB-Q			
	* 3.1798 *	* 2.5789 *	* 2.7263 *	* 3.1722 *	M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0774 *	* 1.4457 *	* 1.2683 *	* 1.4241 *	* 1.2691 *	* 1.4100 *	* 1.1098 *	* .6311 *
	* 1.8411 *	* 1.3795 *	* 1.5493 *	* 1.3408 *	* 1.4983 *	* 1.3393 *	* 1.6844 *	* 2.9316 *
9	* 1.4457 *	* 1.2686 *	* 1.4333 *	* 1.2457 *	* 1.4186 *	* 1.2974 *	* 1.3966 *	* .7824 *
	* 1.3795 *	* 1.5776 *	* 1.3724 *	* 1.5432 *	* 1.3405 *	* 1.4588 *	* 1.3554 *	* 2.3911 *
10	* 1.2683 *	* 1.4332 *	* 1.1135 *	* 1.2291 *	* 1.2429 *	* 1.3737 *	* 1.3493 *	* .7355 *
	* 1.5493 *	* 1.3732 *	* 1.7628 *	* 1.5905 *	* 1.5791 *	* 1.4125 *	* 1.4338 *	* 2.5641 *
11	* 1.4241 *	* 1.2454 *	* 1.2268 *	* 1.1745 *	* 1.3618 *	* 1.2462 *	* 1.3709 *	* .6511 *
	* 1.3408 *	* 1.5432 *	* 1.5936 *	* 1.6573 *	* 1.4116 *	* 1.5538 *	* 1.4304 *	* 2.9909 *
12	* 1.2691 *	* 1.4185 *	* 1.2424 *	* 1.3617 *	* 1.2964 *	* 1.3776 *	* .9339 *	
	* 1.4983 *	* 1.3406 *	* 1.5797 *	* 1.4116 *	* 1.4777 *	* 1.3854 *	* 2.0618 *	
13	* 1.4100 *	* 1.2972 *	* 1.3735 *	* 1.2461 *	* 1.3775 *	* 1.3492 *	* .6565 *	
	* 1.3393 *	* 1.4591 *	* 1.4127 *	* 1.5539 *	* 1.3855 *	* 1.4018 *	* 2.8851 *	
14	* 1.1098 *	* 1.3968 *	* 1.3493 *	* 1.3709 *	* .9336 *	* .6565 *		
	* 1.6844 *	* 1.3552 *	* 1.4338 *	* 1.4304 *	* 2.0623 *	* 2.8850 *		
15	* .6311 *	* .7826 *	* .7356 *	* .6511 *	F-SUB-Q			
	* 2.9316 *	* 2.3904 *	* 2.5637 *	* 2.9909 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 27 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1222	* 1.5408	* 1.3300	* 1.5114	* 1.3325	* 1.5026	* 1.1659	* .6562 *
	* 1.8132	* 1.3241	* 1.5081	* 1.2856	* 1.4541	* 1.2801	* 1.6333	* 2.8734 *
9	* 1.5408	* 1.3263	* 1.5248	* 1.3033	* 1.5095	* 1.3706	* 1.4930	* .8186 *
	* 1.3241	* 1.5435	* 1.3150	* 1.5021	* 1.2832	* 1.4065	* 1.2900	* 2.3274 *
10	* 1.3300	* 1.5242	* 1.1546	* 1.2829	* 1.3039	* 1.4650	* 1.4487	* .7711 *
	* 1.5081	* 1.3157	* 1.7337	* 1.5531	* 1.5304	* 1.3482	* 1.3586	* 2.4903 *
11	* 1.5114	* 1.3030	* 1.2804	* 1.2396	* 1.4592	* 1.3175	* 1.4681	* .6808 *
	* 1.2856	* 1.5021	* 1.5562	* 1.6064	* 1.3483	* 1.5008	* 1.3645	* 2.9089 *
12	* 1.3325	* 1.5093	* 1.3036	* 1.4592	* 1.3765	* 1.4788	* .9901	*
	* 1.4541	* 1.2833	* 1.5308	* 1.3484	* 1.4250	* 1.3202	* 1.9893	*
13	* 1.5026	* 1.3703	* 1.4647	* 1.3174	* 1.4788	* 1.4503	* .6903	*
	* 1.2801	* 1.4067	* 1.3484	* 1.5009	* 1.3203	* 1.3351	* 2.8111	*
14	* 1.1659	* 1.4931	* 1.4486	* 1.4680	* .9898	* .6904	*	
	* 1.6333	* 1.2900	* 1.3587	* 1.3646	* 1.9899	* 2.8110	*	
15	* .6562	* .8188	* .7711	* .6807	* F-SUB-Q			
	* 2.8734	* 2.3270	* 2.4901	* 2.9090	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1496	* 1.5940	* 1.3662	* 1.5631	* 1.3711	* 1.5585	* 1.2012	* .6733 *
	* 1.8092	* 1.3064	* 1.5021	* 1.2714	* 1.4436	* 1.2620	* 1.6210	* 2.8645 *
9	* 1.5940	* 1.3591	* 1.5759	* 1.3369	* 1.5633	* 1.4167	* 1.5538	* .8424 *
	* 1.3064	* 1.5368	* 1.3004	* 1.4963	* 1.2665	* 1.3909	* 1.2663	* 2.3108 *
10	* 1.3662	* 1.5752	* 1.1788	* 1.3128	* 1.3439	* 1.5211	* 1.5123	* .7974 *
	* 1.5021	* 1.3011	* 1.7363	* 1.5509	* 1.5151	* 1.3251	* 1.3274	* 2.4589 *
11	* 1.5631	* 1.3365	* 1.3102	* 1.2818	* 1.5199	* 1.3630	* 1.5288	* .7037 *
	* 1.2714	* 1.4963	* 1.5540	* 1.5880	* 1.3252	* 1.4819	* 1.3341	* 2.8661 *
12	* 1.3711	* 1.5632	* 1.3436	* 1.5198	* 1.4278	* 1.5458	* 1.0293	*
	* 1.4436	* 1.2666	* 1.5155	* 1.3252	* 1.4064	* 1.2944	* 1.9572	*
13	* 1.5585	* 1.4164	* 1.5208	* 1.3628	* 1.5457	* 1.5129	* .7141	*
	* 1.2620	* 1.3911	* 1.3253	* 1.4821	* 1.2944	* 1.3139	* 2.7902	*
14	* 1.2012	* 1.5537	* 1.5121	* 1.5286	* 1.0290	* .7141	*	
	* 1.6210	* 1.2663	* 1.3275	* 1.3343	* 1.9578	* 2.7901	*	
15	* .6733	* .8425	* .7974	* .7036	* F-SUB-Q			
	* 2.8645	* 2.3105	* 2.4589	* 2.8664	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 28 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1732 *	* 1.6485 *	* 1.4003 *	* 1.6159 *	* 1.4080 *	* 1.6153 *	* 1.2346 *	* .6896 *
	* 1.8066 *	* 1.2818 *	* 1.5035 *	* 1.2633 *	* 1.4423 *	* 1.2506 *	* 1.6197 *	* 2.8718 *
9	* 1.6485 *	* 1.3901 *	* 1.6291 *	* 1.3699 *	* 1.6186 *	* 1.4615 *	* 1.6167 *	* .8662 *
	* 1.2818 *	* 1.5221 *	* 1.2891 *	* 1.4988 *	* 1.2560 *	* 1.3838 *	* 1.2486 *	* 2.3047 *
10	* 1.4003 *	* 1.6284 *	* 1.2022 *	* 1.3436 *	* 1.3833 *	* 1.5777 *	* 1.5750 *	* .8149 *
	* 1.5035 *	* 1.2899 *	* 1.7452 *	* 1.5526 *	* 1.5053 *	* 1.3066 *	* 1.3003 *	* 2.4653 *
11	* 1.6159 *	* 1.3699 *	* 1.3409 *	* 1.3209 *	* 1.5800 *	* 1.4079 *	* 1.5896 *	* .7179 *
	* 1.2633 *	* 1.4988 *	* 1.5558 *	* 1.5767 *	* 1.3066 *	* 1.4699 *	* 1.2994 *	* 2.8608 *
12	* 1.4080 *	* 1.6184 *	* 1.3830 *	* 1.5799 *	* 1.4777 *	* 1.6127 *	* 1.0578 *	
	* 1.4423 *	* 1.2562 *	* 1.5057 *	* 1.3067 *	* 1.3930 *	* 1.2710 *	* 1.9500 *	
13	* 1.6153 *	* 1.4612 *	* 1.5774 *	* 1.4077 *	* 1.6126 *	* 1.5761 *	* .7369 *	
	* 1.2506 *	* 1.3841 *	* 1.3068 *	* 1.4700 *	* 1.2711 *	* 1.2919 *	* 2.7720 *	
14	* 1.2346 *	* 1.6165 *	* 1.5748 *	* 1.5894 *	* 1.0574 *	* .7370 *		
	* 1.6197 *	* 1.2487 *	* 1.3005 *	* 1.2995 *	* 1.9507 *	* 2.7719 *		
15	* .6896 *	* .8663 *	* .8149 *	* .7178 *	* F-SUB-Q			
	* 2.8718 *	* 2.3045 *	* 2.4653 *	* 2.8612 *	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1787 *	* 1.6823 *	* 1.4226 *	* 1.6501 *	* 1.4328 *	* 1.6530 *	* 1.2576 *	* .6953 *
	* 1.8343 *	* 1.2846 *	* 1.5220 *	* 1.2760 *	* 1.4606 *	* 1.2606 *	* 1.6399 *	* 2.9366 *
9	* 1.6823 *	* 1.4095 *	* 1.6625 *	* 1.3922 *	* 1.6550 *	* 1.4924 *	* 1.6593 *	* .8780 *
	* 1.2846 *	* 1.5371 *	* 1.2940 *	* 1.5201 *	* 1.2666 *	* 1.3968 *	* 1.2526 *	* 2.3401 *
10	* 1.4226 *	* 1.6618 *	* 1.2132 *	* 1.3630 *	* 1.4102 *	* 1.6157 *	* 1.6181 *	* .8271 *
	* 1.5220 *	* 1.2946 *	* 1.7735 *	* 1.5694 *	* 1.5082 *	* 1.3079 *	* 1.2968 *	* 2.4974 *
11	* 1.6501 *	* 1.3922 *	* 1.3602 *	* 1.3488 *	* 1.6209 *	* 1.4397 *	* 1.6312 *	* .7269 *
	* 1.2760 *	* 1.5201 *	* 1.5726 *	* 1.5742 *	* 1.2996 *	* 1.4635 *	* 1.2949 *	* 2.8807 *
12	* 1.4328 *	* 1.6548 *	* 1.4098 *	* 1.6209 *	* 1.5129 *	* 1.6590 *	* 1.0801 *	
	* 1.4606 *	* 1.2668 *	* 1.5086 *	* 1.2997 *	* 1.3889 *	* 1.2623 *	* 1.9450 *	
13	* 1.6530 *	* 1.4920 *	* 1.6153 *	* 1.4395 *	* 1.6588 *	* 1.6192 *	* .7485 *	
	* 1.2606 *	* 1.3972 *	* 1.3082 *	* 1.4637 *	* 1.2624 *	* 1.2875 *	* 2.7890 *	
14	* 1.2576 *	* 1.6591 *	* 1.6179 *	* 1.6310 *	* 1.0797 *	* .7485 *		
	* 1.6399 *	* 1.2527 *	* 1.2970 *	* 1.2951 *	* 1.9458 *	* 2.7889 *		
15	* .6953 *	* .8781 *	* .8270 *	* .7268 *	* F-SUB-Q			
	* 2.9366 *	* 2.3400 *	* 2.4975 *	* 2.8812 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 29 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1926	* 1.7158	* 1.4427	* 1.6835	* 1.4559	* 1.6894	* 1.2782	* .7063
	* 1.8790	* 1.3025	* 1.5441	* 1.2959	* 1.4889	* 1.2784	* 1.6717	* 2.9934
9	* 1.7158	* 1.4272	* 1.6961	* 1.4128	* 1.6904	* 1.5208	* 1.7000	* .8916
	* 1.3025	* 1.5663	* 1.3058	* 1.5510	* 1.2845	* 1.4195	* 1.2630	* 2.3824
10	* 1.4427	* 1.6953	* 1.2265	* 1.3826	* 1.4349	* 1.6519	* 1.6593	* .8368
	* 1.5441	* 1.3064	* 1.8074	* 1.5940	* 1.5248	* 1.3170	* 1.3010	* 2.5483
11	* 1.6835	* 1.4128	* 1.3798	* 1.3740	* 1.6599	* 1.4686	* 1.6700	* .7349
	* 1.2959	* 1.5509	* 1.5973	* 1.5960	* 1.3111	* 1.4805	* 1.3008	* 2.9242
12	* 1.4559	* 1.6902	* 1.4345	* 1.6598	* 1.5456	* 1.7034	* 1.0970	*
	* 1.4889	* 1.2847	* 1.5252	* 1.3112	* 1.4065	* 1.2681	* 1.9739	*
13	* 1.6894	* 1.5204	* 1.6515	* 1.4684	* 1.7033	* 1.6599	* .7627	*
	* 1.2784	* 1.4199	* 1.3173	* 1.4807	* 1.2682	* 1.2938	* 2.8179	*
14	* 1.2782	* 1.6998	* 1.6590	* 1.6697	* 1.0963	* .7627	*	*
	* 1.6717	* 1.2632	* 1.3012	* 1.3010	* 1.9752	* 2.8180	*	*
15	* .7063	* .8916	* .8367	* .7348	* F-SUB-Q			
	* 2.9934	* 2.3823	* 2.5486	* 2.9247	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1829	* 1.7096	* 1.4421	* 1.6810	* 1.4583	* 1.6889	* 1.2814	* .7023
	* 1.9527	* 1.3445	* 1.5949	* 1.3515	* 1.5485	* 1.3320	* 1.7363	* 3.1318
9	* 1.7096	* 1.4247	* 1.6905	* 1.4130	* 1.6893	* 1.5249	* 1.7026	* .8960
	* 1.3445	* 1.6152	* 1.3586	* 1.6136	* 1.3355	* 1.4735	* 1.3093	* 2.4623
10	* 1.4421	* 1.6897	* 1.2369	* 1.3804	* 1.4372	* 1.6531	* 1.6634	* .8493
	* 1.5949	* 1.3593	* 1.8602	* 1.6565	* 1.5781	* 1.3640	* 1.3451	* 2.6051
11	* 1.6810	* 1.4130	* 1.3776	* 1.3802	* 1.6637	* 1.4744	* 1.6737	* .7478
	* 1.3515	* 1.6135	* 1.6599	* 1.6511	* 1.3621	* 1.5338	* 1.3402	* 2.9708
12	* 1.4583	* 1.6891	* 1.4368	* 1.6636	* 1.5520	* 1.7082	* 1.1125	*
	* 1.5485	* 1.3358	* 1.5785	* 1.3622	* 1.4595	* 1.3159	* 2.0198	*
13	* 1.6889	* 1.5245	* 1.6526	* 1.4742	* 1.7081	* 1.6634	* .7642	*
	* 1.3320	* 1.4739	* 1.3643	* 1.5341	* 1.3161	* 1.3427	* 2.9227	*
14	* 1.2814	* 1.7023	* 1.6631	* 1.6734	* 1.1121	* .7642	*	*
	* 1.7363	* 1.3095	* 1.3454	* 1.3405	* 2.0209	* 2.9231	*	*
15	* .7023	* .8960	* .8492	* .7476	* F-SUB-Q			
	* 3.1318	* 2.4623	* 2.6054	* 2.9715	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 30 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1978	* 1.7514	* 1.4634	* 1.7206	* 1.4832	* 1.7320	* 1.3020	* .7135 *
	* 1.9550	* 1.3297	* 1.5921	* 1.3492	* 1.5639	* 1.3388	* 1.7791	* 3.2201 *
9	* 1.7514	* 1.4435	* 1.7321	* 1.4342	* 1.7314	* 1.5555	* 1.7509	* .9062 *
	* 1.3297	* 1.6152	* 1.3430	* 1.6202	* 1.3408	* 1.4915	* 1.3248	* 2.5400 *
10	* 1.4634	* 1.7312	* 1.2381	* 1.4020	* 1.4633	* 1.6958	* 1.7129	* .8507 *
	* 1.5921	* 1.3436	* 1.8815	* 1.6621	* 1.5904	* 1.3701	* 1.3551	* 2.7107 *
11	* 1.7206	* 1.4342	* 1.3991	* 1.4052	* 1.7084	* 1.5050	* 1.7184	* .7459 *
	* 1.3492	* 1.6201	* 1.6656	* 1.6641	* 1.3699	* 1.5522	* 1.3541	* 3.0989 *
12	* 1.4832	* 1.7310	* 1.4628	* 1.7082	* 1.5871	* 1.7603	* 1.1230	*
	* 1.5639	* 1.3409	* 1.5909	* 1.3700	* 1.4759	* 1.3277	* 2.0755	*
13	* 1.7320	* 1.5550	* 1.6954	* 1.5048	* 1.7602	* 1.7117	* .7779	*
	* 1.3388	* 1.4919	* 1.3704	* 1.5525	* 1.3278	* 1.3584	* 2.9809	*
14	* 1.3020	* 1.7505	* 1.7125	* 1.7181	* 1.1225	* .7780	*	
	* 1.7791	* 1.3251	* 1.3554	* 1.3544	* 2.0767	* 2.9816	*	
15	* .7135	* .9062	* .8506	* .7458	* F-SUB-Q			
	* 3.2201	* 2.5400	* 2.7111	* 3.0996	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1955	* 1.7633	* 1.4692	* 1.7335	* 1.4919	* 1.7477	* 1.3097	* .7142 *
	* 1.9727	* 1.3320	* 1.5972	* 1.3486	* 1.5650	* 1.3357	* 1.7789	* 3.2559 *
9	* 1.7633	* 1.4472	* 1.7441	* 1.4401	* 1.7483	* 1.5677	* 1.7706	* .9108 *
	* 1.3320	* 1.6230	* 1.3442	* 1.6248	* 1.3378	* 1.4898	* 1.3204	* 2.5601 *
10	* 1.4692	* 1.7433	* 1.2402	* 1.4073	* 1.4727	* 1.7136	* 1.7340	* .8554 *
	* 1.5972	* 1.3448	* 1.8921	* 1.6675	* 1.5930	* 1.3670	* 1.3505	* 2.7308 *
11	* 1.7335	* 1.4402	* 1.4044	* 1.4163	* 1.7269	* 1.5184	* 1.7372	* .7495 *
	* 1.3486	* 1.6247	* 1.6710	* 1.6692	* 1.3731	* 1.5580	* 1.3534	* 3.1294 *
12	* 1.4919	* 1.7479	* 1.4723	* 1.7268	* 1.6025	* 1.7827	* 1.1325	*
	* 1.5650	* 1.3382	* 1.5935	* 1.3732	* 1.4812	* 1.3302	* 2.0871	*
13	* 1.7477	* 1.5673	* 1.7132	* 1.5181	* 1.7825	* 1.7323	* .7817	*
	* 1.3357	* 1.4903	* 1.3674	* 1.5583	* 1.3304	* 1.3709	* 3.0338	*
14	* 1.3097	* 1.7702	* 1.7336	* 1.7369	* 1.1320	* .7817	*	
	* 1.7789	* 1.3207	* 1.3509	* 1.3537	* 2.0882	* 3.0338	*	
15	* .7142	* .9108	* .8552	* .7493	* F-SUB-Q			
	* 3.2559	* 2.5602	* 2.7314	* 3.1302	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 31 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1852	* 1.7498	* 1.4617	* 1.7233	* 1.4869	* 1.7396	* 1.3066	* .7101 *
	* 2.0053	* 1.3536	* 1.6180	* 1.3671	* 1.5824	* 1.3521	* 1.7964	* 3.2975 *
9	* 1.7498	* 1.4382	* 1.7310	* 1.4330	* 1.7405	* 1.5642	* 1.7663	* .9102 *
	* 1.3536	* 1.6460	* 1.3651	* 1.6453	* 1.3534	* 1.5041	* 1.3329	* 2.5779 *
10	* 1.4617	* 1.7302	* 1.2446	* 1.3983	* 1.4677	* 1.7083	* 1.7306	* .8617 *
	* 1.6180	* 1.3658	* 1.9000	* 1.6905	* 1.6104	* 1.3814	* 1.3633	* 2.7270 *
11	* 1.7233	* 1.4331	* 1.3954	* 1.4147	* 1.7229	* 1.5167	* 1.7345	* .7569 *
	* 1.3671	* 1.6452	* 1.6940	* 1.6856	* 1.3894	* 1.5739	* 1.3664	* 3.1179 *
12	* 1.4869	* 1.7401	* 1.4672	* 1.7228	* 1.6010	* 1.7798	* 1.1402	*
	* 1.5824	* 1.3538	* 1.6110	* 1.3895	* 1.4968	* 1.3456	* 2.0908	*
13	* 1.7396	* 1.5638	* 1.7078	* 1.5165	* 1.7796	* 1.7299	* .7806	*
	* 1.3521	* 1.5046	* 1.3817	* 1.5742	* 1.3458	* 1.3859	* 3.0648	*
14	* 1.3066	* 1.7659	* 1.7302	* 1.7342	* 1.1397	* .7806	*	
	* 1.7964	* 1.3332	* 1.3636	* 1.3667	* 2.0918	* 3.0648	*	
15	* .7101	* .9102	* .8615	* .7567	* F-SUB-Q			
	* 3.2975	* 2.5781	* 2.7276	* 3.1187	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1908	* 1.7784	* 1.4724	* 1.7498	* 1.5005	* 1.7697	* 1.3182	* .7157
	* 1.9784	* 1.3231	* 1.5898	* 1.3357	* 1.5561	* 1.3213	* 1.7659	* 3.2268
9	* 1.7784	* 1.4469	* 1.7591	* 1.4434	* 1.7730	* 1.5827	* 1.8034	* .9182
	* 1.3231	* 1.6194	* 1.3328	* 1.6172	* 1.3230	* 1.4786	* 1.3022	* 2.5295
10	* 1.4724	* 1.7583	* 1.2378	* 1.4087	* 1.4826	* 1.7408	* 1.7695	* .8595
	* 1.5898	* 1.3334	* 1.8851	* 1.6608	* 1.5867	* 1.3513	* 1.3315	* 2.7073
11	* 1.7498	* 1.4434	* 1.4057	* 1.4287	* 1.7552	* 1.5363	* 1.7683	* .7528
	* 1.3357	* 1.6171	* 1.6642	* 1.6689	* 1.3715	* 1.5567	* 1.3400	* 3.1099
12	* 1.5005	* 1.7725	* 1.4821	* 1.7551	* 1.6242	* 1.8200	* 1.1434	*
	* 1.5561	* 1.3234	* 1.5872	* 1.3716	* 1.4855	* 1.3242	* 2.0853	*
13	* 1.7697	* 1.5822	* 1.7403	* 1.5360	* 1.8198	* 1.7685	* .7901	*
	* 1.3213	* 1.4791	* 1.3517	* 1.5571	* 1.3243	* 1.3652	* 3.0285	*
14	* 1.3182	* 1.8029	* 1.7691	* 1.7679	* 1.1427	* .7901	*	
	* 1.7659	* 1.3025	* 1.3319	* 1.3403	* 2.0865	* 3.0285	*	
15	* .7157	* .9182	* .8593	* .7526	* F-SUB-Q			
	* 3.2268	* 2.5296	* 2.7079	* 3.1107	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 32 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1810	* 1.7831	* 1.4708	* 1.7552	* 1.5013	* 1.7780	* 1.3193	* .7116 *
	* 1.9315	* 1.2769	* 1.5405	* 1.2892	* 1.5057	* 1.2732	* 1.7086	* 3.1438 *
9	* 1.7831	* 1.4437	* 1.7639	* 1.4417	* 1.7821	* 1.5867	* 1.8174	* .9174 *
	* 1.2769	* 1.5710	* 1.2864	* 1.5674	* 1.2743	* 1.4278	* 1.2519	* 2.4514 *
10	* 1.4708	* 1.7630	* 1.2314	* 1.4061	* 1.4840	* 1.7526	* 1.7850	* .8570 *
	* 1.5405	* 1.2870	* 1.8344	* 1.6103	* 1.5340	* 1.3004	* 1.2790	* 2.6287 *
11	* 1.7552	* 1.4418	* 1.4031	* 1.4313	* 1.7666	* 1.5418	* 1.7818	* .7499 *
	* 1.2892	* 1.5673	* 1.6136	* 1.6116	* 1.3206	* 1.5024	* 1.2880	* 3.0205 *
12	* 1.5013	* 1.7816	* 1.4835	* 1.7664	* 1.6317	* 1.8358	* 1.1436	*
	* 1.5057	* 1.2746	* 1.5345	* 1.3207	* 1.4342	* 1.2736	* 2.0167	*
13	* 1.7780	* 1.5862	* 1.7522	* 1.5415	* 1.8355	* 1.7849	* .7895	*
	* 1.2732	* 1.4282	* 1.3007	* 1.5028	* 1.2738	* 1.3129	* 2.9290	*
14	* 1.3193	* 1.8170	* 1.7845	* 1.7813	* 1.1428	* .7895	*	
	* 1.7086	* 1.2522	* 1.2793	* 1.2883	* 2.0180	* 2.9289	*	
15	* .7116	* .9173	* .8568	* .7497	* F-SUB-Q			
	* 3.1438	* 2.4515	* 2.6293	* 3.0213	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1705	* 1.7730	* 1.4608	* 1.7469	* 1.4929	* 1.7717	* 1.3126	* .7069 *
	* 1.8930	* 1.2468	* 1.5065	* 1.2583	* 1.4708	* 1.2411	* 1.6683	* 3.0750 *
9	* 1.7730	* 1.4325	* 1.7541	* 1.4319	* 1.7759	* 1.5803	* 1.8150	* .9128 *
	* 1.2468	* 1.5376	* 1.2560	* 1.5331	* 1.2417	* 1.3922	* 1.2168	* 2.3930 *
10	* 1.4608	* 1.7532	* 1.2215	* 1.3968	* 1.4761	* 1.7510	* 1.7829	* .8541 *
	* 1.5065	* 1.2567	* 1.7969	* 1.5742	* 1.4971	* 1.2654	* 1.2426	* 2.5617 *
11	* 1.7469	* 1.4320	* 1.3938	* 1.4254	* 1.7633	* 1.5373	* 1.7796	* .7470 *
	* 1.2583	* 1.5329	* 1.5775	* 1.5694	* 1.2823	* 1.4616	* 1.2509	* 2.9431 *
12	* 1.4929	* 1.7754	* 1.4756	* 1.7632	* 1.6279	* 1.8347	* 1.1430	*
	* 1.4708	* 1.2420	* 1.4975	* 1.2824	* 1.3932	* 1.2344	* 1.9556	*
13	* 1.7717	* 1.5797	* 1.7506	* 1.5370	* 1.8344	* 1.7851	* .7863	*
	* 1.2411	* 1.3926	* 1.2658	* 1.4619	* 1.2345	* 1.2711	* 2.8488	*
14	* 1.3126	* 1.8145	* 1.7824	* 1.7791	* 1.1423	* .7863	*	
	* 1.6683	* 1.2172	* 1.2429	* 1.2512	* 1.9567	* 2.8487	*	
15	* .7069	* .9127	* .8539	* .7468	* F-SUB-Q			
	* 3.0750	* 2.3932	* 2.5623	* 2.9439	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 33 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1503	* 1.7413	* 1.4394	* 1.7190	* 1.4723	* 1.7450	* 1.2957	* .6954 *
	* 1.8743	* 1.2354	* 1.4890	* 1.2455	* 1.4527	* 1.2273	* 1.6463	* 3.0461 *
9	* 1.7413	* 1.4105	* 1.7231	* 1.4108	* 1.7478	* 1.5599	* 1.7906	* .9046 *
	* 1.2354	* 1.5206	* 1.2449	* 1.5158	* 1.2279	* 1.3734	* 1.2003	* 2.3520 *
10	* 1.4394	* 1.7222	* 1.2184	* 1.3759	* 1.4556	* 1.7299	* 1.7583	* .8519 *
	* 1.4890	* 1.2455	* 1.7560	* 1.5564	* 1.4777	* 1.2474	* 1.2257	* 2.5012 *
11	* 1.7190	* 1.4110	* 1.3729	* 1.4083	* 1.7402	* 1.5191	* 1.7579	* .7479 *
	* 1.2455	* 1.5156	* 1.5596	* 1.5434	* 1.2610	* 1.4363	* 1.2311	* 2.8606 *
12	* 1.4723	* 1.7473	* 1.4551	* 1.7401	* 1.6091	* 1.8101	* 1.1379	*
	* 1.4527	* 1.2283	* 1.4782	* 1.2611	* 1.3675	* 1.2134	* 1.9079	*
13	* 1.7450	* 1.5594	* 1.7294	* 1.5188	* 1.8099	* 1.7641	* .7769	*
	* 1.2273	* 1.3739	* 1.2477	* 1.4365	* 1.2136	* 1.2469	* 2.7987	*
14	* 1.2957	* 1.7900	* 1.7578	* 1.7574	* 1.1373	* .7769	*	
	* 1.6463	* 1.2007	* 1.2261	* 1.2314	* 1.9090	* 2.7986	*	
15	* .6954	* .9045	* .8516	* .7477	* F-SUB-Q			
	* 3.0461	* 2.3521	* 2.5018	* 2.8614	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1432	* 1.7479	* 1.4326	* 1.7243	* 1.4665	* 1.7524	* 1.2897	* .6923 *
	* 1.8184	* 1.1885	* 1.4474	* 1.2038	* 1.4155	* 1.1859	* 1.6084	* 2.9839 *
9	* 1.7479	* 1.4027	* 1.7297	* 1.4037	* 1.7561	* 1.5576	* 1.8032	* .8975 *
	* 1.1885	* 1.4786	* 1.1996	* 1.4772	* 1.1851	* 1.3350	* 1.1564	* 2.3076 *
10	* 1.4326	* 1.7289	* 1.1939	* 1.3716	* 1.4514	* 1.7392	* 1.7716	* .8353 *
	* 1.4474	* 1.2002	* 1.7344	* 1.5126	* 1.4357	* 1.2019	* 1.1792	* 2.4819 *
11	* 1.7243	* 1.4039	* 1.3686	* 1.4035	* 1.7493	* 1.5181	* 1.7683	* .7306 *
	* 1.2038	* 1.4770	* 1.5158	* 1.4939	* 1.2063	* 1.3860	* 1.1844	* 2.8450 *
12	* 1.4665	* 1.7556	* 1.4509	* 1.7492	* 1.6110	* 1.8245	* 1.1227	*
	* 1.4155	* 1.1854	* 1.4362	* 1.2064	* 1.3114	* 1.1582	* 1.8680	*
13	* 1.7524	* 1.5570	* 1.7387	* 1.5178	* 1.8243	* 1.7801	* .7745	*
	* 1.1859	* 1.3355	* 1.2022	* 1.3862	* 1.1583	* 1.1890	* 2.7109	*
14	* 1.2897	* 1.8026	* 1.7711	* 1.7678	* 1.1219	* .7745	*	
	* 1.6084	* 1.1568	* 1.1795	* 1.1847	* 1.8693	* 2.7109	*	
15	* .6923	* .8975	* .8351	* .7304	* F-SUB-Q			
	* 2.9839	* 2.3078	* 2.4825	* 2.8458	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 34 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1186	* 1.7139	* 1.4049	* 1.6929	* 1.4388	* 1.7214	* 1.2650	* .6780 *
	* 1.7928	* 1.1717	* 1.4282	* 1.1871	* 1.3971	* 1.1688	* 1.5884	* 2.9536 *
9	* 1.7139	* 1.3747	* 1.6970	* 1.3764	* 1.7240	* 1.5299	* 1.7737	* .8805 *
	* 1.1717	* 1.4595	* 1.1829	* 1.4586	* 1.1683	* 1.3159	* 1.1376	* 2.2794 *
10	* 1.4049	* 1.6962	* 1.1707	* 1.3477	* 1.4247	* 1.7100	* 1.7410	* .8180 *
	* 1.4282	* 1.1835	* 1.7124	* 1.4900	* 1.4151	* 1.1824	* 1.1608	* 2.4553 *
11	* 1.6929	* 1.3766	* 1.3448	* 1.3787	* 1.7207	* 1.4924	* 1.7399	* .7157 *
	* 1.1871	* 1.4584	* 1.4932	* 1.4684	* 1.1816	* 1.3606	* 1.1638	* 2.8124 *
12	* 1.4388	* 1.7235	* 1.4242	* 1.7206	* 1.5852	* 1.7949	* 1.1020	*
	* 1.3971	* 1.1687	* 1.4156	* 1.1817	* 1.2825	* 1.1347	* 1.8386	*
13	* 1.7214	* 1.5294	* 1.7095	* 1.4921	* 1.7946	* 1.7545	* .7594	*
	* 1.1688	* 1.3163	* 1.1827	* 1.3609	* 1.1348	* 1.1626	* 2.6701	*
14	* 1.2650	* 1.7731	* 1.7405	* 1.7394	* 1.1012	* .7594	*	
	* 1.5884	* 1.1379	* 1.1611	* 1.1641	* 1.8399	* 2.6701	*	
15	* .6780	* .8804	* .8178	* .7155	* F-SUB-Q			
	* 2.9536	* 2.2795	* 2.4559	* 2.8132	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0701	* 1.6279	* 1.3493	* 1.6134	* 1.3821	* 1.6404	* 1.2156	* .6483 *
	* 1.8223	* 1.1995	* 1.4469	* 1.2124	* 1.4159	* 1.1939	* 1.6096	* 3.0109 *
9	* 1.6279	* 1.3206	* 1.6135	* 1.3229	* 1.6442	* 1.4689	* 1.6895	* .8484 *
	* 1.1995	* 1.4781	* 1.2105	* 1.4774	* 1.1921	* 1.3339	* 1.1620	* 2.3046 *
10	* 1.3493	* 1.6128	* 1.1446	* 1.2978	* 1.3692	* 1.6303	* 1.6538	* .7970 *
	* 1.4469	* 1.2110	* 1.7046	* 1.5059	* 1.4325	* 1.2062	* 1.1885	* 2.4547 *
11	* 1.6134	* 1.3231	* 1.2950	* 1.3273	* 1.6431	* 1.4347	* 1.6606	* .7005 *
	* 1.2124	* 1.4772	* 1.5091	* 1.4817	* 1.2009	* 1.3744	* 1.1854	* 2.7975 *
12	* 1.3821	* 1.6437	* 1.3687	* 1.6429	* 1.5228	* 1.7084	* 1.0709	*
	* 1.4159	* 1.1924	* 1.4330	* 1.2010	* 1.2952	* 1.1565	* 1.8384	*
13	* 1.6404	* 1.4684	* 1.6298	* 1.4344	* 1.7081	* 1.6743	* .7273	*
	* 1.1939	* 1.3343	* 1.2065	* 1.3747	* 1.1566	* 1.1816	* 2.7089	*
14	* 1.2156	* 1.6890	* 1.6533	* 1.6601	* 1.0703	* .7272	*	
	* 1.6096	* 1.1623	* 1.1888	* 1.1857	* 1.8394	* 2.7086	*	
15	* .6483	* .8483	* .7968	* .7003	* F-SUB-Q			
	* 3.0109	* 2.3044	* 2.4551	* 2.7982	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 35 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0248	* 1.5546	* 1.2932	* 1.5433	* 1.3248	* 1.5696	* 1.1629	* .6204 *
	* 1.8625	* 1.2289	* 1.4774	* 1.2408	* 1.4460	* 1.2214	* 1.6476	* 3.0834 *
9	* 1.5546	* 1.2661	* 1.5422	* 1.2684	* 1.5738	* 1.4092	* 1.6167	* .8094 *
	* 1.2289	* 1.5087	* 1.2394	* 1.5086	* 1.2189	* 1.3610	* 1.1880	* 2.3670 *
10	* 1.2932	* 1.5415	* 1.0866	* 1.2516	* 1.3171	* 1.5549	* 1.5778	* .7521 *
	* 1.4774	* 1.2399	* 1.7585	* 1.5286	* 1.4571	* 1.2370	* 1.2187	* 2.5482 *
11	* 1.5433	* 1.2685	* 1.2488	* 1.2744	* 1.5741	* 1.3777	* 1.5879	* .6597 *
	* 1.2408	* 1.5084	* 1.5319	* 1.5088	* 1.2248	* 1.3986	* 1.2123	* 2.9085 *
12	* 1.3248	* 1.5734	* 1.3166	* 1.5739	* 1.4635	* 1.6339	* 1.0145	*
	* 1.4460	* 1.2192	* 1.4575	* 1.2249	* 1.3165	* 1.1809	* 1.8973	*
13	* 1.5696	* 1.4087	* 1.5544	* 1.3774	* 1.6337	* 1.6040	* .6957	*
	* 1.2214	* 1.3614	* 1.2373	* 1.3989	* 1.1811	* 1.2042	* 2.7701	*
14	* 1.1629	* 1.6162	* 1.5773	* 1.5874	* 1.0139	* .6957	*	
	* 1.6476	* 1.1883	* 1.2190	* 1.2125	* 1.8983	* 2.7684	*	
15	* .6204	* .8093	* .7519	* .6595	* F-SUB-Q			
	* 3.0834	* 2.3659	* 2.5482	* 2.9093	* M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9396	* 1.3971	* 1.1785	* 1.3890	* 1.2076	* 1.4131	* 1.0585	* .5639 *
	* 1.9995	* 1.3455	* 1.5956	* 1.3569	* 1.5613	* 1.3352	* 1.7820	* 3.3431 *
9	* 1.3971	* 1.1559	* 1.3855	* 1.1565	* 1.4202	* 1.2855	* 1.4548	* .7371 *
	* 1.3455	* 1.6265	* 1.3576	* 1.6286	* 1.3292	* 1.4682	* 1.2990	* 2.5588 *
10	* 1.1785	* 1.3851	* 1.0045	* 1.1440	* 1.2118	* 1.4027	* 1.4219	* .6880 *
	* 1.5956	* 1.3580	* 1.8727	* 1.6464	* 1.5587	* 1.3488	* 1.3302	* 2.7429 *
11	* 1.3890	* 1.1567	* 1.1416	* 1.1673	* 1.4229	* 1.2598	* 1.4294	* .6031 *
	* 1.3569	* 1.6284	* 1.6499	* 1.6200	* 1.3319	* 1.5039	* 1.3244	* 3.1327 *
12	* 1.2076	* 1.4198	* 1.2114	* 1.4228	* 1.3378	* 1.4680	* .9181	*
	* 1.5613	* 1.3295	* 1.5592	* 1.3320	* 1.4158	* 1.2918	* 2.0623	*
13	* 1.4131	* 1.2851	* 1.4022	* 1.2595	* 1.4678	* 1.4408	* .6340	*
	* 1.3352	* 1.4687	* 1.3491	* 1.5042	* 1.2919	* 1.3174	* 2.9887	*
14	* 1.0585	* 1.4543	* 1.4215	* 1.4290	* .9175	* .6340	*	
	* 1.7820	* 1.2993	* 1.3305	* 1.3247	* 2.0635	* 2.9885	*	
15	* .5639	* .7371	* .6878	* .6029	* F-SUB-Q			
	* 3.3431	* 2.5586	* 2.7433	* 3.1335	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 36 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7879 *	* 1.1930 *	* .9181 *	* 1.1786 *	* .9412 *	* 1.1985 *	* .8379 *	* .4612 *
	* 2.3597 *	* 1.5589 *	* 2.0264 *	* 1.5813 *	* 1.9819 *	* 1.5573 *	* 2.2273 *	* 4.0491 *
9	* 1.1930 *	* .9030 *	* 1.1797 *	* .9018 *	* 1.2096 *	* 1.0238 *	* 1.2050 *	* .5984 *
	* 1.5589 *	* 2.0598 *	* 1.5776 *	* 2.0665 *	* 1.5428 *	* 1.8231 *	* 1.5506 *	* 3.1207 *
10	* .9181 *	* 1.1797 *	* .8495 *	* .9303 *	* 1.0001 *	* 1.2106 *	* 1.2048 *	* .5692 *
	* 2.0264 *	* 1.5777 *	* 2.1912 *	* 2.0051 *	* 1.8687 *	* 1.5444 *	* 1.5518 *	* 3.2827 *
11	* 1.1786 *	* .9018 *	* .9296 *	* .9314 *	* 1.2134 *	* 1.0093 *	* 1.1374 *	* .4924 *
	* 1.5813 *	* 2.0663 *	* 2.0066 *	* 2.0081 *	* 1.5435 *	* 1.8555 *	* 1.6456 *	* 3.7980 *
12	* .9412 *	* 1.2093 *	* .9998 *	* 1.2132 *	* 1.0963 *	* 1.2484 *	* .7412 *	
	* 1.9819 *	* 1.5431 *	* 1.8692 *	* 1.5436 *	* 1.7083 *	* 1.5013 *	* 2.5266 *	
13	* 1.1985 *	* 1.0235 *	* 1.2103 *	* 1.0091 *	* 1.2483 *	* 1.1432 *	* .5198 *	
	* 1.5573 *	* 1.8236 *	* 1.5448 *	* 1.8558 *	* 1.5014 *	* 1.6410 *	* 3.6067 *	
14	* .8379 *	* 1.2046 *	* 1.2045 *	* 1.1371 *	* .7408 *	* .5197 *		
	* 2.2273 *	* 1.5510 *	* 1.5521 *	* 1.6460 *	* 2.5278 *	* 3.6069 *		
15	* .4612 *	* .5983 *	* .5690 *	* .4923 *	F-SUB-Q			
	* 4.0491 *	* 3.1209 *	* 3.2835 *	* 3.7989 *	M-SUB-Q			

AT 100% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5547 *	* .4919 *	* .4208 *	* .4935 *	* .4322 *	* .5011 *	* .3919 *	* .3157 *
	* 3.3323 *	* 3.7587 *	* 4.3954 *	* 3.7549 *	* 4.2929 *	* 3.7029 *	* 4.7369 *	* 5.8871 *
9	* .4919 *	* .4174 *	* .4860 *	* .4200 *	* .5064 *	* .4483 *	* .4656 *	* .2818 *
	* 3.7587 *	* 4.4319 *	* 3.8078 *	* 4.4133 *	* 3.6649 *	* 4.1390 *	* 3.9906 *	* 6.5985 *
10	* .4208 *	* .4862 *	* .4225 *	* .4106 *	* .4410 *	* .5086 *	* .4805 *	* .2740 *
	* 4.3954 *	* 3.8062 *	* 4.3805 *	* 4.5186 *	* 4.2102 *	* 3.6529 *	* 3.8687 *	* 6.7870 *
11	* .4935 *	* .4201 *	* .4104 *	* .4390 *	* .5103 *	* .4446 *	* .4420 *	* .2402 *
	* 3.7549 *	* 4.4123 *	* 4.5208 *	* 4.2367 *	* 3.6473 *	* 4.1862 *	* 4.2092 *	* 7.7494 *
12	* .4322 *	* .5063 *	* .4409 *	* .5102 *	* .4724 *	* .4866 *	* .3422 *	
	* 4.2929 *	* 3.6655 *	* 4.2112 *	* 3.6477 *	* 3.9400 *	* 3.8286 *	* 5.4442 *	
13	* .5011 *	* .4482 *	* .5085 *	* .4445 *	* .4865 *	* .4451 *	* .3574 *	
	* 3.7029 *	* 4.1399 *	* 3.6538 *	* 4.1872 *	* 3.8290 *	* 4.1878 *	* 5.2189 *	
14	* .3919 *	* .4655 *	* .4803 *	* .4419 *	* .3423 *	* .3573 *		
	* 4.7370 *	* 3.9916 *	* 3.8695 *	* 4.2102 *	* 5.4424 *	* 5.2199 *		
15	* .3157 *	* .2817 *	* .2739 *	* .2402 *	F-SUB-Q			
	* 5.8871 *	* 6.5998 *	* 6.7886 *	* 7.7514 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 37 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6010 *	* .5384 *	* .4813 *	* .5475 *	* .4906 *	* .5407 *	* .4402 *	* .3957 *
	* 2.9850 *	* 3.5689 *	* 3.9776 *	* 3.4334 *	* 3.8122 *	* 3.4372 *	* 4.2008 *	* 4.6132 *
9	* .5384 *	* .4846 *	* .5408 *	* .4799 *	* .5469 *	* .4927 *	* .4931 *	* .3337 *
	* 3.5689 *	* 4.0031 *	* 3.5507 *	* 3.9273 *	* 3.4258 *	* 3.7895 *	* 3.7986 *	* 5.5530 *
10	* .4813 *	* .5413 *	* .4840 *	* .4722 *	* .4872 *	* .5367 *	* .4998 *	* .3191 *
	* 3.9776 *	* 3.5502 *	* 4.0035 *	* 4.0803 *	* 3.9580 *	* 3.5807 *	* 3.8078 *	* 5.8328 *
11	* .5475 *	* .4800 *	* .4720 *	* .4518 *	* .5238 *	* .4730 *	* .4651 *	* .2843 *
	* 3.4334 *	* 3.9272 *	* 4.0824 *	* 4.0897 *	* 3.5680 *	* 4.0208 *	* 4.1872 *	* 6.7581 *
12	* .4906 *	* .5469 *	* .4872 *	* .5238 *	* .4500 *	* .4697 *	* .3674 *	
	* 3.8122 *	* 3.4258 *	* 3.9583 *	* 3.5681 *	* 3.7220 *	* 3.7583 *	* 5.1256 *	
13	* .5407 *	* .4927 *	* .5367 *	* .4730 *	* .4697 *	* .4300 *	* .4066 *	
	* 3.4372 *	* 3.7894 *	* 3.5806 *	* 4.0209 *	* 3.7583 *	* 4.0716 *	* 4.5275 *	
14	* .4402 *	* .4933 *	* .4999 *	* .4651 *	* .3675 *	* .4065 *		
	* 4.2008 *	* 3.7971 *	* 3.8071 *	* 4.1870 *	* 5.1239 *	* 4.5289 *		
15	* .3957 *	* .3338 *	* .3192 *	* .2843 *	F-SUB-Q			
	* 4.6132 *	* 5.5494 *	* 5.8308 *	* 6.7575 *	M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7979 *	* 1.1346 *	* .9929 *	* 1.1360 *	* 1.0086 *	* 1.1251 *	* .8894 *	* .5292 *
	* 2.2571 *	* 1.7280 *	* 1.9655 *	* 1.6880 *	* 1.8847 *	* 1.6842 *	* 2.1126 *	* 3.5154 *
9	* 1.1346 *	* .9956 *	* 1.1361 *	* .9895 *	* 1.1363 *	* 1.0222 *	* 1.1019 *	* .6525 *
	* 1.7280 *	* 1.9854 *	* 1.7298 *	* 1.9416 *	* 1.6833 *	* 1.8613 *	* 1.7321 *	* 2.8828 *
10	* .9929 *	* 1.1362 *	* .9109 *	* .9631 *	* .9983 *	* 1.1159 *	* 1.0869 *	* .6199 *
	* 1.9655 *	* 1.7299 *	* 2.1538 *	* 2.0368 *	* 1.9691 *	* 1.7550 *	* 1.7825 *	* 3.0586 *
11	* 1.1360 *	* .9895 *	* .9625 *	* .9317 *	* 1.0970 *	* .9898 *	* 1.0423 *	* .5501 *
	* 1.6880 *	* 1.9416 *	* 2.0396 *	* 2.0567 *	* 1.7412 *	* 1.9620 *	* 1.8887 *	* 3.5552 *
12	* 1.0086 *	* 1.1363 *	* .9983 *	* 1.0970 *	* .9810 *	* 1.0880 *	* .7321 *	
	* 1.8847 *	* 1.6833 *	* 1.9692 *	* 1.7412 *	* 1.8524 *	* 1.7109 *	* 2.6195 *	
13	* 1.1251 *	* 1.0222 *	* 1.1159 *	* .9898 *	* 1.0880 *	* .9999 *	* .5396 *	
	* 1.6842 *	* 1.8612 *	* 1.7550 *	* 1.9621 *	* 1.7110 *	* 1.8510 *	* 3.4838 *	
14	* .8894 *	* 1.1022 *	* 1.0870 *	* 1.0424 *	* .7320 *	* .5396 *		
	* 2.1126 *	* 1.7316 *	* 1.7823 *	* 1.8887 *	* 2.6197 *	* 3.4840 *		
15	* .5292 *	* .6528 *	* .6200 *	* .5501 *	F-SUB-Q			
	* 3.5154 *	* 2.8816 *	* 3.0577 *	* 3.5550 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 38 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9993	* 1.3332	* 1.1707	* 1.3185	* 1.1933	* 1.3150	* 1.0640	* .6234
	* 1.9827	* 1.5036	* 1.6920	* 1.4704	* 1.6145	* 1.4596	* 1.7876	* 3.0209
9	* 1.3332	* 1.1731	* 1.3282	* 1.1643	* 1.3189	* 1.2238	* 1.3072	* .7717
	* 1.5036	* 1.7172	* 1.5011	* 1.6716	* 1.4655	* 1.5726	* 1.4770	* 2.4680
10	* 1.1707	* 1.3280	* 1.0512	* 1.1365	* 1.1743	* 1.2844	* 1.2822	* .7370
	* 1.6920	* 1.5015	* 1.8938	* 1.7467	* 1.6960	* 1.5349	* 1.5312	* 2.6045
11	* 1.3185	* 1.1643	* 1.1348	* 1.1104	* 1.2727	* 1.1848	* 1.2765	* .6544
	* 1.4704	* 1.6715	* 1.7493	* 1.7681	* 1.5221	* 1.6576	* 1.5607	* 3.0260
12	* 1.1933	* 1.3188	* 1.1742	* 1.2727	* 1.2169	* 1.3026	* .8979	*
	* 1.6145	* 1.4655	* 1.6962	* 1.5222	* 1.5868	* 1.4781	* 2.1718	*
13	* 1.3150	* 1.2237	* 1.2843	* 1.1847	* 1.3025	* 1.2421	* .6398	*
	* 1.4596	* 1.5728	* 1.5349	* 1.6576	* 1.4781	* 1.5386	* 2.9959	*
14	* 1.0640	* 1.3074	* 1.2822	* 1.2765	* .8977	* .6398	*	*
	* 1.7876	* 1.4767	* 1.5311	* 1.5607	* 2.1722	* 2.9959	*	*
15	* .6234	* .7719	* .7371	* .6544	* F-SUB-Q			
	* 3.0209	* 2.4673	* 2.6039	* 3.0259	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0936	* 1.5041	* 1.2770	* 1.4845	* 1.3037	* 1.4829	* 1.1629	* .6796
	* 1.8589	* 1.3575	* 1.5738	* 1.3213	* 1.4929	* 1.3079	* 1.6540	* 2.8040
9	* 1.5041	* 1.2754	* 1.4931	* 1.2677	* 1.4893	* 1.3495	* 1.4795	* .8379
	* 1.3575	* 1.6073	* 1.3527	* 1.5542	* 1.3140	* 1.4422	* 1.3194	* 2.2982
10	* 1.2770	* 1.4927	* 1.1252	* 1.2376	* 1.2860	* 1.4565	* 1.4606	* .7894
	* 1.5738	* 1.3532	* 1.7926	* 1.6244	* 1.5673	* 1.3736	* 1.3581	* 2.4597
11	* 1.4845	* 1.2678	* 1.2357	* 1.2187	* 1.4429	* 1.3066	* 1.4427	* .6972
	* 1.3213	* 1.5541	* 1.6268	* 1.6411	* 1.3710	* 1.5252	* 1.3995	* 2.8725
12	* 1.3037	* 1.4892	* 1.2859	* 1.4428	* 1.3549	* 1.4890	* .9825	*
	* 1.4929	* 1.3141	* 1.5675	* 1.3710	* 1.4559	* 1.3192	* 2.0185	*
13	* 1.4829	* 1.3493	* 1.4564	* 1.3065	* 1.4890	* 1.4124	* .7024	*
	* 1.3079	* 1.4424	* 1.3737	* 1.5253	* 1.3193	* 1.3810	* 2.7812	*
14	* 1.1629	* 1.4796	* 1.4607	* 1.4426	* .9822	* .7024	*	*
	* 1.6540	* 1.3192	* 1.3581	* 1.3996	* 2.0190	* 2.7811	*	*
15	* .6796	* .8381	* .7895	* .6972	* F-SUB-Q			
	* 2.8040	* 2.2976	* 2.4594	* 2.8725	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 39 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1241	* 1.5761	* 1.3193	* 1.5587	* 1.3514	* 1.5635	* 1.2047	* .6980 *
	* 1.8469	* 1.3195	* 1.5471	* 1.2762	* 1.4602	* 1.2574	* 1.6191	* 2.7696 *
9	* 1.5761	* 1.3140	* 1.5619	* 1.3092	* 1.5713	* 1.4043	* 1.5631	* .8660 *
	* 1.3195	* 1.5885	* 1.3120	* 1.5270	* 1.2637	* 1.4050	* 1.2642	* 2.2555 *
10	* 1.3193	* 1.5615	* 1.1509	* 1.2724	* 1.3346	* 1.5438	* 1.5489	* .8183 *
	* 1.5471	* 1.3125	* 1.7792	* 1.6033	* 1.5309	* 1.3129	* 1.2957	* 2.4049 *
11	* 1.5587	* 1.3093	* 1.2704	* 1.2690	* 1.5313	* 1.3610	* 1.5233	* .7202 *
	* 1.2762	* 1.5269	* 1.6058	* 1.6056	* 1.3188	* 1.4900	* 1.3466	* 2.8156 *
12	* 1.3514	* 1.5711	* 1.3344	* 1.5312	* 1.4180	* 1.5779	* 1.0266	*
	* 1.4602	* 1.2638	* 1.5311	* 1.3189	* 1.4187	* 1.2687	* 1.9673	*
13	* 1.5635	* 1.4041	* 1.5436	* 1.3609	* 1.5779	* 1.4937	* .7277	*
	* 1.2574	* 1.4052	* 1.3130	* 1.4901	* 1.2687	* 1.3326	* 2.7386	*
14	* 1.2047	* 1.5632	* 1.5489	* 1.5233	* 1.0263	* .7277	*	
	* 1.6191	* 1.2641	* 1.2957	* 1.3466	* 1.9679	* 2.7385	*	
15	* .6980	* .8661	* .8184	* .7202	* F-SUB-Q			
	* 2.7696	* 2.2551	* 2.4047	* 2.8157	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1352	* 1.6037	* 1.3347	* 1.5896	* 1.3716	* 1.5993	* 1.2230	* .7064 *
	* 1.8599	* 1.3166	* 1.5557	* 1.2727	* 1.4632	* 1.2497	* 1.6219	* 2.7841 *
9	* 1.6037	* 1.3263	* 1.5880	* 1.3248	* 1.6079	* 1.4289	* 1.6024	* .8786 *
	* 1.3166	* 1.5972	* 1.3116	* 1.5351	* 1.2549	* 1.4038	* 1.2519	* 2.2592 *
10	* 1.3347	* 1.5875	* 1.1613	* 1.2830	* 1.3556	* 1.5864	* 1.5923	* .8345 *
	* 1.5557	* 1.3122	* 1.7976	* 1.6160	* 1.5297	* 1.2929	* 1.2780	* 2.3954 *
11	* 1.5896	* 1.3249	* 1.2810	* 1.2928	* 1.5746	* 1.3861	* 1.5624	* .7339 *
	* 1.2727	* 1.5349	* 1.6185	* 1.6028	* 1.3057	* 1.4885	* 1.3296	* 2.8002 *
12	* 1.3716	* 1.6078	* 1.3554	* 1.5745	* 1.4475	* 1.6196	* 1.0508	*
	* 1.4632	* 1.2550	* 1.5299	* 1.3058	* 1.4158	* 1.2605	* 1.9564	*
13	* 1.5993	* 1.4287	* 1.5862	* 1.3860	* 1.6196	* 1.5324	* .7404	*
	* 1.2497	* 1.4041	* 1.2930	* 1.4886	* 1.2606	* 1.3271	* 2.7506	*
14	* 1.2230	* 1.6024	* 1.5922	* 1.5623	* 1.0505	* .7404	*	
	* 1.6219	* 1.2519	* 1.2781	* 1.3296	* 1.9570	* 2.7504	*	
15	* .7064	* .8787	* .8345	* .7338	* F-SUB-Q			
	* 2.7841	* 2.2588	* 2.3952	* 2.8004	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 40 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1421	* 1.6325	* 1.3474	* 1.6220	* 1.3889	* 1.6359	* 1.2381	* .7132 *
	* 1.8736	* 1.3056	* 1.5708	* 1.2736	* 1.4752	* 1.2466	* 1.6355	* 2.8151 *
9	* 1.6325	* 1.3364	* 1.6160	* 1.3380	* 1.6448	* 1.4504	* 1.6417	* .8898 *
	* 1.3056	* 1.5973	* 1.3125	* 1.5510	* 1.2511	* 1.4111	* 1.2445	* 2.2743 *
10	* 1.3474	* 1.6155	* 1.1641	* 1.2937	* 1.3746	* 1.6272	* 1.6342	* .8405 *
	* 1.5708	* 1.3131	* 1.8218	* 1.6318	* 1.5318	* 1.2793	* 1.2657	* 2.4227 *
11	* 1.6220	* 1.3381	* 1.2916	* 1.3120	* 1.6156	* 1.4084	* 1.5973	* .7379 *
	* 1.2736	* 1.5508	* 1.6344	* 1.6079	* 1.2966	* 1.4920	* 1.3101	* 2.8219 *
12	* 1.3889	* 1.6446	* 1.3744	* 1.6155	* 1.4735	* 1.6605	* 1.0625	*
	* 1.4752	* 1.2512	* 1.5320	* 1.2967	* 1.4173	* 1.2523	* 1.9703	*
13	* 1.6359	* 1.4502	* 1.6270	* 1.4083	* 1.6605	* 1.5676	* .7524	*
	* 1.2466	* 1.4113	* 1.2794	* 1.4922	* 1.2524	* 1.3215	* 2.7587	*
14	* 1.2381	* 1.6416	* 1.6341	* 1.5972	* 1.0622	* .7524	*	
	* 1.6355	* 1.2446	* 1.2658	* 1.3102	* 1.9710	* 2.7586	*	
15	* .7132	* .8899	* .8405	* .7378	* F-SUB-Q			
	* 2.8151	* 2.2740	* 2.4227	* 2.8221	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1336	* 1.6431	* 1.3506	* 1.6362	* 1.3955	* 1.6538	* 1.2438	* .7101 *
	* 1.9112	* 1.3172	* 1.5981	* 1.2937	* 1.5048	* 1.2631	* 1.6683	* 2.8967 *
9	* 1.6431	* 1.3371	* 1.6264	* 1.3417	* 1.6623	* 1.4597	* 1.6612	* .8899 *
	* 1.3172	* 1.6228	* 1.3255	* 1.5835	* 1.2669	* 1.4359	* 1.2570	* 2.3262 *
10	* 1.3506	* 1.6258	* 1.1601	* 1.2949	* 1.3822	* 1.6502	* 1.6560	* .8415 *
	* 1.5981	* 1.3259	* 1.8588	* 1.6577	* 1.5468	* 1.2830	* 1.2733	* 2.4726 *
11	* 1.6362	* 1.3418	* 1.2928	* 1.3210	* 1.6364	* 1.4183	* 1.6148	* .7372 *
	* 1.2937	* 1.5833	* 1.6604	* 1.6165	* 1.2970	* 1.5003	* 1.3166	* 2.8616 *
12	* 1.3955	* 1.6621	* 1.3820	* 1.6363	* 1.4861	* 1.6810	* 1.0692	*
	* 1.5048	* 1.2671	* 1.5470	* 1.2971	* 1.4253	* 1.2560	* 1.9807	*
13	* 1.6538	* 1.4594	* 1.6501	* 1.4182	* 1.6810	* 1.5852	* .7534	*
	* 1.2631	* 1.4361	* 1.2831	* 1.5004	* 1.2561	* 1.3298	* 2.7968	*
14	* 1.2438	* 1.6611	* 1.6559	* 1.6147	* 1.0688	* .7534	*	
	* 1.6683	* 1.2570	* 1.2733	* 1.3167	* 1.9814	* 2.7967	*	
15	* .7101	* .8900	* .8415	* .7371	* F-SUB-Q			
	* 2.8967	* 2.3260	* 2.4727	* 2.8618	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 41 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1341	* 1.6555	* 1.3536	* 1.6517	* 1.4014	* 1.6725	* 1.2487	* .7128 *
	* 1.9641	* 1.3420	* 1.6320	* 1.3185	* 1.5428	* 1.2855	* 1.7107	* 2.9696 *
9	* 1.6555	* 1.3382	* 1.6389	* 1.3453	* 1.6806	* 1.4684	* 1.6806	* .8926 *
	* 1.3420	* 1.6612	* 1.3439	* 1.6235	* 1.2882	* 1.4683	* 1.2753	* 2.3825 *
10	* 1.3536	* 1.6384	* 1.1595	* 1.2981	* 1.3892	* 1.6725	* 1.6767	* .8403 *
	* 1.6320	* 1.3443	* 1.9017	* 1.6912	* 1.5715	* 1.2937	* 1.2857	* 2.5404 *
11	* 1.6517	* 1.3454	* 1.2960	* 1.3286	* 1.6571	* 1.4271	* 1.6310	* .7347 *
	* 1.3185	* 1.6233	* 1.6935	* 1.6482	* 1.3128	* 1.5278	* 1.3320	* 2.9280 *
12	* 1.4014	* 1.6804	* 1.3890	* 1.6570	* 1.4975	* 1.7014	* 1.0721	* .7578 *
	* 1.5428	* 1.2884	* 1.5718	* 1.3129	* 1.4520	* 1.2710	* 2.0222	* .7578 *
13	* 1.6725	* 1.4681	* 1.6723	* 1.4269	* 1.7013	* 1.6012	* 2.8431	* .7579 *
	* 1.2855	* 1.4686	* 1.2938	* 1.5279	* 1.2711	* 1.3472	* 2.8431	* .7579 *
14	* 1.2487	* 1.6805	* 1.6766	* 1.6309	* 1.0718	* .7579	* 2.8429	* .7579 *
	* 1.7107	* 1.2754	* 1.2858	* 1.3320	* 2.0229	* 2.8429	* 2.8429	* .7579 *
15	* .7128	* .8926	* .8403	* .7347	* F-SUB-Q			
	* 2.9696	* 2.3823	* 2.5405	* 2.9282	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1164	* 1.6346	* 1.3414	* 1.6336	* 1.3907	* 1.6568	* 1.2401	* .7029 *
	* 2.0555	* 1.3947	* 1.6982	* 1.3782	* 1.6089	* 1.3428	* 1.7823	* 3.1138 *
9	* 1.6346	* 1.3246	* 1.6185	* 1.3336	* 1.6643	* 1.4583	* 1.6657	* .8893 *
	* 1.3947	* 1.7232	* 1.4017	* 1.6924	* 1.3442	* 1.5290	* 1.3279	* 2.4688 *
10	* 1.3414	* 1.6179	* 1.1646	* 1.2883	* 1.3784	* 1.6596	* 1.6634	* .8460 *
	* 1.6982	* 1.4022	* 1.9548	* 1.7534	* 1.6303	* 1.3423	* 1.3349	* 2.6025 *
11	* 1.6336	* 1.3338	* 1.2877	* 1.3217	* 1.6431	* 1.4172	* 1.6200	* .7428 *
	* 1.3782	* 1.6922	* 1.7542	* 1.7106	* 1.3690	* 1.5848	* 1.3759	* 2.9757 *
12	* 1.3907	* 1.6642	* 1.3782	* 1.6430	* 1.4880	* 1.6868	* 1.0763	* .7428 *
	* 1.6089	* 1.3443	* 1.6305	* 1.3691	* 1.5122	* 1.3253	* 2.0770	* .7428 *
13	* 1.6568	* 1.4580	* 1.6594	* 1.4170	* 1.6867	* 1.5897	* .7506	* .7506 *
	* 1.3428	* 1.5292	* 1.3424	* 1.5850	* 1.3253	* 1.4029	* 2.9637	* .7506 *
14	* 1.2401	* 1.6656	* 1.6633	* 1.6199	* 1.0759	* .7506	* 2.9636	* .7506 *
	* 1.7823	* 1.3280	* 1.3350	* 1.3760	* 2.0778	* 2.9636	* 2.9636	* .7506 *
15	* .7029	* .8894	* .8459	* .7427	* F-SUB-Q			
	* 3.1138	* 2.4686	* 2.6026	* 2.9759	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 42 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1218	* 1.6610	* 1.3501	* 1.6620	* 1.4019	* 1.6881	* 1.2491	* .7080 *
	* 2.0887	* 1.4018	* 1.7228	* 1.3949	* 1.6528	* 1.3706	* 1.8400	* 3.2117 *
9	* 1.6610	* 1.3314	* 1.6446	* 1.3423	* 1.6955	* 1.4736	* 1.6982	* .8913 *
	* 1.4018	* 1.7488	* 1.4125	* 1.7288	* 1.3674	* 1.5725	* 1.3516	* 2.5559 *
10	* 1.3501	* 1.6441	* 1.1518	* 1.2938	* 1.3909	* 1.6946	* 1.6970	* .8400 *
	* 1.7228	* 1.4130	* 2.0192	* 1.7984	* 1.6734	* 1.3629	* 1.3561	* 2.7171 *
11	* 1.6620	* 1.3425	* 1.2917	* 1.3332	* 1.6760	* 1.4320	* 1.6452	* .7333 *
	* 1.3949	* 1.7285	* 1.8013	* 1.7514	* 1.3857	* 1.6210	* 1.4018	* 3.1188 *
12	* 1.4019	* 1.6953	* 1.3907	* 1.6759	* 1.5063	* 1.7197	* 1.0758	*
	* 1.6528	* 1.3675	* 1.6737	* 1.3858	* 1.5442	* 1.3435	* 2.1425	*
13	* 1.6881	* 1.4734	* 1.6944	* 1.4318	* 1.7197	* 1.6157	* .7577	*
	* 1.3706	* 1.5728	* 1.3630	* 1.6212	* 1.3436	* 1.4273	* 3.0295	*
14	* 1.2491	* 1.6980	* 1.6969	* 1.6451	* 1.0754	* .7578	*	
	* 1.8400	* 1.3517	* 1.3562	* 1.4019	* 2.1433	* 3.0293	*	
15	* .7080	* .8914	* .8400	* .7333	* F-SUB-Q			
	* 3.2117	* 2.5557	* 2.7172	* 3.1190	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1150	* 1.6641	* 1.3490	* 1.6667	* 1.4022	* 1.6954	* 1.2493	* .7051 *
	* 2.0955	* 1.3976	* 1.7198	* 1.3879	* 1.6472	* 1.3625	* 1.8454	* 3.2586 *
9	* 1.6641	* 1.3286	* 1.6476	* 1.3410	* 1.7022	* 1.4762	* 1.7066	* .8909 *
	* 1.3976	* 1.7483	* 1.4075	* 1.7250	* 1.3597	* 1.5656	* 1.3568	* 2.5890 *
10	* 1.3490	* 1.6470	* 1.1484	* 1.2919	* 1.3919	* 1.7048	* 1.7067	* .8401 *
	* 1.7198	* 1.4079	* 2.0185	* 1.7960	* 1.6705	* 1.3634	* 1.3610	* 2.7502 *
11	* 1.6667	* 1.3412	* 1.2898	* 1.3355	* 1.6846	* 1.4344	* 1.6522	* .7332 *
	* 1.3879	* 1.7247	* 1.7989	* 1.7615	* 1.4023	* 1.6353	* 1.4135	* 3.1679 *
12	* 1.4022	* 1.7020	* 1.3917	* 1.6845	* 1.5103	* 1.7282	* 1.0778	*
	* 1.6472	* 1.3598	* 1.6708	* 1.4024	* 1.5703	* 1.3712	* 2.1830	*
13	* 1.6954	* 1.4759	* 1.7047	* 1.4342	* 1.7281	* 1.6226	* .7564	*
	* 1.3625	* 1.5659	* 1.3636	* 1.6356	* 1.3712	* 1.4636	* 3.1248	*
14	* 1.2493	* 1.7064	* 1.7066	* 1.6521	* 1.0774	* .7565	*	
	* 1.8454	* 1.3569	* 1.3611	* 1.4136	* 2.1839	* 3.1247	*	
15	* .7051	* .8909	* .8400	* .7331	* F-SUB-Q			
	* 3.2586	* 2.5889	* 2.7505	* 3.1685	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 43 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1048	* 1.6489	* 1.3400	* 1.6527	* 1.3941	* 1.6837	* 1.2431	* .6997 *
	* 2.1099	* 1.4081	* 1.7273	* 1.3962	* 1.6513	* 1.3681	* 1.8475	* 3.2701 *
9	* 1.6489	* 1.3185	* 1.6324	* 1.3318	* 1.6898	* 1.4688	* 1.6966	* .8885 *
	* 1.4081	* 1.7577	* 1.4177	* 1.7318	* 1.3661	* 1.5688	* 1.3609	* 2.5847 *
10	* 1.3400	* 1.6318	* 1.1563	* 1.2874	* 1.3836	* 1.6958	* 1.6981	* .8445 *
	* 1.7273	* 1.4182	* 2.0008	* 1.7976	* 1.6764	* 1.3676	* 1.3646	* 2.7244 *
11	* 1.6527	* 1.3320	* 1.2868	* 1.3300	* 1.6739	* 1.4273	* 1.6457	* .7392 *
	* 1.3962	* 1.7315	* 1.7984	* 1.7661	* 1.4102	* 1.6410	* 1.4164	* 3.1305 *
12	* 1.3941	* 1.6896	* 1.3834	* 1.6738	* 1.5033	* 1.7178	* 1.0817	* .6997 *
	* 1.6513	* 1.3662	* 1.6767	* 1.4103	* 1.5764	* 1.3776	* 1.3646	* 2.7244 *
13	* 1.6837	* 1.4685	* 1.6956	* 1.4271	* 1.7177	* 1.6152	* .7517	* .8445 *
	* 1.3681	* 1.5691	* 1.3678	* 1.6412	* 1.3777	* 1.4686	* 3.1385	* 2.5847 *
14	* 1.2431	* 1.6964	* 1.6979	* 1.6455	* 1.0812	* .7517	* .7517	* .7517 *
	* 1.8475	* 1.3610	* 1.3648	* 1.4165	* 2.1726	* 3.1383	* 3.1383	* 3.1383 *
15	* .6997	* .8885	* .8445	* .7392	* F-SUB-Q			
	* 3.2701	* 2.5846	* 2.7246	* 3.1309	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1104	* 1.6762	* 1.3494	* 1.6806	* 1.4054	* 1.7151	* 1.2526	* .7045 *
	* 2.0844	* 1.3798	* 1.7036	* 1.3686	* 1.6324	* 1.3405	* 1.8264	* 3.2228 *
9	* 1.6762	* 1.3262	* 1.6589	* 1.3405	* 1.7205	* 1.4839	* 1.7304	* .8949 *
	* 1.3798	* 1.7350	* 1.3890	* 1.7110	* 1.3389	* 1.5486	* 1.3326	* 2.5530 *
10	* 1.3494	* 1.6584	* 1.1449	* 1.2895	* 1.3960	* 1.7315	* 1.7331	* .8412 *
	* 1.7036	* 1.3895	* 2.0021	* 1.7814	* 1.6563	* 1.3381	* 1.3357	* 2.7212 *
11	* 1.6806	* 1.3408	* 1.2874	* 1.3410	* 1.7064	* 1.4417	* 1.6722	* .7332 *
	* 1.3686	* 1.7106	* 1.7837	* 1.7469	* 1.3824	* 1.6211	* 1.3915	* 3.1389 *
12	* 1.4054	* 1.7203	* 1.3958	* 1.7062	* 1.5212	* 1.7514	* 1.0820	* .8950 *
	* 1.6324	* 1.3391	* 1.6566	* 1.3825	* 1.5567	* 1.3503	* 2.1640	* 2.1640 *
13	* 1.7151	* 1.4836	* 1.7313	* 1.4416	* 1.7513	* 1.6426	* .7600	* .7600 *
	* 1.3405	* 1.5489	* 1.3383	* 1.6213	* 1.3503	* 1.4430	* 3.0910	* 3.0910 *
14	* 1.2526	* 1.7302	* 1.7329	* 1.6721	* 1.0815	* .7600	* .7600	* .7600 *
	* 1.8264	* 1.3327	* 1.3359	* 1.3916	* 2.1649	* 3.0908	* 3.0908	* 3.0908 *
15	* .7045	* .8950	* .8411	* .7331	* F-SUB-Q			
	* 3.2228	* 2.5528	* 2.7215	* 3.1393	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 44 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1064	* 1.6877	* 1.3527	* 1.6925	* 1.4100	* 1.7299	* 1.2568	* .7026 *
	* 2.0290	* 1.3284	* 1.6477	* 1.3183	* 1.5780	* 1.2909	* 1.7655	* 3.1327 *
9	* 1.6877	* 1.3282	* 1.6698	* 1.3433	* 1.7346	* 1.4910	* 1.7477	* .8965 *
	* 1.3284	* 1.6798	* 1.3376	* 1.6554	* 1.2895	* 1.4958	* 1.2823	* 2.4696 *
10	* 1.3527	* 1.6693	* 1.1430	* 1.2909	* 1.4009	* 1.7501	* 1.7519	* .8406 *
	* 1.6477	* 1.3380	* 1.9438	* 1.7246	* 1.6010	* 1.2868	* 1.2845	* 2.6387 *
11	* 1.6925	* 1.3436	* 1.2888	* 1.3463	* 1.7220	* 1.4486	* 1.6873	* .7310 *
	* 1.3183	* 1.6549	* 1.7274	* 1.6877	* 1.3322	* 1.5661	* 1.3394	* 3.0494 *
12	* 1.4100	* 1.7344	* 1.4007	* 1.7219	* 1.5302	* 1.7678	* 1.0847	* .7602 *
	* 1.5780	* 1.2897	* 1.6012	* 1.3323	* 1.5065	* 1.3035	* 2.0932	* .7603 *
13	* 1.7299	* 1.4907	* 1.7499	* 1.4484	* 1.7677	* 1.6576	* 1.3932	* 2.9931 *
	* 1.2909	* 1.4961	* 1.2870	* 1.5663	* 1.3036	* 1.3932	* 2.9931	* .7603 *
14	* 1.2568	* 1.7475	* 1.7517	* 1.6871	* 1.0842	* .7603	* 2.9929	* .7603 *
	* 1.7655	* 1.2824	* 1.2846	* 1.3395	* 2.0941	* 2.9929	* 2.9929	* .7603 *
15	* .7026	* .8965	* .8405	* .7309	* F-SUB-Q			
	* 3.1327	* 2.4694	* 2.6389	* 3.0497	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1052	* 1.6914	* 1.3534	* 1.6962	* 1.4111	* 1.7356	* 1.2582	* .7024 *
	* 1.9794	* 1.2908	* 1.6045	* 1.2810	* 1.5355	* 1.2524	* 1.7172	* 3.0508 *
9	* 1.6914	* 1.3279	* 1.6732	* 1.3433	* 1.7398	* 1.4938	* 1.7555	* .8976 *
	* 1.2908	* 1.6369	* 1.3000	* 1.6124	* 1.2515	* 1.4534	* 1.2419	* 2.4005 *
10	* 1.3534	* 1.6727	* 1.1445	* 1.2907	* 1.4020	* 1.7580	* 1.7604	* .8437 *
	* 1.6045	* 1.3004	* 1.8940	* 1.6794	* 1.5566	* 1.2458	* 1.2431	* 2.5583 *
11	* 1.6962	* 1.3436	* 1.2886	* 1.3485	* 1.7283	* 1.4511	* 1.6946	* .7342 *
	* 1.2810	* 1.6120	* 1.6809	* 1.6379	* 1.2893	* 1.5195	* 1.2963	* 2.9523 *
12	* 1.4111	* 1.7396	* 1.4018	* 1.7282	* 1.5344	* 1.7754	* 1.0890	* .7615 *
	* 1.5355	* 1.2516	* 1.5568	* 1.2894	* 1.4594	* 1.2599	* 2.0249	* .7615 *
13	* 1.7356	* 1.4935	* 1.7578	* 1.4510	* 1.7754	* 1.6650	* .7614	* .7614 *
	* 1.2524	* 1.4537	* 1.2460	* 1.5197	* 1.2599	* 1.3459	* 2.9003	* .7614 *
14	* 1.2582	* 1.7553	* 1.7602	* 1.6945	* 1.0885	* .7615	* 2.9001	* .7615 *
	* 1.7172	* 1.2420	* 1.2432	* 1.2964	* 2.0258	* 2.9001	* 2.9001	* .7615 *
15	* .7024	* .8976	* .8436	* .7341	* F-SUB-Q			
	* 3.0508	* 2.4004	* 2.5585	* 2.9526	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 45 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0993	* 1.6812	* 1.3486	* 1.6854	* 1.4063	* 1.7261	* 1.2545	* .6983
	* 1.9450	* 1.2690	* 1.5746	* 1.2603	* 1.5063	* 1.2306	* 1.6832	* 2.9996
9	* 1.6812	* 1.3225	* 1.6628	* 1.3378	* 1.7298	* 1.4894	* 1.7482	* .8987
	* 1.2690	* 1.6070	* 1.2788	* 1.5832	* 1.2298	* 1.4245	* 1.2175	* 2.3421
10	* 1.3486	* 1.6622	* 1.1578	* 1.2918	* 1.3964	* 1.7501	* 1.7539	* .8501
	* 1.5746	* 1.2792	* 1.8310	* 1.6431	* 1.5263	* 1.2214	* 1.2176	* 2.4799
11	* 1.6854	* 1.3381	* 1.2912	* 1.3452	* 1.7192	* 1.4467	* 1.6915	* .7425
	* 1.2603	* 1.5828	* 1.6439	* 1.6007	* 1.2622	* 1.4860	* 1.2666	* 2.8492
12	* 1.4063	* 1.7296	* 1.3962	* 1.7190	* 1.5306	* 1.7682	* 1.0944	*
	* 1.5063	* 1.2300	* 1.5265	* 1.2623	* 1.4242	* 1.2307	* 1.9630	*
13	* 1.7261	* 1.4890	* 1.7498	* 1.4465	* 1.7681	* 1.6612	* .7585	*
	* 1.2306	* 1.4248	* 1.2215	* 1.4862	* 1.2308	* 1.3119	* 2.8342	*
14	* 1.2545	* 1.7479	* 1.7537	* 1.6914	* 1.0940	* .7585	*	*
	* 1.6832	* 1.2177	* 1.2177	* 1.2667	* 1.9638	* 2.8340	*	*
15	* .6983	* .8988	* .8501	* .7424	* F-SUB-Q			
	* 2.9996	* 2.3419	* 2.4801	* 2.8495	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1070	* 1.7114	* 1.3594	* 1.7143	* 1.4175	* 1.7574	* 1.2636	* .7029
	* 1.8722	* 1.2100	* 1.5185	* 1.2055	* 1.4560	* 1.1774	* 1.6316	* 2.9186
9	* 1.7114	* 1.3320	* 1.6922	* 1.3473	* 1.7607	* 1.5045	* 1.7825	* .9020
	* 1.2100	* 1.5505	* 1.2214	* 1.5306	* 1.1761	* 1.3742	* 1.1642	* 2.2827
10	* 1.3594	* 1.6916	* 1.1440	* 1.2954	* 1.4088	* 1.7843	* 1.7887	* .8432
	* 1.5185	* 1.2218	* 1.8020	* 1.5931	* 1.4726	* 1.1663	* 1.1629	* 2.4447
11	* 1.7143	* 1.3477	* 1.2932	* 1.3558	* 1.7510	* 1.4612	* 1.7187	* .7323
	* 1.2055	* 1.5301	* 1.5947	* 1.5419	* 1.2016	* 1.4303	* 1.2135	* 2.8237
12	* 1.4175	* 1.7605	* 1.4086	* 1.7509	* 1.5490	* 1.8024	* 1.0925	*
	* 1.4560	* 1.1763	* 1.4728	* 1.2016	* 1.3615	* 1.1710	* 1.9137	*
13	* 1.7574	* 1.5041	* 1.7841	* 1.4611	* 1.8023	* 1.6898	* .7642	*
	* 1.1774	* 1.3745	* 1.1665	* 1.4305	* 1.1710	* 1.2506	* 2.7397	*
14	* 1.2636	* 1.7822	* 1.7885	* 1.7186	* 1.0920	* .7642	*	*
	* 1.6316	* 1.1644	* 1.1630	* 1.2136	* 1.9145	* 2.7396	*	*
15	* .7029	* .9021	* .8432	* .7322	* F-SUB-Q			
	* 2.9186	* 2.2825	* 2.4449	* 2.8240	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 46 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1017	* 1.7086	* 1.3551	* 1.7097	* 1.4127	* 1.7536	* 1.2587	* .6989 *
	* 1.8164	* 1.1734	* 1.4764	* 1.1718	* 1.4168	* 1.1436	* 1.5886	* 2.8491 *
9	* 1.7086	* 1.3273	* 1.6895	* 1.3423	* 1.7567	* 1.5007	* 1.7812	* .8986 *
	* 1.1734	* 1.5076	* 1.1854	* 1.4899	* 1.1423	* 1.3355	* 1.1286	* 2.2224 *
10	* 1.3551	* 1.6889	* 1.1398	* 1.2922	* 1.4045	* 1.7808	* 1.7872	* .8390 *
	* 1.4764	* 1.1858	* 1.7536	* 1.5484	* 1.4311	* 1.1315	* 1.1269	* 2.3827 *
11	* 1.7097	* 1.3427	* 1.2900	* 1.3518	* 1.7474	* 1.4581	* 1.7175	* .7283 *
	* 1.1718	* 1.4895	* 1.5508	* 1.4944	* 1.1617	* 1.3866	* 1.1752	* 2.7517 *
12	* 1.4127	* 1.7565	* 1.4042	* 1.7472	* 1.5470	* 1.8018	* 1.0886	*
	* 1.4168	* 1.1425	* 1.4313	* 1.1617	* 1.3123	* 1.1293	* 1.8566	*
13	* 1.7536	* 1.5004	* 1.7806	* 1.4580	* 1.8017	* 1.6896	* .7603	*
	* 1.1436	* 1.3358	* 1.1316	* 1.3868	* 1.1293	* 1.2053	* 2.6605	*
14	* 1.2587	* 1.7809	* 1.7870	* 1.7173	* 1.0881	* .7604	*	
	* 1.5886	* 1.1288	* 1.1270	* 1.1753	* 1.8575	* 2.6603	*	
15	* .6989	* .8987	* .8389	* .7282	* F-SUB-Q			
	* 2.8491	* 2.2222	* 2.3829	* 2.7518	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0753	* 1.6575	* 1.3271	* 1.6565	* 1.3826	* 1.6987	* 1.2319	* .6805 *
	* 1.8119	* 1.1777	* 1.4692	* 1.1788	* 1.4112	* 1.1505	* 1.5827	* 2.8548 *
9	* 1.6575	* 1.3003	* 1.6399	* 1.3144	* 1.7023	* 1.4683	* 1.7280	* .8823 *
	* 1.1777	* 1.4995	* 1.1899	* 1.4836	* 1.1486	* 1.3303	* 1.1329	* 2.2068 *
10	* 1.3271	* 1.6394	* 1.1403	* 1.2732	* 1.3743	* 1.7228	* 1.7326	* .8329 *
	* 1.4692	* 1.1903	* 1.7090	* 1.5332	* 1.4245	* 1.1386	* 1.1318	* 2.3401 *
11	* 1.6565	* 1.3147	* 1.2726	* 1.3247	* 1.6928	* 1.4276	* 1.6730	* .7266 *
	* 1.1788	* 1.4832	* 1.5339	* 1.4825	* 1.1645	* 1.3783	* 1.1738	* 2.6878 *
12	* 1.3826	* 1.7021	* 1.3741	* 1.6926	* 1.5138	* 1.7498	* 1.0768	*
	* 1.4112	* 1.1488	* 1.4247	* 1.1646	* 1.3016	* 1.1284	* 1.8250	*
13	* 1.6987	* 1.4679	* 1.7225	* 1.4275	* 1.7497	* 1.6458	* .7420	*
	* 1.1505	* 1.3307	* 1.1388	* 1.3784	* 1.1284	* 1.2005	* 2.6495	*
14	* 1.2319	* 1.7277	* 1.7324	* 1.6728	* 1.0763	* .7420	*	
	* 1.5827	* 1.1331	* 1.1319	* 1.1739	* 1.8258	* 2.6494	*	
15	* .6805	* .8824	* .8328	* .7265	* F-SUB-Q			
	* 2.8548	* 2.2066	* 2.3402	* 2.6874	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 47 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0466	* 1.6151	* 1.2940	* 1.6098	* 1.3471	* 1.6510	* 1.1979	* .6607 *
	* 1.8238	* 1.1837	* 1.4765	* 1.1886	* 1.4198	* 1.1597	* 1.5954	* 2.8841 *
9	* 1.6151	* 1.2683	* 1.5992	* 1.2812	* 1.6555	* 1.4326	* 1.6828	* .8551 *
	* 1.1837	* 1.5063	* 1.1954	* 1.4919	* 1.1570	* 1.3361	* 1.1390	* 2.2323 *
10	* 1.2940	* 1.5987	* 1.0960	* 1.2425	* 1.3428	* 1.6712	* 1.6843	* .7990 *
	* 1.4765	* 1.1957	* 1.7427	* 1.5382	* 1.4280	* 1.1490	* 1.1395	* 2.3908 *
11	* 1.6098	* 1.2815	* 1.2404	* 1.2920	* 1.6460	* 1.3944	* 1.6262	* .6948 *
	* 1.1886	* 1.4915	* 1.5408	* 1.4871	* 1.1707	* 1.3804	* 1.1817	* 2.7531 *
12	* 1.3471	* 1.6552	* 1.3425	* 1.6458	* 1.4790	* 1.7064	* 1.0372	*
	* 1.4198	* 1.1572	* 1.4282	* 1.1708	* 1.3021	* 1.1303	* 1.8532	*
13	* 1.6510	* 1.4323	* 1.6709	* 1.3943	* 1.7063	* 1.6031	* .7206	*
	* 1.1597	* 1.3364	* 1.1491	* 1.3805	* 1.1304	* 1.2039	* 2.6676	*
14	* 1.1979	* 1.6826	* 1.6840	* 1.6260	* 1.0367	* .7206	*	
	* 1.5954	* 1.1392	* 1.1397	* 1.1818	* 1.8541	* 2.6676	*	
15	* .6607	* .8551	* .7989	* .6947	* F-SUB-Q			
	* 2.8841	* 2.2321	* 2.3910	* 2.7533	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9700	* 1.4717	* 1.1958	* 1.4631	* 1.2432	* 1.4987	* 1.1048	* .6082 *
	* 1.9387	* 1.2789	* 1.5739	* 1.2880	* 1.5154	* 1.2581	* 1.7042	* 3.0879 *
9	* 1.4717	* 1.1734	* 1.4577	* 1.1836	* 1.5064	* 1.3256	* 1.5298	* .7875 *
	* 1.2789	* 1.6037	* 1.2914	* 1.5910	* 1.2521	* 1.4220	* 1.2332	* 2.3876 *
10	* 1.1958	* 1.4574	* 1.0247	* 1.1563	* 1.2499	* 1.5132	* 1.5292	* .7377 *
	* 1.5739	* 1.2916	* 1.8362	* 1.6279	* 1.5111	* 1.2487	* 1.2351	* 2.5506 *
11	* 1.4631	* 1.1839	* 1.1544	* 1.1990	* 1.4961	* 1.2936	* 1.4819	* .6423 *
	* 1.2880	* 1.5906	* 1.6307	* 1.5767	* 1.2664	* 1.4634	* 1.2758	* 2.9329 *
12	* 1.2432	* 1.5062	* 1.2497	* 1.4959	* 1.3693	* 1.5555	* .9524	*
	* 1.5154	* 1.2523	* 1.5113	* 1.2665	* 1.3826	* 1.2186	* 1.9854	*
13	* 1.4987	* 1.3253	* 1.5130	* 1.2934	* 1.5554	* 1.4626	* .6653	*
	* 1.2581	* 1.4224	* 1.2489	* 1.4636	* 1.2187	* 1.2965	* 2.8425	*
14	* 1.1048	* 1.5296	* 1.5290	* 1.4818	* .9519	* .6653	*	
	* 1.7042	* 1.2334	* 1.2353	* 1.2759	* 1.9863	* 2.8424	*	
15	* .6082	* .7875	* .7376	* .6422	* F-SUB-Q			
	* 3.0879	* 2.3875	* 2.5510	* 2.9333	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 48 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 250 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8186	* 1.2195	* .9462	* 1.2230	* .9825	* 1.2522	* .8789	* .5024
	* 2.2730	* 1.5265	* 1.9672	* 1.5236	* 1.8968	* 1.4888	* 2.1193	* 3.7010
9	* 1.2195	* .9310	* 1.2065	* .9373	* 1.2590	* 1.0691	* 1.2587	* .6431
	* 1.5265	* 1.9991	* 1.5434	* 1.9873	* 1.4812	* 1.7434	* 1.4815	* 2.8931
10	* .9462	* 1.2066	* .8762	* .9624	* 1.0429	* 1.2737	* 1.2572	* .6119
	* 1.9672	* 1.5433	* 2.1246	* 1.9364	* 1.7905	* 1.4659	* 1.4846	* 3.0431
11	* 1.2230	* .9374	* .9618	* .9686	* 1.2641	* 1.0489	* 1.1874	* .5283
	* 1.5236	* 1.9870	* 1.9375	* 1.9294	* 1.4805	* 1.7834	* 1.5738	* 3.5273
12	* .9825	* 1.2588	* 1.0427	* 1.2641	* 1.1331	* 1.2838	* .7752	*
	* 1.8968	* 1.4814	* 1.7908	* 1.4806	* 1.6513	* 1.4583	* 2.4108	*
13	* 1.2522	* 1.0689	* 1.2736	* 1.0488	* 1.2837	* 1.1743	* .5493	*
	* 1.4888	* 1.7439	* 1.4661	* 1.7835	* 1.4584	* 1.5951	* 3.4030	*
14	* .8789	* 1.2585	* 1.2570	* 1.1872	* .7749	* .5493	*	*
	* 2.1193	* 1.4818	* 1.4848	* 1.5739	* 2.4117	* 3.4032	*	*
15	* .5024	* .6431	* .6118	* .5282	* F-SUB-Q			
	* 3.7010	* 2.8931	* 3.0437	* 3.5278	* M-SUB-Q			

AT 100% POWER, 250 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5810	* .5241	* .4456	* .5308	* .4631	* .5424	* .4247	* .3522
	* 3.1796	* 3.5260	* 4.1479	* 3.4849	* 3.9959	* 3.4120	* 4.3554	* 5.2473
9	* .5241	* .4420	* .5188	* .4486	* .5463	* .4816	* .5080	* .3138
	* 3.5260	* 4.1821	* 3.5636	* 4.1239	* 3.3887	* 3.8429	* 3.6442	* 5.8947
10	* .4456	* .5190	* .4495	* .4421	* .4741	* .5505	* .5228	* .3046
	* 4.1479	* 3.5622	* 4.1120	* 4.1876	* 3.9108	* 3.3659	* 3.5429	* 6.0730
11	* .5308	* .4487	* .4419	* .4680	* .5484	* .4767	* .4837	* .2672
	* 3.4849	* 4.1228	* 4.1891	* 3.9658	* 3.3856	* 3.8909	* 3.8340	* 6.9321
12	* .4631	* .5462	* .4740	* .5484	* .5066	* .5227	* .3702	*
	* 3.9959	* 3.3891	* 3.9114	* 3.3858	* 3.6653	* 3.5538	* 5.0127	*
13	* .5424	* .4815	* .5504	* .4766	* .5227	* .4799	* .3874	*
	* 3.4120	* 3.8435	* 3.3664	* 3.8914	* 3.5540	* 3.8724	* 4.7918	*
14	* .4247	* .5079	* .5228	* .4836	* .3703	* .3874	*	*
	* 4.3555	* 3.6449	* 3.5434	* 3.8344	* 5.0113	* 4.7925	*	*
15	* .3522	* .3138	* .3046	* .2671	* F-SUB-Q			
	* 5.2473	* 5.8955	* 6.0741	* 6.9332	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 49 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6427 *	* .5891 *	* .5303 *	* .6052 *	* .5453 *	* .6040 *	* .4943 *	* .4573 *
	* 2.8290 *	* 3.3251 *	* 3.6961 *	* 3.1827 *	* 3.5073 *	* 3.1560 *	* 3.8392 *	* 4.0990 *
9	* .5891 *	* .5315 *	* .5942 *	* .5326 *	* .6086 *	* .5515 *	* .5575 *	* .3858 *
	* 3.3251 *	* 3.7245 *	* 3.3049 *	* 3.6264 *	* 3.1563 *	* 3.4696 *	* 3.4471 *	* 4.9247 *
10	* .5303 *	* .5943 *	* .5320 *	* .5279 *	* .5453 *	* .6009 *	* .5634 *	* .3690 *
	* 3.6961 *	* 3.3043 *	* 3.7196 *	* 3.7396 *	* 3.6259 *	* 3.2785 *	* 3.4654 *	* 5.1769 *
11	* .6052 *	* .5326 *	* .5277 *	* .5078 *	* .5875 *	* .5333 *	* .5284 *	* .3304 *
	* 3.1827 *	* 3.6261 *	* 3.7411 *	* 3.7485 *	* 3.2468 *	* 3.6450 *	* 3.7794 *	* 5.9619 *
12	* .5453 *	* .6086 *	* .5453 *	* .5875 *	* .5000 *	* .5316 *	* .4181 *	
	* 3.5073 *	* 3.1562 *	* 3.6259 *	* 3.2468 *	* 3.3546 *	* 3.3916 *	* 4.6182 *	
13	* .6040 *	* .5515 *	* .6009 *	* .5333 *	* .5316 *	* .4886 *	* .4664 *	
	* 3.1560 *	* 3.4694 *	* 3.2783 *	* 3.6450 *	* 3.3916 *	* 3.6592 *	* 4.0483 *	
14	* .4943 *	* .5578 *	* .5635 *	* .5284 *	* .4182 *	* .4662 *		
	* 3.8392 *	* 3.4456 *	* 3.4647 *	* 3.7792 *	* 4.6163 *	* 4.0496 *		
15	* .4573 *	* .3860 *	* .3691 *	* .3305 *	F-SUB-Q			
	* 4.0990 *	* 4.9212 *	* 5.1749 *	* 5.9612 *	M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8311 *	* 1.1768 *	* 1.0408 *	* 1.1962 *	* 1.0706 *	* 1.1976 *	* .9706 *	* .5901 *
	* 2.1895 *	* 1.6964 *	* 1.9184 *	* 1.6405 *	* 1.8167 *	* 1.6208 *	* 1.9840 *	* 3.2283 *
9	* 1.1768 *	* 1.0404 *	* 1.1824 *	* 1.0447 *	* 1.2051 *	* 1.0991 *	* 1.1801 *	* .7196 *
	* 1.6964 *	* 1.9371 *	* 1.6962 *	* 1.8823 *	* 1.6258 *	* 1.7722 *	* 1.6573 *	* 2.6771 *
10	* 1.0408 *	* 1.1827 *	* .9576 *	* 1.0237 *	* 1.0657 *	* 1.1966 *	* 1.1644 *	* .6796 *
	* 1.9184 *	* 1.6962 *	* 2.0964 *	* 1.9638 *	* 1.8888 *	* 1.6759 *	* 1.7047 *	* 2.8602 *
11	* 1.1962 *	* 1.0448 *	* 1.0232 *	* .9976 *	* 1.1780 *	* 1.0719 *	* 1.1216 *	* .6068 *
	* 1.6405 *	* 1.8821 *	* 1.9648 *	* 1.9607 *	* 1.6541 *	* 1.8447 *	* 1.7932 *	* 3.3009 *
12	* 1.0706 *	* 1.2051 *	* 1.0656 *	* 1.1779 *	* 1.0517 *	* 1.1651 *	* .7985 *	
	* 1.8167 *	* 1.6258 *	* 1.8888 *	* 1.6542 *	* 1.7610 *	* 1.6320 *	* 2.4479 *	
13	* 1.1976 *	* 1.0991 *	* 1.1966 *	* 1.0719 *	* 1.1651 *	* 1.0770 *	* .5969 *	
	* 1.6208 *	* 1.7722 *	* 1.6758 *	* 1.8447 *	* 1.6320 *	* 1.7599 *	* 3.2249 *	
14	* .9706 *	* 1.1804 *	* 1.1646 *	* 1.1216 *	* .7985 *	* .5969 *		
	* 1.9840 *	* 1.6568 *	* 1.7045 *	* 1.7932 *	* 2.4480 *	* 3.2251 *		
15	* .5901 *	* .7200 *	* .6798 *	* .6069 *	F-SUB-Q			
	* 3.2284 *	* 2.6758 *	* 2.8593 *	* 3.3006 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 50 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0279	* 1.3793	* 1.1983	* 1.3896	* 1.2370	* 1.3967	* 1.1238	* .6828 *
	* 1.9591	* 1.4771	* 1.6866	* 1.4260	* 1.5884	* 1.4036	* 1.7309	* 2.8171 *
9	* 1.3793	* 1.1960	* 1.3784	* 1.2013	* 1.4034	* 1.2778	* 1.3924	* .8348 *
	* 1.4771	* 1.7126	* 1.4739	* 1.6550	* 1.4100	* 1.5396	* 1.4184	* 2.3345 *
10	* 1.1983	* 1.3784	* 1.0818	* 1.1725	* 1.2260	* 1.3905	* 1.3775	* .7974 *
	* 1.6866	* 1.4742	* 1.8793	* 1.7301	* 1.6604	* 1.4578	* 1.4556	* 2.4630 *
11	* 1.3896	* 1.2014	* 1.1711	* 1.1644	* 1.3721	* 1.2472	* 1.3490	* .7111 *
	* 1.4260	* 1.6548	* 1.7322	* 1.7192	* 1.4451	* 1.6057	* 1.5073	* 2.8471 *
12	* 1.2370	* 1.4034	* 1.2259	* 1.3721	* 1.2790	* 1.3986	* .9574 *	
	* 1.5884	* 1.4100	* 1.6605	* 1.4451	* 1.5410	* 1.4056	* 2.0805 *	
13	* 1.3967	* 1.2777	* 1.3905	* 1.2471	* 1.3986	* 1.3124	* .6949 *	
	* 1.4036	* 1.5397	* 1.4578	* 1.6057	* 1.4056	* 1.4874	* 2.8205 *	
14	* 1.1238	* 1.3927	* 1.3776	* 1.3490	* .9573	* .6949 *		
	* 1.7309	* 1.4181	* 1.4555	* 1.5072	* 2.0808	* 2.8204 *		
15	* .6828	* .8351	* .7976	* .7111	* F-SUB-Q			
	* 2.8171	* 2.3337	* 2.4625	* 2.8470	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1070	* 1.5247	* 1.2817	* 1.5373	* 1.3290	* 1.5509	* 1.2044	* .7296 *
	* 1.8634	* 1.3579	* 1.5932	* 1.3004	* 1.4910	* 1.2739	* 1.6287	* 2.6634 *
9	* 1.5247	* 1.2771	* 1.5187	* 1.2845	* 1.5576	* 1.3807	* 1.5496	* .8917 *
	* 1.3579	* 1.6280	* 1.3502	* 1.5622	* 1.2811	* 1.4367	* 1.2842	* 2.2018 *
10	* 1.2817	* 1.5187	* 1.1386	* 1.2512	* 1.3198	* 1.5528	* 1.5393	* .8406 *
	* 1.5932	* 1.3506	* 1.8045	* 1.6377	* 1.5572	* 1.3126	* 1.3120	* 2.3568 *
11	* 1.5373	* 1.2847	* 1.2497	* 1.2558	* 1.5392	* 1.3493	* 1.4947	* .7442 *
	* 1.3004	* 1.5619	* 1.6396	* 1.6204	* 1.3107	* 1.5058	* 1.3748	* 2.7439 *
12	* 1.3290	* 1.5575	* 1.3197	* 1.5391	* 1.3974	* 1.5637	* 1.0277 *	
	* 1.4910	* 1.2811	* 1.5573	* 1.3108	* 1.4384	* 1.2803	* 1.9664 *	
13	* 1.5509	* 1.3806	* 1.5527	* 1.3493	* 1.5637	* 1.4627	* .7486 *	
	* 1.2739	* 1.4368	* 1.3126	* 1.5059	* 1.2803	* 1.3605	* 2.6624 *	
14	* 1.2044	* 1.5498	* 1.5394	* 1.4947	* 1.0274	* .7486 *		
	* 1.6287	* 1.2840	* 1.3119	* 1.3748	* 1.9669	* 2.6623 *		
15	* .7296	* .8920	* .8407	* .7442	* F-SUB-Q			
	* 2.6634	* 2.2012	* 2.3564	* 2.7438	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 51 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1206	* 1.5692	* 1.3026	* 1.5855	* 1.3545	* 1.6044	* 1.2265	* .7382
	* 1.8748	* 1.3401	* 1.5859	* 1.2749	* 1.4783	* 1.2430	* 1.6159	* 2.6636
9	* 1.5692	* 1.2951	* 1.5603	* 1.3052	* 1.6106	* 1.4120	* 1.6057	* .9056
	* 1.3401	* 1.6301	* 1.3292	* 1.5545	* 1.2515	* 1.4192	* 1.2506	* 2.1909
10	* 1.3026	* 1.5603	* 1.1478	* 1.2658	* 1.3468	* 1.6138	* 1.6003	* .8577
	* 1.5859	* 1.3296	* 1.8111	* 1.6374	* 1.5422	* 1.2711	* 1.2730	* 2.3329
11	* 1.5855	* 1.3054	* 1.2648	* 1.2853	* 1.6016	* 1.3811	* 1.5488	* .7568
	* 1.2749	* 1.5542	* 1.6393	* 1.6081	* 1.2794	* 1.4934	* 1.3438	* 2.7233
12	* 1.3545	* 1.6105	* 1.3467	* 1.6016	* 1.4360	* 1.6223	* 1.0552	*
	* 1.4783	* 1.2516	* 1.5423	* 1.2794	* 1.4235	* 1.2540	* 1.9446	*
13	* 1.6044	* 1.4118	* 1.6137	* 1.3811	* 1.6223	* 1.5172	* .7628	*
	* 1.2430	* 1.4194	* 1.2711	* 1.4934	* 1.2540	* 1.3340	* 2.6579	*
14	* 1.2265	* 1.6058	* 1.6003	* 1.5488	* 1.0550	* .7628	*	*
	* 1.6159	* 1.2505	* 1.2730	* 1.3438	* 1.9451	* 2.6578	*	*
15	* .7382	* .9058	* .8578	* .7568	* F-SUB-Q			
	* 2.6636	* 2.1905	* 2.3327	* 2.7233	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1170	* 1.5733	* 1.2992	* 1.5920	* 1.3541	* 1.6152	* 1.2260	* .7374
	* 1.9059	* 1.3527	* 1.6102	* 1.2858	* 1.4977	* 1.2498	* 1.6369	* 2.7012
9	* 1.5733	* 1.2897	* 1.5631	* 1.3019	* 1.6205	* 1.4142	* 1.6182	* .9055
	* 1.3527	* 1.6551	* 1.3432	* 1.5784	* 1.2581	* 1.4344	* 1.2546	* 2.2196
10	* 1.2992	* 1.5630	* 1.1443	* 1.2594	* 1.3474	* 1.6294	* 1.6158	* .8615
	* 1.6102	* 1.3437	* 1.8455	* 1.6614	* 1.5588	* 1.2709	* 1.2734	* 2.3496
11	* 1.5920	* 1.3022	* 1.2586	* 1.2896	* 1.6160	* 1.3841	* 1.5623	* .7602
	* 1.2858	* 1.5782	* 1.6620	* 1.6250	* 1.2873	* 1.5118	* 1.3446	* 2.7370
12	* 1.3541	* 1.6204	* 1.3474	* 1.6160	* 1.4420	* 1.6355	* 1.0636	*
	* 1.4977	* 1.2581	* 1.5589	* 1.2873	* 1.4402	* 1.2651	* 1.9579	*
13	* 1.6152	* 1.4140	* 1.6294	* 1.3841	* 1.6354	* 1.5306	* .7644	*
	* 1.2498	* 1.4346	* 1.2709	* 1.5119	* 1.2652	* 1.3476	* 2.7029	*
14	* 1.2260	* 1.6182	* 1.6158	* 1.5622	* 1.0633	* .7644	*	*
	* 1.6369	* 1.2546	* 1.2734	* 1.3446	* 1.9584	* 2.7027	*	*
15	* .7374	* .9057	* .8615	* .7602	* F-SUB-Q			
	* 2.7012	* 2.2193	* 2.3494	* 2.7370	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 52 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1117	* 1.5818	* 1.2959	* 1.6024	* 1.3527	* 1.6293	* 1.2246	* .7343
	* 1.9322	* 1.3517	* 1.6376	* 1.2973	* 1.5233	* 1.2588	* 1.6652	* 2.7565
9	* 1.5818	* 1.2846	* 1.5709	* 1.2986	* 1.6338	* 1.4157	* 1.6334	* .9048
	* 1.3517	* 1.6663	* 1.3554	* 1.6072	* 1.2660	* 1.4552	* 1.2601	* 2.2545
10	* 1.2959	* 1.5706	* 1.1339	* 1.2551	* 1.3475	* 1.6476	* 1.6328	* .8564
	* 1.6376	* 1.3559	* 1.8812	* 1.6922	* 1.5701	* 1.2722	* 1.2754	* 2.3969
11	* 1.6024	* 1.2988	* 1.2543	* 1.2910	* 1.6316	* 1.3861	* 1.5735	* .7536
	* 1.2973	* 1.6069	* 1.6932	* 1.6455	* 1.2929	* 1.5265	* 1.3387	* 2.7838
12	* 1.3527	* 1.6337	* 1.3475	* 1.6316	* 1.4465	* 1.6506	* 1.0605	*
	* 1.5233	* 1.2661	* 1.5702	* 1.2930	* 1.4563	* 1.2708	* 1.9912	*
13	* 1.6293	* 1.4155	* 1.6476	* 1.3861	* 1.6506	* 1.5423	* .7659	*
	* 1.2588	* 1.4554	* 1.2723	* 1.5266	* 1.2708	* 1.3558	* 2.7365	*
14	* 1.2246	* 1.6334	* 1.6328	* 1.5734	* 1.0602	* .7660	*	*
	* 1.6652	* 1.2601	* 1.2754	* 1.3387	* 1.9917	* 2.7363	*	*
15	* .7343	* .9049	* .8564	* .7535	* F-SUB-Q			
	* 2.7565	* 2.2542	* 2.3967	* 2.7839	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0953	* 1.5769	* 1.2868	* 1.5991	* 1.3446	* 1.6288	* 1.2171	* .7238
	* 1.9743	* 1.3692	* 1.6697	* 1.3244	* 1.5626	* 1.2841	* 1.7083	* 2.8511
9	* 1.5769	* 1.2741	* 1.5657	* 1.2894	* 1.6329	* 1.4089	* 1.6333	* .8955
	* 1.3692	* 1.6987	* 1.3746	* 1.6484	* 1.2900	* 1.4897	* 1.2815	* 2.3187
10	* 1.2868	* 1.5655	* 1.1209	* 1.2449	* 1.3405	* 1.6497	* 1.6341	* .8489
	* 1.6697	* 1.3751	* 1.9235	* 1.7238	* 1.5965	* 1.2842	* 1.2913	* 2.4587
11	* 1.5991	* 1.2896	* 1.2442	* 1.2857	* 1.6318	* 1.3800	* 1.5720	* .7450
	* 1.3244	* 1.6481	* 1.7248	* 1.6631	* 1.3029	* 1.5460	* 1.3543	* 2.8401
12	* 1.3446	* 1.6328	* 1.3404	* 1.6318	* 1.4417	* 1.6503	* 1.0555	*
	* 1.5626	* 1.2901	* 1.5966	* 1.3029	* 1.4737	* 1.2838	* 2.0128	*
13	* 1.6288	* 1.4087	* 1.6497	* 1.3799	* 1.6502	* 1.5413	* .7587	*
	* 1.2841	* 1.4899	* 1.2842	* 1.5460	* 1.2838	* 1.3734	* 2.7906	*
14	* 1.2171	* 1.6333	* 1.6341	* 1.5720	* 1.0552	* .7587	*	*
	* 1.7083	* 1.2815	* 1.2913	* 1.3544	* 2.0134	* 2.7904	*	*
15	* .7238	* .8956	* .8489	* .7450	* F-SUB-Q			
	* 2.8511	* 2.3184	* 2.4587	* 2.8401	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 53 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0889	* 1.5773	* 1.2805	* 1.6004	* 1.3388	* 1.6323	* 1.2114	* .7203
	* 2.0300	* 1.3981	* 1.7078	* 1.3535	* 1.6072	* 1.3123	* 1.7577	* 2.9328
9	* 1.5773	* 1.2665	* 1.5659	* 1.2827	* 1.6361	* 1.4044	* 1.6366	* .8904
	* 1.3981	* 1.7429	* 1.3976	* 1.6941	* 1.3167	* 1.5292	* 1.3060	* 2.3835
10	* 1.2805	* 1.5656	* 1.1118	* 1.2384	* 1.3356	* 1.6546	* 1.6381	* .8402
	* 1.7078	* 1.3979	* 1.9702	* 1.7611	* 1.6274	* 1.3015	* 1.3102	* 2.5362
11	* 1.6004	* 1.2830	* 1.2376	* 1.2817	* 1.6353	* 1.3755	* 1.5722	* .7373
	* 1.3535	* 1.6937	* 1.7622	* 1.7016	* 1.3254	* 1.5815	* 1.3774	* 2.9116
12	* 1.3388	* 1.6360	* 1.3355	* 1.6352	* 1.4390	* 1.6532	* 1.0489	*
	* 1.6072	* 1.3167	* 1.6275	* 1.3254	* 1.5067	* 1.3053	* 2.0627	*
13	* 1.6323	* 1.4043	* 1.6546	* 1.3754	* 1.6531	* 1.5418	* .7563	*
	* 1.3123	* 1.5294	* 1.3016	* 1.5816	* 1.3053	* 1.3976	* 2.8472	*
14	* 1.2114	* 1.6365	* 1.6381	* 1.5722	* 1.0486	* .7563	*	*
	* 1.7577	* 1.3060	* 1.3102	* 1.3774	* 2.0633	* 2.8470	*	*
15	* .7203	* .8905	* .8402	* .7372	* F-SUB-Q			
	* 2.9328	* 2.3832	* 2.5361	* 2.9117	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0683	* 1.5504	* 1.2637	* 1.5742	* 1.3211	* 1.6069	* 1.1961	* .7078
	* 2.1206	* 1.4520	* 1.7753	* 1.4148	* 1.6767	* 1.3722	* 1.8324	* 3.0710
9	* 1.5504	* 1.2487	* 1.5391	* 1.2653	* 1.6105	* 1.3866	* 1.6116	* .8827
	* 1.4520	* 1.8049	* 1.4563	* 1.7644	* 1.3753	* 1.5933	* 1.3616	* 2.4702
10	* 1.2637	* 1.5388	* 1.1111	* 1.2278	* 1.3175	* 1.6307	* 1.6138	* .8413
	* 1.7753	* 1.4566	* 2.0234	* 1.8196	* 1.6894	* 1.3526	* 1.3625	* 2.5990
11	* 1.5742	* 1.2656	* 1.2274	* 1.2677	* 1.6105	* 1.3574	* 1.5539	* .7407
	* 1.4148	* 1.7640	* 1.8202	* 1.7674	* 1.3846	* 1.6403	* 1.4224	* 2.9629
12	* 1.3211	* 1.6104	* 1.3174	* 1.6105	* 1.4208	* 1.6276	* 1.0474	*
	* 1.6767	* 1.3753	* 1.6895	* 1.3847	* 1.5710	* 1.3636	* 2.1194	*
13	* 1.6069	* 1.3864	* 1.6307	* 1.3574	* 1.6276	* 1.5218	* .7452	*
	* 1.3722	* 1.5935	* 1.3526	* 1.6403	* 1.3636	* 1.4559	* 2.9686	*
14	* 1.1961	* 1.6116	* 1.6138	* 1.5539	* 1.0471	* .7453	*	*
	* 1.8324	* 1.3616	* 1.3625	* 1.4224	* 2.1200	* 2.9684	*	*
15	* .7078	* .8828	* .8413	* .7406	* F-SUB-Q			
	* 3.0710	* 2.4699	* 2.5990	* 2.9629	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 54 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0701	* 1.5684	* 1.2667	* 1.5929	* 1.3243	* 1.6275	* 1.1981	* .7081
	* 2.1790	* 1.4776	* 1.8227	* 1.4459	* 1.7312	* 1.4022	* 1.8931	* 3.1745
9	* 1.5684	* 1.2503	* 1.5568	* 1.2676	* 1.6302	* 1.3926	* 1.6323	* .8795
	* 1.4776	* 1.8509	* 1.4844	* 1.8196	* 1.4050	* 1.6410	* 1.3882	* 2.5604
10	* 1.2667	* 1.5565	* 1.0965	* 1.2229	* 1.3223	* 1.6530	* 1.6353	* .8312
	* 1.8227	* 1.4847	* 2.1072	* 1.8861	* 1.7359	* 1.3770	* 1.3875	* 2.7145
11	* 1.5929	* 1.2679	* 1.2221	* 1.2713	* 1.6308	* 1.3631	* 1.5659	* .7273
	* 1.4459	* 1.8192	* 1.8872	* 1.8108	* 1.4046	* 1.6799	* 1.4536	* 3.1080
12	* 1.3243	* 1.6302	* 1.3222	* 1.6308	* 1.4289	* 1.6474	* 1.0403	*
	* 1.7312	* 1.4050	* 1.7360	* 1.4046	* 1.6062	* 1.3852	* 2.1892	*
13	* 1.6275	* 1.3924	* 1.6530	* 1.3630	* 1.6473	* 1.5355	* .7475	*
	* 1.4022	* 1.6412	* 1.3770	* 1.6800	* 1.3852	* 1.4856	* 3.0384	*
14	* 1.1981	* 1.6322	* 1.6352	* 1.5659	* 1.0400	* .7476	*	*
	* 1.8931	* 1.3882	* 1.3875	* 1.4536	* 2.1899	* 3.0382	*	*
15	* .7081	* .8796	* .8312	* .7273	* F-SUB-Q			
	* 3.1745	* 2.5601	* 2.7145	* 3.1081	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0626	* 1.5677	* 1.2631	* 1.5922	* 1.3201	* 1.6278	* 1.1942	* .7032
	* 2.1652	* 1.4611	* 1.8042	* 1.4304	* 1.7222	* 1.3989	* 1.9003	* 3.2140
9	* 1.5677	* 1.2455	* 1.5557	* 1.2629	* 1.6303	* 1.3896	* 1.6333	* .8761
	* 1.4611	* 1.8342	* 1.4673	* 1.8015	* 1.3990	* 1.6387	* 1.3994	* 2.5913
10	* 1.2631	* 1.5554	* 1.0930	* 1.2183	* 1.3185	* 1.6552	* 1.6370	* .8289
	* 1.8042	* 1.4676	* 2.0860	* 1.8716	* 1.7413	* 1.3875	* 1.4016	* 2.7449
11	* 1.5922	* 1.2632	* 1.2173	* 1.2689	* 1.6316	* 1.3598	* 1.5660	* .7243
	* 1.4304	* 1.8011	* 1.8736	* 1.8339	* 1.4336	* 1.7065	* 1.4745	* 3.1610
12	* 1.3201	* 1.6302	* 1.3184	* 1.6315	* 1.4267	* 1.6474	* 1.0384	*
	* 1.7222	* 1.3990	* 1.7414	* 1.4336	* 1.6480	* 1.4242	* 2.2414	*
13	* 1.6278	* 1.3894	* 1.6552	* 1.3598	* 1.6474	* 1.5354	* .7436	*
	* 1.3989	* 1.6389	* 1.3876	* 1.7066	* 1.4242	* 1.5322	* 3.1444	*
14	* 1.1942	* 1.6332	* 1.6370	* 1.5660	* 1.0381	* .7436	*	*
	* 1.9003	* 1.3995	* 1.4017	* 1.4745	* 2.2422	* 3.1442	*	*
15	* .7032	* .8762	* .8289	* .7243	* F-SUB-Q			
	* 3.2140	* 2.5910	* 2.7449	* 3.1611	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 55 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0532	* 1.5533	* 1.2544	* 1.5774	* 1.3105	* 1.6138	* 1.1864	* .6979 *
	* 2.1563	* 1.4565	* 1.7931	* 1.4244	* 1.7105	* 1.3916	* 1.8850	* 3.1880 *
9	* 1.5533	* 1.2361	* 1.5409	* 1.2537	* 1.6161	* 1.3801	* 1.6201	* .8729 *
	* 1.4565	* 1.8243	* 1.4626	* 1.7898	* 1.3922	* 1.6270	* 1.3913	* 2.5621 *
10	* 1.2544	* 1.5406	* 1.0970	* 1.2161	* 1.3086	* 1.6427	* 1.6244	* .8316 *
	* 1.7931	* 1.4629	* 2.0512	* 1.8529	* 1.7315	* 1.3797	* 1.3935	* 2.6953 *
11	* 1.5774	* 1.2539	* 1.2157	* 1.2618	* 1.6176	* 1.3503	* 1.5579	* .7297 *
	* 1.4244	* 1.7895	* 1.8538	* 1.8211	* 1.4292	* 1.6966	* 1.4629	* 3.0927 *
12	* 1.3105	* 1.6161	* 1.3085	* 1.6176	* 1.4170	* 1.6333	* 1.0407	*
	* 1.7105	* 1.3922	* 1.7316	* 1.4292	* 1.6394	* 1.4207	* 2.2074	*
13	* 1.6138	* 1.3800	* 1.6427	* 1.3502	* 1.6333	* 1.5255	* .7380	*
	* 1.3916	* 1.6272	* 1.3798	* 1.6967	* 1.4207	* 1.5254	* 3.1267	*
14	* 1.1864	* 1.6201	* 1.6244	* 1.5579	* 1.0404	* .7380	*	
	* 1.8850	* 1.3914	* 1.3935	* 1.4630	* 2.2081	* 3.1264	*	
15	* .6979	* .8730	* .8316	* .7297	F-SUB-Q			
	* 3.1880	* 2.5618	* 2.6953	* 3.0928	M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0594	* 1.5782	* 1.2631	* 1.6020	* 1.3191	* 1.6395	* 1.1937	* .7011 *
	* 2.1284	* 1.4228	* 1.7689	* 1.3921	* 1.6861	* 1.3585	* 1.8579	* 3.1466 *
9	* 1.5782	* 1.2434	* 1.5651	* 1.2606	* 1.6416	* 1.3915	* 1.6478	* .8776 *
	* 1.4228	* 1.8004	* 1.4293	* 1.7667	* 1.3593	* 1.6003	* 1.3553	* 2.5253 *
10	* 1.2631	* 1.5648	* 1.0900	* 1.2159	* 1.3183	* 1.6720	* 1.6536	* .8274 *
	* 1.7689	* 1.4296	* 2.0493	* 1.8358	* 1.7033	* 1.3425	* 1.3555	* 2.6838 *
11	* 1.6020	* 1.2610	* 1.2146	* 1.2702	* 1.6439	* 1.3611	* 1.5774	* .7224 *
	* 1.3921	* 1.7662	* 1.8376	* 1.7905	* 1.3926	* 1.6654	* 1.4295	* 3.0913 *
12	* 1.3191	* 1.6415	* 1.3183	* 1.6439	* 1.4305	* 1.6596	* 1.0386	*
	* 1.6861	* 1.3594	* 1.7034	* 1.3926	* 1.6080	* 1.3843	* 2.1875	*
13	* 1.6395	* 1.3913	* 1.6720	* 1.3610	* 1.6596	* 1.5462	* .7444	*
	* 1.3585	* 1.6005	* 1.3425	* 1.6654	* 1.3843	* 1.4899	* 3.0641	*
14	* 1.1937	* 1.6477	* 1.6537	* 1.5774	* 1.0382	* .7445	*	
	* 1.8579	* 1.3554	* 1.3555	* 1.4295	* 2.1882	* 3.0638	*	
15	* .7011	* .8777	* .8274	* .7224	F-SUB-Q			
	* 3.1466	* 2.5250	* 2.6838	* 3.0913	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 56 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0590	* 1.5925	* 1.2690	* 1.6159	* 1.3248	* 1.6544	* 1.1989	* .7001
	* 2.0775	* 1.3792	* 1.7195	* 1.3518	* 1.6435	* 1.3209	* 1.8108	* 3.0742
9	* 1.5925	* 1.2483	* 1.5786	* 1.2654	* 1.6562	* 1.3990	* 1.6642	* .8800
	* 1.3792	* 1.7502	* 1.3858	* 1.7198	* 1.3215	* 1.5599	* 1.3180	* 2.4611
10	* 1.2690	* 1.5783	* 1.0885	* 1.2194	* 1.3243	* 1.6896	* 1.6712	* .8272
	* 1.7195	* 1.3860	* 1.9982	* 1.7851	* 1.6606	* 1.3054	* 1.3178	* 2.6235
11	* 1.6159	* 1.2658	* 1.2182	* 1.2763	* 1.6589	* 1.3681	* 1.5914	* .7216
	* 1.3518	* 1.7193	* 1.7866	* 1.7440	* 1.3549	* 1.6239	* 1.3902	* 3.0218
12	* 1.3248	* 1.6562	* 1.3243	* 1.6589	* 1.4392	* 1.6748	* 1.0417	*
	* 1.6435	* 1.3215	* 1.6607	* 1.3549	* 1.5696	* 1.3478	* 2.1339	*
13	* 1.6544	* 1.3989	* 1.6896	* 1.3681	* 1.6748	* 1.5598	* .7457	*
	* 1.3209	* 1.5601	* 1.3054	* 1.6240	* 1.3478	* 1.4501	* 2.9867	*
14	* 1.1989	* 1.6642	* 1.6713	* 1.5914	* 1.0414	* .7458	*	*
	* 1.8108	* 1.3181	* 1.3178	* 1.3902	* 2.1346	* 2.9864	*	*
15	* .7001	* .8802	* .8272	* .7216	* F-SUB-Q			
	* 3.0742	* 2.4608	* 2.6235	* 3.0219	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0639	* 1.6039	* 1.2758	* 1.6270	* 1.3310	* 1.6662	* 1.2046	* .7030
	* 2.0261	* 1.3409	* 1.6755	* 1.3141	* 1.6008	* 1.2829	* 1.7627	* 2.9938
9	* 1.6039	* 1.2542	* 1.5894	* 1.2711	* 1.6678	* 1.4067	* 1.6768	* .8845
	* 1.3409	* 1.7063	* 1.3476	* 1.6763	* 1.2836	* 1.5175	* 1.2782	* 2.3933
10	* 1.2758	* 1.5891	* 1.0984	* 1.2269	* 1.3303	* 1.7028	* 1.6842	* .8343
	* 1.6755	* 1.3478	* 1.9427	* 1.7370	* 1.6162	* 1.2652	* 1.2772	* 2.5420
11	* 1.6270	* 1.2715	* 1.2258	* 1.2831	* 1.6704	* 1.3749	* 1.6033	* .7264
	* 1.3141	* 1.6758	* 1.7385	* 1.6943	* 1.3132	* 1.5776	* 1.3471	* 2.9312
12	* 1.3310	* 1.6678	* 1.3303	* 1.6704	* 1.4475	* 1.6864	* 1.0494	*
	* 1.6008	* 1.2836	* 1.6163	* 1.3132	* 1.5228	* 1.3049	* 2.0659	*
13	* 1.6662	* 1.4065	* 1.7028	* 1.3749	* 1.6864	* 1.5710	* .7488	*
	* 1.2829	* 1.5177	* 1.2651	* 1.5776	* 1.3049	* 1.4029	* 2.8983	*
14	* 1.2046	* 1.6768	* 1.6843	* 1.6034	* 1.0490	* .7489	*	*
	* 1.7627	* 1.2783	* 1.2771	* 1.3470	* 2.0667	* 2.8980	*	*
15	* .7030	* .8847	* .8343	* .7264	* F-SUB-Q			
	* 2.9938	* 2.3929	* 2.5420	* 2.9313	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 57 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0674	* 1.6075	* 1.2813	* 1.6302	* 1.3361	* 1.6699	* 1.2095	* .7047 *
	* 1.9878	* 1.3166	* 1.6428	* 1.2907	* 1.5692	* 1.2587	* 1.7263	* 2.9363 *
9	* 1.6075	* 1.2591	* 1.5925	* 1.2767	* 1.6715	* 1.4123	* 1.6812	* .8922 *
	* 1.3166	* 1.6735	* 1.3239	* 1.6432	* 1.2595	* 1.4865	* 1.2521	* 2.3311 *
10	* 1.2813	* 1.5922	* 1.1160	* 1.2367	* 1.3344	* 1.7079	* 1.6892	* .8463 *
	* 1.6428	* 1.3241	* 1.8829	* 1.6964	* 1.5837	* 1.2385	* 1.2501	* 2.4617 *
11	* 1.6302	* 1.2770	* 1.2358	* 1.2889	* 1.6741	* 1.3798	* 1.6120	* .7405 *
	* 1.2907	* 1.6428	* 1.6981	* 1.6545	* 1.2836	* 1.5419	* 1.3144	* 2.8223 *
12	* 1.3361	* 1.6715	* 1.3344	* 1.6741	* 1.4532	* 1.6900	* 1.0620	*
	* 1.5692	* 1.2595	* 1.5838	* 1.2836	* 1.4857	* 1.2743	* 2.0002	*
13	* 1.6699	* 1.4121	* 1.7080	* 1.3798	* 1.6900	* 1.5777	* .7511	*
	* 1.2587	* 1.4867	* 1.2384	* 1.5419	* 1.2743	* 1.3664	* 2.8281	*
14	* 1.2095	* 1.6812	* 1.6892	* 1.6120	* 1.0616	* .7512	*	
	* 1.7263	* 1.2521	* 1.2500	* 1.3144	* 2.0008	* 2.8278	*	
15	* .7047	* .8923	* .8463	* .7405	* F-SUB-Q			
	* 2.9363	* 2.3307	* 2.4617	* 2.8223	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0857	* 1.6522	* 1.3038	* 1.6743	* 1.3590	* 1.7150	* 1.2291	* .7151 *
	* 1.9130	* 1.2559	* 1.5848	* 1.2346	* 1.5173	* 1.2052	* 1.6741	* 2.8563 *
9	* 1.6522	* 1.2803	* 1.6362	* 1.2969	* 1.7165	* 1.4389	* 1.7282	* .9031 *
	* 1.2559	* 1.6151	* 1.2649	* 1.5899	* 1.2054	* 1.4351	* 1.1991	* 2.2722 *
10	* 1.3038	* 1.6359	* 1.1153	* 1.2518	* 1.3584	* 1.7560	* 1.7371	* .8467 *
	* 1.5848	* 1.2651	* 1.8499	* 1.6471	* 1.5288	* 1.1841	* 1.1957	* 2.4273 *
11	* 1.6743	* 1.2973	* 1.2508	* 1.3104	* 1.7191	* 1.4053	* 1.6493	* .7369 *
	* 1.2346	* 1.5893	* 1.6483	* 1.5951	* 1.2237	* 1.4858	* 1.2627	* 2.7949 *
12	* 1.3590	* 1.7165	* 1.3583	* 1.7191	* 1.4825	* 1.7360	* 1.0684	*
	* 1.5173	* 1.2054	* 1.5288	* 1.2237	* 1.4225	* 1.2149	* 1.9536	*
13	* 1.7150	* 1.4387	* 1.7560	* 1.4052	* 1.7360	* 1.6156	* .7637	*
	* 1.2052	* 1.4353	* 1.1840	* 1.4858	* 1.2149	* 1.3067	* 2.7320	*
14	* 1.2291	* 1.7281	* 1.7372	* 1.6494	* 1.0680	* .7638	*	
	* 1.6741	* 1.1991	* 1.1957	* 1.2626	* 1.9543	* 2.7317	*	
15	* .7151	* .9033	* .8467	* .7369	* F-SUB-Q			
	* 2.8563	* 2.2718	* 2.4272	* 2.7948	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 58 of 311

	H	G	F	E	D	C	B	A
8	* 1.0896	* 1.6574	* 1.3155	* 1.6775	* 1.3704	* 1.7179	* 1.2381	* .7160
	* 1.8071	* 1.1904	* 1.4970	* 1.1742	* 1.4344	* 1.1457	* 1.5839	* 2.7239
9	* 1.6574	* 1.2918	* 1.6417	* 1.3088	* 1.7203	* 1.4517	* 1.7344	* .9131
	* 1.1904	* 1.5248	* 1.2008	* 1.5026	* 1.1451	* 1.3550	* 1.1358	* 2.1416
10	* 1.3155	* 1.6414	* 1.1470	* 1.2710	* 1.3693	* 1.7603	* 1.7431	* .8643
	* 1.4970	* 1.2010	* 1.7155	* 1.5471	* 1.4423	* 1.1216	* 1.1315	* 2.2648
11	* 1.6775	* 1.3091	* 1.2699	* 1.3224	* 1.7236	* 1.4168	* 1.6618	* .7550
	* 1.1742	* 1.5021	* 1.5485	* 1.4963	* 1.1518	* 1.3964	* 1.1887	* 2.5963
12	* 1.3704	* 1.7202	* 1.3692	* 1.7236	* 1.4959	* 1.7436	* 1.0877	*
	* 1.4344	* 1.1451	* 1.4422	* 1.1517	* 1.3269	* 1.1398	* 1.8165	*
13	* 1.7179	* 1.4514	* 1.7603	* 1.4168	* 1.7436	* 1.6260	* .7644	*
	* 1.1457	* 1.3552	* 1.1215	* 1.3963	* 1.1398	* 1.2224	* 2.5828	*
14	* 1.2381	* 1.7343	* 1.7432	* 1.6618	* 1.0873	* .7645	*	
	* 1.5839	* 1.1358	* 1.1314	* 1.1886	* 1.8171	* 2.5825	*	
15	* .7160	* .9132	* .8643	* .7550	* F-SUB-Q			
	* 2.7239	* 2.1412	* 2.2647	* 2.5962	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 59 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0819	* 1.6534	* 1.3097	* 1.6695	* 1.3636	* 1.7088	* 1.2293	* .7087 *
	* 1.7885	* 1.1725	* 1.4783	* 1.1598	* 1.4173	* 1.1317	* 1.5681	* 2.7062 *
9	* 1.6534	* 1.2863	* 1.6380	* 1.3016	* 1.7114	* 1.4464	* 1.7276	* .9027 *
	* 1.1725	* 1.5053	* 1.1827	* 1.4857	* 1.1311	* 1.3366	* 1.1194	* 2.1290 *
10	* 1.3097	* 1.6378	* 1.1275	* 1.2621	* 1.3660	* 1.7498	* 1.7356	* .8464 *
	* 1.4783	* 1.1829	* 1.7160	* 1.5321	* 1.4203	* 1.1073	* 1.1153	* 2.2725 *
11	* 1.6695	* 1.3020	* 1.2609	* 1.3163	* 1.7161	* 1.4119	* 1.6490	* .7364 *
	* 1.1598	* 1.4852	* 1.5335	* 1.4749	* 1.1337	* 1.3747	* 1.1753	* 2.6141 *
12	* 1.3636	* 1.7114	* 1.3660	* 1.7161	* 1.4922	* 1.7390	* 1.0687	*
	* 1.4173	* 1.1311	* 1.4193	* 1.1337	* 1.3037	* 1.1193	* 1.8128	*
13	* 1.7088	* 1.4462	* 1.7498	* 1.4119	* 1.7390	* 1.6163	* .7583	*
	* 1.1317	* 1.3367	* 1.1072	* 1.3746	* 1.1193	* 1.2042	* 2.5521	*
14	* 1.2293	* 1.7275	* 1.7356	* 1.6490	* 1.0683	* .7584	*	
	* 1.5681	* 1.1194	* 1.1152	* 1.1752	* 1.8134	* 2.5517	*	
15	* .7087	* .9029	* .8463	* .7364	* F-SUB-Q			
	* 2.7062	* 2.1285	* 2.2724	* 2.6139	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0250	* 1.5471	* 1.2399	* 1.5556	* 1.2888	* 1.5926	* 1.1608	* .6663 *
	* 1.8635	* 1.2360	* 1.5412	* 1.2281	* 1.4800	* 1.1980	* 1.6385	* 2.8406 *
9	* 1.5471	* 1.2188	* 1.5333	* 1.2316	* 1.5970	* 1.3699	* 1.6115	* .8494 *
	* 1.2360	* 1.5681	* 1.2464	* 1.5499	* 1.1958	* 1.3923	* 1.1831	* 2.2319 *
10	* 1.2399	* 1.5331	* 1.0752	* 1.2046	* 1.3008	* 1.6275	* 1.6171	* .7975 *
	* 1.5412	* 1.2465	* 1.7754	* 1.5838	* 1.4697	* 1.1735	* 1.1796	* 2.3786 *
11	* 1.5556	* 1.2320	* 1.2030	* 1.2495	* 1.6020	* 1.3402	* 1.5403	* .6947 *
	* 1.2281	* 1.5494	* 1.5859	* 1.5313	* 1.1959	* 1.4271	* 1.2399	* 2.7326 *
12	* 1.2888	* 1.5969	* 1.3007	* 1.6020	* 1.4148	* 1.6261	* 1.0039	*
	* 1.4800	* 1.1958	* 1.4695	* 1.1958	* 1.3540	* 1.1783	* 1.9011	*
13	* 1.5926	* 1.3696	* 1.6274	* 1.3402	* 1.6260	* 1.5101	* .7146	*
	* 1.1980	* 1.3925	* 1.1734	* 1.4270	* 1.1783	* 1.2684	* 2.6671	*
14	* 1.1608	* 1.6114	* 1.6171	* 1.5403	* 1.0035	* .7146	*	
	* 1.6385	* 1.1831	* 1.1796	* 1.2398	* 1.9017	* 2.6668	*	
15	* .6663	* .8495	* .7975	* .6946	* F-SUB-Q			
	* 2.8406	* 2.2314	* 2.3786	* 2.7325	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 60 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 350 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8848	* 1.2959	* 1.0147	* 1.3083	* 1.0526	* 1.3370	* .9466	* .5638
	* 2.1372	* 1.4601	* 1.8634	* 1.4447	* 1.7933	* 1.4116	* 1.9884	* 3.3235
9	* 1.2959	* .9995	* 1.2839	* 1.0077	* 1.3426	* 1.1414	* 1.3408	* .7094
	* 1.4601	* 1.8918	* 1.4731	* 1.8745	* 1.4070	* 1.6531	* 1.4052	* 2.6442
10	* 1.0147	* 1.2840	* .9432	* 1.0348	* 1.1163	* 1.3638	* 1.3378	* .6748
	* 1.8634	* 1.4729	* 2.0032	* 1.8248	* 1.6935	* 1.3845	* 1.4099	* 2.7819
11	* 1.3083	* 1.0080	* 1.0343	* 1.0401	* 1.3508	* 1.1207	* 1.2689	* .5840
	* 1.4447	* 1.8740	* 1.8256	* 1.8191	* 1.4018	* 1.6872	* 1.4882	* 3.2154
12	* 1.0526	* 1.3426	* 1.1162	* 1.3508	* 1.2059	* 1.3571	* .8375	*
	* 1.7933	* 1.4070	* 1.6935	* 1.4017	* 1.5699	* 1.3942	* 2.2523	*
13	* 1.3370	* 1.1412	* 1.3638	* 1.1207	* 1.3571	* 1.2457	* .6034	*
	* 1.4116	* 1.6533	* 1.3845	* 1.6871	* 1.3941	* 1.5176	* 3.1219	*
14	* .9466	* 1.3408	* 1.3378	* 1.2689	* .8372	* .6034	*	*
	* 1.9884	* 1.4053	* 1.4098	* 1.4880	* 2.2528	* 3.1218	*	*
15	* .5638	* .7095	* .6748	* .5840	* F-SUB-Q			
	* 3.3235	* 2.6439	* 2.7820	* 3.2153	* M-SUB-Q			

AT 100% POWER, 350 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6460	* .5908	* .5029	* .5991	* .5201	* .6110	* .4812	* .4114
	* 2.9033	* 3.1751	* 3.7290	* 3.1278	* 3.5997	* 3.0623	* 3.8811	* 4.5218
9	* .5908	* .4979	* .5856	* .5050	* .6147	* .5423	* .5760	* .3655
	* 3.1751	* 3.7671	* 3.2046	* 3.7098	* 3.0468	* 3.4503	* 3.2433	* 5.0954
10	* .5029	* .5858	* .5095	* .5020	* .5352	* .6197	* .5906	* .3544
	* 3.7290	* 3.2011	* 3.6799	* 3.7328	* 3.5021	* 3.0222	* 3.1658	* 5.2566
11	* .5991	* .5052	* .5019	* .5252	* .6159	* .5357	* .5506	* .3116
	* 3.1278	* 3.7086	* 3.7334	* 3.5727	* 3.0463	* 3.4997	* 3.3985	* 5.9811
12	* .5201	* .6147	* .5351	* .6159	* .5693	* .5877	* .4214	*
	* 3.5997	* 3.0468	* 3.5020	* 3.0460	* 3.2958	* 3.1904	* 4.4390	*
13	* .6110	* .5422	* .6196	* .5356	* .5877	* .5423	* .4432	*
	* 3.0623	* 3.4506	* 3.0221	* 3.4994	* 3.1901	* 3.4560	* 4.2151	*
14	* .4812	* .5760	* .5905	* .5506	* .4215	* .4432	*	*
	* 3.8811	* 3.2434	* 3.1656	* 3.3982	* 4.4376	* 4.2154	*	*
15	* .4114	* .3655	* .3543	* .3116	* F-SUB-Q			
	* 4.5218	* 5.0953	* 5.2567	* 5.9810	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 61 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6995 *	* .6559 *	* .5941 *	* .6773 *	* .6132 *	* .6802 *	* .5627 *	* .5352 *
	* 2.5057 *	* 2.9198 *	* 3.3364 *	* 2.8840 *	* 3.1612 *	* 2.8449 *	* 3.4127 *	* 3.5599 *
9	* .6559 *	* .5937 *	* .6641 *	* .5989 *	* .6835 *	* .6225 *	* .6354 *	* .4523 *
	* 2.9198 *	* 3.2603 *	* 2.9872 *	* 3.2705 *	* 2.8519 *	* 3.1190 *	* 3.0696 *	* 4.2487 *
10	* .5941 *	* .6643 *	* .6007 *	* .5980 *	* .6158 *	* .6783 *	* .6402 *	* .4337 *
	* 3.3364 *	* 2.9850 *	* 3.3195 *	* 3.3308 *	* 3.1995 *	* 2.9253 *	* 3.0933 *	* 4.4738 *
11	* .6773 *	* .5990 *	* .5978 *	* .5762 *	* .6643 *	* .6055 *	* .6054 *	* .3909 *
	* 2.8839 *	* 3.2702 *	* 3.3316 *	* 3.2334 *	* 2.8081 *	* 3.1462 *	* 3.2518 *	* 5.0703 *
12	* .6132 *	* .6835 *	* .6158 *	* .6642 *	* .5600 *	* .6053 *	* .4812 *	
	* 3.1612 *	* 2.8518 *	* 3.1995 *	* 2.8082 *	* 2.8692 *	* 2.9109 *	* 3.9443 *	
13	* .6802 *	* .6225 *	* .6783 *	* .6055 *	* .6053 *	* .5624 *	* .5425 *	
	* 2.8449 *	* 3.1189 *	* 2.9253 *	* 3.1462 *	* 2.9109 *	* 3.1214 *	* 3.4177 *	
14	* .5627 *	* .6356 *	* .6403 *	* .6055 *	* .4814 *	* .5423 *		
	* 3.4127 *	* 3.0684 *	* 3.0928 *	* 3.2516 *	* 3.9427 *	* 3.4187 *		
15	* .5352 *	* .4525 *	* .4338 *	* .3909 *	F-SUB-Q			
	* 3.5599 *	* 4.2460 *	* 4.4723 *	* 5.0698 *	M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8664 *	* 1.2240 *	* 1.0851 *	* 1.2553 *	* 1.1231 *	* 1.2670 *	* 1.0368 *	* .6582 *
	* 2.0672 *	* 1.6213 *	* 1.8597 *	* 1.5797 *	* 1.7519 *	* 1.5510 *	* 1.8811 *	* 2.9271 *
9	* 1.2240 *	* 1.0828 *	* 1.2325 *	* 1.0938 *	* 1.2705 *	* 1.1589 *	* 1.2518 *	* .7914 *
	* 1.6213 *	* 1.8452 *	* 1.6397 *	* 1.8182 *	* 1.5584 *	* 1.7009 *	* 1.5814 *	* 2.4670 *
10	* 1.0851 *	* 1.2325 *	* 1.0044 *	* 1.0812 *	* 1.1238 *	* 1.2678 *	* 1.2347 *	* .7420 *
	* 1.8597 *	* 1.6398 *	* 2.0205 *	* 1.8810 *	* 1.7904 *	* 1.5980 *	* 1.6272 *	* 2.6536 *
11	* 1.2553 *	* 1.0939 *	* 1.0807 *	* 1.0561 *	* 1.2501 *	* 1.1379 *	* 1.1942 *	* .6679 *
	* 1.5797 *	* 1.8180 *	* 1.8817 *	* 1.8409 *	* 1.5498 *	* 1.7271 *	* 1.6767 *	* 3.0261 *
12	* 1.1231 *	* 1.2705 *	* 1.1238 *	* 1.2501 *	* 1.1131 *	* 1.2345 *	* .8706 *	
	* 1.7519 *	* 1.5583 *	* 1.7905 *	* 1.5498 *	* 1.6479 *	* 1.5308 *	* 2.2359 *	
13	* 1.2670 *	* 1.1589 *	* 1.2678 *	* 1.1379 *	* 1.2345 *	* 1.1505 *	* .6602 *	
	* 1.5510 *	* 1.7009 *	* 1.5980 *	* 1.7271 *	* 1.5308 *	* 1.6443 *	* 2.9027 *	
14	* 1.0368 *	* 1.2522 *	* 1.2348 *	* 1.1942 *	* .8706 *	* .6602 *		
	* 1.8811 *	* 1.5810 *	* 1.6271 *	* 1.6767 *	* 2.2360 *	* 2.9029 *		
15	* .6582 *	* .7917 *	* .7422 *	* .6679 *	F-SUB-Q			
	* 2.9271 *	* 2.4660 *	* 2.6529 *	* 3.0259 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 62 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0468	* 1.4015	* 1.2096	* 1.4299	* 1.2560	* 1.4482	* 1.1616	* .7414 *
	* 1.9129	* 1.4517	* 1.6853	* 1.3980	* 1.5788	* 1.3668	* 1.6921	* 2.6223 *
9	* 1.4015	* 1.2049	* 1.4043	* 1.2173	* 1.4515	* 1.3015	* 1.4464	* .8912 *
	* 1.4517	* 1.6954	* 1.4536	* 1.6480	* 1.3746	* 1.5263	* 1.3791	* 2.2083 *
10	* 1.2096	* 1.4042	* 1.1016	* 1.1949	* 1.2527	* 1.4536	* 1.4348	* .8507 *
	* 1.6853	* 1.4538	* 1.8620	* 1.7139	* 1.6284	* 1.4045	* 1.4106	* 2.3334 *
11	* 1.4299	* 1.2175	* 1.1939	* 1.1959	* 1.4379	* 1.2805	* 1.3929	* .7637 *
	* 1.3980	* 1.6477	* 1.7154	* 1.6743	* 1.3804	* 1.5656	* 1.4647	* 2.6771 *
12	* 1.2560	* 1.4515	* 1.2527	* 1.4379	* 1.3121	* 1.4537	* 1.0053	*
	* 1.5788	* 1.3746	* 1.6285	* 1.3804	* 1.5031	* 1.3539	* 1.9854	*
13	* 1.4482	* 1.3014	* 1.4536	* 1.2805	* 1.4537	* 1.3580	* .7478	*
	* 1.3668	* 1.5264	* 1.4044	* 1.5657	* 1.3539	* 1.4397	* 2.6225	*
14	* 1.1616	* 1.4467	* 1.4349	* 1.3929	* 1.0052	* .7478	*	
	* 1.6921	* 1.3789	* 1.4105	* 1.4647	* 1.9857	* 2.6224	*	
15	* .7414	* .8914	* .8508	* .7637	* F-SUB-Q			
	* 2.6223	* 2.2076	* 2.3329	* 2.6770	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1057	* 1.5137	* 1.2664	* 1.5433	* 1.3188	* 1.5682	* 1.2167	* .7742 *
	* 1.8600	* 1.3696	* 1.6230	* 1.3035	* 1.5126	* 1.2690	* 1.6248	* 2.5276 *
9	* 1.5137	* 1.2597	* 1.5126	* 1.2735	* 1.5707	* 1.3732	* 1.5659	* .9328 *
	* 1.3696	* 1.6489	* 1.3604	* 1.5862	* 1.2776	* 1.4550	* 1.2803	* 2.1227 *
10	* 1.2664	* 1.5128	* 1.1372	* 1.2465	* 1.3174	* 1.5761	* 1.5595	* .8790 *
	* 1.6230	* 1.3607	* 1.8193	* 1.6563	* 1.5679	* 1.2990	* 1.3047	* 2.2719 *
11	* 1.5433	* 1.2737	* 1.2454	* 1.2605	* 1.5651	* 1.3525	* 1.5030	* .7826 *
	* 1.3035	* 1.5859	* 1.6577	* 1.6181	* 1.2935	* 1.5066	* 1.3714	* 2.6291 *
12	* 1.3188	* 1.5707	* 1.3174	* 1.5651	* 1.3989	* 1.5815	* 1.0542	*
	* 1.5126	* 1.2776	* 1.5679	* 1.2935	* 1.4415	* 1.2703	* 1.9243	*
13	* 1.5682	* 1.3731	* 1.5761	* 1.3525	* 1.5815	* 1.4770	* .7878	*
	* 1.2690	* 1.4551	* 1.2989	* 1.5067	* 1.2703	* 1.3528	* 2.5364	*
14	* 1.2167	* 1.5661	* 1.5595	* 1.5030	* 1.0539	* .7878	*	
	* 1.6248	* 1.2802	* 1.3046	* 1.3714	* 1.9246	* 2.5363	*	
15	* .7742	* .9330	* .8791	* .7827	* F-SUB-Q			
	* 2.5276	* 2.1222	* 2.2716	* 2.6290	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 63 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1044	* 1.5335	* 1.2681	* 1.5641	* 1.3221	* 1.5927	* 1.2187	* .7702 *
	* 1.8983	* 1.3734	* 1.6360	* 1.2967	* 1.5207	* 1.2586	* 1.6343	* 2.5637 *
9	* 1.5335	* 1.2593	* 1.5307	* 1.2740	* 1.5947	* 1.3797	* 1.5904	* .9317 *
	* 1.3734	* 1.6757	* 1.3568	* 1.5991	* 1.2677	* 1.4591	* 1.2688	* 2.1411 *
10	* 1.2681	* 1.5308	* 1.1309	* 1.2428	* 1.3220	* 1.6051	* 1.5869	* .8825 *
	* 1.6360	* 1.3571	* 1.8469	* 1.6753	* 1.5814	* 1.2836	* 1.2902	* 2.2795 *
11	* 1.5641	* 1.2743	* 1.2418	* 1.2680	* 1.5927	* 1.3591	* 1.5285	* .7828 *
	* 1.2967	* 1.5988	* 1.6768	* 1.6350	* 1.2921	* 1.5228	* 1.3688	* 2.6467 *
12	* 1.3221	* 1.5947	* 1.3220	* 1.5927	* 1.4113	* 1.6080	* 1.0648	*
	* 1.5207	* 1.2677	* 1.5815	* 1.2921	* 1.4542	* 1.2707	* 1.9356	*
13	* 1.5927	* 1.3795	* 1.6051	* 1.3591	* 1.6079	* 1.5045	* .7897	*
	* 1.2586	* 1.4593	* 1.2836	* 1.5228	* 1.2707	* 1.3517	* 2.5761	*
14	* 1.2187	* 1.5905	* 1.5870	* 1.5285	* 1.0645	* .7897	*	
	* 1.6343	* 1.2688	* 1.2901	* 1.3688	* 1.9360	* 2.5759	*	
15	* .7702	* .9319	* .8826	* .7828	* F-SUB-Q			
	* 2.5637	* 2.1407	* 2.2793	* 2.6467	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0916	* 1.5224	* 1.2528	* 1.5531	* 1.3068	* 1.5832	* 1.2042	* .7608 *
	* 1.9446	* 1.3971	* 1.6725	* 1.3187	* 1.5538	* 1.2779	* 1.6700	* 2.6258 *
9	* 1.5224	* 1.2429	* 1.5187	* 1.2579	* 1.5849	* 1.3651	* 1.5813	* .9195 *
	* 1.3971	* 1.7143	* 1.3810	* 1.6358	* 1.2872	* 1.4885	* 1.2865	* 2.1911 *
10	* 1.2528	* 1.5187	* 1.1175	* 1.2251	* 1.3074	* 1.5990	* 1.5793	* .8765 *
	* 1.6725	* 1.3813	* 1.8935	* 1.7114	* 1.6131	* 1.2983	* 1.3058	* 2.3150 *
11	* 1.5531	* 1.2582	* 1.2237	* 1.2571	* 1.5846	* 1.3447	* 1.5224	* .7797 *
	* 1.3187	* 1.6355	* 1.7126	* 1.6708	* 1.3175	* 1.5603	* 1.3846	* 2.6757 *
12	* 1.3068	* 1.5849	* 1.3074	* 1.5846	* 1.3990	* 1.5988	* 1.0611	*
	* 1.5538	* 1.2872	* 1.6131	* 1.3175	* 1.4895	* 1.2993	* 1.9697	*
13	* 1.5832	* 1.3650	* 1.5990	* 1.3447	* 1.5988	* 1.4990	* .7822	*
	* 1.2779	* 1.4887	* 1.2983	* 1.5603	* 1.2993	* 1.3824	* 2.6504	*
14	* 1.2042	* 1.5813	* 1.5793	* 1.5224	* 1.0608	* .7822	*	
	* 1.6700	* 1.2865	* 1.3058	* 1.3846	* 1.9702	* 2.6502	*	
15	* .7608	* .9196	* .8766	* .7797	* F-SUB-Q			
	* 2.6258	* 2.1908	* 2.3148	* 2.6757	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 64 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0813	* 1.5199	* 1.2420	* 1.5510	* 1.2955	* 1.5822	* 1.1929	* .7516 *
	* 1.9788	* 1.4011	* 1.7061	* 1.3370	* 1.5878	* 1.2948	* 1.7076	* 2.6927 *
9	* 1.5199	* 1.2312	* 1.5160	* 1.2463	* 1.5830	* 1.3548	* 1.5811	* .9112 *
	* 1.4011	* 1.7317	* 1.3982	* 1.6717	* 1.3042	* 1.5183	* 1.3005	* 2.2356 *
10	* 1.2420	* 1.5161	* 1.1011	* 1.2127	* 1.2975	* 1.6007	* 1.5800	* .8639 *
	* 1.7061	* 1.3985	* 1.9296	* 1.7478	* 1.6301	* 1.3082	* 1.3170	* 2.3750 *
11	* 1.5510	* 1.2465	* 1.2117	* 1.2481	* 1.5844	* 1.3350	* 1.5189	* .7643 *
	* 1.3370	* 1.6713	* 1.7491	* 1.7017	* 1.3333	* 1.5849	* 1.3869	* 2.7436 *
12	* 1.2955	* 1.5830	* 1.2974	* 1.5844	* 1.3909	* 1.5982	* 1.0491	* .7772 *
	* 1.5878	* 1.3042	* 1.6301	* 1.3333	* 1.5164	* 1.3148	* 2.0145	* .7772 *
13	* 1.5822	* 1.3547	* 1.6007	* 1.3350	* 1.5982	* 1.4963	* 1.4008	* 2.7000 *
	* 1.2948	* 1.5185	* 1.3082	* 1.5849	* 1.3148	* 1.4008	* 2.7000 *	
14	* 1.1929	* 1.5811	* 1.5800	* 1.5190	* 1.0488	* .7772		
	* 1.7076	* 1.3004	* 1.3170	* 1.3868	* 2.0150	* 2.6998		
15	* .7516	* .9113	* .8639	* .7643	* F-SUB-Q			
	* 2.6927	* 2.2353	* 2.3748	* 2.7435	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0646	* 1.5105	* 1.2299	* 1.5408	* 1.2823	* 1.5722	* 1.1806	* .7383 *
	* 2.0161	* 1.4202	* 1.7368	* 1.3665	* 1.6302	* 1.3239	* 1.7534	* 2.7861 *
9	* 1.5105	* 1.2186	* 1.5062	* 1.2333	* 1.5729	* 1.3421	* 1.5725	* .8982 *
	* 1.4202	* 1.7636	* 1.4181	* 1.7145	* 1.3323	* 1.5565	* 1.3253	* 2.3016 *
10	* 1.2299	* 1.5062	* 1.0863	* 1.1996	* 1.2848	* 1.5935	* 1.5721	* .8526 *
	* 1.7368	* 1.4184	* 1.9735	* 1.7807	* 1.6595	* 1.3239	* 1.3369	* 2.4392 *
11	* 1.5408	* 1.2336	* 1.1985	* 1.2374	* 1.5756	* 1.3226	* 1.5099	* .7523 *
	* 1.3665	* 1.7141	* 1.7822	* 1.7219	* 1.3460	* 1.6080	* 1.4061	* 2.8035 *
12	* 1.2823	* 1.5729	* 1.2848	* 1.5756	* 1.3793	* 1.5885	* 1.0395	* .7669 *
	* 1.6302	* 1.3323	* 1.6595	* 1.3460	* 1.5370	* 1.3311	* 2.0390	* .7669 *
13	* 1.5722	* 1.3419	* 1.5935	* 1.3226	* 1.5885	* 1.4876	* 1.4210	* 2.7553 *
	* 1.3239	* 1.5567	* 1.3239	* 1.6080	* 1.3311	* 1.4210	* 2.7553 *	
14	* 1.1806	* 1.5725	* 1.5721	* 1.5099	* 1.0393	* .7669		
	* 1.7534	* 1.3253	* 1.3369	* 1.4061	* 2.0395	* 2.7551		
15	* .7383	* .8983	* .8526	* .7523	* F-SUB-Q			
	* 2.7861	* 2.3011	* 2.4389	* 2.8034	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 65 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0586	* 1.5087	* 1.2228	* 1.5381	* 1.2739	* 1.5694	* 1.1725	* .7330 *
	* 2.0664	* 1.4484	* 1.7723	* 1.3955	* 1.6747	* 1.3532	* 1.8021	* 2.8641 *
9	* 1.5087	* 1.2110	* 1.5040	* 1.2253	* 1.5700	* 1.3343	* 1.5705	* .8915 *
	* 1.4484	* 1.8070	* 1.4406	* 1.7584	* 1.3603	* 1.5964	* 1.3505	* 2.3626 *
10	* 1.2228	* 1.5041	* 1.0774	* 1.1925	* 1.2770	* 1.5919	* 1.5705	* .8429 *
	* 1.7723	* 1.4409	* 2.0157	* 1.8158	* 1.6918	* 1.3430	* 1.3571	* 2.5109 *
11	* 1.5381	* 1.2256	* 1.1915	* 1.2306	* 1.5730	* 1.3148	* 1.5055	* .7425 *
	* 1.3955	* 1.7579	* 1.8174	* 1.7609	* 1.3703	* 1.6447	* 1.4291	* 2.8732 *
12	* 1.2739	* 1.5700	* 1.2770	* 1.5730	* 1.3728	* 1.5857	* 1.0306	*
	* 1.6747	* 1.3603	* 1.6917	* 1.3703	* 1.5707	* 1.3541	* 2.0885	*
13	* 1.5694	* 1.3342	* 1.5919	* 1.3148	* 1.5857	* 1.4835	* .7626	*
	* 1.3532	* 1.5965	* 1.3430	* 1.6447	* 1.3541	* 1.4460	* 2.8097	*
14	* 1.1725	* 1.5706	* 1.5706	* 1.5055	* 1.0303	* .7627	*	
	* 1.8021	* 1.3505	* 1.3570	* 1.4290	* 2.0890	* 2.8095	*	
15	* .7330	* .8917	* .8429	* .7425	* F-SUB-Q			
	* 2.8641	* 2.3618	* 2.5105	* 2.8731	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0412	* 1.4868	* 1.2084	* 1.5148	* 1.2575	* 1.5453	* 1.1582	* .7213 *
	* 2.1500	* 1.4957	* 1.8344	* 1.4522	* 1.7408	* 1.4098	* 1.8720	* 2.9859 *
9	* 1.4868	* 1.1963	* 1.4818	* 1.2102	* 1.5459	* 1.3174	* 1.5464	* .8837 *
	* 1.4957	* 1.8617	* 1.4951	* 1.8236	* 1.4157	* 1.6578	* 1.4036	* 2.4435 *
10	* 1.2084	* 1.4819	* 1.0790	* 1.1832	* 1.2594	* 1.5683	* 1.5465	* .8442 *
	* 1.8344	* 1.4954	* 2.0592	* 1.8721	* 1.7507	* 1.3922	* 1.4078	* 2.5648 *
11	* 1.5148	* 1.2104	* 1.1816	* 1.2175	* 1.5488	* 1.2972	* 1.4898	* .7475 *
	* 1.4522	* 1.8232	* 1.8730	* 1.8224	* 1.4278	* 1.7000	* 1.4697	* 2.9098 *
12	* 1.2575	* 1.5459	* 1.2594	* 1.5488	* 1.3552	* 1.5607	* 1.0300	*
	* 1.7408	* 1.4157	* 1.7507	* 1.4278	* 1.6338	* 1.4114	* 2.1362	*
13	* 1.5453	* 1.3173	* 1.5683	* 1.2972	* 1.5607	* 1.4653	* .7520	*
	* 1.4098	* 1.6579	* 1.3922	* 1.7000	* 1.4114	* 1.5014	* 2.9200	*
14	* 1.1582	* 1.5464	* 1.5466	* 1.4898	* 1.0297	* .7521	*	
	* 1.8720	* 1.4035	* 1.4077	* 1.4696	* 2.1367	* 2.9198	*	
15	* .7213	* .8838	* .8442	* .7475	* F-SUB-Q			
	* 2.9859	* 2.4425	* 2.5643	* 2.9096	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 66 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0450	* 1.5034	* 1.2126	* 1.5305	* 1.2600	* 1.5612	* 1.1598	* .7212 *
	* 2.1998	* 1.5214	* 1.8854	* 1.4819	* 1.7927	* 1.4398	* 1.9289	* 3.0792 *
9	* 1.5034	* 1.1994	* 1.4980	* 1.2123	* 1.5617	* 1.3220	* 1.5637	* .8803 *
	* 1.5214	* 1.9106	* 1.5242	* 1.8763	* 1.4448	* 1.7036	* 1.4291	* 2.5248 *
10	* 1.2126	* 1.4980	* 1.0658	* 1.1805	* 1.2632	* 1.5856	* 1.5639	* .8335 *
	* 1.8854	* 1.5243	* 2.1462	* 1.9303	* 1.7941	* 1.4174	* 1.4322	* 2.6726 *
11	* 1.5305	* 1.2126	* 1.1795	* 1.2200	* 1.5645	* 1.3014	* 1.4977	* .7327 *
	* 1.4819	* 1.8757	* 1.9320	* 1.8636	* 1.4462	* 1.7381	* 1.5015	* 3.0504 *
12	* 1.2600	* 1.5617	* 1.2632	* 1.5645	* 1.3612	* 1.5770	* 1.0221	*
	* 1.7927	* 1.4448	* 1.7941	* 1.4462	* 1.6658	* 1.4302	* 2.2026	*
13	* 1.5612	* 1.3219	* 1.5857	* 1.3014	* 1.5770	* 1.4758	* .7540	*
	* 1.4398	* 1.7037	* 1.4173	* 1.7380	* 1.4302	* 1.5282	* 2.9800	*
14	* 1.1598	* 1.5637	* 1.5640	* 1.4978	* 1.0218	* .7541	*	
	* 1.9289	* 1.4290	* 1.4320	* 1.5014	* 2.2032	* 2.9798	*	
15	* .7212	* .8804	* .8336	* .7327	* F-SUB-Q			
	* 3.0792	* 2.5240	* 2.6722	* 3.0502	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0406	* 1.5050	* 1.2113	* 1.5308	* 1.2567	* 1.5612	* 1.1567	* .7171 *
	* 2.1751	* 1.4960	* 1.8488	* 1.4638	* 1.7799	* 1.4366	* 1.9305	* 3.0951 *
9	* 1.5050	* 1.1971	* 1.4991	* 1.2092	* 1.5617	* 1.3194	* 1.5642	* .8776 *
	* 1.4960	* 1.8748	* 1.4978	* 1.8493	* 1.4382	* 1.6994	* 1.4394	* 2.5443 *
10	* 1.2113	* 1.4992	* 1.0643	* 1.1782	* 1.2598	* 1.5865	* 1.5645	* .8314 *
	* 1.8488	* 1.4977	* 2.1040	* 1.9005	* 1.7964	* 1.4258	* 1.4445	* 2.6923 *
11	* 1.5308	* 1.2096	* 1.1768	* 1.2181	* 1.5643	* 1.2983	* 1.4979	* .7304 *
	* 1.4638	* 1.8488	* 1.9026	* 1.8811	* 1.4721	* 1.7598	* 1.5176	* 3.0858 *
12	* 1.2567	* 1.5617	* 1.2598	* 1.5643	* 1.3590	* 1.5766	* 1.0209	*
	* 1.7799	* 1.4382	* 1.7964	* 1.4721	* 1.7082	* 1.4700	* 2.2448	*
13	* 1.5612	* 1.3193	* 1.5866	* 1.2983	* 1.5766	* 1.4758	* .7508	*
	* 1.4366	* 1.6996	* 1.4258	* 1.7598	* 1.4700	* 1.5751	* 3.0669	*
14	* 1.1567	* 1.5643	* 1.5646	* 1.4980	* 1.0207	* .7508	*	
	* 1.9305	* 1.4393	* 1.4444	* 1.5176	* 2.2454	* 3.0666	*	
15	* .7171	* .8777	* .8315	* .7304	* F-SUB-Q			
	* 3.0951	* 2.5440	* 2.6922	* 3.0858	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 67 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0343	* 1.4950	* 1.2055	* 1.5194	* 1.2489	* 1.5491	* 1.1503	* .7130 *
	* 2.1350	* 1.4700	* 1.8123	* 1.4379	* 1.7447	* 1.4111	* 1.8900	* 3.0285 *
9	* 1.4950	* 1.1909	* 1.4887	* 1.2026	* 1.5496	* 1.3113	* 1.5525	* .8754 *
	* 1.4700	* 1.8388	* 1.4716	* 1.8123	* 1.4133	* 1.6657	* 1.4151	* 2.4830 *
10	* 1.2055	* 1.4888	* 1.0714	* 1.1780	* 1.2509	* 1.5752	* 1.5530	* .8359 *
	* 1.8123	* 1.4716	* 2.0386	* 1.8533	* 1.7650	* 1.4025	* 1.4208	* 2.6072 *
11	* 1.5194	* 1.2029	* 1.1764	* 1.2123	* 1.5519	* 1.2897	* 1.4924	* .7378 *
	* 1.4379	* 1.8118	* 1.8556	* 1.8455	* 1.4506	* 1.7303	* 1.4879	* 2.9752 *
12	* 1.2489	* 1.5496	* 1.2509	* 1.5519	* 1.3508	* 1.5638	* 1.0248	*
	* 1.7447	* 1.4133	* 1.7650	* 1.4505	* 1.6789	* 1.4502	* 2.1846	*
13	* 1.5491	* 1.3112	* 1.5753	* 1.2897	* 1.5639	* 1.4683	* .7461	*
	* 1.4111	* 1.6658	* 1.4025	* 1.7302	* 1.4501	* 1.5496	* 3.0139	*
14	* 1.1503	* 1.5525	* 1.5531	* 1.4924	* 1.0245	* .7462	*	
	* 1.8900	* 1.4151	* 1.4208	* 1.4878	* 2.1852	* 3.0136	*	
15	* .7130	* .8756	* .8359	* .7378	* F-SUB-Q			
	* 3.0285	* 2.4826	* 2.6071	* 2.9751	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0415	* 1.5180	* 1.2147	* 1.5414	* 1.2564	* 1.5714	* 1.1569	* .7160 *
	* 2.0819	* 1.4207	* 1.7665	* 1.3903	* 1.7006	* 1.3635	* 1.8422	* 2.9569 *
9	* 1.5180	* 1.1990	* 1.5112	* 1.2092	* 1.5717	* 1.3210	* 1.5769	* .8797 *
	* 1.4207	* 1.7927	* 1.4227	* 1.7684	* 1.3658	* 1.6207	* 1.3643	* 2.4208 *
10	* 1.2147	* 1.5113	* 1.0651	* 1.1791	* 1.2594	* 1.5995	* 1.5775	* .8310 *
	* 1.7665	* 1.4226	* 2.0129	* 1.8169	* 1.7173	* 1.3530	* 1.3699	* 2.5687 *
11	* 1.5414	* 1.2096	* 1.1779	* 1.2195	* 1.5740	* 1.2988	* 1.5074	* .7291 *
	* 1.3903	* 1.7678	* 1.8186	* 1.7982	* 1.4021	* 1.6833	* 1.4427	* 2.9460 *
12	* 1.2564	* 1.5717	* 1.2595	* 1.5740	* 1.3616	* 1.5867	* 1.0218	*
	* 1.7006	* 1.3658	* 1.7172	* 1.4021	* 1.6337	* 1.4011	* 2.1456	*
13	* 1.5714	* 1.3209	* 1.5996	* 1.2988	* 1.5868	* 1.4854	* .7524	*
	* 1.3635	* 1.6208	* 1.3529	* 1.6833	* 1.4011	* 1.5015	* 2.9261	*
14	* 1.1569	* 1.5769	* 1.5775	* 1.5075	* 1.0215	* .7525	*	
	* 1.8422	* 1.3642	* 1.3698	* 1.4426	* 2.1462	* 2.9258	*	
15	* .7160	* .8799	* .8310	* .7292	* F-SUB-Q			
	* 2.9569	* 2.4204	* 2.5686	* 2.9460	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 68 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0437	* 1.5326	* 1.2218	* 1.5548	* 1.2620	* 1.5848	* 1.1621	* .7159 *
	* 2.0517	* 1.3912	* 1.7348	* 1.3628	* 1.6730	* 1.3371	* 1.8114	* 2.9153 *
9	* 1.5326	* 1.2053	* 1.5253	* 1.2146	* 1.5850	* 1.3279	* 1.5917	* .8826 *
	* 1.3912	* 1.7612	* 1.3932	* 1.7386	* 1.3392	* 1.5935	* 1.3363	* 2.3794 *
10	* 1.2218	* 1.5253	* 1.0666	* 1.1835	* 1.2650	* 1.6147	* 1.5925	* .8314 *
	* 1.7348	* 1.3932	* 1.9828	* 1.7860	* 1.6885	* 1.3252	* 1.3415	* 2.5320 *
11	* 1.5548	* 1.2150	* 1.1824	* 1.2254	* 1.5872	* 1.3051	* 1.5196	* .7290 *
	* 1.3628	* 1.7381	* 1.7874	* 1.7651	* 1.3732	* 1.6531	* 1.4131	* 2.9021 *
12	* 1.2620	* 1.5851	* 1.2650	* 1.5873	* 1.3692	* 1.6002	* 1.0251	*
	* 1.6730	* 1.3392	* 1.6884	* 1.3732	* 1.6037	* 1.3710	* 2.1066	*
13	* 1.5848	* 1.3278	* 1.6148	* 1.3051	* 1.6003	* 1.4975	* .7545	*
	* 1.3371	* 1.5937	* 1.3251	* 1.6531	* 1.3710	* 1.4686	* 2.8690	*
14	* 1.1621	* 1.5917	* 1.5926	* 1.5197	* 1.0248	* .7546	*	
	* 1.8114	* 1.3363	* 1.3414	* 1.4130	* 2.1073	* 2.8687	*	
15	* .7159	* .8828	* .8314	* .7291	* F-SUB-Q			
	* 2.9153	* 2.3790	* 2.5318	* 2.9021	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0506	* 1.5458	* 1.2302	* 1.5671	* 1.2690	* 1.5968	* 1.1687	* .7200 *
	* 2.0137	* 1.3618	* 1.7014	* 1.3337	* 1.6405	* 1.3075	* 1.7743	* 2.8547 *
9	* 1.5458	* 1.2131	* 1.5380	* 1.2216	* 1.5970	* 1.3358	* 1.6040	* .8883 *
	* 1.3618	* 1.7282	* 1.3639	* 1.7057	* 1.3098	* 1.5610	* 1.3050	* 2.3279 *
10	* 1.2302	* 1.5381	* 1.0769	* 1.1933	* 1.2715	* 1.6274	* 1.6048	* .8391 *
	* 1.7014	* 1.3639	* 1.9405	* 1.7480	* 1.6545	* 1.2934	* 1.3093	* 2.4689 *
11	* 1.5671	* 1.2220	* 1.1922	* 1.2329	* 1.5987	* 1.3122	* 1.5319	* .7349 *
	* 1.3337	* 1.7051	* 1.7495	* 1.7260	* 1.3406	* 1.6167	* 1.3780	* 2.8304 *
12	* 1.2690	* 1.5970	* 1.2716	* 1.5987	* 1.3777	* 1.6116	* 1.0339	*
	* 1.6405	* 1.3098	* 1.6544	* 1.3406	* 1.5660	* 1.3363	* 2.0511	*
13	* 1.5968	* 1.3357	* 1.6275	* 1.3122	* 1.6117	* 1.5091	* .7586	*
	* 1.3075	* 1.5611	* 1.2934	* 1.6167	* 1.3363	* 1.4297	* 2.7990	*
14	* 1.1687	* 1.6040	* 1.6050	* 1.5320	* 1.0336	* .7587	*	
	* 1.7743	* 1.3050	* 1.3093	* 1.3779	* 2.0517	* 2.7987	*	
15	* .7200	* .8884	* .8392	* .7349	* F-SUB-Q			
	* 2.8547	* 2.3275	* 2.4688	* 2.8304	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 69 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0578	* 1.5545	* 1.2391	* 1.5749	* 1.2768	* 1.6043	* 1.1765	* .7242 *
	* 1.9899	* 1.3472	* 1.6813	* 1.3196	* 1.6206	* 1.2925	* 1.7500	* 2.8158 *
9	* 1.5545	* 1.2217	* 1.5463	* 1.2306	* 1.6046	* 1.3440	* 1.6113	* .8986 *
	* 1.3472	* 1.7081	* 1.3497	* 1.6844	* 1.2949	* 1.5409	* 1.2882	* 2.2839 *
10	* 1.2391	* 1.5463	* 1.0984	* 1.2081	* 1.2784	* 1.6356	* 1.6124	* .8543 *
	* 1.6813	* 1.3497	* 1.8934	* 1.7175	* 1.6327	* 1.2757	* 1.2915	* 2.4051 *
11	* 1.5749	* 1.2309	* 1.2067	* 1.2417	* 1.6057	* 1.3196	* 1.5445	* .7523 *
	* 1.3196	* 1.6840	* 1.7193	* 1.6977	* 1.3216	* 1.5920	* 1.3535	* 2.7380 *
12	* 1.2768	* 1.6046	* 1.2785	* 1.6058	* 1.3873	* 1.6182	* 1.0496	*
	* 1.6206	* 1.2948	* 1.6327	* 1.3215	* 1.5379	* 1.3144	* 1.9976	*
13	* 1.6043	* 1.3438	* 1.6357	* 1.3197	* 1.6182	* 1.5198	* .7631	*
	* 1.2925	* 1.5411	* 1.2756	* 1.5920	* 1.3144	* 1.4011	* 2.7471	*
14	* 1.1765	* 1.6114	* 1.6125	* 1.5446	* 1.0493	* .7632	*	
	* 1.7500	* 1.2882	* 1.2914	* 1.3534	* 1.9982	* 2.7468	*	
15	* .7242	* .8987	* .8544	* .7523	* F-SUB-Q			
	* 2.8158	* 2.2835	* 2.4050	* 2.7379	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0801	* 1.6009	* 1.2652	* 1.6211	* 1.3025	* 1.6513	* 1.1993	* .7377 *
	* 1.9356	* 1.3023	* 1.6408	* 1.2785	* 1.5856	* 1.2533	* 1.7146	* 2.7582 *
9	* 1.6009	* 1.2465	* 1.5922	* 1.2540	* 1.6514	* 1.3729	* 1.6601	* .9127 *
	* 1.3023	* 1.6673	* 1.3060	* 1.6489	* 1.2551	* 1.5058	* 1.2471	* 2.2401 *
10	* 1.2652	* 1.5922	* 1.1033	* 1.2252	* 1.3049	* 1.6846	* 1.6612	* .8582 *
	* 1.6408	* 1.3060	* 1.8786	* 1.6891	* 1.5954	* 1.2352	* 1.2496	* 2.3857 *
11	* 1.6211	* 1.2545	* 1.2243	* 1.2660	* 1.6524	* 1.3475	* 1.5820	* .7504 *
	* 1.2785	* 1.6483	* 1.6902	* 1.6552	* 1.2760	* 1.5519	* 1.3160	* 2.7335 *
12	* 1.3025	* 1.6514	* 1.3050	* 1.6525	* 1.4175	* 1.6656	* 1.0589	*
	* 1.5856	* 1.2550	* 1.5954	* 1.2760	* 1.4909	* 1.2668	* 1.9682	*
13	* 1.6513	* 1.3728	* 1.6847	* 1.3475	* 1.6657	* 1.5583	* .7787	*
	* 1.2533	* 1.5059	* 1.2351	* 1.5519	* 1.2668	* 1.3543	* 2.6714	*
14	* 1.1993	* 1.6601	* 1.6613	* 1.5821	* 1.0585	* .7787	*	
	* 1.7146	* 1.2471	* 1.2495	* 1.3159	* 1.9688	* 2.6711	*	
15	* .7377	* .9129	* .8583	* .7504	* F-SUB-Q			
	* 2.7582	* 2.2397	* 2.3856	* 2.7335	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 70 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0988	* 1.6338	* 1.2883	* 1.6543	* 1.3258	* 1.6849	* 1.2203	* .7497 *
	* 1.8616	* 1.2532	* 1.5840	* 1.2315	* 1.5309	* 1.2063	* 1.6565	* 2.6764 *
9	* 1.6338	* 1.2690	* 1.6248	* 1.2764	* 1.6850	* 1.3982	* 1.6942	* .9291 *
	* 1.2532	* 1.6094	* 1.2578	* 1.5928	* 1.2081	* 1.4523	* 1.1999	* 2.1674 *
10	* 1.2883	* 1.6249	* 1.1234	* 1.2480	* 1.3284	* 1.7195	* 1.6954	* .8727 *
	* 1.5840	* 1.2578	* 1.8140	* 1.6302	* 1.5376	* 1.1864	* 1.2015	* 2.3100 *
11	* 1.6543	* 1.2769	* 1.2472	* 1.2889	* 1.6858	* 1.3720	* 1.6135	* .7626 *
	* 1.2315	* 1.5921	* 1.6312	* 1.5909	* 1.2214	* 1.4922	* 1.2651	* 2.6482 *
12	* 1.3258	* 1.6851	* 1.3285	* 1.6859	* 1.4445	* 1.6992	* 1.0771	*
	* 1.5309	* 1.2080	* 1.5376	* 1.2214	* 1.4257	* 1.2127	* 1.8966	*
13	* 1.6849	* 1.3981	* 1.7197	* 1.3720	* 1.6992	* 1.5889	* .7911	*
	* 1.2063	* 1.4524	* 1.1863	* 1.4922	* 1.2126	* 1.2970	* 2.5800	*
14	* 1.2203	* 1.6942	* 1.6956	* 1.6136	* 1.0767	* .7912	*	
	* 1.6565	* 1.1998	* 1.2014	* 1.2650	* 1.8972	* 2.5798	*	
15	* .7497	* .9293	* .8727	* .7626	* F-SUB-Q			
	* 2.6764	* 2.1669	* 2.3099	* 2.6482	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1070	* 1.6423	* 1.3025	* 1.6630	* 1.3407	* 1.6935	* 1.2336	* .7553 *
	* 1.8216	* 1.2298	* 1.5468	* 1.2092	* 1.4943	* 1.1838	* 1.6162	* 2.6195 *
9	* 1.6423	* 1.2838	* 1.6334	* 1.2926	* 1.6941	* 1.4134	* 1.7019	* .9431 *
	* 1.2298	* 1.5703	* 1.2347	* 1.5531	* 1.1853	* 1.4172	* 1.1766	* 2.1038 *
10	* 1.3025	* 1.6335	* 1.1564	* 1.2723	* 1.3436	* 1.7285	* 1.7035	* .8956 *
	* 1.5468	* 1.2347	* 1.7400	* 1.5787	* 1.4974	* 1.1622	* 1.1772	* 2.2176 *
11	* 1.6630	* 1.2930	* 1.2712	* 1.3047	* 1.6951	* 1.3868	* 1.6301	* .7870 *
	* 1.2092	* 1.5527	* 1.5801	* 1.5456	* 1.1927	* 1.4520	* 1.2320	* 2.5259 *
12	* 1.3407	* 1.6942	* 1.3436	* 1.6951	* 1.4613	* 1.7077	* 1.1012	*
	* 1.4943	* 1.1853	* 1.4974	* 1.1927	* 1.3834	* 1.1835	* 1.8226	*
13	* 1.6935	* 1.4132	* 1.7286	* 1.3868	* 1.7077	* 1.6019	* .7958	*
	* 1.1838	* 1.4174	* 1.1621	* 1.4520	* 1.1835	* 1.2612	* 2.5170	*
14	* 1.2336	* 1.7020	* 1.7037	* 1.6302	* 1.1009	* .7959	*	
	* 1.6162	* 1.1766	* 1.1771	* 1.2319	* 1.8232	* 2.5168	*	
15	* .7553	* .9433	* .8956	* .7870	* F-SUB-Q			
	* 2.6195	* 2.1034	* 2.2175	* 2.5258	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 71 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1173	* 1.6679	* 1.3190	* 1.6884	* 1.3578	* 1.7198	* 1.2470	* .7611 *
	* 1.7864	* 1.1984	* 1.5125	* 1.1790	* 1.4608	* 1.1532	* 1.5818	* 2.5710 *
9	* 1.6679	* 1.2996	* 1.6592	* 1.3074	* 1.7208	* 1.4340	* 1.7291	* .9491 *
	* 1.1984	* 1.5356	* 1.2032	* 1.5205	* 1.1545	* 1.3822	* 1.1443	* 2.0665 *
10	* 1.3190	* 1.6593	* 1.1560	* 1.2831	* 1.3638	* 1.7551	* 1.7301	* .8925 *
	* 1.5125	* 1.2032	* 1.7237	* 1.5500	* 1.4578	* 1.1306	* 1.1448	* 2.1993 *
11	* 1.6884	* 1.3079	* 1.2826	* 1.3216	* 1.7228	* 1.4069	* 1.6455	* .7800 *
	* 1.1790	* 1.5199	* 1.5506	* 1.5069	* 1.1575	* 1.4131	* 1.2049	* 2.5170 *
12	* 1.3578	* 1.7209	* 1.3638	* 1.7229	* 1.4818	* 1.7364	* 1.1002	*
	* 1.4608	* 1.1544	* 1.4578	* 1.1574	* 1.3457	* 1.1471	* 1.7993	*
13	* 1.7198	* 1.4339	* 1.7552	* 1.4070	* 1.7364	* 1.6196	* .8026	*
	* 1.1532	* 1.3824	* 1.1306	* 1.4131	* 1.1471	* 1.2287	* 2.4595	*
14	* 1.2470	* 1.7291	* 1.7302	* 1.6456	* 1.0998	* .8027	*	
	* 1.5818	* 1.1443	* 1.1448	* 1.2048	* 1.7999	* 2.4593	*	
15	* .7611	* .9493	* .8925	* .7800	* F-SUB-Q			
	* 2.5710	* 2.0661	* 2.1992	* 2.5170	* M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0826	* 1.6019	* 1.2808	* 1.6171	* 1.3168	* 1.6488	* 1.2084	* .7338 *
	* 1.8286	* 1.2370	* 1.5449	* 1.2204	* 1.4937	* 1.1920	* 1.6176	* 2.6422 *
9	* 1.6019	* 1.2625	* 1.5907	* 1.2692	* 1.6514	* 1.3953	* 1.6604	* .9155 *
	* 1.2370	* 1.5679	* 1.2442	* 1.5535	* 1.1922	* 1.4081	* 1.1797	* 2.1213 *
10	* 1.2808	* 1.5910	* 1.1287	* 1.2543	* 1.3324	* 1.6819	* 1.6598	* .8611 *
	* 1.5449	* 1.2440	* 1.7492	* 1.5714	* 1.4778	* 1.1678	* 1.1809	* 2.2569 *
11	* 1.6171	* 1.2697	* 1.2531	* 1.2869	* 1.6562	* 1.3711	* 1.5790	* .7545 *
	* 1.2204	* 1.5529	* 1.5728	* 1.5321	* 1.1906	* 1.4351	* 1.2423	* 2.5752 *
12	* 1.3168	* 1.6515	* 1.3324	* 1.6562	* 1.4418	* 1.6712	* 1.0591	*
	* 1.4937	* 1.1922	* 1.4778	* 1.1906	* 1.3679	* 1.1778	* 1.8483	*
13	* 1.6488	* 1.3951	* 1.6820	* 1.3712	* 1.6712	* 1.5536	* .7747	*
	* 1.1920	* 1.4082	* 1.1678	* 1.4351	* 1.1778	* 1.2654	* 2.5183	*
14	* 1.2084	* 1.6604	* 1.6598	* 1.5791	* 1.0588	* .7747	*	
	* 1.6176	* 1.1797	* 1.1808	* 1.2422	* 1.8489	* 2.5181	*	
15	* .7338	* .9156	* .8611	* .7545	* F-SUB-Q			
	* 2.6422	* 2.1209	* 2.2569	* 2.5752	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 72 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 460 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9646 *	* 1.3863 *	* 1.0954 *	* 1.3985 *	* 1.1245 *	* 1.4240 *	* 1.0275 *	* .6410 *
	* 2.0367 *	* 1.4176 *	* 1.7919 *	* 1.3995 *	* 1.7351 *	* 1.3684 *	* 1.8860 *	* 2.9990 *
9	* 1.3863 *	* 1.0813 *	* 1.3769 *	* 1.0854 *	* 1.4278 *	* 1.2135 *	* 1.4277 *	* .7899 *
	* 1.4176 *	* 1.8158 *	* 1.4255 *	* 1.8019 *	* 1.3671 *	* 1.6054 *	* 1.3585 *	* 2.4365 *
10	* 1.0954 *	* 1.3773 *	* 1.0244 *	* 1.1214 *	* 1.1902 *	* 1.4474 *	* 1.4187 *	* .7509 *
	* 1.7919 *	* 1.4251 *	* 1.9120 *	* 1.7428 *	* 1.6399 *	* 1.3442 *	* 1.3683 *	* 2.5646 *
11	* 1.3985 *	* 1.0857 *	* 1.1203 *	* 1.1164 *	* 1.4349 *	* 1.1955 *	* 1.3551 *	* .6537 *
	* 1.3995 *	* 1.8014 *	* 1.7445 *	* 1.7499 *	* 1.3608 *	* 1.6307 *	* 1.4310 *	* 2.9446 *
12	* 1.1245 *	* 1.4279 *	* 1.1902 *	* 1.4349 *	* 1.2795 *	* 1.4392 *	* .9157 *	
	* 1.7351 *	* 1.3670 *	* 1.6398 *	* 1.3608 *	* 1.5263 *	* 1.3532 *	* 2.1166 *	
13	* 1.4240 *	* 1.2134 *	* 1.4475 *	* 1.1955 *	* 1.4393 *	* 1.3344 *	* .6747 *	
	* 1.3684 *	* 1.6056 *	* 1.3441 *	* 1.6307 *	* 1.3532 *	* 1.4545 *	* 2.8620 *	
14	* 1.0275 *	* 1.4277 *	* 1.4188 *	* 1.3551 *	* .9154 *	* .6747 *		
	* 1.8860 *	* 1.3585 *	* 1.3683 *	* 1.4310 *	* 2.1171 *	* 2.8619 *		
15	* .6410 *	* .7900 *	* .7509 *	* .6537 *	F-SUB-Q			
	* 2.9990 *	* 2.4362 *	* 2.5647 *	* 2.9446 *	M-SUB-Q			

AT 100% POWER, 460 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7348 *	* .6809 *	* .5838 *	* .6870 *	* .5977 *	* .6971 *	* .5565 *	* .4932 *
	* 2.6513 *	* 2.8606 *	* 3.3339 *	* 2.8238 *	* 3.2364 *	* 2.7705 *	* 3.4560 *	* 3.8665 *
9	* .6809 *	* .5787 *	* .6757 *	* .5808 *	* .7005 *	* .6213 *	* .6630 *	* .4373 *
	* 2.8606 *	* 3.3653 *	* 2.8796 *	* 3.3385 *	* 2.7614 *	* 3.1078 *	* 2.8998 *	* 4.3677 *
10	* .5838 *	* .6759 *	* .5940 *	* .5811 *	* .6137 *	* .7057 *	* .6767 *	* .4235 *
	* 3.3339 *	* 2.8786 *	* 3.2728 *	* 3.3337 *	* 3.1509 *	* 2.7370 *	* 2.8426 *	* 4.5111 *
11	* .6870 *	* .5810 *	* .5810 *	* .6007 *	* .7018 *	* .6144 *	* .6377 *	* .3746 *
	* 2.8238 *	* 3.3375 *	* 3.3342 *	* 3.2228 *	* 2.7556 *	* 3.1439 *	* 3.0183 *	* 5.0981 *
12	* .5977 *	* .7005 *	* .6137 *	* .7018 *	* .6500 *	* .6734 *	* .4930 *	
	* 3.2364 *	* 2.7614 *	* 3.1509 *	* 2.7556 *	* 2.9761 *	* 2.8645 *	* 3.8963 *	
13	* .6971 *	* .6212 *	* .7057 *	* .6144 *	* .6734 *	* .6277 *	* .5233 *	
	* 2.7705 *	* 3.1081 *	* 2.7369 *	* 3.1439 *	* 2.8645 *	* 3.0688 *	* 3.6570 *	
14	* .5565 *	* .6630 *	* .6767 *	* .6377 *	* .4930 *	* .5232 *		
	* 3.4560 *	* 2.8999 *	* 2.8426 *	* 3.0183 *	* 3.8959 *	* 3.6573 *		
15	* .4932 *	* .4373 *	* .4234 *	* .3746 *	F-SUB-Q			
	* 3.8665 *	* 4.3676 *	* 4.5112 *	* 5.0982 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 73 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6220 *	* .5611 *	* .5271 *	* .6002 *	* .5332 *	* .5797 *	* .4730 *	* .3949 *
	* 2.7650 *	* 3.4309 *	* 3.6256 *	* 3.1756 *	* 3.5719 *	* 3.2694 *	* 3.9891 *	* 4.7324 *
9	* .5611 *	* .5202 *	* .5885 *	* .5288 *	* .5911 *	* .5358 *	* .5079 *	* .3280 *
	* 3.4309 *	* 3.6931 *	* 3.2473 *	* 3.6019 *	* 3.2160 *	* 3.5414 *	* 3.7125 *	* 5.6969 *
10	* .5271 *	* .5885 *	* .5370 *	* .5009 *	* .5112 *	* .5548 *	* .5105 *	* .3118 *
	* 3.6256 *	* 3.2472 *	* 3.5675 *	* 3.8042 *	* 3.7009 *	* 3.3999 *	* 3.6819 *	* 5.9977 *
11	* .6002 *	* .5289 *	* .5000 *	* .4456 *	* .4972 *	* .4663 *	* .4438 *	* .2649 *
	* 3.1756 *	* 3.6013 *	* 3.8106 *	* 4.0168 *	* 3.5984 *	* 4.0392 *	* 4.2252 *	* 7.0125 *
12	* .5332 *	* .5909 *	* .5111 *	* .4970 *	* .3933 *	* .3861 *	* .3265 *	
	* 3.5719 *	* 3.2166 *	* 3.7015 *	* 3.5987 *	* 3.8087 *	* 3.8502 *	* 5.3036 *	
13	* .5797 *	* .5357 *	* .5547 *	* .4663 *	* .3861 *	* .3346 *	* .3316 *	
	* 3.2694 *	* 3.5418 *	* 3.4003 *	* 4.0395 *	* 3.8504 *	* 4.2363 *	* 4.7565 *	
14	* .4730 *	* .5081 *	* .5106 *	* .4438 *	* .3267 *	* .3315 *		
	* 3.9891 *	* 3.7107 *	* 3.6815 *	* 4.2254 *	* 5.3009 *	* 4.7582 *		
15	* .3949 *	* .3282 *	* .3119 *	* .2650 *	F-SUB-Q			
	* 4.7324 *	* 5.6925 *	* 5.9954 *	* 7.0123 *	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7718 *	* 1.2257 *	* 1.0487 *	* 1.2947 *	* 1.0586 *	* 1.2578 *	* .9385 *	* .5326 *
	* 2.2022 *	* 1.6179 *	* 1.8802 *	* 1.5191 *	* 1.8535 *	* 1.5569 *	* 2.0784 *	* 3.6153 *
9	* 1.2257 *	* 1.0311 *	* 1.3122 *	* 1.0479 *	* 1.2813 *	* 1.0953 *	* 1.2086 *	* .6715 *
	* 1.6179 *	* 1.9160 *	* 1.5033 *	* 1.8778 *	* 1.5291 *	* 1.7872 *	* 1.6108 *	* 2.8727 *
10	* 1.0487 *	* 1.3118 *	* 1.0350 *	* 1.0724 *	* 1.0730 *	* 1.1872 *	* 1.1691 *	* .6354 *
	* 1.8802 *	* 1.5040 *	* 1.9028 *	* 1.8334 *	* 1.8211 *	* 1.6400 *	* 1.6568 *	* 3.0268 *
11	* 1.2947 *	* 1.0473 *	* 1.0700 *	* .9227 *	* 1.0724 *	* .9507 *	* 1.0537 *	* .5369 *
	* 1.5191 *	* 1.8785 *	* 1.8373 *	* 2.0698 *	* 1.7099 *	* 2.0015 *	* 1.8380 *	* 3.5685 *
12	* 1.0586 *	* 1.2809 *	* 1.0724 *	* 1.0721 *	* .8110 *	* .9174 *	* .6709 *	
	* 1.8535 *	* 1.5294 *	* 1.8217 *	* 1.7100 *	* 1.8188 *	* 1.6593 *	* 2.6500 *	
13	* 1.2578 *	* 1.0952 *	* 1.1871 *	* .9505 *	* .9173 *	* .8229 *	* .4438 *	
	* 1.5569 *	* 1.7872 *	* 1.6402 *	* 2.0016 *	* 1.6594 *	* 1.8185 *	* 3.6488 *	
14	* .9385 *	* 1.2090 *	* 1.1692 *	* 1.0536 *	* .6707 *	* .4438 *		
	* 2.0784 *	* 1.6103 *	* 1.6567 *	* 1.8382 *	* 2.6505 *	* 3.6491 *		
15	* .5326 *	* .6718 *	* .6356 *	* .5369 *	F-SUB-Q			
	* 3.6153 *	* 2.8713 *	* 3.0260 *	* 3.5685 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 74 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8329	* 1.2954	* 1.2242	* 1.3540	* 1.2243	* 1.3294	* 1.0621	* .6088
	* 2.0467	* 1.5703	* 1.6509	* 1.4845	* 1.6385	* 1.5052	* 1.8736	* 3.2232
9	* 1.2954	* 1.1947	* 1.3537	* 1.2272	* 1.3453	* 1.2459	* 1.2975	* .7548
	* 1.5703	* 1.6985	* 1.4942	* 1.6406	* 1.4905	* 1.6031	* 1.5337	* 2.6078
10	* 1.2242	* 1.3519	* 1.1675	* 1.2816	* 1.2480	* 1.2762	* 1.2305	* .7075
	* 1.6509	* 1.4961	* 1.7313	* 1.5741	* 1.6071	* 1.5663	* 1.6163	* 2.7800
11	* 1.3540	* 1.2262	* 1.2784	* 1.1134	* 1.1976	* 1.0665	* 1.2066	* .6105
	* 1.4845	* 1.6415	* 1.5781	* 1.8130	* 1.6202	* 1.7983	* 1.6504	* 3.2246
12	* 1.2243	* 1.3450	* 1.2472	* 1.1970	* .9183	* .9745	* .7882	*
	* 1.6385	* 1.4908	* 1.6081	* 1.6202	* 1.6323	* 1.6329	* 2.3227	*
13	* 1.3294	* 1.2457	* 1.2759	* 1.0662	* .9744	* .9612	* .5052	*
	* 1.5052	* 1.6034	* 1.5667	* 1.7985	* 1.6330	* 1.6104	* 3.3115	*
14	* 1.0621	* 1.2977	* 1.2305	* 1.2065	* .7880	* .5052	*	*
	* 1.8736	* 1.5335	* 1.6163	* 1.6505	* 2.3232	* 3.3115	*	*
15	* .6088	* .7550	* .7076	* .6104	* F-SUB-Q			
	* 3.2232	* 2.6070	* 2.7796	* 3.2248	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8775	* 1.4088	* 1.3442	* 1.4711	* 1.3420	* 1.4416	* 1.1651	* .6509
	* 2.0229	* 1.4910	* 1.5484	* 1.4080	* 1.5385	* 1.4281	* 1.7515	* 3.0900
9	* 1.4088	* 1.3115	* 1.4780	* 1.3545	* 1.4621	* 1.3455	* 1.4121	* .7921
	* 1.4910	* 1.5955	* 1.4078	* 1.5324	* 1.4138	* 1.5268	* 1.4511	* 2.5569
10	* 1.3442	* 1.4757	* 1.2356	* 1.4016	* 1.3486	* 1.3813	* 1.3218	* .7279
	* 1.5484	* 1.4100	* 1.6827	* 1.4803	* 1.5356	* 1.4945	* 1.5538	* 2.7800
11	* 1.4711	* 1.3530	* 1.3977	* 1.2396	* 1.3203	* 1.1569	* 1.3280	* .6341
	* 1.4080	* 1.5341	* 1.4844	* 1.6796	* 1.5381	* 1.7163	* 1.5489	* 3.2066
12	* 1.3420	* 1.4612	* 1.3475	* 1.3196	* .9948	* 1.0788	* .8545	*
	* 1.5385	* 1.4142	* 1.5368	* 1.5382	* 1.5674	* 1.5496	* 2.2352	*
13	* 1.4416	* 1.3453	* 1.3809	* 1.1566	* 1.0787	* 1.0814	* .5508	*
	* 1.4281	* 1.5271	* 1.4950	* 1.7166	* 1.5498	* 1.5059	* 3.1926	*
14	* 1.1651	* 1.4122	* 1.3217	* .8541	* .5508	*		*
	* 1.7515	* 1.4510	* 1.5540	* 1.5491	* 2.2361	* 3.1926	*	*
15	* .6509	* .7922	* .7280	* .6340	* F-SUB-Q			
	* 3.0900	* 2.5564	* 2.7796	* 3.2070	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 75 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9061	* 1.4716	* 1.3865	* 1.5308	* 1.4004	* 1.4983	* 1.2001	* .6587
	* 2.0826	* 1.4955	* 1.5657	* 1.4060	* 1.5305	* 1.4246	* 1.7639	* 3.1691
9	* 1.4716	* 1.3507	* 1.5387	* 1.3969	* 1.5223	* 1.3928	* 1.4671	* .8069
	* 1.4955	* 1.6198	* 1.4092	* 1.5482	* 1.4104	* 1.5294	* 1.4482	* 2.6031
10	* 1.3865	* 1.5362	* 1.2696	* 1.4504	* 1.3953	* 1.4388	* 1.3792	* .7424
	* 1.5657	* 1.4115	* 1.7093	* 1.4923	* 1.5482	* 1.4911	* 1.5455	* 2.8327
11	* 1.5308	* 1.3958	* 1.4462	* 1.2997	* 1.3915	* 1.2178	* 1.4018	* .6502
	* 1.4060	* 1.5494	* 1.4967	* 1.6807	* 1.5329	* 1.7183	* 1.5349	* 3.2574
12	* 1.4004	* 1.5213	* 1.3940	* 1.3907	* 1.0650	* 1.1564	* .9051	*
	* 1.5305	* 1.4108	* 1.5495	* 1.5330	* 1.5738	* 1.5446	* 2.2394	*
13	* 1.4983	* 1.3924	* 1.4383	* 1.2174	* 1.1561	* 1.1822	* .5841	*
	* 1.4246	* 1.5298	* 1.4917	* 1.7185	* 1.5448	* 1.4894	* 3.2332	*
14	* 1.2001	* 1.4670	* 1.3790	* 1.4015	* .9046	* .5841	*	*
	* 1.7639	* 1.4483	* 1.5458	* 1.5352	* 2.2405	* 3.2332	*	*
15	* .6587	* .8070	* .7424	* .6501	F-SUB-Q			
	* 3.1691	* 2.6028	* 2.8328	* 3.2580	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9704	* 1.5223	* 1.4167	* 1.5665	* 1.4285	* 1.5319	* 1.2189	* .6640
	* 2.1455	* 1.5325	* 1.6067	* 1.4328	* 1.5645	* 1.4501	* 1.8021	* 3.2582
9	* 1.5223	* 1.3826	* 1.5756	* 1.4239	* 1.5586	* 1.4238	* 1.5016	* .8178
	* 1.5324	* 1.6703	* 1.4410	* 1.5871	* 1.4370	* 1.5584	* 1.4711	* 2.6737
10	* 1.4167	* 1.5730	* 1.2966	* 1.4830	* 1.4311	* 1.4809	* 1.4202	* .7577
	* 1.6067	* 1.4434	* 1.7549	* 1.5300	* 1.5862	* 1.5204	* 1.5717	* 2.8987
11	* 1.5664	* 1.4228	* 1.4786	* 1.3434	* 1.4530	* 1.2777	* 1.4619	* .6675
	* 1.4328	* 1.5877	* 1.5345	* 1.7183	* 1.5579	* 1.7488	* 1.5627	* 3.3498
12	* 1.4285	* 1.5574	* 1.4298	* 1.4521	* 1.1872	* 1.2564	* .9596	*
	* 1.5645	* 1.4374	* 1.5875	* 1.5580	* 1.6036	* 1.5716	* 2.2739	*
13	* 1.5319	* 1.4234	* 1.4802	* 1.2772	* 1.2561	* 1.3040	* .6245	*
	* 1.4501	* 1.5588	* 1.5210	* 1.7492	* 1.5718	* 1.5129	* 3.3178	*
14	* 1.2189	* 1.5015	* 1.4199	* 1.4615	* .9591	* .6245	*	*
	* 1.8021	* 1.4713	* 1.5720	* 1.5630	* 2.2749	* 3.3179	*	*
15	* .6640	* .8178	* .7576	* .6674	F-SUB-Q			
	* 3.2582	* 2.6735	* 2.8989	* 3.3506	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 76 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0570	* 1.5920	* 1.4568	* 1.6150	* 1.4623	* 1.5770	* 1.2439	* .6740 *
	* 2.1978	* 1.5717	* 1.6573	* 1.4684	* 1.6125	* 1.4834	* 1.8561	* 3.3724 *
9	* 1.5920	* 1.4263	* 1.6259	* 1.4597	* 1.6071	* 1.4639	* 1.5494	* .8355 *
	* 1.5717	* 1.7267	* 1.4785	* 1.6375	* 1.4717	* 1.5978	* 1.5029	* 2.7576 *
10	* 1.4568	* 1.6231	* 1.3228	* 1.5267	* 1.4782	* 1.5365	* 1.4716	* .7691 *
	* 1.6573	* 1.4811	* 1.8241	* 1.5774	* 1.6348	* 1.5560	* 1.6063	* 3.0165 *
11	* 1.6150	* 1.4585	* 1.5221	* 1.3967	* 1.5321	* 1.3562	* 1.5365	* .6844 *
	* 1.4684	* 1.6381	* 1.5822	* 1.7721	* 1.5793	* 1.7742	* 1.5799	* 3.4845 *
12	* 1.4623	* 1.6059	* 1.4768	* 1.5311	* 1.3654	* 1.4200	* 1.0157	*
	* 1.6125	* 1.4721	* 1.6363	* 1.5793	* 1.6292	* 1.5898	* 2.3275	*
13	* 1.5770	* 1.4635	* 1.5358	* 1.3558	* 1.4197	* 1.4587	* .6753	*
	* 1.4834	* 1.5982	* 1.5567	* 1.7747	* 1.5900	* 1.5248	* 3.3713	*
14	* 1.2439	* 1.5491	* 1.4712	* 1.5361	* 1.0150	* .6752	*	
	* 1.8561	* 1.5031	* 1.6068	* 1.5803	* 2.3289	* 3.3714	*	
15	* .6740	* .8355	* .7690	* .6842	* F-SUB-Q			
	* 3.3724	* 2.7575	* 3.0169	* 3.4854	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1511	* 1.6449	* 1.4887	* 1.6516	* 1.4883	* 1.6093	* 1.2634	* .6771 *
	* 2.2884	* 1.6322	* 1.7389	* 1.5347	* 1.6897	* 1.5471	* 1.9421	* 3.5687 *
9	* 1.6449	* 1.4633	* 1.6646	* 1.4880	* 1.6426	* 1.4941	* 1.5851	* .8449 *
	* 1.6322	* 1.8156	* 1.5478	* 1.7176	* 1.5368	* 1.6678	* 1.5647	* 2.9022 *
10	* 1.4887	* 1.6638	* 1.3459	* 1.5621	* 1.5168	* 1.5791	* 1.5108	* .7793 *
	* 1.7389	* 1.5505	* 1.9230	* 1.6546	* 1.7127	* 1.6229	* 1.6726	* 3.1746 *
11	* 1.6516	* 1.4867	* 1.5572	* 1.4418	* 1.5945	* 1.4197	* 1.5968	* .6978 *
	* 1.5347	* 1.7183	* 1.6599	* 1.8334	* 1.6086	* 1.8089	* 1.6102	* 3.6743 *
12	* 1.4883	* 1.6414	* 1.5153	* 1.5934	* 1.5034	* 1.5417	* 1.0653	*
	* 1.6897	* 1.5373	* 1.7143	* 1.6087	* 1.6630	* 1.6212	* 2.3742	*
13	* 1.6093	* 1.4936	* 1.5783	* 1.4192	* 1.5415	* 1.5787	* .7129	*
	* 1.5471	* 1.6683	* 1.6236	* 1.8094	* 1.6215	* 1.5565	* 3.4739	*
14	* 1.2634	* 1.5848	* 1.5103	* 1.5963	* 1.0646	* .7129	*	
	* 1.9421	* 1.5650	* 1.6731	* 1.6107	* 2.3757	* 3.4739	*	
15	* .6771	* .8449	* .7792	* .6976	* F-SUB-Q			
	* 3.5687	* 2.9022	* 3.1752	* 3.6754	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 77 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1900	* 1.6912	* 1.5198	* 1.6893	* 1.5148	* 1.6438	* 1.2833	* .6877 *
	* 2.3999	* 1.6906	* 1.8395	* 1.6147	* 1.7842	* 1.6242	* 2.0471	* 3.7627 *
9	* 1.6912	* 1.4975	* 1.7054	* 1.5162	* 1.6807	* 1.5248	* 1.6218	* .8581 *
	* 1.6906	* 1.9107	* 1.6313	* 1.8157	* 1.6154	* 1.7537	* 1.6402	* 3.0621 *
10	* 1.5198	* 1.7045	* 1.3676	* 1.5982	* 1.5541	* 1.6215	* 1.5494	* .7889 *
	* 1.8395	* 1.6341	* 2.0443	* 1.7477	* 1.8071	* 1.7035	* 1.7537	* 3.3653 *
11	* 1.6893	* 1.5149	* 1.5932	* 1.4828	* 1.6505	* 1.4723	* 1.6532	* .7105 *
	* 1.6147	* 1.8164	* 1.7533	* 1.9018	* 1.6602	* 1.8674	* 1.6579	* 3.8520 *
12	* 1.5148	* 1.6793	* 1.5526	* 1.6504	* 1.5808	* 1.6224	* 1.1035	*
	* 1.7842	* 1.6159	* 1.8089	* 1.6603	* 1.7207	* 1.6697	* 2.4598	*
13	* 1.6438	* 1.5244	* 1.6206	* 1.4718	* 1.6222	* 1.6677	* .7471	*
	* 1.6242	* 1.7542	* 1.7043	* 1.8679	* 1.6699	* 1.5968	* 3.5774	*
14	* 1.2833	* 1.6214	* 1.5489	* 1.6527	* 1.1027	* .7470	*	
	* 2.0471	* 1.6405	* 1.7543	* 1.6584	* 2.4615	* 3.5775	*	
15	* .6877	* .8580	* .7887	* .7103	* F-SUB-Q			
	* 3.7627	* 3.0622	* 3.3660	* 3.8532	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1881	* 1.6898	* 1.5233	* 1.6851	* 1.5151	* 1.6392	* 1.2835	* .6810 *
	* 2.5650	* 1.7981	* 1.9929	* 1.7508	* 1.9292	* 1.7574	* 2.2052	* 4.0888 *
9	* 1.6898	* 1.5003	* 1.7021	* 1.5173	* 1.6780	* 1.5250	* 1.6212	* .8601 *
	* 1.7981	* 2.0258	* 1.7723	* 1.9649	* 1.7495	* 1.8936	* 1.7693	* 3.2903 *
10	* 1.5233	* 1.7012	* 1.3832	* 1.6031	* 1.5612	* 1.6232	* 1.5520	* .8013 *
	* 1.9929	* 1.7754	* 2.1883	* 1.8772	* 1.9140	* 1.8269	* 1.8895	* 3.5722 *
11	* 1.6851	* 1.5161	* 1.5981	* 1.4931	* 1.6712	* 1.4854	* 1.6647	* .7241 *
	* 1.7508	* 1.9656	* 1.8831	* 2.0092	* 1.7672	* 1.9839	* 1.7507	* 4.0084 *
12	* 1.5151	* 1.6765	* 1.5597	* 1.6712	* 1.6081	* 1.6446	* 1.1300	*
	* 1.9292	* 1.7500	* 1.9158	* 1.7673	* 1.8272	* 1.7769	* 2.5810	*
13	* 1.6392	* 1.5245	* 1.6223	* 1.4849	* 1.6443	* 1.6974	* .7574	*
	* 1.7574	* 1.8942	* 1.8278	* 1.9844	* 1.7772	* 1.6946	* 3.8055	*
14	* 1.2835	* 1.6207	* 1.5514	* 1.6642	* 1.1293	* .7574	*	
	* 2.2052	* 1.7698	* 1.8901	* 1.7512	* 2.5824	* 3.8056	*	
15	* .6810	* .8601	* .8011	* .7239	* F-SUB-Q			
	* 4.0888	* 3.2906	* 3.5731	* 4.0097	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 78 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2067	* 1.7314	* 1.5507	* 1.7260	* 1.5419	* 1.6803	* 1.3040	* .6929 *
	* 2.6016	* 1.8041	* 2.0128	* 1.8066	* 2.0200	* 1.8536	* 2.3441	* 4.3360 *
9	* 1.7314	* 1.5252	* 1.7440	* 1.5438	* 1.7205	* 1.5590	* 1.6630	* .8703 *
	* 1.8041	* 2.0482	* 1.7888	* 2.0194	* 1.8123	* 1.9977	* 1.8631	* 3.5082 *
10	* 1.5507	* 1.7430	* 1.3925	* 1.6375	* 1.5960	* 1.6677	* 1.5930	* .8008 *
	* 2.0128	* 1.7897	* 2.2417	* 1.9047	* 1.9560	* 1.8731	* 1.9590	* 3.8572 *
11	* 1.7260	* 1.5425	* 1.6324	* 1.5287	* 1.7265	* 1.5278	* 1.7177	* .7260 *
	* 1.8066	* 2.0211	* 1.9107	* 2.0457	* 1.8123	* 2.0452	* 1.8078	* 4.2582 *
12	* 1.5419	* 1.7190	* 1.5944	* 1.7264	* 1.6577	* 1.7030	* 1.1485	*
	* 2.0200	* 1.8140	* 1.9580	* 1.8124	* 1.8876	* 1.8358	* 2.7083	*
13	* 1.6803	* 1.5584	* 1.6667	* 1.5272	* 1.7027	* 1.7625	* .7809	*
	* 1.8536	* 1.9984	* 1.8742	* 2.0461	* 1.8362	* 1.7551	* 3.9596	*
14	* 1.3040	* 1.6624	* 1.5924	* 1.7170	* 1.1476	* .7809	*	
	* 2.3441	* 1.8636	* 1.9597	* 1.8084	* 2.7103	* 3.9597	*	
15	* .6929	* .8702	* .8006	* .7257	F-SUB-Q			
	* 4.3360	* 3.5085	* 3.8582	* 4.2597	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2024	* 1.7392	* 1.5559	* 1.7344	* 1.5478	* 1.6906	* 1.3086	* .6920 *
	* 2.6670	* 1.8348	* 2.0493	* 1.8350	* 2.0518	* 1.8776	* 2.4249	* 4.5895 *
9	* 1.7392	* 1.5281	* 1.7525	* 1.5486	* 1.7316	* 1.5685	* 1.6756	* .8724 *
	* 1.8348	* 2.0886	* 1.8179	* 2.0546	* 1.8386	* 2.0244	* 1.8973	* 3.6478 *
10	* 1.5559	* 1.7515	* 1.3970	* 1.6471	* 1.6067	* 1.6808	* 1.6070	* .8031 *
	* 2.0493	* 1.8189	* 2.2824	* 1.9344	* 1.9842	* 1.8973	* 1.9847	* 3.9691 *
11	* 1.7344	* 1.5474	* 1.6418	* 1.5397	* 1.7471	* 1.5428	* 1.7373	* .7294 *
	* 1.8350	* 2.0562	* 1.9407	* 2.0739	* 1.8387	* 2.0751	* 1.8397	* 4.3866 *
12	* 1.5478	* 1.7302	* 1.6050	* 1.7470	* 1.6785	* 1.7252	* 1.1606	*
	* 2.0518	* 1.8402	* 1.9862	* 1.8388	* 1.9162	* 1.8641	* 2.7672	*
13	* 1.6906	* 1.5679	* 1.6798	* 1.5422	* 1.7248	* 1.7900	* .7878	*
	* 1.8776	* 2.0252	* 1.8984	* 2.0760	* 1.8644	* 1.7970	* 4.0907	*
14	* 1.3086	* 1.6750	* 1.6063	* 1.7366	* 1.1596	* .7877	*	
	* 2.4249	* 1.8980	* 1.9856	* 1.8405	* 2.7694	* 4.0910	*	
15	* .6920	* .8722	* .8029	* .7291	F-SUB-Q			
	* 4.5895	* 3.6484	* 3.9704	* 4.3885	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 79 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1876	* 1.7183	* 1.5419	* 1.7149	* 1.5352	* 1.6742	* 1.2994	* .6842 *
	* 2.7536	* 1.8936	* 2.1075	* 1.8919	* 2.1079	* 1.9299	* 2.4783	* 4.6901 *
9	* 1.7183	* 1.5127	* 1.7324	* 1.5350	* 1.7164	* 1.5565	* 1.6629	* .8672 *
	* 1.8936	* 2.1506	* 1.8749	* 2.1133	* 1.8928	* 2.0788	* 1.9482	* 3.7317 *
10	* 1.5419	* 1.7314	* 1.3956	* 1.6347	* 1.5971	* 1.6668	* 1.5977	* .8068 *
	* 2.1075	* 1.8759	* 2.3291	* 1.9878	* 2.0369	* 1.9503	* 2.0362	* 4.0192 *
11	* 1.7149	* 1.5338	* 1.6296	* 1.5289	* 1.7387	* 1.5347	* 1.7284	* .7330 *
	* 1.8919	* 2.1149	* 1.9941	* 2.1320	* 1.8893	* 2.1315	* 1.8885	* 4.4485 *
12	* 1.5352	* 1.7150	* 1.5957	* 1.7386	* 1.6751	* 1.7173	* 1.1666	*
	* 2.1079	* 1.8944	* 2.0390	* 1.8894	* 1.9647	* 1.9162	* 2.8145	*
13	* 1.6742	* 1.5559	* 1.6659	* 1.5340	* 1.7170	* 1.7865	* .7844	*
	* 1.9299	* 2.0796	* 1.9514	* 2.1324	* 1.9166	* 1.8446	* 4.2048	*
14	* 1.2994	* 1.6622	* 1.5971	* 1.7277	* 1.1658	* .7844	*	
	* 2.4783	* 1.9489	* 2.0371	* 1.8893	* 2.8164	* 4.2051	*	
15	* .6842	* .8671	* .8065	* .7327	* F-SUB-Q			
	* 4.6901	* 3.7324	* 4.0206	* 4.4505	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1886	* 1.7375	* 1.5497	* 1.7349	* 1.5446	* 1.6971	* 1.3069	* .6887 *
	* 2.6766	* 1.8284	* 2.0448	* 1.8243	* 2.0436	* 1.8612	* 2.4057	* 4.5238 *
9	* 1.7375	* 1.5180	* 1.7525	* 1.5436	* 1.7393	* 1.5732	* 1.6877	* .8723 *
	* 1.8284	* 2.0888	* 1.8096	* 2.0504	* 1.8281	* 2.0118	* 1.8812	* 3.5946 *
10	* 1.5497	* 1.7516	* 1.3887	* 1.6477	* 1.6121	* 1.6911	* 1.6230	* .8000 *
	* 2.0448	* 1.8106	* 2.2819	* 1.9331	* 1.9843	* 1.8864	* 1.9676	* 3.9254 *
11	* 1.7349	* 1.5415	* 1.6425	* 1.5432	* 1.7670	* 1.5558	* 1.7594	* .7287 *
	* 1.8243	* 2.0519	* 1.9391	* 2.0748	* 1.8401	* 2.0733	* 1.8325	* 4.3480 *
12	* 1.5446	* 1.7379	* 1.6107	* 1.7668	* 1.6977	* 1.7488	* 1.1681	*
	* 2.0436	* 1.8297	* 1.9862	* 1.8402	* 1.9278	* 1.8627	* 2.7540	*
13	* 1.6971	* 1.5726	* 1.6901	* 1.5553	* 1.7484	* 1.8235	* .7961	*
	* 1.8612	* 2.0126	* 1.8875	* 2.0742	* 1.8631	* 1.7932	* 4.0398	*
14	* 1.3069	* 1.6870	* 1.6222	* 1.7586	* 1.1671	* .7960	*	
	* 2.4057	* 1.8819	* 1.9684	* 1.8333	* 2.7562	* 4.0400	*	
15	* .6887	* .8722	* .7997	* .7284	* F-SUB-Q			
	* 4.5238	* 3.5952	* 3.9269	* 4.3499	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 80 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1722	* 1.7326	* 1.5419	* 1.7312	* 1.5383	* 1.6967	* 1.3023	* .6822 *
	* 2.4983	* 1.6904	* 1.8951	* 1.6892	* 1.8991	* 1.7251	* 2.2345	* 4.2250 *
9	* 1.7326	* 1.5083	* 1.7486	* 1.5369	* 1.7386	* 1.5718	* 1.6903	* .8675 *
	* 1.6904	* 1.9376	* 1.6740	* 1.9032	* 1.6917	* 1.8651	* 1.7387	* 3.3492 *
10	* 1.5419	* 1.7477	* 1.3771	* 1.6425	* 1.6093	* 1.6920	* 1.6269	* .7935 *
	* 1.8951	* 1.6748	* 2.1229	* 1.7891	* 1.8349	* 1.7419	* 1.8172	* 3.6652 *
11	* 1.7312	* 1.5347	* 1.6372	* 1.5398	* 1.7711	* 1.5581	* 1.7661	* .7232 *
	* 1.6892	* 1.9046	* 1.7946	* 1.9154	* 1.6982	* 1.9167	* 1.6883	* 4.0497 *
12	* 1.5383	* 1.7372	* 1.6078	* 1.7710	* 1.7011	* 1.7551	* 1.1656	*
	* 1.8991	* 1.6932	* 1.8367	* 1.6983	* 1.7795	* 1.7176	* 2.5552	*
13	* 1.6967	* 1.5711	* 1.6910	* 1.5576	* 1.7547	* 1.8347	* .7940	*
	* 1.7251	* 1.8658	* 1.7430	* 1.9176	* 1.7180	* 1.6491	* 3.7507	*
14	* 1.3023	* 1.6896	* 1.6261	* 1.7653	* 1.1646	* .7939	*	
	* 2.2345	* 1.7394	* 1.8180	* 1.6891	* 2.5573	* 3.7509	*	
15	* .6822	* .8673	* .7932	* .7228	* F-SUB-Q			
	* 4.2250	* 3.3498	* 3.6667	* 4.0516	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1568	* 1.7151	* 1.5254	* 1.7148	* 1.5232	* 1.6832	* 1.2904	* .6750 *
	* 2.3515	* 1.5873	* 1.7807	* 1.5861	* 1.7800	* 1.6135	* 2.0937	* 3.9677 *
9	* 1.7151	* 1.4906	* 1.7318	* 1.5216	* 1.7251	* 1.5591	* 1.6792	* .8594 *
	* 1.5873	* 1.8219	* 1.5718	* 1.7884	* 1.5875	* 1.7466	* 1.6297	* 3.1447 *
10	* 1.5254	* 1.7308	* 1.3660	* 1.6281	* 1.5968	* 1.6797	* 1.6173	* .7875 *
	* 1.7807	* 1.5726	* 1.9909	* 1.6773	* 1.7202	* 1.6333	* 1.7039	* 3.4439 *
11	* 1.7148	* 1.5194	* 1.6228	* 1.5278	* 1.7614	* 1.5487	* 1.7572	* .7178 *
	* 1.5861	* 1.7897	* 1.6825	* 1.7941	* 1.5849	* 1.7925	* 1.5772	* 3.8002 *
12	* 1.5232	* 1.7236	* 1.5954	* 1.7613	* 1.6924	* 1.7464	* 1.1600	*
	* 1.7800	* 1.5888	* 1.7219	* 1.5850	* 1.6602	* 1.6041	* 2.3863	*
13	* 1.6832	* 1.5585	* 1.6787	* 1.5482	* 1.7460	* 1.8285	* .7883	*
	* 1.6135	* 1.7473	* 1.6343	* 1.7934	* 1.6045	* 1.5392	* 3.5161	*
14	* 1.2904	* 1.6785	* 1.6166	* 1.7563	* 1.1590	* .7882	*	
	* 2.0937	* 1.6304	* 1.7047	* 1.5779	* 2.3883	* 3.5163	*	
15	* .6750	* .8592	* .7872	* .7174	* F-SUB-Q			
	* 3.9677	* 3.1453	* 3.4454	* 3.8021	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 81 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1337	* 1.6803	* 1.4980	* 1.6810	* 1.4970	* 1.6520	* 1.2698	* .6616 *
	* 2.2421	* 1.5137	* 1.6918	* 1.5077	* 1.6892	* 1.5350	* 1.9882	* 3.7862 *
9	* 1.6803	* 1.4629	* 1.6973	* 1.4953	* 1.6938	* 1.5329	* 1.6512	* .8486 *
	* 1.5137	* 1.7339	* 1.4957	* 1.6956	* 1.5082	* 1.6573	* 1.5464	* 2.9735 *
10	* 1.4980	* 1.6964	* 1.3529	* 1.6008	* 1.5715	* 1.6497	* 1.5915	* .7846 *
	* 1.6918	* 1.4964	* 1.8744	* 1.5913	* 1.6344	* 1.5553	* 1.6195	* 3.2249 *
11	* 1.6810	* 1.4932	* 1.5957	* 1.5063	* 1.7333	* 1.5251	* 1.7295	* .7152 *
	* 1.5077	* 1.6968	* 1.5962	* 1.7065	* 1.5048	* 1.7028	* 1.5002	* 3.5766 *
12	* 1.4970	* 1.6924	* 1.5701	* 1.7332	* 1.6693	* 1.7181	* 1.1517	*
	* 1.6892	* 1.5095	* 1.6360	* 1.5048	* 1.5710	* 1.5229	* 2.2484	*
13	* 1.6520	* 1.5322	* 1.6487	* 1.5245	* 1.7178	* 1.8024	* .7757	*
	* 1.5350	* 1.6580	* 1.5562	* 1.7036	* 1.5233	* 1.4573	* 3.3406	*
14	* 1.2698	* 1.6504	* 1.5907	* 1.7287	* 1.1508	* .7756	*	*
	* 1.9882	* 1.5471	* 1.6203	* 1.5009	* 2.2501	* 3.3408	*	*
15	* .6616	* .8485	* .7842	* .7148	* F-SUB-Q			
	* 3.7862	* 2.9742	* 3.2263	* 3.5784	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1295	* 1.6892	* 1.4952	* 1.6899	* 1.4951	* 1.6631	* 1.2671	* .6619 *
	* 2.1017	* 1.4097	* 1.5876	* 1.4077	* 1.5898	* 1.4347	* 1.8757	* 3.5659 *
9	* 1.6892	* 1.4586	* 1.7067	* 1.4929	* 1.7042	* 1.5379	* 1.6632	* .8447 *
	* 1.4097	* 1.6275	* 1.3945	* 1.5945	* 1.4072	* 1.5531	* 1.4425	* 2.8116 *
10	* 1.4952	* 1.7058	* 1.3368	* 1.6026	* 1.5736	* 1.6612	* 1.6024	* .7693 *
	* 1.5876	* 1.3952	* 1.7815	* 1.4888	* 1.5289	* 1.4483	* 1.5104	* 3.0928 *
11	* 1.6899	* 1.4908	* 1.5975	* 1.5067	* 1.7460	* 1.5316	* 1.7446	* .7020 *
	* 1.4077	* 1.5956	* 1.4935	* 1.5941	* 1.4024	* 1.5964	* 1.3971	* 3.4174 *
12	* 1.4951	* 1.7028	* 1.5722	* 1.7459	* 1.6761	* 1.7334	* 1.1397	*
	* 1.5898	* 1.4083	* 1.5305	* 1.4024	* 1.4657	* 1.4186	* 2.1389	*
13	* 1.6631	* 1.5373	* 1.6601	* 1.5310	* 1.7330	* 1.8205	* .7774	*
	* 1.4347	* 1.5537	* 1.4492	* 1.5969	* 1.4189	* 1.3567	* 3.1410	*
14	* 1.2671	* 1.6624	* 1.6016	* 1.7437	* 1.1387	* .7774	*	*
	* 1.8757	* 1.4432	* 1.5112	* 1.3978	* 2.1408	* 3.1412	*	*
15	* .6619	* .8445	* .7690	* .7016	* F-SUB-Q			
	* 3.5659	* 2.8121	* 3.0942	* 3.4192	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 82 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1135	* 1.6691	* 1.4761	* 1.6699	* 1.4765	* 1.6448	* 1.2514	* .6535 *
	* 2.0090	* 1.3495	* 1.5222	* 1.3500	* 1.5268	* 1.3766	* 1.8035	* 3.4328 *
9	* 1.6691	* 1.4394	* 1.6867	* 1.4750	* 1.6861	* 1.5206	* 1.6462	* .8347 *
	* 1.3495	* 1.5601	* 1.3361	* 1.5286	* 1.3467	* 1.4899	* 1.3821	* 2.7017 *
10	* 1.4761	* 1.6859	* 1.3215	* 1.5860	* 1.5572	* 1.6436	* 1.5851	* .7588 *
	* 1.5222	* 1.3367	* 1.7071	* 1.4234	* 1.4607	* 1.3859	* 1.4462	* 2.9758 *
11	* 1.6699	* 1.4730	* 1.5809	* 1.4904	* 1.7288	* 1.5149	* 1.7273	* .6924 *
	* 1.3500	* 1.5306	* 1.4279	* 1.5230	* 1.3327	* 1.5203	* 1.3317	* 3.2794 *
12	* 1.4765	* 1.6847	* 1.5559	* 1.7287	* 1.6604	* 1.7163	* 1.1253	*
	* 1.5268	* 1.3478	* 1.4620	* 1.3328	* 1.3897	* 1.3484	* 2.0427	*
13	* 1.6448	* 1.5199	* 1.6426	* 1.5144	* 1.7159	* 1.8030	* .7672	*
	* 1.3766	* 1.4905	* 1.3868	* 1.5208	* 1.3487	* 1.2914	* 3.0021	*
14	* 1.2514	* 1.6454	* 1.5843	* 1.7264	* 1.1242	* .7671	*	
	* 1.8035	* 1.3827	* 1.4470	* 1.3323	* 2.0445	* 3.0023	*	
15	* .6535	* .8345	* .7585	* .6920	* F-SUB-Q			
	* 3.4328	* 2.7022	* 2.9771	* 3.2812	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0832	* 1.6134	* 1.4370	* 1.6136	* 1.4376	* 1.5903	* 1.2196	* .6334 *
	* 1.9721	* 1.3341	* 1.4947	* 1.3364	* 1.5007	* 1.3629	* 1.7722	* 3.3958 *
9	* 1.6134	* 1.4022	* 1.6301	* 1.4376	* 1.6324	* 1.4756	* 1.5928	* .8161 *
	* 1.3341	* 1.5306	* 1.3218	* 1.4996	* 1.3297	* 1.4690	* 1.3671	* 2.6471 *
10	* 1.4370	* 1.6293	* 1.3051	* 1.5457	* 1.5185	* 1.5906	* 1.5326	* .7527 *
	* 1.4947	* 1.3224	* 1.6516	* 1.3957	* 1.4298	* 1.3689	* 1.4281	* 2.8731 *
11	* 1.6136	* 1.4357	* 1.5409	* 1.4530	* 1.6743	* 1.4701	* 1.6693	* .6863 *
	* 1.3364	* 1.5016	* 1.3999	* 1.4948	* 1.3099	* 1.4916	* 1.3138	* 3.1631 *
12	* 1.4376	* 1.6311	* 1.5172	* 1.6742	* 1.6172	* 1.6598	* 1.1063	*
	* 1.5007	* 1.3307	* 1.4310	* 1.3100	* 1.3568	* 1.3262	* 1.9794	*
13	* 1.5903	* 1.4750	* 1.5896	* 1.4696	* 1.6595	* 1.7408	* .7420	*
	* 1.3629	* 1.4696	* 1.3697	* 1.4922	* 1.3265	* 1.2702	* 2.9539	*
14	* 1.2196	* 1.5920	* 1.5318	* 1.6684	* 1.1055	* .7420	*	
	* 1.7722	* 1.3677	* 1.4288	* 1.3145	* 1.9810	* 2.9541	*	
15	* .6334	* .8159	* .7523	* .6859	* F-SUB-Q			
	* 3.3958	* 2.6476	* 2.8744	* 3.1648	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 83 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0764	* 1.5947	* 1.4201	* 1.5918	* 1.4200	* 1.5712	* 1.2030	* .6260 *
	* 1.9145	* 1.3018	* 1.4590	* 1.3072	* 1.4664	* 1.3315	* 1.7353	* 3.3224 *
9	* 1.5947	* 1.3875	* 1.6091	* 1.4191	* 1.6121	* 1.4580	* 1.5741	* .8046 *
	* 1.3018	* 1.4919	* 1.2917	* 1.4658	* 1.2987	* 1.4346	* 1.3339	* 2.5942 *
10	* 1.4201	* 1.6085	* 1.2779	* 1.5261	* 1.5028	* 1.5739	* 1.5100	* .7330 *
	* 1.4590	* 1.2923	* 1.6273	* 1.3634	* 1.3923	* 1.3341	* 1.3968	* 2.8500 *
11	* 1.5918	* 1.4173	* 1.5215	* 1.4312	* 1.6530	* 1.4512	* 1.6445	* .6671 *
	* 1.3072	* 1.4677	* 1.3675	* 1.4660	* 1.2768	* 1.4538	* 1.2840	* 3.1405 *
12	* 1.4200	* 1.6108	* 1.5015	* 1.6529	* 1.6019	* 1.6408	* 1.0772	*
	* 1.4664	* 1.2997	* 1.3935	* 1.2769	* 1.3171	* 1.2901	* 1.9572	*
13	* 1.5712	* 1.4573	* 1.5730	* 1.4507	* 1.6404	* 1.7111	* .7314	*
	* 1.3315	* 1.4352	* 1.3349	* 1.4543	* 1.2904	* 1.2413	* 2.8843	*
14	* 1.2030	* 1.5733	* 1.5092	* 1.6436	* 1.0763	* .7313	*	
	* 1.7353	* 1.3345	* 1.3975	* 1.2846	* 1.9589	* 2.8845	*	
15	* .6260	* .8045	* .7326	* .6667	* F-SUB-Q			
	* 3.3224	* 2.5948	* 2.8513	* 3.1421	* M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0518	* 1.5251	* 1.3559	* 1.5178	* 1.3484	* 1.5026	* 1.1521	* .5959 *
	* 1.9069	* 1.3236	* 1.4876	* 1.3334	* 1.5043	* 1.3543	* 1.7642	* 3.4042 *
9	* 1.5251	* 1.3361	* 1.5336	* 1.3490	* 1.5363	* 1.3948	* 1.5044	* .7737 *
	* 1.3236	* 1.5072	* 1.3181	* 1.4973	* 1.3253	* 1.4587	* 1.3577	* 2.6286 *
10	* 1.3559	* 1.5331	* 1.2164	* 1.4358	* 1.4315	* 1.5104	* 1.4552	* .7114 *
	* 1.4876	* 1.3182	* 1.6602	* 1.4102	* 1.4214	* 1.3517	* 1.4056	* 2.8605 *
11	* 1.5178	* 1.3478	* 1.4318	* 1.3548	* 1.5809	* 1.3880	* 1.5502	* .6413 *
	* 1.3334	* 1.4986	* 1.4141	* 1.5055	* 1.2964	* 1.4763	* 1.3227	* 3.1804 *
12	* 1.3484	* 1.5352	* 1.4305	* 1.5808	* 1.5438	* 1.5704	* 1.0220	*
	* 1.5043	* 1.3262	* 1.4225	* 1.2965	* 1.3267	* 1.3085	* 2.0051	*
13	* 1.5026	* 1.3942	* 1.5096	* 1.3876	* 1.5700	* 1.6158	* .6989	*
	* 1.3543	* 1.4593	* 1.3524	* 1.4767	* 1.3088	* 1.2750	* 2.9343	*
14	* 1.1521	* 1.5037	* 1.4545	* 1.5495	* 1.0213	* .6988	*	
	* 1.7642	* 1.3584	* 1.4063	* 1.3234	* 2.0067	* 2.9346	*	
15	* .5959	* .7735	* .7111	* .6410	* F-SUB-Q			
	* 3.4042	* 2.6292	* 2.8619	* 3.1820	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 84 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9505 *	* 1.4648 *	* 1.1311 *	* 1.4286 *	* 1.1292 *	* 1.4053 *	* .9848 *	* .5131 *
	* 2.0702 *	* 1.3479 *	* 1.7452 *	* 1.3883 *	* 1.7576 *	* 1.4182 *	* 2.0241 *	* 3.8838 *
9	* 1.4648 *	* 1.1113 *	* 1.4704 *	* 1.1094 *	* 1.4487 *	* 1.2155 *	* 1.3958 *	* .6722 *
	* 1.3479 *	* 1.7751 *	* 1.3455 *	* 1.7846 *	* 1.3758 *	* 1.6391 *	* 1.4324 *	* 2.9692 *
10	* 1.1311 *	* 1.4701 *	* 1.0762 *	* 1.2021 *	* 1.2236 *	* 1.4085 *	* 1.3852 *	* .6371 *
	* 1.7452 *	* 1.3458 *	* 1.8363 *	* 1.6507 *	* 1.6299 *	* 1.4195 *	* 1.4446 *	* 3.1343 *
11	* 1.4286 *	* 1.1090 *	* 1.1994 *	* 1.1633 *	* 1.4551 *	* 1.2156 *	* 1.3356 *	* .5567 *
	* 1.3883 *	* 1.7851 *	* 1.6544 *	* 1.7191 *	* 1.3767 *	* 1.6493 *	* 1.5025 *	* 3.5946 *
12	* 1.1292 *	* 1.4479 *	* 1.2228 *	* 1.4548 *	* 1.3485 *	* 1.5066 *	* .8820 *	
	* 1.7576 *	* 1.3765 *	* 1.6310 *	* 1.3770 *	* 1.4861 *	* 1.3344 *	* 2.2756 *	
13	* 1.4053 *	* 1.2149 *	* 1.4078 *	* 1.2152 *	* 1.5063 *	* 1.3777 *	* .6095 *	
	* 1.4182 *	* 1.6398 *	* 1.4202 *	* 1.6499 *	* 1.3346 *	* 1.4624 *	* 3.2982 *	
14	* .9848 *	* 1.3951 *	* 1.3845 *	* 1.3350 *	* .8814 *	* .6094 *		
	* 2.0241 *	* 1.4331 *	* 1.4453 *	* 1.5032 *	* 2.2772 *	* 3.2988 *		
15	* .5131 *	* .6720 *	* .6367 *	* .5564 *	F-SUB-Q			
	* 3.8838 *	* 2.9701 *	* 3.1360 *	* 3.5965 *	M-SUB-Q			

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7113 *	* .6091 *	* .5350 *	* .6063 *	* .5318 *	* .5957 *	* .4671 *	* .3592 *
	* 2.7247 *	* 3.1797 *	* 3.6255 *	* 3.2092 *	* 3.6660 *	* 3.2827 *	* 4.1938 *	* 5.4676 *
9	* .6091 *	* .5305 *	* .6051 *	* .5271 *	* .6123 *	* .5483 *	* .5399 *	* .3190 *
	* 3.1797 *	* 3.6557 *	* 3.2076 *	* 3.6913 *	* 3.1933 *	* 3.5660 *	* 3.6337 *	* 6.1615 *
10	* .5350 *	* .6053 *	* .5396 *	* .5160 *	* .5458 *	* .6068 *	* .5588 *	* .3109 *
	* 3.6255 *	* 3.2062 *	* 3.5998 *	* 3.7859 *	* 3.5971 *	* 3.2304 *	* 3.5143 *	* 6.3223 *
11	* .6063 *	* .5271 *	* .5156 *	* .5558 *	* .6250 *	* .5512 *	* .5132 *	* .2735 *
	* 3.2092 *	* 3.6911 *	* 3.7888 *	* 3.5330 *	* 3.1425 *	* 3.5725 *	* 3.8349 *	* 7.2021 *
12	* .5318 *	* .6120 *	* .5455 *	* .6249 *	* .5858 *	* .5872 *	* .4115 *	
	* 3.6660 *	* 3.1948 *	* 3.5988 *	* 3.1430 *	* 3.3570 *	* 3.3571 *	* 4.7932 *	
13	* .5957 *	* .5481 *	* .6065 *	* .5510 *	* .5871 *	* .5334 *	* .4281 *	
	* 3.2827 *	* 3.5671 *	* 3.2320 *	* 3.5733 *	* 3.3578 *	* 3.7029 *	* 4.6205 *	
14	* .4671 *	* .5397 *	* .5585 *	* .5129 *	* .4116 *	* .4280 *		
	* 4.1938 *	* 3.6355 *	* 3.5160 *	* 3.8366 *	* 4.7921 *	* 4.6217 *		
15	* .3592 *	* .3188 *	* .3107 *	* .2734 *	F-SUB-Q			
	* 5.4676 *	* 6.1642 *	* 6.3253 *	* 7.2057 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 85 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5474 *	* .4997 *	* .4641 *	* .5332 *	* .4704 *	* .5182 *	* .4208 *	* .3540 *
	* 3.1163 *	* 3.8117 *	* 4.0715 *	* 3.5346 *	* 3.9883 *	* 3.6159 *	* 4.4334 *	* 5.2183 *
9	* .4997 *	* .4587 *	* .5222 *	* .4664 *	* .5262 *	* .4750 *	* .4552 *	* .2946 *
	* 3.8117 *	* 4.1459 *	* 3.6185 *	* 4.0349 *	* 3.5673 *	* 3.9497 *	* 4.0982 *	* 6.2734 *
10	* .4641 *	* .5222 *	* .4722 *	* .4414 *	* .4515 *	* .4949 *	* .4572 *	* .2805 *
	* 4.0715 *	* 3.6185 *	* 4.0121 *	* 4.2685 *	* 4.1445 *	* 3.7711 *	* 4.0694 *	* 6.5997 *
11	* .5332 *	* .4666 *	* .4407 *	* .3914 *	* .4416 *	* .4124 *	* .3990 *	* .2386 *
	* 3.5346 *	* 4.0331 *	* 4.2754 *	* 4.5134 *	* 4.0108 *	* 4.5150 *	* 4.6606 *	* 7.7187 *
12	* .4704 *	* .5260 *	* .4514 *	* .4415 *	* .3474 *	* .3459 *	* .2918 *	
	* 3.9883 *	* 3.5677 *	* 4.1451 *	* 4.0111 *	* 4.2347 *	* 4.2718 *	* 5.8927 *	
13	* .5182 *	* .4750 *	* .4949 *	* .4123 *	* .3459 *	* .3012 *	* .2971 *	
	* 3.6159 *	* 3.9501 *	* 3.7715 *	* 4.5153 *	* 4.2719 *	* 4.6874 *	* 5.2800 *	
14	* .4208 *	* .4554 *	* .4572 *	* .3990 *	* .2919 *	* .2970 *		
	* 4.4334 *	* 4.0964 *	* 4.0689 *	* 4.6608 *	* 5.8898 *	* 5.2819 *		
15	* .3540 *	* .2948 *	* .2806 *	* .2386 *	F-SUB-Q			
	* 5.2183 *	* 6.2687 *	* 6.5976 *	* 7.7185 *	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7020 *	* 1.1175 *	* .9668 *	* 1.1803 *	* .9761 *	* 1.1517 *	* .8546 *	* .4893 *
	* 2.3944 *	* 1.7599 *	* 2.0195 *	* 1.6481 *	* 1.9859 *	* 1.6817 *	* 2.2598 *	* 3.8957 *
9	* 1.1175 *	* .9453 *	* 1.1877 *	* .9637 *	* 1.1675 *	* 1.0014 *	* 1.1060 *	* .6155 *
	* 1.7599 *	* 2.0715 *	* 1.6455 *	* 2.0179 *	* 1.6590 *	* 1.9310 *	* 1.7429 *	* 3.1032 *
10	* .9668 *	* 1.1874 *	* .9302 *	* .9649 *	* .9742 *	* 1.0886 *	* 1.0719 *	* .5821 *
	* 2.0195 *	* 1.6460 *	* 2.0967 *	* 2.0185 *	* 1.9847 *	* 1.7727 *	* 1.7914 *	* 3.2729 *
11	* 1.1803 *	* .9634 *	* .9628 *	* .8280 *	* .9730 *	* .8625 *	* .9665 *	* .4927 *
	* 1.6481 *	* 2.0186 *	* 2.0227 *	* 2.2767 *	* 1.8655 *	* 2.1746 *	* 1.9915 *	* 3.8614 *
12	* .9761 *	* 1.1673 *	* .9739 *	* .9727 *	* .7352 *	* .8396 *	* .6129 *	
	* 1.9859 *	* 1.6592 *	* 1.9852 *	* 1.8657 *	* 1.9873 *	* 1.8091 *	* 2.8877 *	
13	* 1.1517 *	* 1.0013 *	* 1.0885 *	* .8623 *	* .8395 *	* .7556 *	* .4078 *	
	* 1.6817 *	* 1.9312 *	* 1.7729 *	* 2.1748 *	* 1.8092 *	* 1.9811 *	* 3.9616 *	
14	* .8546 *	* 1.1063 *	* 1.0720 *	* .9664 *	* .6128 *	* .4078 *		
	* 2.2598 *	* 1.7425 *	* 1.7913 *	* 1.9916 *	* 2.8882 *	* 3.9619 *		
15	* .4893 *	* .6158 *	* .5823 *	* .4927 *	F-SUB-Q			
	* 3.8957 *	* 3.1019 *	* 3.2721 *	* 3.8614 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 86 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7934 *	* 1.2429 *	* 1.1738 *	* 1.2976 *	* 1.1762 *	* 1.2789 *	* 1.0197 *	* .5739 *
	* 2.1528 *	* 1.6230 *	* 1.7058 *	* 1.5358 *	* 1.6896 *	* 1.5517 *	* 1.9332 *	* 3.3981 *
9	* 1.2429 *	* 1.1419 *	* 1.2866 *	* 1.1702 *	* 1.2898 *	* 1.1900 *	* 1.2486 *	* .7160 *
	* 1.6230 *	* 1.7636 *	* 1.5617 *	* 1.7023 *	* 1.5418 *	* 1.6637 *	* 1.5812 *	* 2.7270 *
10	* 1.1738 *	* 1.2862 *	* 1.0695 *	* 1.1718 *	* 1.1567 *	* 1.2176 *	* 1.1843 *	* .6737 *
	* 1.7058 *	* 1.5621 *	* 1.8758 *	* 1.7080 *	* 1.7212 *	* 1.6300 *	* 1.6685 *	* 2.8986 *
11	* 1.2976 *	* 1.1696 *	* 1.1690 *	* 1.0196 *	* 1.1146 *	* 1.0153 *	* 1.1571 *	* .5791 *
	* 1.5358 *	* 1.7033 *	* 1.7120 *	* 1.9488 *	* 1.7101 *	* 1.8844 *	* 1.7136 *	* 3.3825 *
12	* 1.1762 *	* 1.2896 *	* 1.1560 *	* 1.1141 *	* .8656 *	* .9395 *	* .7464 *	
	* 1.6896 *	* 1.5421 *	* 1.7221 *	* 1.7101 *	* 1.7331 *	* 1.6987 *	* 2.4497 *	
13	* 1.2789 *	* 1.1898 *	* 1.2173 *	* 1.0151 *	* .9394 *	* .9179 *	* .4801 *	
	* 1.5517 *	* 1.6639 *	* 1.6304 *	* 1.8846 *	* 1.6988 *	* 1.6922 *	* 3.4895 *	
14	* 1.0197 *	* 1.2488 *	* 1.1843 *	* 1.1570 *	* .7462 *	* .4801 *		
	* 1.9332 *	* 1.5809 *	* 1.6685 *	* 1.7138 *	* 2.4502 *	* 3.4894 *		
15	* .5739 *	* .7163 *	* .6739 *	* .5791 *	F-SUB-Q			
	* 3.3981 *	* 2.7262 *	* 2.8982 *	* 3.3826 *	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8631 *	* 1.3938 *	* 1.2975 *	* 1.4500 *	* 1.3185 *	* 1.4294 *	* 1.1366 *	* .6266 *
	* 2.0675 *	* 1.4996 *	* 1.5940 *	* 1.4186 *	* 1.5551 *	* 1.4315 *	* 1.7835 *	* 3.1964 *
9	* 1.3938 *	* 1.2638 *	* 1.4411 *	* 1.2982 *	* 1.4418 *	* 1.3229 *	* 1.4001 *	* .7735 *
	* 1.4996 *	* 1.6466 *	* 1.4402 *	* 1.5877 *	* 1.4237 *	* 1.5432 *	* 1.4542 *	* 2.6038 *
10	* 1.2975 *	* 1.4406 *	* 1.1528 *	* 1.3009 *	* 1.2750 *	* 1.3607 *	* 1.3193 *	* .7153 *
	* 1.5940 *	* 1.4410 *	* 1.7946 *	* 1.5864 *	* 1.6160 *	* 1.5104 *	* 1.5502 *	* 2.8217 *
11	* 1.4500 *	* 1.2975 *	* 1.2975 *	* 1.1457 *	* 1.2585 *	* 1.1384 *	* 1.3081 *	* .6187 *
	* 1.4186 *	* 1.5881 *	* 1.5904 *	* 1.8115 *	* 1.5821 *	* 1.7492 *	* 1.5723 *	* 3.2780 *
12	* 1.3185 *	* 1.4415 *	* 1.2741 *	* 1.2578 *	* .9646 *	* 1.0753 *	* .8297 *	
	* 1.5551 *	* 1.4240 *	* 1.6170 *	* 1.5822 *	* 1.6247 *	* 1.5655 *	* 2.3083 *	
13	* 1.4294 *	* 1.3227 *	* 1.3603 *	* 1.1382 *	* 1.0751 *	* 1.0673 *	* .5381 *	
	* 1.4315 *	* 1.5434 *	* 1.5109 *	* 1.7495 *	* 1.5656 *	* 1.5409 *	* 3.2880 *	
14	* 1.1366 *	* 1.4002 *	* 1.3192 *	* 1.3079 *	* .8293 *	* .5381 *		
	* 1.7835 *	* 1.4541 *	* 1.5504 *	* 1.5725 *	* 2.3092 *	* 3.2880 *		
15	* .6266 *	* .7737 *	* .7154 *	* .6186 *	F-SUB-Q			
	* 3.1964 *	* 2.6033 *	* 2.8214 *	* 3.2783 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 87 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9150	* 1.4877	* 1.3624	* 1.5369	* 1.3825	* 1.5160	* 1.1899	* .6483
	* 2.0879	* 1.4781	* 1.5884	* 1.3936	* 1.5434	* 1.4023	* 1.7706	* 3.2174
9	* 1.4877	* 1.3261	* 1.5310	* 1.3603	* 1.5291	* 1.3990	* 1.4899	* .8056
	* 1.4781	* 1.6468	* 1.4195	* 1.5809	* 1.3964	* 1.5161	* 1.4199	* 2.5984
10	* 1.3624	* 1.5304	* 1.2034	* 1.3652	* 1.3417	* 1.4482	* 1.4093	* .7467
	* 1.5884	* 1.4201	* 1.7984	* 1.5820	* 1.6053	* 1.4788	* 1.5096	* 2.8094
11	* 1.5369	* 1.3596	* 1.3615	* 1.2104	* 1.3518	* 1.2229	* 1.4087	* .6485
	* 1.3936	* 1.5813	* 1.5863	* 1.8017	* 1.5495	* 1.7177	* 1.5299	* 3.2670
12	* 1.3825	* 1.5287	* 1.3408	* 1.3511	* 1.0603	* 1.1843	* .8982	*
	* 1.5434	* 1.3967	* 1.6064	* 1.5496	* 1.6030	* 1.5304	* 2.2727	*
13	* 1.5160	* 1.3988	* 1.4477	* 1.2225	* 1.1841	* 1.1969	* .5840	*
	* 1.4023	* 1.5164	* 1.4793	* 1.7180	* 1.5305	* 1.4967	* 3.2698	*
14	* 1.1899	* 1.4898	* 1.4091	* 1.4084	* .8977	* .5840	*	*
	* 1.7706	* 1.4200	* 1.5099	* 1.5302	* 2.2739	* 3.2698	*	*
15	* .6483	* .8058	* .7467	* .6484	* F-SUB-Q			
	* 3.2174	* 2.5980	* 2.8094	* 3.2676	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0024	* 1.5649	* 1.4119	* 1.5950	* 1.4279	* 1.5743	* 1.2277	* .6656
	* 2.1231	* 1.4963	* 1.6126	* 1.4049	* 1.5635	* 1.4101	* 1.7872	* 3.2621
9	* 1.5649	* 1.3778	* 1.5959	* 1.4053	* 1.5879	* 1.4530	* 1.5533	* .8306
	* 1.4963	* 1.6797	* 1.4357	* 1.6035	* 1.4064	* 1.5259	* 1.4230	* 2.6327
10	* 1.4119	* 1.5952	* 1.2448	* 1.4125	* 1.3943	* 1.5129	* 1.4765	* .7756
	* 1.6126	* 1.4363	* 1.8295	* 1.6087	* 1.6286	* 1.4889	* 1.5134	* 2.8338
11	* 1.5950	* 1.4046	* 1.4087	* 1.2656	* 1.4331	* 1.3005	* 1.4904	* .6769
	* 1.4049	* 1.6039	* 1.6131	* 1.8140	* 1.5552	* 1.7247	* 1.5372	* 3.3123
12	* 1.4279	* 1.5875	* 1.3933	* 1.4323	* 1.2143	* 1.3200	* .9686	*
	* 1.5635	* 1.4067	* 1.6298	* 1.5553	* 1.6134	* 1.5359	* 2.2764	*
13	* 1.5743	* 1.4527	* 1.5123	* 1.3001	* 1.3198	* 1.3446	* .6348	*
	* 1.4101	* 1.5262	* 1.4894	* 1.7250	* 1.5360	* 1.5000	* 3.3101	*
14	* 1.2277	* 1.5531	* 1.4762	* 1.4901	* .9681	* .6348	*	*
	* 1.7872	* 1.4232	* 1.5137	* 1.5376	* 2.2774	* 3.3101	*	*
15	* .6656	* .8306	* .7755	* .6768	* F-SUB-Q			
	* 3.2621	* 2.6325	* 2.8340	* 3.3130	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 88 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1231	* 1.6550	* 1.4670	* 1.6617	* 1.4770	* 1.6400	* 1.2680	* .6852
	* 2.1570	* 1.5229	* 1.6524	* 1.4287	* 1.6002	* 1.4301	* 1.8253	* 3.3411
9	* 1.6550	* 1.4425	* 1.6702	* 1.4548	* 1.6542	* 1.5119	* 1.6239	* .8593
	* 1.5229	* 1.7250	* 1.4615	* 1.6436	* 1.4283	* 1.5509	* 1.4390	* 2.6901
10	* 1.4670	* 1.6695	* 1.2815	* 1.4664	* 1.4531	* 1.5861	* 1.5501	* .7973
	* 1.6524	* 1.4622	* 1.8913	* 1.6505	* 1.6675	* 1.5105	* 1.5313	* 2.9202
11	* 1.6617	* 1.4540	* 1.4624	* 1.3275	* 1.5265	* 1.3901	* 1.5851	* .7023
	* 1.4287	* 1.6440	* 1.6550	* 1.8322	* 1.5638	* 1.7364	* 1.5440	* 3.4118
12	* 1.4770	* 1.6538	* 1.4520	* 1.5259	* 1.4085	* 1.4983	* 1.0343	*
	* 1.6002	* 1.4286	* 1.6688	* 1.5639	* 1.6265	* 1.5397	* 2.3112	*
13	* 1.6400	* 1.5115	* 1.5854	* 1.3897	* 1.4981	* 1.5129	* .6922	*
	* 1.4301	* 1.5513	* 1.5110	* 1.7367	* 1.5399	* 1.4992	* 3.3369	*
14	* 1.2680	* 1.6237	* 1.5497	* 1.5847	* 1.0337	* .6922	*	*
	* 1.8253	* 1.4393	* 1.5316	* 1.5444	* 2.3126	* 3.3369	*	*
15	* .6852	* .8593	* .7972	* .7021	* F-SUB-Q			
	* 3.3411	* 2.6900	* 2.9205	* 3.4127	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1987	* 1.7221	* 1.5144	* 1.7127	* 1.5150	* 1.6884	* 1.2994	* .6949
	* 2.2325	* 1.5773	* 1.7267	* 1.4856	* 1.6691	* 1.4829	* 1.8989	* 3.5101
9	* 1.7221	* 1.4939	* 1.7263	* 1.4932	* 1.7032	* 1.5564	* 1.6772	* .8770
	* 1.5773	* 1.8064	* 1.5223	* 1.7168	* 1.4829	* 1.6096	* 1.4878	* 2.8129
10	* 1.5144	* 1.7258	* 1.3121	* 1.5087	* 1.4997	* 1.6417	* 1.6071	* .8156
	* 1.7267	* 1.5230	* 1.9871	* 1.7266	* 1.7399	* 1.5661	* 1.5833	* 3.0519
11	* 1.7127	* 1.4924	* 1.5045	* 1.3968	* 1.6178	* 1.4614	* 1.6598	* .7218
	* 1.4856	* 1.7172	* 1.7315	* 1.8620	* 1.5847	* 1.7599	* 1.5651	* 3.5736
12	* 1.5150	* 1.7028	* 1.4985	* 1.6177	* 1.5346	* 1.6235	* 1.0907	*
	* 1.6691	* 1.4833	* 1.7413	* 1.5848	* 1.6520	* 1.5612	* 2.3451	*
13	* 1.6884	* 1.5559	* 1.6410	* 1.4610	* 1.6232	* 1.6386	* .7338	*
	* 1.4829	* 1.6101	* 1.5667	* 1.7603	* 1.5614	* 1.5212	* 3.4176	*
14	* 1.2994	* 1.6768	* 1.6066	* 1.6593	* 1.0900	* .7338	*	*
	* 1.8989	* 1.4882	* 1.5838	* 1.5655	* 2.3465	* 3.4177	*	*
15	* .6949	* .8770	* .8155	* .7216	* F-SUB-Q			
	* 3.5101	* 2.8129	* 3.0524	* 3.5746	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 89 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2410	* 1.7788	* 1.5563	* 1.7611	* 1.5502	* 1.7355	* 1.3281	* .7103 *
	* 2.3353	* 1.6243	* 1.8235	* 1.5590	* 1.7574	* 1.5517	* 1.9953	* 3.6856 *
9	* 1.7788	* 1.5353	* 1.7782	* 1.5284	* 1.7508	* 1.5979	* 1.7279	* .8966 *
	* 1.6243	* 1.8833	* 1.6010	* 1.8114	* 1.5538	* 1.6876	* 1.5529	* 2.9567 *
10	* 1.5563	* 1.7777	* 1.3382	* 1.5488	* 1.5422	* 1.6946	* 1.6596	* .8313 *
	* 1.8235	* 1.6017	* 2.1104	* 1.8223	* 1.8327	* 1.6386	* 1.6533	* 3.2216 *
11	* 1.7611	* 1.5276	* 1.5445	* 1.4560	* 1.6998	* 1.5214	* 1.7265	* .7390 *
	* 1.5590	* 1.8119	* 1.8275	* 1.9236	* 1.6312	* 1.8133	* 1.6060	* 3.7352 *
12	* 1.5502	* 1.7503	* 1.5410	* 1.6997	* 1.6147	* 1.7111	* 1.1336	*
	* 1.7574	* 1.5541	* 1.8341	* 1.6312	* 1.7055	* 1.6029	* 2.4224	*
13	* 1.7355	* 1.5974	* 1.6938	* 1.5210	* 1.7108	* 1.7332	* .7705	*
	* 1.5517	* 1.6882	* 1.6393	* 1.8137	* 1.6031	* 1.5562	* 3.5102	*
14	* 1.3281	* 1.7275	* 1.6591	* 1.7260	* 1.1329	* .7705	*	
	* 1.9953	* 1.5533	* 1.6538	* 1.6065	* 2.4240	* 3.5102	*	
15	* .7103	* .8965	* .8311	* .7387	* F-SUB-Q			
	* 3.6856	* 2.9568	* 3.2223	* 3.7363	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2423	* 1.7837	* 1.5654	* 1.7636	* 1.5568	* 1.7388	* 1.3349	* .7075 *
	* 2.4963	* 1.7267	* 1.9669	* 1.6883	* 1.8958	* 1.6762	* 2.1458	* 3.9942 *
9	* 1.7837	* 1.5435	* 1.7816	* 1.5348	* 1.7541	* 1.6050	* 1.7353	* .9036 *
	* 1.7267	* 1.9982	* 1.7233	* 1.9588	* 1.6803	* 1.8197	* 1.6720	* 3.1689 *
10	* 1.5654	* 1.7811	* 1.3578	* 1.5572	* 1.5538	* 1.7031	* 1.6712	* .8484 *
	* 1.9669	* 1.7238	* 2.2543	* 1.9541	* 1.9427	* 1.7593	* 1.7733	* 3.4125 *
11	* 1.7636	* 1.5340	* 1.5529	* 1.4800	* 1.7254	* 1.5474	* 1.7442	* .7564 *
	* 1.6883	* 1.9593	* 1.9596	* 2.0329	* 1.7331	* 1.9202	* 1.6891	* 3.8777 *
12	* 1.5568	* 1.7536	* 1.5525	* 1.7254	* 1.6454	* 1.7387	* 1.1654	*
	* 1.8958	* 1.6807	* 1.9442	* 1.7332	* 1.8086	* 1.7018	* 2.5336	*
13	* 1.7388	* 1.6045	* 1.7023	* 1.5469	* 1.7384	* 1.7673	* .7835	*
	* 1.6762	* 1.8202	* 1.7600	* 1.9206	* 1.7019	* 1.6488	* 3.7241	*
14	* 1.3349	* 1.7348	* 1.6707	* 1.7436	* 1.1647	* .7835	*	
	* 2.1458	* 1.6725	* 1.7739	* 1.6896	* 2.5350	* 3.7242	*	
15	* .7075	* .9036	* .8482	* .7562	* F-SUB-Q			
	* 3.9942	* 3.1691	* 3.4133	* 3.8789	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 90 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2639	* 1.8309	* 1.5954	* 1.8094	* 1.5868	* 1.7868	* 1.3594	* .7212 *
	* 2.5210	* 1.7318	* 1.9862	* 1.7490	* 1.9918	* 1.7680	* 2.2828	* 4.2377 *
9	* 1.8308	* 1.5709	* 1.8285	* 1.5630	* 1.8018	* 1.6441	* 1.7863	* .9166 *
	* 1.7318	* 2.0190	* 1.7321	* 2.0246	* 1.7544	* 1.9218	* 1.7600	* 3.3799 *
10	* 1.5954	* 1.8280	* 1.3671	* 1.5903	* 1.5886	* 1.7531	* 1.7209	* .8507 *
	* 1.9862	* 1.7326	* 2.3192	* 1.9929	* 1.9956	* 1.8079	* 1.8402	* 3.6805 *
11	* 1.8094	* 1.5622	* 1.5857	* 1.5185	* 1.7841	* 1.5928	* 1.8032	* .7597 *
	* 1.7490	* 2.0257	* 1.9987	* 2.0956	* 1.7835	* 1.9922	* 1.7446	* 4.1205 *
12	* 1.5868	* 1.8013	* 1.5874	* 1.7841	* 1.6971	* 1.8028	* 1.1847	*
	* 1.9918	* 1.7548	* 1.9972	* 1.7836	* 1.8758	* 1.7589	* 2.6585	*
13	* 1.7868	* 1.6435	* 1.7522	* 1.5924	* 1.8025	* 1.8372	* .8080	*
	* 1.7680	* 1.9226	* 1.8088	* 1.9927	* 1.7591	* 1.7051	* 3.8735	*
14	* 1.3594	* 1.7857	* 1.7202	* 1.8025	* 1.1839	* .8079	*	*
	* 2.2828	* 1.7605	* 1.8408	* 1.7452	* 2.6604	* 3.8736	*	*
15	* .7212	* .9165	* .8504	* .7594	* F-SUB-Q			
	* 4.2377	* 3.3802	* 3.6814	* 4.1219	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2604	* 1.8402	* 1.6011	* 1.8192	* 1.5936	* 1.8000	* 1.3659	* .7213 *
	* 2.5742	* 1.7546	* 2.0147	* 1.7692	* 2.0150	* 1.7826	* 2.3479	* 4.4488 *
9	* 1.8402	* 1.5743	* 1.8382	* 1.5680	* 1.8144	* 1.6554	* 1.8029	* .9203 *
	* 1.7546	* 2.0517	* 1.7535	* 2.0522	* 1.7703	* 1.9392	* 1.7824	* 3.4943 *
10	* 1.6011	* 1.8377	* 1.3707	* 1.5979	* 1.5986	* 1.7686	* 1.7383	* .8546 *
	* 2.0147	* 1.7540	* 2.3538	* 2.0189	* 2.0192	* 1.8243	* 1.8553	* 3.7691 *
11	* 1.8192	* 1.5671	* 1.5933	* 1.5338	* 1.8060	* 1.6109	* 1.8251	* .7642 *
	* 1.7692	* 2.0533	* 2.0248	* 2.1175	* 1.8019	* 2.0172	* 1.7727	* 4.2351 *
12	* 1.5936	* 1.8139	* 1.5973	* 1.8060	* 1.7183	* 1.8273	* 1.1979	*
	* 2.0150	* 1.7707	* 2.0208	* 1.8020	* 1.8966	* 1.7824	* 2.7145	*
13	* 1.8000	* 1.6548	* 1.7677	* 1.6105	* 1.8270	* 1.8665	* .8154	*
	* 1.7826	* 1.9399	* 1.8252	* 2.0178	* 1.7827	* 1.7461	* 4.0017	*
14	* 1.3659	* 1.8023	* 1.7376	* 1.8244	* 1.1970	* .8154	*	*
	* 2.3479	* 1.7830	* 1.8560	* 1.7734	* 2.7165	* 4.0019	*	*
15	* .7213	* .9202	* .8543	* .7639	* F-SUB-Q			
	* 4.4488	* 3.4946	* 3.7702	* 4.2368	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 91 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2438	* 1.8172	* 1.5854	* 1.7976	* 1.5798	* 1.7825	* 1.3565	* .7137 *
	* 2.6486	* 1.8027	* 2.0636	* 1.8140	* 2.0584	* 1.8222	* 2.3882	* 4.5280 *
9	* 1.8172	* 1.5571	* 1.8158	* 1.5528	* 1.7960	* 1.6432	* 1.7895	* .9154 *
	* 1.8027	* 2.1038	* 1.8011	* 2.1021	* 1.8125	* 1.9801	* 1.8226	* 3.5518 *
10	* 1.5854	* 1.8152	* 1.3677	* 1.5832	* 1.5868	* 1.7539	* 1.7275	* .8587 *
	* 2.0636	* 1.8016	* 2.3923	* 2.0682	* 2.0657	* 1.8678	* 1.8946	* 3.7999 *
11	* 1.7976	* 1.5520	* 1.5787	* 1.5285	* 1.7966	* 1.6055	* 1.8151	* .7682 *
	* 1.8140	* 2.1032	* 2.0740	* 2.1622	* 1.8444	* 2.0609	* 1.8127	* 4.2748 *
12	* 1.5798	* 1.7955	* 1.5854	* 1.7965	* 1.7134	* 1.8186	* 1.2049	*
	* 2.0584	* 1.8130	* 2.0674	* 1.8445	* 1.9378	* 1.8250	* 2.7471	*
13	* 1.7825	* 1.6427	* 1.7530	* 1.6050	* 1.8182	* 1.8619	* .8120	*
	* 1.8222	* 1.9808	* 1.8688	* 2.0616	* 1.8254	* 1.7859	* 4.0947	*
14	* 1.3565	* 1.7888	* 1.7268	* 1.8144	* 1.2042	* .8120	*	
	* 2.3882	* 1.8233	* 1.8954	* 1.8134	* 2.7489	* 4.0949	*	
15	* .7137	* .9153	* .8584	* .7679	F-SUB-Q			
	* 4.5280	* 3.5521	* 3.8011	* 4.2766	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2419	* 1.8328	* 1.5884	* 1.8137	* 1.5848	* 1.8031	* 1.3614	* .7166 *
	* 2.5450	* 1.7210	* 1.9804	* 1.7334	* 1.9793	* 1.7424	* 2.2962	* 4.3219 *
9	* 1.8328	* 1.5578	* 1.8319	* 1.5553	* 1.8156	* 1.6552	* 1.8144	* .9191 *
	* 1.7210	* 2.0209	* 1.7189	* 2.0174	* 1.7319	* 1.9013	* 1.7397	* 3.3898 *
10	* 1.5884	* 1.8313	* 1.3556	* 1.5888	* 1.5942	* 1.7753	* 1.7512	* .8505 *
	* 1.9804	* 1.7194	* 2.3155	* 1.9840	* 1.9840	* 1.7827	* 1.8088	* 3.6688 *
11	* 1.8137	* 1.5545	* 1.5842	* 1.5380	* 1.8211	* 1.6205	* 1.8442	* .7621 *
	* 1.7334	* 2.0184	* 1.9894	* 2.0860	* 1.7762	* 1.9890	* 1.7384	* 4.1265 *
12	* 1.5848	* 1.8151	* 1.5928	* 1.8210	* 1.7316	* 1.8481	* 1.2026	*
	* 1.9793	* 1.7323	* 1.9856	* 1.7763	* 1.8803	* 1.7552	* 2.6642	*
13	* 1.8031	* 1.6544	* 1.7744	* 1.6200	* 1.8477	* 1.8969	* .8217	*
	* 1.7424	* 1.9021	* 1.7836	* 1.9896	* 1.7556	* 1.7161	* 3.9015	*
14	* 1.3614	* 1.8136	* 1.7504	* 1.8435	* 1.2017	* .8217	*	
	* 2.2962	* 1.7404	* 1.8095	* 1.7390	* 2.6663	* 3.9017	*	
15	* .7166	* .9189	* .8502	* .7617	F-SUB-Q			
	* 4.3219	* 3.3904	* 3.6702	* 4.1284	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 92 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2200	* 1.8202	* 1.5732	* 1.8021	* 1.5714	* 1.7960	* 1.3516	* .7072 *
	* 2.3805	* 1.5949	* 1.8401	* 1.6053	* 1.8377	* 1.6120	* 2.1305	* 4.0335 *
9	* 1.8202	* 1.5407	* 1.8198	* 1.5404	* 1.8073	* 1.6461	* 1.8115	* .9111 *
	* 1.5949	* 1.8797	* 1.5928	* 1.8746	* 1.6030	* 1.7617	* 1.6076	* 3.1560 *
10	* 1.5732	* 1.8192	* 1.3374	* 1.5750	* 1.5826	* 1.7696	* 1.7491	* .8411 *
	* 1.8401	* 1.5933	* 2.1598	* 1.8421	* 1.8416	* 1.6496	* 1.6721	* 3.4250 *
11	* 1.8021	* 1.5396	* 1.5704	* 1.5303	* 1.8182	* 1.6153	* 1.8446	* .7537 *
	* 1.6053	* 1.8755	* 1.8473	* 1.9269	* 1.6378	* 1.8376	* 1.6004	* 3.8512 *
12	* 1.5714	* 1.8068	* 1.5813	* 1.8181	* 1.7276	* 1.8485	* 1.1957	* .8165 *
	* 1.8377	* 1.6034	* 1.8431	* 1.6379	* 1.7357	* 1.6181	* 2.4688	* .8165 *
13	* 1.7960	* 1.6454	* 1.7686	* 1.6148	* 1.8482	* 1.9020	* 1.8165	* .8165 *
	* 1.6120	* 1.7625	* 1.6504	* 1.8382	* 1.6184	* 1.5806	* 3.6229	* .8165 *
14	* 1.3516	* 1.8107	* 1.7482	* 1.8438	* 1.1947	* .8164	* .8164	* .8164 *
	* 2.1305	* 1.6083	* 1.6729	* 1.6010	* 2.4708	* 3.6230	* 3.6230	* 3.6230 *
15	* .7072	* .9109	* .8407	* .7533	* F-SUB-Q			
	* 4.0335	* 3.1566	* 3.4264	* 3.8530	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1963	* 1.7903	* 1.5462	* 1.7750	* 1.5463	* 1.7712	* 1.3316	* .6961 *
	* 2.2411	* 1.4976	* 1.7292	* 1.5080	* 1.7269	* 1.5117	* 2.0002	* 3.7940 *
9	* 1.7903	* 1.5128	* 1.7905	* 1.5143	* 1.7815	* 1.6232	* 1.7899	* .8978 *
	* 1.4976	* 1.7676	* 1.4961	* 1.7645	* 1.5050	* 1.6534	* 1.5085	* 2.9682 *
10	* 1.5462	* 1.7900	* 1.3168	* 1.5504	* 1.5592	* 1.7466	* 1.7288	* .8303 *
	* 1.7292	* 1.4965	* 2.0281	* 1.7294	* 1.7280	* 1.5473	* 1.5672	* 3.2199 *
11	* 1.7750	* 1.5135	* 1.5459	* 1.5105	* 1.7976	* 1.5961	* 1.8250	* .7440 *
	* 1.5080	* 1.7653	* 1.7342	* 1.8060	* 1.5337	* 1.7221	* 1.4983	* 3.6158 *
12	* 1.5463	* 1.7810	* 1.5579	* 1.7975	* 1.7084	* 1.8297	* 1.1834	* .8062 *
	* 1.7269	* 1.5054	* 1.7294	* 1.5338	* 1.6247	* 1.5148	* 2.3115	* .8062 *
13	* 1.7712	* 1.6224	* 1.7456	* 1.5956	* 1.8295	* 1.8852	* .8063	* .8063 *
	* 1.5117	* 1.6541	* 1.5481	* 1.7226	* 1.5151	* 1.4755	* 3.3991	* .8063 *
14	* 1.3316	* 1.7891	* 1.7280	* 1.8242	* 1.1824	* .8062	* .8062	* .8062 *
	* 2.0002	* 1.5091	* 1.5679	* 1.4990	* 2.3135	* 3.3993	* 3.3993	* 3.3993 *
15	* .6961	* .8976	* .8299	* .7436	* F-SUB-Q			
	* 3.7940	* 2.9689	* 3.2213	* 3.6175	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 93 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1618	* 1.7385	* 1.5050	* 1.7258	* 1.5067	* 1.7238	* 1.2998	* .6771 *
	* 2.1465	* 1.4353	* 1.6525	* 1.4413	* 1.6473	* 1.4454	* 1.9086	* 3.6370 *
9	* 1.7385	* 1.4715	* 1.7393	* 1.4745	* 1.7345	* 1.5839	* 1.7454	* .8798 *
	* 1.4353	* 1.6909	* 1.4323	* 1.6823	* 1.4381	* 1.5754	* 1.4378	* 2.8199 *
10	* 1.5050	* 1.7388	* 1.2931	* 1.5109	* 1.5215	* 1.7014	* 1.6871	* .8205 *
	* 1.6525	* 1.4326	* 1.9199	* 1.6503	* 1.6497	* 1.4790	* 1.4964	* 3.0314 *
11	* 1.7258	* 1.4738	* 1.5065	* 1.4767	* 1.7546	* 1.5603	* 1.7815	* .7358 *
	* 1.4413	* 1.6830	* 1.6549	* 1.7172	* 1.4590	* 1.6367	* 1.4294	* 3.4134 *
12	* 1.5067	* 1.7337	* 1.5204	* 1.7545	* 1.6710	* 1.7865	* 1.1669	*
	* 1.6473	* 1.4385	* 1.6511	* 1.4591	* 1.5404	* 1.4404	* 2.1798	*
13	* 1.7238	* 1.5832	* 1.7004	* 1.5597	* 1.7862	* 1.8434	* .7876	*
	* 1.4454	* 1.5761	* 1.4797	* 1.6373	* 1.4408	* 1.4007	* 3.2341	*
14	* 1.2998	* 1.7446	* 1.6863	* 1.7807	* 1.1661	* .7876	*	
	* 1.9086	* 1.4384	* 1.4971	* 1.4300	* 2.1814	* 3.2343	*	
15	* .6771	* .8796	* .8201	* .7354	* F-SUB-Q			
	* 3.6370	* 2.8205	* 3.0328	* 3.4151	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1431	* 1.7257	* 1.4830	* 1.7141	* 1.4859	* 1.7143	* 1.2815	* .6690 *
	* 2.0314	* 1.3494	* 1.5654	* 1.3600	* 1.5656	* 1.3635	* 1.8175	* 3.4599 *
9	* 1.7257	* 1.4483	* 1.7269	* 1.4527	* 1.7247	* 1.5667	* 1.7384	* .8653 *
	* 1.3494	* 1.6029	* 1.3476	* 1.5981	* 1.3562	* 1.4931	* 1.3530	* 2.6912 *
10	* 1.4830	* 1.7264	* 1.2591	* 1.4928	* 1.5043	* 1.6925	* 1.6790	* .7956 *
	* 1.5654	* 1.3480	* 1.8433	* 1.5604	* 1.5599	* 1.3909	* 1.4073	* 2.9324 *
11	* 1.7141	* 1.4521	* 1.4885	* 1.4589	* 1.7465	* 1.5452	* 1.7767	* .7136 *
	* 1.3600	* 1.5988	* 1.5648	* 1.6270	* 1.3710	* 1.5481	* 1.3420	* 3.2929 *
12	* 1.4859	* 1.7239	* 1.5032	* 1.7464	* 1.6576	* 1.7819	* 1.1404	*
	* 1.5656	* 1.3566	* 1.5612	* 1.3710	* 1.4488	* 1.3515	* 2.0919	*
13	* 1.7143	* 1.5659	* 1.6915	* 1.5447	* 1.7817	* 1.8413	* .7799	*
	* 1.3635	* 1.4938	* 1.3917	* 1.5486	* 1.3518	* 1.3125	* 3.0642	*
14	* 1.2815	* 1.7375	* 1.6781	* 1.7758	* 1.1394	* .7798	*	
	* 1.8175	* 1.3537	* 1.4080	* 1.3426	* 2.0938	* 3.0644	*	
15	* .6690	* .8651	* .7953	* .7132	* F-SUB-Q			
	* 3.4599	* 2.6918	* 2.9337	* 3.2946	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 94 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1082	* 1.6771	* 1.4401	* 1.6672	* 1.4440	* 1.6685	* 1.2457	* .6502 *
	* 1.9708	* 1.3100	* 1.5219	* 1.3230	* 1.5242	* 1.3263	* 1.7713	* 3.3765 *
9	* 1.6771	* 1.4057	* 1.6790	* 1.4113	* 1.6791	* 1.5249	* 1.6937	* .8419 *
	* 1.3100	* 1.5582	* 1.3090	* 1.5549	* 1.3187	* 1.4516	* 1.3138	* 2.6213 *
10	* 1.4401	* 1.6785	* 1.2242	* 1.4542	* 1.4655	* 1.6484	* 1.6349	* .7727 *
	* 1.5219	* 1.3094	* 1.7912	* 1.5125	* 1.5125	* 1.3497	* 1.3657	* 2.8599 *
11	* 1.6672	* 1.4111	* 1.4499	* 1.4211	* 1.7030	* 1.5054	* 1.7323	* .6932 *
	* 1.3230	* 1.5556	* 1.5168	* 1.5700	* 1.3201	* 1.4935	* 1.2964	* 3.2030 *
12	* 1.4440	* 1.6783	* 1.4645	* 1.7029	* 1.6169	* 1.7376	* 1.1092	*
	* 1.5242	* 1.3191	* 1.5137	* 1.3202	* 1.3924	* 1.3018	* 2.0237	*
13	* 1.6685	* 1.5242	* 1.6475	* 1.5049	* 1.7373	* 1.7967	* .7582	*
	* 1.3263	* 1.4523	* 1.3504	* 1.4940	* 1.3021	* 1.2649	* 2.9668	*
14	* 1.2457	* 1.6929	* 1.6341	* 1.7314	* 1.1082	* .7582	*	
	* 1.7713	* 1.3144	* 1.3664	* 1.2971	* 2.0255	* 2.9670	*	
15	* .6502	* .8417	* .7723	* .6928	* F-SUB-Q			
	* 3.3765	* 2.6218	* 2.8612	* 3.2047	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0533	* 1.5862	* 1.3727	* 1.5780	* 1.3776	* 1.5794	* 1.1895	* .6179 *
	* 1.9764	* 1.3211	* 1.5233	* 1.3351	* 1.5263	* 1.3387	* 1.7736	* 3.4012 *
9	* 1.5862	* 1.3405	* 1.5885	* 1.3469	* 1.5910	* 1.4523	* 1.6040	* .8065 *
	* 1.3211	* 1.5586	* 1.3202	* 1.5560	* 1.3304	* 1.4556	* 1.3246	* 2.6170 *
10	* 1.3727	* 1.5881	* 1.1860	* 1.3907	* 1.4018	* 1.5628	* 1.5479	* .7503 *
	* 1.5233	* 1.3205	* 1.7650	* 1.5091	* 1.5087	* 1.3582	* 1.3763	* 2.8158 *
11	* 1.5780	* 1.3467	* 1.3868	* 1.3594	* 1.6171	* 1.4370	* 1.6402	* .6738 *
	* 1.3351	* 1.5566	* 1.5132	* 1.5618	* 1.3214	* 1.4876	* 1.3036	* 3.1460 *
12	* 1.3776	* 1.5903	* 1.4008	* 1.6170	* 1.5437	* 1.6459	* 1.0705	*
	* 1.5263	* 1.3308	* 1.5099	* 1.3214	* 1.3850	* 1.3049	* 1.9952	*
13	* 1.5794	* 1.4517	* 1.5619	* 1.4365	* 1.6457	* 1.7005	* .7199	*
	* 1.3387	* 1.4562	* 1.3590	* 1.4882	* 1.3051	* 1.2676	* 2.9704	*
14	* 1.1895	* 1.6032	* 1.5472	* 1.6394	* 1.0697	* .7199	*	
	* 1.7736	* 1.3252	* 1.3770	* 1.3042	* 1.9967	* 2.9706	*	
15	* .6179	* .8063	* .7500	* .6735	* F-SUB-Q			
	* 3.4013	* 2.6176	* 2.8171	* 3.1476	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 95 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0132	* 1.5217	* 1.3179	* 1.5130	* 1.3233	* 1.5158	* 1.1405	* .5939 *
	* 1.9787	* 1.3263	* 1.5284	* 1.3422	* 1.5315	* 1.3446	* 1.7842	* 3.4175 *
9	* 1.5217	* 1.2878	* 1.5235	* 1.2932	* 1.5276	* 1.3934	* 1.5388	* .7728 *
	* 1.3263	* 1.5627	* 1.3260	* 1.5620	* 1.3358	* 1.4620	* 1.3301	* 2.6358 *
10	* 1.3179	* 1.5232	* 1.1318	* 1.3403	* 1.3522	* 1.5029	* 1.4825	* .7102 *
	* 1.5284	* 1.3263	* 1.7829	* 1.5088	* 1.5069	* 1.3603	* 1.3841	* 2.8702 *
11	* 1.5130	* 1.2931	* 1.3366	* 1.3074	* 1.5540	* 1.3814	* 1.5722	* .6369 *
	* 1.3422	* 1.5626	* 1.5129	* 1.5622	* 1.3218	* 1.4872	* 1.3080	* 3.2086 *
12	* 1.3233	* 1.5270	* 1.3513	* 1.5539	* 1.4876	* 1.5801	* 1.0141	*
	* 1.5315	* 1.3364	* 1.5081	* 1.3219	* 1.3808	* 1.3045	* 2.0259	*
13	* 1.5158	* 1.3929	* 1.5021	* 1.3809	* 1.5798	* 1.6272	* .6906	*
	* 1.3446	* 1.4626	* 1.3611	* 1.4877	* 1.3048	* 1.2714	* 2.9777	*
14	* 1.1405	* 1.5381	* 1.4818	* 1.5715	* 1.0132	* .6906	*	
	* 1.7842	* 1.3308	* 1.3848	* 1.3086	* 2.0276	* 2.9779	*	
15	* .5939	* .7726	* .7099	* .6366	* F-SUB-Q			
	* 3.4175	* 2.6364	* 2.8715	* 3.2102	* M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9486	* 1.3942	* 1.2173	* 1.3860	* 1.2234	* 1.3907	* 1.0523	* .5466 *
	* 2.0552	* 1.4065	* 1.6083	* 1.4241	* 1.6116	* 1.4245	* 1.8813	* 3.6187 *
9	* 1.3942	* 1.1922	* 1.3938	* 1.1932	* 1.4044	* 1.2796	* 1.4096	* .7157 *
	* 1.4065	* 1.6407	* 1.4086	* 1.6472	* 1.4120	* 1.5475	* 1.4110	* 2.7709 *
10	* 1.2173	* 1.3937	* 1.0506	* 1.2285	* 1.2518	* 1.3851	* 1.3699	* .6624 *
	* 1.6083	* 1.4087	* 1.8648	* 1.6012	* 1.5817	* 1.4339	* 1.4543	* 2.9953 *
11	* 1.3860	* 1.1931	* 1.2254	* 1.2116	* 1.4301	* 1.2697	* 1.4283	* .5908 *
	* 1.4241	* 1.6478	* 1.6052	* 1.6372	* 1.3939	* 1.5706	* 1.3978	* 3.3657 *
12	* 1.2234	* 1.4038	* 1.2510	* 1.4300	* 1.3809	* 1.4506	* .9294	*
	* 1.6116	* 1.4126	* 1.5827	* 1.3939	* 1.4432	* 1.3784	* 2.1472	*
13	* 1.3907	* 1.2791	* 1.3844	* 1.2693	* 1.4503	* 1.4787	* .6372	*
	* 1.4245	* 1.5481	* 1.4346	* 1.5711	* 1.3786	* 1.3565	* 3.1360	*
14	* 1.0523	* 1.4089	* 1.3692	* 1.4276	* .9287	* .6371	*	
	* 1.8813	* 1.4116	* 1.4550	* 1.3985	* 2.1489	* 3.1363	*	
15	* .5466	* .7155	* .6621	* .5905	* F-SUB-Q			
	* 3.6187	* 2.7715	* 2.9967	* 3.3674	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 96 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8182 *	* 1.2597 *	* .9663 *	* 1.2309 *	* .9725 *	* 1.2298 *	* .8590 *	* .4545 *
	* 2.3364 *	* 1.5225 *	* 1.9844 *	* 1.5674 *	* 1.9864 *	* 1.5771 *	* 2.2594 *	* 4.2738 *
9	* 1.2597 *	* .9494 *	* 1.2545 *	* .9449 *	* 1.2551 *	* 1.0549 *	* 1.2313 *	* .5958 *
	* 1.5225 *	* 2.0182 *	* 1.5320 *	* 2.0392 *	* 1.5446 *	* 1.8374 *	* 1.5812 *	* 3.2652 *
10	* .9663 *	* 1.2543 *	* .9054 *	* 1.0004 *	* 1.0426 *	* 1.2332 *	* 1.2254 *	* .5657 *
	* 1.9844 *	* 1.5322 *	* 2.1204 *	* 1.9268 *	* 1.8626 *	* 1.5774 *	* 1.5900 *	* 3.4404 *
11	* 1.2309 *	* .9449 *	* .9983 *	* .9892 *	* 1.2600 *	* 1.0518 *	* 1.1717 *	* .4927 *
	* 1.5674 *	* 2.0393 *	* 1.9309 *	* 1.9663 *	* 1.5480 *	* 1.8547 *	* 1.6675 *	* 3.9588 *
12	* .9725 *	* 1.2545 *	* 1.0421 *	* 1.2597 *	* 1.1563 *	* 1.3110 *	* .7679 *	
	* 1.9864 *	* 1.5453 *	* 1.8634 *	* 1.5484 *	* 1.6860 *	* 1.4923 *	* 2.5450 *	
13	* 1.2298 *	* 1.0544 *	* 1.2327 *	* 1.0515 *	* 1.3108 *	* 1.2008 *	* .5336 *	
	* 1.5771 *	* 1.8381 *	* 1.5781 *	* 1.8553 *	* 1.4926 *	* 1.6331 *	* 3.6694 *	
14	* .8590 *	* 1.2307 *	* 1.2249 *	* 1.1712 *	* .7674 *	* .5336 *		
	* 2.2594 *	* 1.5819 *	* 1.5907 *	* 1.6683 *	* 2.5467 *	* 3.6700 *		
15	* .4545 *	* .5956 *	* .5654 *	* .4924 *	F-SUB-Q			
	* 4.2738 *	* 3.2661 *	* 3.4422 *	* 3.9607 *	M-SUB-Q			

AT 75% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5878 *	* .5094 *	* .4425 *	* .5070 *	* .4455 *	* .5063 *	* .3972 *	* .3100 *
	* 3.2045 *	* 3.6954 *	* 4.2603 *	* 3.7321 *	* 4.2704 *	* 3.7597 *	* 4.8050 *	* 6.1757 *
9	* .5094 *	* .4388 *	* .5038 *	* .4378 *	* .5163 *	* .4609 *	* .4641 *	* .2765 *
	* 3.6954 *	* 4.2951 *	* 3.7434 *	* 4.3310 *	* 3.6860 *	* 4.1289 *	* 4.1181 *	* 6.9282 *
10	* .4425 *	* .5041 *	* .4449 *	* .4271 *	* .4569 *	* .5151 *	* .4804 *	* .2693 *
	* 4.2603 *	* 3.7418 *	* 4.2433 *	* 4.4486 *	* 4.1825 *	* 3.7043 *	* 3.9813 *	* 7.1146 *
11	* .5070 *	* .4378 *	* .4268 *	* .4607 *	* .5241 *	* .4623 *	* .4410 *	* .2368 *
	* 3.7321 *	* 4.3304 *	* 4.4516 *	* 4.1480 *	* 3.6475 *	* 4.1466 *	* 4.3458 *	* 8.1108 *
12	* .4455 *	* .5161 *	* .4567 *	* .5240 *	* .4903 *	* .4982 *	* .3496 *	
	* 4.2704 *	* 3.6875 *	* 4.1843 *	* 3.6480 *	* 3.9035 *	* 3.8528 *	* 5.4962 *	
13	* .5063 *	* .4608 *	* .5149 *	* .4622 *	* .4981 *	* .4542 *	* .3648 *	
	* 3.7597 *	* 4.1301 *	* 3.7059 *	* 4.1475 *	* 3.8535 *	* 4.2344 *	* 5.2837 *	
14	* .3972 *	* .4639 *	* .4802 *	* .4408 *	* .3497 *	* .3647 *		
	* 4.8050 *	* 4.1200 *	* 3.9830 *	* 4.3477 *	* 5.4949 *	* 5.2850 *		
15	* .3100 *	* .2764 *	* .2692 *	* .2367 *	F-SUB-Q			
	* 6.1757 *	* 6.9311 *	* 7.1178 *	* 8.1147 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 97 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .4974 *	* .4684 *	* .4327 *	* .5055 *	* .4487 *	* .5018 *	* .4049 *	* .3492 *
	* 3.5204 *	* 4.1577 *	* 4.4627 *	* 3.8088 *	* 4.2770 *	* 3.8258 *	* 4.7217 *	* 5.4215 *
9	* .4684 *	* .4238 *	* .4902 *	* .4366 *	* .5048 *	* .4515 *	* .4466 *	* .2911 *
	* 4.1577 *	* 4.5710 *	* 3.9409 *	* 4.4077 *	* 3.7999 *	* 4.2557 *	* 4.2789 *	* 6.5075 *
10	* .4327 *	* .4902 *	* .4339 *	* .4142 *	* .4293 *	* .4785 *	* .4467 *	* .2773 *
	* 4.4627 *	* 3.9407 *	* 4.4620 *	* 4.6466 *	* 4.4573 *	* 3.9900 *	* 4.2643 *	* 6.8377 *
11	* .5055 *	* .4368 *	* .4140 *	* .3672 *	* .4244 *	* .3913 *	* .3933 *	* .2363 *
	* 3.8088 *	* 4.4057 *	* 4.6489 *	* 4.9142 *	* 4.2912 *	* 4.8617 *	* 4.8331 *	* 7.9685 *
12	* .4487 *	* .5048 *	* .4293 *	* .4244 *	* .3282 *	* .3372 *	* .2827 *	
	* 4.2770 *	* 3.8001 *	* 4.4578 *	* 4.2914 *	* 4.5151 *	* 4.5225 *	* 6.2747 *	
13	* .5018 *	* .4514 *	* .4785 *	* .3913 *	* .3372 *	* .2961 *	* .2888 *	
	* 3.8258 *	* 4.2559 *	* 3.9901 *	* 4.8619 *	* 4.5227 *	* 4.9316 *	* 5.6078 *	
14	* .4049 *	* .4468 *	* .4468 *	* .3933 *	* .2828 *	* .2887 *		
	* 4.7217 *	* 4.2769 *	* 4.2636 *	* 4.8331 *	* 6.2718 *	* 5.6097 *		
15	* .3492 *	* .2913 *	* .2774 *	* .2363 *	F-SUB-Q			
	* 5.4215 *	* 6.5026 *	* 6.8353 *	* 7.9680 *	M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6513 *	* 1.0405 *	* .9340 *	* 1.1189 *	* .9594 *	* 1.1126 *	* .8390 *	* .4876 *
	* 2.6122 *	* 1.9283 *	* 2.1344 *	* 1.7759 *	* 2.0611 *	* 1.7809 *	* 2.3501 *	* 4.0029 *
9	* 1.0405 *	* .9043 *	* 1.1017 *	* .9375 *	* 1.1177 *	* .9820 *	* 1.0751 *	* .6078 *
	* 1.9283 *	* 2.2099 *	* 1.8110 *	* 2.1170 *	* 1.7714 *	* 2.0129 *	* 1.8339 *	* 3.2165 *
10	* .9340 *	* 1.1015 *	* .8616 *	* .9026 *	* .9336 *	* 1.0551 *	* 1.0404 *	* .5734 *
	* 2.1344 *	* 1.8114 *	* 2.3098 *	* 2.2013 *	* 2.1140 *	* 1.8683 *	* 1.8871 *	* 3.3996 *
11	* 1.1189 *	* .9372 *	* .9009 *	* .7794 *	* .9351 *	* .8392 *	* .9431 *	* .4863 *
	* 1.7759 *	* 2.1176 *	* 2.2052 *	* 2.4130 *	* 1.9858 *	* 2.2891 *	* 2.0821 *	* 3.9940 *
12	* .9594 *	* 1.1176 *	* .9334 *	* .9350 *	* .6991 *	* .8102 *	* .5946 *	
	* 2.0611 *	* 1.7715 *	* 2.1143 *	* 1.9859 *	* 2.1197 *	* 1.9297 *	* 3.0590 *	
13	* 1.1126 *	* .9820 *	* 1.0550 *	* .8391 *	* .8101 *	* .7329 *	* .3998 *	
	* 1.7809 *	* 2.0129 *	* 1.8684 *	* 2.2892 *	* 1.9298 *	* 2.1054 *	* 4.1548 *	
14	* .8390 *	* 1.0754 *	* 1.0405 *	* .9431 *	* .5945 *	* .3998 *		
	* 2.3501 *	* 1.8334 *	* 1.8869 *	* 2.0821 *	* 3.0594 *	* 4.1551 *		
15	* .4876 *	* .6081 *	* .5736 *	* .4863 *	F-SUB-Q			
	* 4.0029 *	* 3.2150 *	* 3.3986 *	* 3.9938 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 98 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7644 *	* 1.2149 *	* 1.1378 *	* 1.2946 *	* 1.1792 *	* 1.2960 *	* 1.0409 *	* .5830 *
	* 2.2854 *	* 1.6897 *	* 1.7925 *	* 1.5694 *	* 1.7171 *	* 1.5626 *	* 1.9345 *	* 3.4192 *
9	* 1.2149 *	* 1.1028 *	* 1.2592 *	* 1.1434 *	* 1.2950 *	* 1.2033 *	* 1.2745 *	* .7259 *
	* 1.6897 *	* 1.8587 *	* 1.6247 *	* 1.7759 *	* 1.5656 *	* 1.6794 *	* 1.5812 *	* 2.7484 *
10	* 1.1378 *	* 1.2585 *	* 1.0098 *	* 1.0957 *	* 1.1135 *	* 1.2249 *	* 1.2062 *	* .6859 *
	* 1.7925 *	* 1.6256 *	* 2.0238 *	* 1.8584 *	* 1.8171 *	* 1.6521 *	* 1.6712 *	* 2.9084 *
11	* 1.2946 *	* 1.1433 *	* 1.0935 *	* .9578 *	* 1.1054 *	* 1.0253 *	* 1.1683 *	* .5854 *
	* 1.5694 *	* 1.7760 *	* 1.8620 *	* 2.0362 *	* 1.7553 *	* 1.9126 *	* 1.7262 *	* 3.4075 *
12	* 1.1792 *	* 1.2948 *	* 1.1133 *	* 1.1052 *	* .8458 *	* .9543 *	* .7404 *	
	* 1.7171 *	* 1.5658 *	* 1.8174 *	* 1.7554 *	* 1.8073 *	* 1.7218 *	* 2.5230 *	
13	* 1.2960 *	* 1.2032 *	* 1.2247 *	* 1.0252 *	* .9543 *	* .9116 *	* .4804 *	
	* 1.5626 *	* 1.6795 *	* 1.6524 *	* 1.9127 *	* 1.7218 *	* 1.7449 *	* 3.5611 *	
14	* 1.0409 *	* 1.2748 *	* 1.2063 *	* 1.1682 *	* .7402 *	* .4804 *		
	* 1.9345 *	* 1.5809 *	* 1.6711 *	* 1.7263 *	* 2.5234 *	* 3.5610 *		
15	* .5830 *	* .7262 *	* .6860 *	* .5854 *	* F-SUB-Q			
	* 3.4192 *	* 2.7474 *	* 2.9078 *	* 3.4074 *	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8431 *	* 1.3804 *	* 1.2596 *	* 1.4690 *	* 1.3086 *	* 1.4743 *	* 1.1545 *	* .6442 *
	* 2.1491 *	* 1.5340 *	* 1.6677 *	* 1.4238 *	* 1.5911 *	* 1.4127 *	* 1.7899 *	* 3.1761 *
9	* 1.3804 *	* 1.2157 *	* 1.4320 *	* 1.2652 *	* 1.4715 *	* 1.3501 *	* 1.4584 *	* .7982 *
	* 1.5340 *	* 1.7356 *	* 1.4698 *	* 1.6526 *	* 1.4182 *	* 1.5395 *	* 1.4210 *	* 2.5716 *
10	* 1.2596 *	* 1.4311 *	* 1.0963 *	* 1.2163 *	* 1.2374 *	* 1.3947 *	* 1.3785 *	* .7439 *
	* 1.6677 *	* 1.4707 *	* 1.9177 *	* 1.7216 *	* 1.6876 *	* 1.4969 *	* 1.5086 *	* 2.7636 *
11	* 1.4690 *	* 1.2651 *	* 1.2137 *	* 1.0602 *	* 1.2623 *	* 1.1486 *	* 1.3417 *	* .6344 *
	* 1.4238 *	* 1.6527 *	* 1.7252 *	* 1.8897 *	* 1.5867 *	* 1.7505 *	* 1.5511 *	* 3.2424 *
12	* 1.3086 *	* 1.4714 *	* 1.2371 *	* 1.2620 *	* .9516 *	* 1.1050 *	* .8283 *	
	* 1.5911 *	* 1.4183 *	* 1.6880 *	* 1.5868 *	* 1.6619 *	* 1.5496 *	* 2.3426 *	
13	* 1.4743 *	* 1.3499 *	* 1.3944 *	* 1.1484 *	* 1.1049 *	* 1.0663 *	* .5403 *	
	* 1.4127 *	* 1.5397 *	* 1.4972 *	* 1.7507 *	* 1.5497 *	* 1.5610 *	* 3.3085 *	
14	* 1.1545 *	* 1.4585 *	* 1.3784 *	* 1.3416 *	* .8280 *	* .5403 *		
	* 1.7899 *	* 1.4208 *	* 1.5087 *	* 1.5513 *	* 2.3433 *	* 3.3085 *		
15	* .6442 *	* .7984 *	* .7440 *	* .6343 *	* F-SUB-Q			
	* 3.1761 *	* 2.5709 *	* 2.7632 *	* 3.2426 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 99 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8911	* 1.4743	* 1.3246	* 1.5643	* 1.3782	* 1.5735	* 1.2150	* .6717
	* 2.1438	* 1.5014	* 1.6527	* 1.3874	* 1.5651	* 1.3708	* 1.7625	* 3.1589
9	* 1.4743	* 1.2757	* 1.5294	* 1.3285	* 1.5691	* 1.4290	* 1.5632	* .8383
	* 1.5014	* 1.7271	* 1.4338	* 1.6356	* 1.3784	* 1.5064	* 1.3727	* 2.5368
10	* 1.3246	* 1.5285	* 1.1419	* 1.2753	* 1.3084	* 1.4944	* 1.4870	* .7836
	* 1.6527	* 1.4348	* 1.9195	* 1.7124	* 1.6588	* 1.4497	* 1.4492	* 2.7172
11	* 1.5643	* 1.3285	* 1.2725	* 1.1186	* 1.3638	* 1.2303	* 1.4507	* .6692
	* 1.3874	* 1.6357	* 1.7161	* 1.8547	* 1.5350	* 1.7123	* 1.4949	* 3.1971
12	* 1.3782	* 1.5689	* 1.3080	* 1.3634	* 1.0346	* 1.2093	* .8948	*
	* 1.5651	* 1.3786	* 1.6593	* 1.5351	* 1.6235	* 1.4917	* 2.2868	*
13	* 1.5735	* 1.4287	* 1.4940	* 1.2301	* 1.2092	* 1.1816	* .5840	*
	* 1.3708	* 1.5067	* 1.4500	* 1.7124	* 1.4917	* 1.5052	* 3.2596	*
14	* 1.2150	* 1.5632	* 1.4868	* 1.4505	* .8945	* .5840	*	*
	* 1.7625	* 1.3727	* 1.4493	* 1.4951	* 2.2876	* 3.2596	*	*
15	* .6717	* .8385	* .7837	* .6692	* F-SUB-Q			
	* 3.1589	* 2.5363	* 2.7171	* 3.1974	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9466	* 1.5441	* 1.3699	* 1.6237	* 1.4244	* 1.6365	* 1.2554	* .6918
	* 2.1710	* 1.5167	* 1.6753	* 1.3952	* 1.5791	* 1.3731	* 1.7728	* 3.1860
9	* 1.5441	* 1.3208	* 1.5929	* 1.3709	* 1.6311	* 1.4820	* 1.6324	* .8671
	* 1.5167	* 1.7592	* 1.4451	* 1.6565	* 1.3837	* 1.5145	* 1.3699	* 2.5558
10	* 1.3699	* 1.5919	* 1.1760	* 1.3159	* 1.3615	* 1.5634	* 1.5635	* .8157
	* 1.6753	* 1.4461	* 1.9585	* 1.7407	* 1.6762	* 1.4492	* 1.4426	* 2.7272
11	* 1.6237	* 1.3708	* 1.3130	* 1.1786	* 1.4484	* 1.3036	* 1.5333	* .7004
	* 1.3952	* 1.6565	* 1.7446	* 1.8608	* 1.5319	* 1.7165	* 1.4959	* 3.2200
12	* 1.4244	* 1.6308	* 1.3611	* 1.4481	* 1.1397	* 1.3184	* .9596	*
	* 1.5791	* 1.3838	* 1.6767	* 1.5319	* 1.6271	* 1.4852	* 2.2826	*
13	* 1.6365	* 1.4817	* 1.5630	* 1.3033	* 1.3183	* 1.3034	* .6311	*
	* 1.3731	* 1.5148	* 1.4494	* 1.7167	* 1.4853	* 1.5043	* 3.2816	*
14	* 1.2554	* 1.6323	* 1.5633	* 1.5331	* .9592	* .6311	*	*
	* 1.7728	* 1.3700	* 1.4427	* 1.4961	* 2.2834	* 3.2815	*	*
15	* .6918	* .8672	* .8157	* .7003	* F-SUB-Q			
	* 3.1860	* 2.5555	* 2.7273	* 3.2204	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 100 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0495	* 1.6286	* 1.4164	* 1.6852	* 1.4697	* 1.7009	* 1.2939	* .7113 *
	* 2.2029	* 1.5350	* 1.7203	* 1.4199	* 1.6150	* 1.3927	* 1.8106	* 3.2612 *
9	* 1.6286	* 1.3785	* 1.6630	* 1.4130	* 1.6951	* 1.5346	* 1.7043	* .8963 *
	* 1.5350	* 1.8104	* 1.4706	* 1.7005	* 1.4058	* 1.5435	* 1.3842	* 2.6083 *
10	* 1.4164	* 1.6621	* 1.2116	* 1.3602	* 1.4171	* 1.6363	* 1.6454	* .8393 *
	* 1.7203	* 1.4716	* 2.0201	* 1.7905	* 1.7147	* 1.4661	* 1.4523	* 2.8017 *
11	* 1.6852	* 1.4129	* 1.3572	* 1.2529	* 1.5458	* 1.3868	* 1.6221	* .7242 *
	* 1.4199	* 1.7006	* 1.7945	* 1.8796	* 1.5367	* 1.7320	* 1.5142	* 3.3190 *
12	* 1.4697	* 1.6949	* 1.4167	* 1.5454	* 1.3134	* 1.4952	* 1.0241	*
	* 1.6150	* 1.4059	* 1.7152	* 1.5368	* 1.6398	* 1.4839	* 2.3129	*
13	* 1.7009	* 1.5343	* 1.6360	* 1.3865	* 1.4950	* 1.4644	* .6864	*
	* 1.3927	* 1.5438	* 1.4664	* 1.7322	* 1.4840	* 1.5048	* 3.3127	*
14	* 1.2939	* 1.7041	* 1.6452	* 1.6218	* 1.0237	* .6864	*	
	* 1.8106	* 1.3844	* 1.4525	* 1.5144	* 2.3138	* 3.3127	*	
15	* .7113	* .8964	* .8393	* .7241	* F-SUB-Q			
	* 3.2612	* 2.6080	* 2.8018	* 3.3196	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1495	* 1.7070	* 1.4520	* 1.7280	* 1.5024	* 1.7457	* 1.3217	* .7199 *
	* 2.2799	* 1.5696	* 1.8020	* 1.4790	* 1.6851	* 1.4462	* 1.8864	* 3.4279 *
9	* 1.7070	* 1.4262	* 1.7156	* 1.4442	* 1.7400	* 1.5729	* 1.7583	* .9133 *
	* 1.5696	* 1.8928	* 1.5335	* 1.7802	* 1.4618	* 1.6063	* 1.4328	* 2.7280 *
10	* 1.4520	* 1.7147	* 1.2356	* 1.3936	* 1.4605	* 1.6915	* 1.7059	* .8575 *
	* 1.8020	* 1.5345	* 2.1301	* 1.8791	* 1.7896	* 1.5180	* 1.4997	* 2.9276 *
11	* 1.7280	* 1.4441	* 1.3905	* 1.3426	* 1.6246	* 1.4597	* 1.6918	* .7429 *
	* 1.4790	* 1.7803	* 1.8834	* 1.9116	* 1.5581	* 1.7576	* 1.5484	* 3.4798 *
12	* 1.5024	* 1.7397	* 1.4601	* 1.6242	* 1.4908	* 1.6493	* 1.0821	*
	* 1.6851	* 1.4620	* 1.7902	* 1.5583	* 1.6670	* 1.5029	* 2.3493	*
13	* 1.7457	* 1.5725	* 1.6911	* 1.4594	* 1.6491	* 1.6034	* .7306	*
	* 1.4462	* 1.6068	* 1.5183	* 1.7578	* 1.5030	* 1.5295	* 3.3957	*
14	* 1.3217	* 1.7581	* 1.7057	* 1.6915	* 1.0816	* .7306	*	
	* 1.8864	* 1.4330	* 1.5000	* 1.5487	* 2.3503	* 3.3956	*	
15	* .7199	* .9133	* .8575	* .7428	* F-SUB-Q			
	* 3.4279	* 2.7278	* 2.9279	* 3.4804	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 101 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2041	* 1.7722	* 1.4873	* 1.7681	* 1.5313	* 1.7873	* 1.3458	* .7333
	* 2.3849	* 1.6264	* 1.9085	* 1.5561	* 1.7778	* 1.5174	* 1.9874	* 3.6076
9	* 1.7722	* 1.4654	* 1.7640	* 1.4715	* 1.7826	* 1.6069	* 1.8078	* .9309
	* 1.6264	* 1.9701	* 1.6150	* 1.8837	* 1.5358	* 1.6906	* 1.4991	* 2.8735
10	* 1.4873	* 1.7631	* 1.2593	* 1.4246	* 1.4981	* 1.7415	* 1.7607	* .8720
	* 1.9085	* 1.6161	* 2.2632	* 1.9904	* 1.8877	* 1.5891	* 1.5662	* 3.0951
11	* 1.7681	* 1.4714	* 1.4215	* 1.4058	* 1.7064	* 1.5182	* 1.7527	* .7587
	* 1.5561	* 1.8837	* 1.9949	* 1.9785	* 1.6051	* 1.8153	* 1.5905	* 3.6540
12	* 1.5313	* 1.7822	* 1.4976	* 1.7063	* 1.5846	* 1.7564	* 1.1255	*
	* 1.7778	* 1.5360	* 1.8883	* 1.6052	* 1.7239	* 1.5419	* 2.4332	*
13	* 1.7873	* 1.6064	* 1.7411	* 1.5178	* 1.7562	* 1.7063	* .7691	*
	* 1.5174	* 1.6911	* 1.5894	* 1.8156	* 1.5421	* 1.5695	* 3.4988	*
14	* 1.3458	* 1.8075	* 1.7603	* 1.7524	* 1.1248	* .7691	*	*
	* 1.9874	* 1.4993	* 1.5665	* 1.5908	* 2.4348	* 3.4989	*	*
15	* .7333	* .9309	* .8719	* .7585	* F-SUB-Q			
	* 3.6076	* 2.8734	* 3.0955	* 3.6548	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2096	* 1.7790	* 1.4947	* 1.7664	* 1.5342	* 1.7865	* 1.3492	* .7299
	* 2.5175	* 1.7053	* 2.0346	* 1.6872	* 1.9204	* 1.6415	* 2.1409	* 3.9099
9	* 1.7790	* 1.4731	* 1.7646	* 1.4743	* 1.7851	* 1.6118	* 1.8123	* .9371
	* 1.7053	* 2.0639	* 1.7218	* 2.0394	* 1.6625	* 1.8237	* 1.6181	* 3.0824
10	* 1.4947	* 1.7637	* 1.2795	* 1.4282	* 1.5066	* 1.7480	* 1.7689	* .8873
	* 2.0346	* 1.7226	* 2.3802	* 2.1299	* 1.9986	* 1.7050	* 1.6783	* 3.2879
11	* 1.7664	* 1.4742	* 1.4251	* 1.4309	* 1.7384	* 1.5399	* 1.7679	* .7768
	* 1.6872	* 2.0394	* 2.1346	* 2.0975	* 1.7066	* 1.9252	* 1.6765	* 3.7933
12	* 1.5342	* 1.7847	* 1.5061	* 1.7383	* 1.6187	* 1.7913	* 1.1570	*
	* 1.9204	* 1.6629	* 1.9992	* 1.7067	* 1.8309	* 1.6381	* 2.5504	*
13	* 1.7865	* 1.6114	* 1.7475	* 1.5397	* 1.7911	* 1.7423	* .7852	*
	* 1.6415	* 1.8242	* 1.7054	* 1.9255	* 1.6383	* 1.6674	* 3.7095	*
14	* 1.3492	* 1.8119	* 1.7685	* 1.7675	* 1.1564	* .7852	*	*
	* 2.1409	* 1.6184	* 1.6787	* 1.6769	* 2.5518	* 3.7100	*	*
15	* .7299	* .9371	* .8872	* .7766	* F-SUB-Q			
	* 3.9099	* 3.0825	* 3.2884	* 3.7943	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 102 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2292	* 1.8253	* 1.5178	* 1.8054	* 1.5576	* 1.8282	* 1.3684	* .7407 *
	* 2.5608	* 1.7162	* 2.0628	* 1.7290	* 2.0023	* 1.7051	* 2.2790	* 4.1659 *
9	* 1.8253	* 1.4945	* 1.8080	* 1.4949	* 1.8299	* 1.6411	* 1.8611	* .9472 *
	* 1.7162	* 2.0969	* 1.7297	* 2.0901	* 1.7047	* 1.8996	* 1.6753	* 3.2996 *
10	* 1.5178	* 1.8071	* 1.2776	* 1.4516	* 1.5345	* 1.7944	* 1.8215	* .8888 *
	* 2.0628	* 1.7305	* 2.4521	* 2.1575	* 2.0382	* 1.7404	* 1.7136	* 3.5199 *
11	* 1.8054	* 1.4949	* 1.4483	* 1.4641	* 1.7962	* 1.5805	* 1.8187	* .7766 *
	* 1.7290	* 2.0901	* 2.1624	* 2.1439	* 1.7445	* 1.9801	* 1.7196	* 4.0394 *
12	* 1.5576	* 1.8294	* 1.5340	* 1.7961	* 1.6660	* 1.8587	* 1.1747	*
	* 2.0023	* 1.7052	* 2.0389	* 1.7447	* 1.8823	* 1.6808	* 2.6663	*
13	* 1.8282	* 1.6406	* 1.7939	* 1.5802	* 1.8585	* 1.8078	* .8065	*
	* 1.7051	* 1.9002	* 1.7409	* 1.9805	* 1.6810	* 1.7259	* 3.8826	*
14	* 1.3684	* 1.8608	* 1.8211	* 1.8183	* 1.1741	* .8066	*	*
	* 2.2790	* 1.6757	* 1.7140	* 1.7200	* 2.6677	* 3.8836	*	*
15	* .7407	* .9472	* .8886	* .7764	* F-SUB-Q			
	* 4.1659	* 3.2997	* 3.5206	* 4.0406	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2254	* 1.8329	* 1.5201	* 1.8121	* 1.5607	* 1.8371	* 1.3714	* .7394 *
	* 2.6349	* 1.7528	* 2.1100	* 1.7608	* 2.0413	* 1.7332	* 2.3209	* 4.3101 *
9	* 1.8329	* 1.4951	* 1.8149	* 1.4963	* 1.8407	* 1.6475	* 1.8750	* .9493 *
	* 1.7528	* 2.1486	* 1.7650	* 2.1352	* 1.7328	* 1.9334	* 1.7006	* 3.3624 *
10	* 1.5201	* 1.8140	* 1.2777	* 1.4537	* 1.5405	* 1.8075	* 1.8380	* .8915 *
	* 2.1100	* 1.7659	* 2.5117	* 2.2062	* 2.0797	* 1.7685	* 1.7388	* 3.5856 *
11	* 1.8121	* 1.4964	* 1.4505	* 1.4755	* 1.8161	* 1.5945	* 1.8354	* .7796 *
	* 1.7608	* 2.1351	* 2.2112	* 2.1858	* 1.7783	* 2.0209	* 1.7471	* 4.1200 *
12	* 1.5607	* 1.8402	* 1.5400	* 1.8159	* 1.6827	* 1.8832	* 1.1853	*
	* 2.0413	* 1.7333	* 2.0804	* 1.7784	* 1.9210	* 1.7132	* 2.7205	*
13	* 1.8371	* 1.6470	* 1.8070	* 1.5942	* 1.8829	* 1.8318	* .8126	*
	* 1.7332	* 1.9340	* 1.7690	* 2.0213	* 1.7134	* 1.7628	* 3.9821	*
14	* 1.3714	* 1.8746	* 1.8375	* 1.8350	* 1.1847	* .8126	*	*
	* 2.3209	* 1.7011	* 1.7393	* 1.7475	* 2.7219	* 3.9822	*	*
15	* .7394	* .9492	* .8913	* .7794	* F-SUB-Q			
	* 4.3101	* 3.3626	* 3.5864	* 4.1212	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 103 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2099	* 1.8095	* 1.5049	* 1.7913	* 1.5468	* 1.8181	* 1.3607	* .7319 *
	* 2.7232	* 1.8118	* 2.1728	* 1.8136	* 2.0948	* 1.7821	* 2.3750	* 4.4065 *
9	* 1.8095	* 1.4787	* 1.7916	* 1.4812	* 1.8220	* 1.6345	* 1.8598	* .9443 *
	* 1.8118	* 2.2144	* 1.8239	* 2.1968	* 1.7873	* 1.9854	* 1.7518	* 3.4356 *
10	* 1.5049	* 1.7907	* 1.2790	* 1.4379	* 1.5278	* 1.7964	* 1.8244	* .8942 *
	* 2.1728	* 1.8249	* 2.5567	* 2.2742	* 2.1412	* 1.8210	* 1.7904	* 3.6416 *
11	* 1.7913	* 1.4813	* 1.4348	* 1.4687	* 1.8055	* 1.5871	* 1.8242	* .7846 *
	* 1.8136	* 2.1967	* 2.2792	* 2.2503	* 1.8352	* 2.0823	* 1.7990	* 4.1763 *
12	* 1.5468	* 1.8215	* 1.5273	* 1.8054	* 1.6752	* 1.8736	* 1.1897	* .8942 *
	* 2.0948	* 1.7878	* 2.1420	* 1.8354	* 1.9801	* 1.7684	* 2.7788	* 4.4065 *
13	* 1.8181	* 1.6340	* 1.7959	* 1.5868	* 1.8734	* 1.8237	* .8100	* .9443 *
	* 1.7821	* 1.9860	* 1.8215	* 2.0827	* 1.7686	* 1.8200	* 4.1011	* 3.4356 *
14	* 1.3607	* 1.8593	* 1.8239	* 1.8238	* 1.1891	* .8100	* .8100	* .8100 *
	* 2.3750	* 1.7523	* 1.7909	* 1.7995	* 2.7803	* 4.1011	* 4.1011	* 4.1011 *
15	* .7319	* .9443	* .8940	* .7844	* F-SUB-Q			
	* 4.4065	* 3.4359	* 3.6425	* 4.1775	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2081	* 1.8261	* 1.5057	* 1.8062	* 1.5499	* 1.8363	* 1.3633	* .7332 *
	* 2.6164	* 1.7327	* 2.0882	* 1.7424	* 2.0295	* 1.7175	* 2.2992	* 4.2388 *
9	* 1.8261	* 1.4777	* 1.8080	* 1.4818	* 1.8427	* 1.6418	* 1.8852	* .9468 *
	* 1.7327	* 2.1292	* 1.7437	* 2.1180	* 1.7180	* 1.9229	* 1.6862	* 3.3062 *
10	* 1.5057	* 1.8071	* 1.2615	* 1.4393	* 1.5333	* 1.8195	* 1.8524	* .8865 *
	* 2.0882	* 1.7446	* 2.4831	* 2.1836	* 2.0683	* 1.7527	* 1.7225	* 3.5373 *
11	* 1.8062	* 1.4819	* 1.4361	* 1.4745	* 1.8284	* 1.5979	* 1.8478	* .7760 *
	* 1.7424	* 2.1179	* 2.1882	* 2.1799	* 1.7794	* 2.0256	* 1.7367	* 4.0670 *
12	* 1.5499	* 1.8422	* 1.5327	* 1.8283	* 1.6891	* 1.9042	* 1.1864	* .8865 *
	* 2.0295	* 1.7184	* 2.0690	* 1.7795	* 1.9325	* 1.7126	* 2.7105	* 4.2388 *
13	* 1.8363	* 1.6413	* 1.8190	* 1.5976	* 1.9039	* 1.8538	* .8161	* .8161 *
	* 1.7175	* 1.9235	* 1.7532	* 2.0259	* 1.7128	* 1.7626	* 3.9420	* 3.9420 *
14	* 1.3633	* 1.8847	* 1.8519	* 1.8473	* 1.1858	* .8161	* .8161	* .8161 *
	* 2.2992	* 1.6866	* 1.7230	* 1.7371	* 2.7119	* 3.9419	* 3.9419	* 3.9419 *
15	* .7332	* .9467	* .8863	* .7758	* F-SUB-Q			
	* 4.2388	* 3.3064	* 3.5381	* 4.0681	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 104 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1894	* 1.8159	* 1.4922	* 1.7970	* 1.5381	* 1.8296	* 1.3536	* .7238 *
	* 2.4311	* 1.5950	* 1.9307	* 1.6065	* 1.8760	* 1.5818	* 2.1259	* 3.9375 *
9	* 1.8159	* 1.4629	* 1.7979	* 1.4684	* 1.8367	* 1.6324	* 1.8838	* .9390 *
	* 1.5950	* 1.9697	* 1.6073	* 1.9601	* 1.5821	* 1.7748	* 1.5503	* 3.0638 *
10	* 1.4922	* 1.7970	* 1.2449	* 1.4258	* 1.5227	* 1.8189	* 1.8531	* .8776 *
	* 1.9307	* 1.6081	* 2.3060	* 2.0210	* 1.9112	* 1.6131	* 1.5819	* 3.2854 *
11	* 1.7970	* 1.4685	* 1.4225	* 1.4662	* 1.8261	* 1.5913	* 1.8470	* .7677 *
	* 1.6065	* 1.9600	* 2.0254	* 2.0060	* 1.6339	* 1.8638	* 1.5933	* 3.7765 *
12	* 1.5381	* 1.8362	* 1.5222	* 1.8259	* 1.6838	* 1.9056	* 1.1781	*
	* 1.8760	* 1.5826	* 1.9118	* 1.6340	* 1.7772	* 1.5713	* 2.5031	*
13	* 1.8296	* 1.6318	* 1.8184	* 1.5910	* 1.9054	* 1.8567	* .8102	*
	* 1.5818	* 1.7754	* 1.6135	* 1.8643	* 1.5715	* 1.6177	* 3.6468	*
14	* 1.3536	* 1.8833	* 1.8526	* 1.8465	* 1.1773	* .8102	*	
	* 2.1259	* 1.5507	* 1.5824	* 1.5937	* 2.5048	* 3.6467	*	
15	* .7238	* .9390	* .8774	* .7675	* F-SUB-Q			
	* 3.9375	* 3.0640	* 3.2862	* 3.7776	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1698	* 1.7897	* 1.4697	* 1.7730	* 1.5164	* 1.8070	* 1.3354	* .7136 *
	* 2.2777	* 1.4910	* 1.8064	* 1.5009	* 1.7524	* 1.4752	* 1.9861	* 3.6845 *
9	* 1.7897	* 1.4395	* 1.7724	* 1.4463	* 1.8140	* 1.6114	* 1.8643	* .9269 *
	* 1.4910	* 1.8446	* 1.5025	* 1.8359	* 1.4787	* 1.6572	* 1.4467	* 2.8645 *
10	* 1.4697	* 1.7714	* 1.2275	* 1.4049	* 1.5019	* 1.8011	* 1.8342	* .8678 *
	* 1.8064	* 1.5032	* 2.1583	* 1.8908	* 1.7879	* 1.5047	* 1.4757	* 3.0718 *
11	* 1.7730	* 1.4464	* 1.4017	* 1.4482	* 1.8071	* 1.5732	* 1.8286	* .7589 *
	* 1.5009	* 1.8358	* 1.8949	* 1.8745	* 1.5228	* 1.7386	* 1.4867	* 3.5316 *
12	* 1.5164	* 1.8135	* 1.5014	* 1.8070	* 1.6655	* 1.8877	* 1.1680	*
	* 1.7524	* 1.4792	* 1.7885	* 1.5229	* 1.6566	* 1.4621	* 2.3313	*
13	* 1.8070	* 1.6108	* 1.8005	* 1.5728	* 1.8875	* 1.8406	* .8009	*
	* 1.4752	* 1.6578	* 1.5051	* 1.7389	* 1.4623	* 1.5035	* 3.4038	*
14	* 1.3354	* 1.8637	* 1.8337	* 1.8281	* 1.1674	* .8009	*	
	* 1.9861	* 1.4471	* 1.4761	* 1.4871	* 2.3326	* 3.4038	*	
15	* .7136	* .9268	* .8675	* .7587	* F-SUB-Q			
	* 3.6845	* 2.8648	* 3.0727	* 3.5326	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 105 of 311

	H	G	F	E	D	C	B	A
8	* 1.1236	* 1.7317	* 1.4155	* 1.7178	* 1.4624	* 1.7538	* 1.2884	* .6873
	* 2.0441	* 1.3309	* 1.6210	* 1.3423	* 1.5771	* 1.3195	* 1.7906	* 3.3355
9	* 1.7317	* 1.3844	* 1.7155	* 1.3924	* 1.7599	* 1.5585	* 1.8166	* .8959
	* 1.3309	* 1.6575	* 1.3415	* 1.6502	* 1.3192	* 1.4858	* 1.2854	* 2.5762
10	* 1.4155	* 1.7146	* 1.1766	* 1.3553	* 1.4498	* 1.7547	* 1.7875	* .8343
	* 1.6210	* 1.3422	* 1.9451	* 1.6953	* 1.6036	* 1.3381	* 1.3116	* 2.7724
11	* 1.7178	* 1.3925	* 1.3523	* 1.4005	* 1.7593	* 1.5248	* 1.7827	* .7298
	* 1.3423	* 1.6500	* 1.6990	* 1.6778	* 1.3517	* 1.5538	* 1.3218	* 3.1889
12	* 1.4624	* 1.7594	* 1.4493	* 1.7591	* 1.6174	* 1.8414	* 1.1270	*
	* 1.5771	* 1.3196	* 1.6042	* 1.3518	* 1.4701	* 1.2966	* 2.0977	*
13	* 1.7538	* 1.5580	* 1.7542	* 1.5244	* 1.8412	* 1.8004	* .7755	*
	* 1.3195	* 1.4863	* 1.3385	* 1.5542	* 1.2968	* 1.3305	* 3.0537	*
14	* 1.2884	* 1.8160	* 1.7870	* 1.7822	* 1.1262	* .7755	*	*
	* 1.7906	* 1.2858	* 1.3121	* 1.3222	* 2.0992	* 3.0537	*	*
15	* .6873	* .8958	* .8340	* .7296	* F-SUB-Q			
	* 3.3355	* 2.5764	* 2.7732	* 3.1899	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 106 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0900	* 1.6825	* 1.3756	* 1.6710	* 1.4216	* 1.7067	* 1.2523	* .6676 *
	* 1.9790	* 1.2896	* 1.5726	* 1.3034	* 1.5333	* 1.2814	* 1.7425	* 3.2521 *
9	* 1.6825	* 1.3447	* 1.6676	* 1.3531	* 1.7113	* 1.5166	* 1.7696	* .8713 *
	* 1.2896	* 1.6079	* 1.3012	* 1.6038	* 1.2809	* 1.4426	* 1.2456	* 2.5058 *
10	* 1.3756	* 1.6668	* 1.1438	* 1.3201	* 1.4101	* 1.7087	* 1.7397	* .8100 *
	* 1.5726	* 1.3018	* 1.8880	* 1.6417	* 1.5547	* 1.2955	* 1.2711	* 2.7000 *
11	* 1.6710	* 1.3532	* 1.3171	* 1.3633	* 1.7142	* 1.4849	* 1.7374	* .7088 *
	* 1.3034	* 1.6036	* 1.6453	* 1.6175	* 1.2998	* 1.4968	* 1.2768	* 3.0983 *
12	* 1.4216	* 1.7108	* 1.4096	* 1.7141	* 1.5765	* 1.7940	* 1.0962	*
	* 1.5333	* 1.2813	* 1.5553	* 1.2999	* 1.4113	* 1.2477	* 2.0254	*
13	* 1.7067	* 1.5160	* 1.7081	* 1.4845	* 1.7937	* 1.7573	* .7539	*
	* 1.2814	* 1.4431	* 1.2959	* 1.4971	* 1.2479	* 1.2789	* 2.9514	*
14	* 1.2523	* 1.7690	* 1.7391	* 1.7369	* 1.0954	* .7539	*	
	* 1.7425	* 1.2460	* 1.2715	* 1.2771	* 2.0268	* 2.9514	*	
15	* .6676	* .8712	* .8097	* .7086	* F-SUB-Q			
	* 3.2521	* 2.5060	* 2.7007	* 3.0993	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0343	* 1.5839	* 1.3100	* 1.5785	* 1.3536	* 1.6117	* 1.1931	* .6332 *
	* 1.9868	* 1.3047	* 1.5745	* 1.3167	* 1.5371	* 1.2951	* 1.7470	* 3.2792 *
9	* 1.5839	* 1.2809	* 1.5716	* 1.2895	* 1.6165	* 1.4431	* 1.6698	* .8326 *
	* 1.3047	* 1.6090	* 1.3162	* 1.6062	* 1.2931	* 1.4467	* 1.2587	* 2.5057 *
10	* 1.3100	* 1.5709	* 1.1111	* 1.2608	* 1.3434	* 1.6136	* 1.6369	* .7827 *
	* 1.5745	* 1.3168	* 1.8561	* 1.6395	* 1.5556	* 1.3069	* 1.2873	* 2.6690 *
11	* 1.5785	* 1.2896	* 1.2580	* 1.3012	* 1.6219	* 1.4147	* 1.6429	* .6881 *
	* 1.3167	* 1.6059	* 1.6431	* 1.6112	* 1.3040	* 1.4925	* 1.2852	* 3.0449 *
12	* 1.3536	* 1.6160	* 1.3429	* 1.6218	* 1.5007	* 1.6915	* 1.0560	*
	* 1.5371	* 1.2934	* 1.5562	* 1.3041	* 1.4067	* 1.2551	* 1.9987	*
13	* 1.6117	* 1.4425	* 1.6131	* 1.4143	* 1.6912	* 1.6611	* .7160	*
	* 1.2950	* 1.4472	* 1.3073	* 1.4928	* 1.2553	* 1.2823	* 2.9519	*
14	* 1.1931	* 1.6693	* 1.6364	* 1.6424	* 1.0554	* .7160	*	
	* 1.7470	* 1.2591	* 1.2877	* 1.2856	* 1.9998	* 2.9518	*	
15	* .6332	* .8325	* .7824	* .6879	* F-SUB-Q			
	* 3.2792	* 2.5058	* 2.6697	* 3.0458	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 107 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9825	* 1.4996	* 1.2451	* 1.4968	* 1.2863	* 1.5285	* 1.1317	* .6014
	* 2.0146	* 1.3265	* 1.5955	* 1.3377	* 1.5584	* 1.3155	* 1.7757	* 3.3337
9	* 1.4996	* 1.2179	* 1.4893	* 1.2259	* 1.5337	* 1.3723	* 1.5834	* .7879
	* 1.3265	* 1.6297	* 1.3375	* 1.6279	* 1.3126	* 1.4655	* 1.2779	* 2.5544
10	* 1.2451	* 1.4886	* 1.0447	* 1.2063	* 1.2815	* 1.5249	* 1.5474	* .7326
	* 1.5955	* 1.3381	* 1.9008	* 1.6513	* 1.5703	* 1.3305	* 1.3105	* 2.7502
11	* 1.4968	* 1.2261	* 1.2035	* 1.2388	* 1.5400	* 1.3465	* 1.5567	* .6428
	* 1.3377	* 1.6276	* 1.6549	* 1.6273	* 1.3190	* 1.5064	* 1.3044	* 3.1413
12	* 1.2863	* 1.5333	* 1.2810	* 1.5399	* 1.4296	* 1.6031	* .9919	*
	* 1.5584	* 1.3129	* 1.5709	* 1.3191	* 1.4181	* 1.2711	* 2.0457	*
13	* 1.5285	* 1.3718	* 1.5245	* 1.3462	* 1.6029	* 1.5769	* .6793	*
	* 1.3155	* 1.4660	* 1.3309	* 1.5068	* 1.2713	* 1.2959	* 2.9915	*
14	* 1.1317	* 1.5828	* 1.5469	* 1.5563	* .9913	* .6793	*	*
	* 1.7757	* 1.2782	* 1.3109	* 1.3048	* 2.0470	* 2.9905	*	*
15	* .6014	* .7879	* .7324	* .6426	* F-SUB-Q			
	* 3.3337	* 2.5540	* 2.7507	* 3.1422	* M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8933	* 1.3361	* 1.1253	* 1.3356	* 1.1625	* 1.3642	* 1.0216	* .5425
	* 2.1536	* 1.4463	* 1.7159	* 1.4571	* 1.6759	* 1.4323	* 1.9132	* 3.6002
9	* 1.3361	* 1.1028	* 1.3267	* 1.1087	* 1.3720	* 1.2412	* 1.4120	* .7120
	* 1.4463	* 1.7495	* 1.4591	* 1.7502	* 1.4257	* 1.5747	* 1.3919	* 2.7511
10	* 1.1253	* 1.3263	* .9584	* 1.0942	* 1.1696	* 1.3631	* 1.3816	* .6649
	* 1.7159	* 1.4595	* 2.0155	* 1.7711	* 1.6726	* 1.4450	* 1.4251	* 2.9486
11	* 1.3356	* 1.1088	* 1.0919	* 1.1255	* 1.3800	* 1.2209	* 1.3889	* .5831
	* 1.4571	* 1.7500	* 1.7748	* 1.7395	* 1.4280	* 1.6127	* 1.4194	* 3.3691
12	* 1.1625	* 1.3717	* 1.1692	* 1.3799	* 1.2956	* 1.4275	* .8903	*
	* 1.6759	* 1.4260	* 1.6731	* 1.4281	* 1.5182	* 1.3844	* 2.2140	*
13	* 1.3642	* 1.2408	* 1.3627	* 1.2206	* 1.4273	* 1.4037	* .6143	*
	* 1.4323	* 1.5752	* 1.4454	* 1.6130	* 1.3845	* 1.4116	* 3.2132	*
14	* 1.0216	* 1.4115	* 1.3811	* 1.3885	* .8897	* .6142	*	*
	* 1.9132	* 1.3923	* 1.4255	* 1.4198	* 2.2154	* 3.2131	*	*
15	* .5425	* .7119	* .6647	* .5829	* F-SUB-Q			
	* 3.6002	* 2.7512	* 2.9493	* 3.3701	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 108 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7431 *	* 1.1303 *	* .8685 *	* 1.1223 *	* .8975 *	* 1.1475 *	* .8023 *	* .4402 *
	* 2.5382 *	* 1.6740 *	* 2.1776 *	* 1.6963 *	* 2.1259 *	* 1.6686 *	* 2.3887 *	* 4.3561 *
9	* 1.1303 *	* .8537 *	* 1.1191 *	* .8567 *	* 1.1567 *	* .9789 *	* 1.1578 *	* .5730 *
	* 1.6740 *	* 2.2139 *	* 1.6940 *	* 2.2190 *	* 1.6534 *	* 1.9542 *	* 1.6607 *	* 3.3524 *
10	* .8685 *	* 1.1190 *	* .8038 *	* .8842 *	* .9565 *	* 1.1638 *	* 1.1587 *	* .5452 *
	* 2.1776 *	* 1.6941 *	* 2.3560 *	* 2.1540 *	* 2.0036 *	* 1.6533 *	* 1.6613 *	* 3.5259 *
11	* 1.1223 *	* .8568 *	* .8835 *	* .8918 *	* 1.1657 *	* .9688 *	* 1.0945 *	* .4720 *
	* 1.6963 *	* 2.2188 *	* 2.1556 *	* 2.1532 *	* 1.6529 *	* 1.9880 *	* 1.7624 *	* 4.0807 *
12	* .8975 *	* 1.1564 *	* .9562 *	* 1.1655 *	* 1.0517 *	* 1.2019 *	* .7121 *	
	* 2.1259 *	* 1.6537 *	* 2.0042 *	* 1.6531 *	* 1.8300 *	* 1.6073 *	* 2.7102 *	
13	* 1.1475 *	* .9786 *	* 1.1635 *	* .9687 *	* 1.2018 *	* 1.1027 *	* .4992 *	
	* 1.6686 *	* 1.9548 *	* 1.6538 *	* 1.9884 *	* 1.6075 *	* 1.7571 *	* 3.8734 *	
14	* .8023 *	* 1.1574 *	* 1.1584 *	* 1.0942 *	* .7117 *	* .4992 *		
	* 2.3887 *	* 1.6612 *	* 1.6617 *	* 1.7628 *	* 2.7116 *	* 3.8737 *		
15	* .4402 *	* .5730 *	* .5451 *	* .4719 *	F-SUB-Q			
	* 4.3561 *	* 3.3527 *	* 3.5271 *	* 4.0819 *	M-SUB-Q			

AT 75% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5169 *	* .4582 *	* .3921 *	* .4620 *	* .4063 *	* .4715 *	* .3693 *	* .2973 *
	* 3.5941 *	* 4.0522 *	* 4.7405 *	* 4.0438 *	* 4.6204 *	* 3.9832 *	* 5.0992 *	* 6.3520 *
9	* .4582 *	* .3889 *	* .4531 *	* .3933 *	* .4763 *	* .4216 *	* .4396 *	* .2659 *
	* 4.0522 *	* 4.7800 *	* 4.1048 *	* 4.7546 *	* 3.9427 *	* 4.4542 *	* 4.2912 *	* 7.1117 *
10	* .3921 *	* .4533 *	* .3939 *	* .3848 *	* .4158 *	* .4795 *	* .4541 *	* .2585 *
	* 4.7405 *	* 4.1031 *	* 4.7260 *	* 4.8694 *	* 4.5300 *	* 3.9275 *	* 4.1583 *	* 7.3148 *
11	* .4620 *	* .3934 *	* .3846 *	* .4136 *	* .4818 *	* .4201 *	* .4181 *	* .2269 *
	* 4.0438 *	* 4.7536 *	* 4.8718 *	* 4.5590 *	* 3.9212 *	* 4.5030 *	* 4.5254 *	* 8.3537 *
12	* .4063 *	* .4762 *	* .4157 *	* .4817 *	* .4457 *	* .4603 *	* .3236 *	
	* 4.6204 *	* 3.9435 *	* 4.5313 *	* 3.9216 *	* 4.2371 *	* 4.1154 *	* 5.8606 *	
13	* .4715 *	* .4215 *	* .4794 *	* .4201 *	* .4603 *	* .4218 *	* .3383 *	
	* 3.9832 *	* 4.4551 *	* 3.9286 *	* 4.5041 *	* 4.1159 *	* 4.5013 *	* 5.6224 *	
14	* .3693 *	* .4395 *	* .4540 *	* .4179 *	* .3237 *	* .3382 *		
	* 5.0992 *	* 4.2925 *	* 4.1594 *	* 4.5265 *	* 5.8588 *	* 5.6235 *		
15	* .2973 *	* .2658 *	* .2585 *	* .2268 *	F-SUB-Q			
	* 6.3520 *	* 7.1134 *	* 7.3169 *	* 8.3562 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 109 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5195 *	* .5041 *	* .4697 *	* .5534 *	* .4958 *	* .5573 *	* .4506 *	* .3989 *
	* 3.5372 *	* 4.0814 *	* 4.3518 *	* 3.6899 *	* 4.1052 *	* 3.6550 *	* 4.5054 *	* 5.0448 *
9	* .5041 *	* .4574 *	* .5310 *	* .4772 *	* .5577 *	* .5010 *	* .5032 *	* .3329 *
	* 4.0814 *	* 4.4793 *	* 3.8509 *	* 4.2725 *	* 3.6501 *	* 4.0601 *	* 4.0312 *	* 6.0462 *
10	* .4697 *	* .5311 *	* .4648 *	* .4547 *	* .4748 *	* .5319 *	* .5015 *	* .3170 *
	* 4.3518 *	* 3.8504 *	* 4.4065 *	* 4.4751 *	* 4.2697 *	* 3.8050 *	* 4.0294 *	* 6.3529 *
11	* .5534 *	* .4773 *	* .4544 *	* .4035 *	* .4712 *	* .4321 *	* .4444 *	* .2709 *
	* 3.6899 *	* 4.2724 *	* 4.4776 *	* 4.7466 *	* 4.1015 *	* 4.6386 *	* 4.5256 *	* 7.3653 *
12	* .4958 *	* .5577 *	* .4747 *	* .4711 *	* .3594 *	* .3787 *	* .3174 *	
	* 4.1052 *	* 3.6502 *	* 4.2700 *	* 4.1017 *	* 4.2880 *	* 4.2908 *	* 5.9608 *	
13	* .5573 *	* .5010 *	* .5319 *	* .4321 *	* .3787 *	* .3348 *	* .3257 *	
	* 3.6550 *	* 4.0600 *	* 3.8050 *	* 4.6387 *	* 4.2909 *	* 4.6558 *	* 5.3097 *	
14	* .4506 *	* .5034 *	* .5016 *	* .4444 *	* .3175 *	* .3256 *		
	* 4.5054 *	* 4.0296 *	* 4.0288 *	* 4.5255 *	* 5.9589 *	* 5.3114 *		
15	* .3989 *	* .3331 *	* .3171 *	* .2709 *	F-SUB-Q			
	* 5.0448 *	* 6.0420 *	* 6.3506 *	* 7.3647 *	M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6720 *	* 1.0804 *	* .9987 *	* 1.1846 *	* 1.0555 *	* 1.1966 *	* .9354 *	* .5456 *
	* 2.6282 *	* 1.9562 *	* 2.1051 *	* 1.7718 *	* 1.9802 *	* 1.7517 *	* 2.2295 *	* 3.7881 *
9	* 1.0804 *	* .9670 *	* 1.1454 *	* 1.0144 *	* 1.1942 *	* 1.0736 *	* 1.1610 *	* .6718 *
	* 1.9562 *	* 2.1776 *	* 1.8372 *	* 2.0661 *	* 1.7520 *	* 1.9469 *	* 1.7962 *	* 3.0818 *
10	* .9987 *	* 1.1452 *	* .9006 *	* .9549 *	* 1.0033 *	* 1.1414 *	* 1.1257 *	* .6324 *
	* 2.1051 *	* 1.8374 *	* 2.3303 *	* 2.1916 *	* 2.0758 *	* 1.8231 *	* 1.8431 *	* 3.2629 *
11	* 1.1846 *	* 1.0144 *	* .9542 *	* .8402 *	* 1.0093 *	* .9208 *	* 1.0258 *	* .5381 *
	* 1.7718 *	* 2.0660 *	* 2.1932 *	* 2.3383 *	* 1.9420 *	* 2.2065 *	* 2.0173 *	* 3.8088 *
12	* 1.0555 *	* 1.1941 *	* 1.0032 *	* 1.0092 *	* .7472 *	* .8719 *	* .6482 *	
	* 1.9802 *	* 1.7521 *	* 2.0760 *	* 1.9420 *	* 2.0775 *	* 1.8997 *	* 2.9725 *	
13	* 1.1966 *	* 1.0736 *	* 1.1413 *	* .9208 *	* .8719 *	* .7917 *	* .4408 *	
	* 1.7517 *	* 1.9469 *	* 1.8232 *	* 2.2066 *	* 1.8997 *	* 2.0622 *	* 3.9982 *	
14	* .9354 *	* 1.1613 *	* 1.1259 *	* 1.0258 *	* .6482 *	* .4407 *		
	* 2.2295 *	* 1.7957 *	* 1.8429 *	* 2.0173 *	* 2.9728 *	* 3.9984 *		
15	* .5456 *	* .6721 *	* .6326 *	* .5382 *	F-SUB-Q			
	* 3.7881 *	* 3.0804 *	* 3.2620 *	* 3.8086 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 110 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7898	* 1.2708	* 1.1818	* 1.3838	* 1.2545	* 1.4011	* 1.1250	* .6462
	* 2.3103	* 1.6963	* 1.8134	* 1.5452	* 1.6973	* 1.5218	* 1.8865	* 3.2556
9	* 1.2708	* 1.1371	* 1.3423	* 1.2000	* 1.3934	* 1.2930	* 1.3842	* .7993
	* 1.6963	* 1.8927	* 1.6002	* 1.7790	* 1.5307	* 1.6448	* 1.5325	* 2.6314
10	* 1.1818	* 1.3418	* 1.0437	* 1.1325	* 1.1853	* 1.3267	* 1.3346	* .7564
	* 1.8134	* 1.6007	* 2.0555	* 1.8873	* 1.7920	* 1.6004	* 1.5863	* 2.7779
11	* 1.3838	* 1.2000	* 1.1306	* .9945	* 1.1953	* 1.1025	* 1.2625	* .6443
	* 1.5452	* 1.7789	* 1.8904	* 2.0083	* 1.7027	* 1.8602	* 1.6741	* 3.2499
12	* 1.2545	* 1.3933	* 1.1852	* 1.1952	* .9022	* 1.0400	* .7981	*
	* 1.6973	* 1.5308	* 1.7922	* 1.7027	* 1.7785	* 1.6415	* 2.4607	*
13	* 1.4011	* 1.2929	* 1.3267	* 1.1024	* 1.0400	* .9755	* .5240	*
	* 1.5218	* 1.6450	* 1.6004	* 1.8603	* 1.6416	* 1.7125	* 3.4339	*
14	* 1.1250	* 1.3845	* 1.3347	* 1.2625	* .7979	* .5240	*	*
	* 1.8865	* 1.5322	* 1.5862	* 1.6742	* 2.4611	* 3.4338	*	*
15	* .6462	* .7996	* .7565	* .6443	* F-SUB-Q			
	* 3.2556	* 2.6306	* 2.7774	* 3.2498	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8585	* 1.4258	* 1.2867	* 1.5581	* 1.3728	* 1.5841	* 1.2301	* .7053
	* 2.1833	* 1.5479	* 1.7043	* 1.4039	* 1.5866	* 1.3754	* 1.7601	* 3.0428
9	* 1.4258	* 1.2312	* 1.5079	* 1.3068	* 1.5728	* 1.4257	* 1.5678	* .8693
	* 1.5479	* 1.7869	* 1.4556	* 1.6718	* 1.3865	* 1.5249	* 1.3819	* 2.4736
10	* 1.2867	* 1.5073	* 1.1170	* 1.2332	* 1.2986	* 1.5005	* 1.5226	* .8118
	* 1.7043	* 1.4562	* 1.9634	* 1.7708	* 1.6765	* 1.4485	* 1.4235	* 2.6496
11	* 1.5581	* 1.3069	* 1.2311	* 1.0820	* 1.3526	* 1.2156	* 1.4298	* .6887
	* 1.4039	* 1.6717	* 1.7737	* 1.8782	* 1.5449	* 1.7251	* 1.5119	* 3.1100
12	* 1.3728	* 1.5727	* 1.2984	* 1.3524	* .9986	* 1.1835	* .8761	*
	* 1.5866	* 1.3867	* 1.6767	* 1.5450	* 1.6450	* 1.4765	* 2.3027	*
13	* 1.5841	* 1.4255	* 1.5004	* 1.2154	* 1.1834	* 1.1159	* .5786	*
	* 1.3754	* 1.5251	* 1.4486	* 1.7251	* 1.4765	* 1.5472	* 3.2078	*
14	* 1.2301	* 1.5679	* 1.5226	* 1.4298	* .8759	* .5786	*	*
	* 1.7601	* 1.3818	* 1.4235	* 1.5120	* 2.3033	* 3.2077	*	*
15	* .7053	* .8695	* .8120	* .6887	* F-SUB-Q			
	* 3.0428	* 2.4729	* 2.6493	* 3.1101	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 111 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8877	* 1.4933	* 1.3285	* 1.6343	* 1.4221	* 1.6678	* 1.2732	* .7246
	* 2.1954	* 1.5294	* 1.7059	* 1.3785	* 1.5748	* 1.3427	* 1.7496	* 3.0496
9	* 1.4933	* 1.2670	* 1.5772	* 1.3490	* 1.6579	* 1.4823	* 1.6566	* .8992
	* 1.5294	* 1.7960	* 1.4376	* 1.6698	* 1.3523	* 1.5076	* 1.3434	* 2.4587
10	* 1.3285	* 1.5765	* 1.1431	* 1.2688	* 1.3493	* 1.5973	* 1.6164	* .8430
	* 1.7059	* 1.4383	* 1.9832	* 1.7803	* 1.6614	* 1.3977	* 1.3761	* 2.6218
11	* 1.6343	* 1.3491	* 1.2666	* 1.1248	* 1.4322	* 1.2725	* 1.5157	* .7145
	* 1.3785	* 1.6697	* 1.7833	* 1.8593	* 1.5006	* 1.7057	* 1.4715	* 3.0904
12	* 1.4221	* 1.6577	* 1.3491	* 1.4320	* 1.0560	* 1.2626	* .9238	*
	* 1.5748	* 1.3525	* 1.6616	* 1.5007	* 1.6225	* 1.4372	* 2.2697	*
13	* 1.6678	* 1.4820	* 1.5972	* 1.2724	* 1.2625	* 1.1959	* .6082	*
	* 1.3427	* 1.5079	* 1.3978	* 1.7058	* 1.4373	* 1.5111	* 3.1925	*
14	* 1.2732	* 1.6567	* 1.6164	* 1.5156	* .9235	* .6082	*	*
	* 1.7496	* 1.3433	* 1.3762	* 1.4716	* 2.2704	* 3.1924	*	*
15	* .7246	* .8994	* .8430	* .7145	* F-SUB-Q			
	* 3.0496	* 2.4582	* 2.6217	* 3.0905	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9120	* 1.5301	* 1.3476	* 1.6674	* 1.4438	* 1.7058	* 1.2927	* .7342
	* 2.2429	* 1.5559	* 1.7460	* 1.3984	* 1.6044	* 1.3551	* 1.7767	* 3.1018
9	* 1.5301	* 1.2846	* 1.6085	* 1.3672	* 1.6978	* 1.5087	* 1.7003	* .9141
	* 1.5559	* 1.8472	* 1.4649	* 1.7072	* 1.3670	* 1.5319	* 1.3536	* 2.4995
10	* 1.3476	* 1.6077	* 1.1581	* 1.2893	* 1.3773	* 1.6510	* 1.6672	* .8624
	* 1.7460	* 1.4657	* 2.0418	* 1.8169	* 1.6945	* 1.4048	* 1.3848	* 2.6551
11	* 1.6674	* 1.3673	* 1.2886	* 1.1595	* 1.4855	* 1.3143	* 1.5681	* .7337
	* 1.3984	* 1.7070	* 1.8179	* 1.8833	* 1.5084	* 1.7293	* 1.4882	* 3.1421
12	* 1.4438	* 1.6975	* 1.3771	* 1.4853	* 1.1101	* 1.3337	* .9645	*
	* 1.6044	* 1.3672	* 1.6947	* 1.5085	* 1.6438	* 1.4499	* 2.2889	*
13	* 1.7058	* 1.5084	* 1.6508	* 1.3141	* 1.3337	* 1.2666	* .6372	*
	* 1.3551	* 1.5321	* 1.4049	* 1.7295	* 1.4500	* 1.5291	* 3.2504	*
14	* 1.2927	* 1.7002	* 1.6671	* 1.5679	* .9642	* .6373	*	*
	* 1.7767	* 1.3536	* 1.3849	* 1.4883	* 2.2896	* 3.2503	*	*
15	* .7342	* .9143	* .8624	* .7337	* F-SUB-Q			
	* 3.1018	* 2.4991	* 2.6550	* 3.1423	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 112 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9588	* 1.5832	* 1.3687	* 1.7035	* 1.4637	* 1.7468	* 1.3095	* .7425 *
	* 2.2942	* 1.5672	* 1.8093	* 1.4343	* 1.6568	* 1.3832	* 1.8320	* 3.2034 *
9	* 1.5832	* 1.3090	* 1.6480	* 1.3851	* 1.7401	* 1.5338	* 1.7463	* .9286 *
	* 1.5672	* 1.9182	* 1.5054	* 1.7685	* 1.3977	* 1.5779	* 1.3802	* 2.5757 *
10	* 1.3687	* 1.6472	* 1.1697	* 1.3059	* 1.4078	* 1.7063	* 1.7205	* .8723 *
	* 1.8093	* 1.5063	* 2.1243	* 1.8911	* 1.7507	* 1.4303	* 1.4106	* 2.7528 *
11	* 1.7035	* 1.3852	* 1.3051	* 1.2062	* 1.5514	* 1.3677	* 1.6247	* .7454 *
	* 1.4343	* 1.7683	* 1.8922	* 1.9203	* 1.5231	* 1.7637	* 1.5244	* 3.2694 *
12	* 1.4637	* 1.7398	* 1.4075	* 1.5511	* 1.2151	* 1.4530	* 1.0063	*
	* 1.6568	* 1.3979	* 1.7510	* 1.5232	* 1.6734	* 1.4649	* 2.3424	*
13	* 1.7468	* 1.5335	* 1.7061	* 1.3675	* 1.4529	* 1.3765	* .6772	*
	* 1.3832	* 1.5782	* 1.4305	* 1.7638	* 1.4650	* 1.5479	* 3.3110	*
14	* 1.3095	* 1.7462	* 1.7204	* 1.6246	* 1.0059	* .6772	*	
	* 1.8320	* 1.3802	* 1.4107	* 1.5245	* 2.3432	* 3.3108	*	
15	* .7425	* .9287	* .8723	* .7454	* F-SUB-Q			
	* 3.2034	* 2.5754	* 2.7528	* 3.2697	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0380	* 1.6380	* 1.3828	* 1.7226	* 1.4734	* 1.7681	* 1.3172	* .7409 *
	* 2.3836	* 1.6121	* 1.9082	* 1.5036	* 1.7422	* 1.4444	* 1.9237	* 3.3896 *
9	* 1.6380	* 1.3368	* 1.6735	* 1.3950	* 1.7637	* 1.5470	* 1.7729	* .9320 *
	* 1.6121	* 2.0046	* 1.5814	* 1.8644	* 1.4615	* 1.6562	* 1.4397	* 2.7150 *
10	* 1.3828	* 1.6727	* 1.1770	* 1.3198	* 1.4298	* 1.7438	* 1.7549	* .8778 *
	* 1.9082	* 1.5823	* 2.2534	* 1.9961	* 1.8416	* 1.4905	* 1.4704	* 2.8996 *
11	* 1.7226	* 1.3951	* 1.3190	* 1.2755	* 1.6190	* 1.4181	* 1.6684	* .7536 *
	* 1.5036	* 1.8641	* 1.9972	* 1.9653	* 1.5517	* 1.8044	* 1.5741	* 3.4549 *
12	* 1.4734	* 1.7635	* 1.4295	* 1.6187	* 1.3618	* 1.5987	* 1.0506	*
	* 1.7422	* 1.4617	* 1.8419	* 1.5518	* 1.7137	* 1.4966	* 2.3967	*
13	* 1.7681	* 1.5467	* 1.7436	* 1.4179	* 1.5986	* 1.4994	* .7139	*
	* 1.4444	* 1.6566	* 1.4906	* 1.8045	* 1.4967	* 1.5867	* 3.4166	*
14	* 1.3172	* 1.7728	* 1.7548	* 1.6683	* 1.0503	* .7140	*	
	* 1.9237	* 1.4398	* 1.4705	* 1.5742	* 2.3975	* 3.4164	*	
15	* .7409	* .9321	* .8778	* .7536	* F-SUB-Q			
	* 3.3896	* 2.7147	* 2.8997	* 3.4552	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 113 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1231	* 1.6938	* 1.3965	* 1.7439	* 1.4820	* 1.7895	* 1.3237	* .7451 *
	* 2.4981	* 1.6772	* 2.0307	* 1.5890	* 1.8491	* 1.5215	* 2.0393	* 3.5891 *
9	* 1.6938	* 1.3628	* 1.7013	* 1.4043	* 1.7877	* 1.5593	* 1.7987	* .9378 *
	* 1.6772	* 2.0956	* 1.6742	* 1.9829	* 1.5412	* 1.7547	* 1.5154	* 2.8782 *
10	* 1.3965	* 1.7007	* 1.1874	* 1.3352	* 1.4504	* 1.7793	* 1.7874	* .8807 *
	* 2.0307	* 1.6752	* 2.4045	* 2.1253	* 1.9435	* 1.5674	* 1.5470	* 3.0880 *
11	* 1.7439	* 1.4044	* 1.3341	* 1.3395	* 1.6893	* 1.4655	* 1.7086	* .7592 *
	* 1.5890	* 1.9827	* 2.1271	* 2.0438	* 1.6025	* 1.8747	* 1.6277	* 3.6592 *
12	* 1.4820	* 1.7875	* 1.4502	* 1.6890	* 1.5027	* 1.7197	* 1.0869	* .7498 *
	* 1.8491	* 1.5414	* 1.9438	* 1.6026	* 1.7806	* 1.5454	* 2.4954	* .7498 *
13	* 1.7895	* 1.5590	* 1.7791	* 1.4653	* 1.7196	* 1.6047	* 1.6387	* 3.5393 *
	* 1.5215	* 1.7550	* 1.5676	* 1.8748	* 1.5455	* 1.6387	* 3.5393 *	
14	* 1.3237	* 1.7985	* 1.7873	* 1.7084	* 1.0865	* .7498		
	* 2.0393	* 1.5155	* 1.5472	* 1.6278	* 2.4963	* 3.5391		
15	* .7451	* .9379	* .8806	* .7591	* F-SUB-Q			
	* 3.5891	* 2.8780	* 3.0881	* 3.6595	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1343	* 1.6959	* 1.3905	* 1.7265	* 1.4711	* 1.7714	* 1.3142	* .7353 *
	* 2.6736	* 1.7841	* 2.1810	* 1.7277	* 2.0027	* 1.6506	* 2.2040	* 3.8994 *
9	* 1.6959	* 1.3651	* 1.6896	* 1.3953	* 1.7718	* 1.5492	* 1.7844	* .9359 *
	* 1.7841	* 2.2222	* 1.7903	* 2.1505	* 1.6730	* 1.8989	* 1.6421	* 3.0964 *
10	* 1.3905	* 1.6890	* 1.2037	* 1.3420	* 1.4481	* 1.7724	* 1.7789	* .8890 *
	* 2.1810	* 1.7909	* 2.5214	* 2.2425	* 2.0613	* 1.6703	* 1.6599	* 3.2885 *
11	* 1.7265	* 1.3954	* 1.3412	* 1.3630	* 1.7119	* 1.4790	* 1.7125	* .7734 *
	* 1.7277	* 2.1503	* 2.2437	* 2.1715	* 1.7088	* 1.9940	* 1.7191	* 3.7984 *
12	* 1.4711	* 1.7716	* 1.4478	* 1.7117	* 1.5393	* 1.7553	* 1.1134	* .7639 *
	* 2.0027	* 1.6732	* 2.0616	* 1.7089	* 1.8960	* 1.6480	* 2.6233	* .7639 *
13	* 1.7714	* 1.5489	* 1.7722	* 1.4789	* 1.7552	* 1.6460	* .7639	
	* 1.6506	* 1.8993	* 1.6705	* 1.9942	* 1.6481	* 1.7463	* 3.7681	
14	* 1.3142	* 1.7843	* 1.7788	* 1.7124	* 1.1130	* .7639		
	* 2.2040	* 1.6422	* 1.6601	* 1.7193	* 2.6243	* 3.7679		
15	* .7353	* .9360	* .8890	* .7733	* F-SUB-Q			
	* 3.8994	* 3.0962	* 3.2886	* 3.7988	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 114 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1502	* 1.7320	* 1.4011	* 1.7548	* 1.4804	* 1.8009	* 1.3210	* .7398 *
	* 2.7232	* 1.7976	* 2.2177	* 1.7671	* 2.0925	* 1.7185	* 2.3441	* 4.1677 *
9	* 1.7320	* 1.3781	* 1.7199	* 1.4039	* 1.8025	* 1.5630	* 1.8171	* .9376 *
	* 1.7976	* 2.2595	* 1.8068	* 2.2108	* 1.7191	* 1.9817	* 1.7048	* 3.3101 *
10	* 1.4011	* 1.7193	* 1.1913	* 1.3428	* 1.4642	* 1.8112	* 1.8157	* .8830 *
	* 2.2177	* 1.8074	* 2.6130	* 2.3177	* 2.1235	* 1.7119	* 1.7073	* 3.5174 *
11	* 1.7548	* 1.4042	* 1.3417	* 1.3885	* 1.7659	* 1.5056	* 1.7461	* .7664 *
	* 1.7671	* 2.2105	* 2.3197	* 2.2453	* 1.7616	* 2.0644	* 1.7770	* 4.0634 *
12	* 1.4804	* 1.8023	* 1.4640	* 1.7657	* 1.5785	* 1.8132	* 1.1243	*
	* 2.0925	* 1.7193	* 2.1239	* 1.7617	* 1.9779	* 1.7134	* 2.7652	*
13	* 1.8009	* 1.5627	* 1.8110	* 1.5054	* 1.8131	* 1.6985	* .7830	*
	* 1.7185	* 1.9821	* 1.7121	* 2.0647	* 1.7135	* 1.8228	* 3.9507	*
14	* 1.3211	* 1.8170	* 1.8155	* 1.7460	* 1.1239	* .7830	*	
	* 2.3441	* 1.7050	* 1.7075	* 1.7772	* 2.7664	* 3.9505	*	
15	* .7398	* .9377	* .8830	* .7663	* F-SUB-Q			
	* 4.1677	* 3.3099	* 3.5177	* 4.0643	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1445	* 1.7338	* 1.3982	* 1.7534	* 1.4751	* 1.8008	* 1.3162	* .7346 *
	* 2.7893	* 1.8292	* 2.2619	* 1.7959	* 2.1300	* 1.7433	* 2.3844	* 4.2759 *
9	* 1.7337	* 1.3744	* 1.7195	* 1.3987	* 1.8029	* 1.5597	* 1.8195	* .9346 *
	* 1.8292	* 2.3076	* 1.8395	* 2.2537	* 1.7453	* 2.0149	* 1.7293	* 3.3681 *
10	* 1.3982	* 1.7189	* 1.1879	* 1.3395	* 1.4629	* 1.8176	* 1.8210	* .8812 *
	* 2.2619	* 1.8402	* 2.6669	* 2.3642	* 2.1615	* 1.7355	* 1.7311	* 3.5783 *
11	* 1.7534	* 1.3989	* 1.3384	* 1.3943	* 1.7797	* 1.5099	* 1.7528	* .7662 *
	* 1.7959	* 2.2534	* 2.3662	* 2.2894	* 1.7952	* 2.1057	* 1.8068	* 4.1345 *
12	* 1.4751	* 1.8027	* 1.4627	* 1.7796	* 1.5883	* 1.8291	* 1.1301	*
	* 2.1300	* 1.7455	* 2.1618	* 1.7953	* 2.0201	* 1.7492	* 2.8228	*
13	* 1.8008	* 1.5594	* 1.8173	* 1.5097	* 1.8290	* 1.7146	* .7865	*
	* 1.7433	* 2.0154	* 1.7357	* 2.1060	* 1.7493	* 1.8709	* 4.0742	*
14	* 1.3162	* 1.8192	* 1.8208	* 1.7527	* 1.1297	* .7866	*	
	* 2.3844	* 1.7295	* 1.7313	* 1.8070	* 2.8240	* 4.0740	*	
15	* .7346	* .9346	* .8811	* .7661	* F-SUB-Q			
	* 4.2759	* 3.3680	* 3.5787	* 4.1352	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 115 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1305	* 1.7103	* 1.3829	* 1.7288	* 1.4583	* 1.7770	* 1.3022	* .7255 *
	* 2.8726	* 1.8867	* 2.3263	* 1.8511	* 2.1850	* 1.7917	* 2.4404	* 4.3720 *
9	* 1.7103	* 1.3586	* 1.6951	* 1.3821	* 1.7792	* 1.5428	* 1.7981	* .9276 *
	* 1.8867	* 2.3737	* 1.8967	* 2.3180	* 1.7970	* 2.0675	* 1.7769	* 3.4413 *
10	* 1.3829	* 1.6945	* 1.1916	* 1.3353	* 1.4477	* 1.7984	* 1.8020	* .8819 *
	* 2.3263	* 1.8974	* 2.7028	* 2.4080	* 2.2205	* 1.7831	* 1.7781	* 3.6299 *
11	* 1.7288	* 1.3823	* 1.3346	* 1.3855	* 1.7643	* 1.4979	* 1.7389	* .7701 *
	* 1.8511	* 2.3176	* 2.4092	* 2.3498	* 1.8494	* 2.1637	* 1.8542	* 4.1803 *
12	* 1.4583	* 1.7790	* 1.4474	* 1.7642	* 1.5778	* 1.8148	* 1.1323	*
	* 2.1850	* 1.7972	* 2.2208	* 1.8495	* 2.0772	* 1.8026	* 2.8752	*
13	* 1.7770	* 1.5425	* 1.7982	* 1.4977	* 1.8147	* 1.7048	* .7817	*
	* 1.7917	* 2.0679	* 1.7833	* 2.1640	* 1.8027	* 1.9252	* 4.1909	*
14	* 1.3022	* 1.7978	* 1.8018	* 1.7388	* 1.1318	* .7817	*	
	* 2.4404	* 1.7772	* 1.7783	* 1.8544	* 2.8764	* 4.1907	*	
15	* .7255	* .9277	* .8819	* .7701	* F-SUB-Q			
	* 4.3720	* 3.4412	* 3.6303	* 4.1810	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1293	* 1.7265	* 1.3832	* 1.7448	* 1.4588	* 1.7958	* 1.3023	* .7255 *
	* 2.7984	* 1.8318	* 2.2671	* 1.7998	* 2.1464	* 1.7498	* 2.3944	* 4.2706 *
9	* 1.7265	* 1.3575	* 1.7106	* 1.3813	* 1.7976	* 1.5466	* 1.8199	* .9280 *
	* 1.8318	* 2.3153	* 1.8393	* 2.2647	* 1.7537	* 2.0318	* 1.7370	* 3.3715 *
10	* 1.3832	* 1.7100	* 1.1721	* 1.3232	* 1.4506	* 1.8228	* 1.8255	* .8727 *
	* 2.2671	* 1.8399	* 2.6725	* 2.3768	* 2.1860	* 1.7467	* 1.7421	* 3.5952 *
11	* 1.7448	* 1.3816	* 1.3221	* 1.3890	* 1.7879	* 1.5038	* 1.7554	* .7595 *
	* 1.7998	* 2.2642	* 2.3797	* 2.3127	* 1.8174	* 2.1422	* 1.8294	* 4.1685 *
12	* 1.4588	* 1.7974	* 1.4504	* 1.7878	* 1.5875	* 1.8399	* 1.1268	*
	* 2.1464	* 1.7539	* 2.1864	* 1.8175	* 2.0531	* 1.7727	* 2.8514	*
13	* 1.7958	* 1.5463	* 1.8225	* 1.5036	* 1.8398	* 1.7251	* .7873	*
	* 1.7498	* 2.0322	* 1.7469	* 2.1424	* 1.7728	* 1.8909	* 4.0697	*
14	* 1.3023	* 1.8196	* 1.8253	* 1.7553	* 1.1263	* .7873	*	
	* 2.3944	* 1.7372	* 1.7423	* 1.8296	* 2.8526	* 4.0695	*	
15	* .7255	* .9281	* .8727	* .7594	* F-SUB-Q			
	* 4.2705	* 3.3713	* 3.5956	* 4.1691	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 116 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1164	* 1.7232	* 1.3750	* 1.7412	* 1.4505	* 1.7943	* 1.2952	* .7178
	* 2.5822	* 1.6787	* 2.0902	* 1.6626	* 1.9904	* 1.6195	* 2.2222	* 3.9694
9	* 1.7232	* 1.3482	* 1.7067	* 1.3722	* 1.7956	* 1.5400	* 1.8211	* .9221
	* 1.6787	* 2.1317	* 1.6914	* 2.0975	* 1.6215	* 1.8841	* 1.6076	* 3.1261
10	* 1.3750	* 1.7061	* 1.1595	* 1.3139	* 1.4438	* 1.8256	* 1.8285	* .8651
	* 2.0902	* 1.6920	* 2.4732	* 2.1918	* 2.0175	* 1.6100	* 1.6073	* 3.3383
11	* 1.7412	* 1.3725	* 1.3129	* 1.3837	* 1.7896	* 1.4987	* 1.7562	* .7515
	* 1.6626	* 2.0970	* 2.1954	* 2.1228	* 1.6606	* 1.9654	* 1.6768	* 3.8571
12	* 1.4505	* 1.7953	* 1.4435	* 1.7895	* 1.5842	* 1.8422	* 1.1211	*
	* 1.9904	* 1.6217	* 2.0178	* 1.6607	* 1.8813	* 1.6195	* 2.6230	*
13	* 1.7943	* 1.5397	* 1.8254	* 1.4985	* 1.8421	* 1.7273	* .7823	*
	* 1.6195	* 1.8844	* 1.6102	* 1.9656	* 1.6196	* 1.7276	* 3.7507	*
14	* 1.2952	* 1.8208	* 1.8283	* 1.7560	* 1.1206	* .7824	*	*
	* 2.2222	* 1.6078	* 1.6074	* 1.6769	* 2.6241	* 3.7505	*	*
15	* .7178	* .9222	* .8651	* .7514	* F-SUB-Q			
	* 3.9694	* 3.1259	* 3.3386	* 3.8576	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1055	* 1.7105	* 1.3632	* 1.7281	* 1.4378	* 1.7822	* 1.2844	* .7115
	* 2.4029	* 1.5581	* 1.9438	* 1.5416	* 1.8456	* 1.4993	* 2.0626	* 3.6889
9	* 1.7105	* 1.3358	* 1.6939	* 1.3596	* 1.7831	* 1.5279	* 1.8109	* .9151
	* 1.5581	* 1.9834	* 1.5709	* 1.9491	* 1.5028	* 1.7457	* 1.4898	* 2.8993
10	* 1.3632	* 1.6933	* 1.1518	* 1.3022	* 1.4318	* 1.8157	* 1.8190	* .8607
	* 1.9438	* 1.5715	* 2.2964	* 2.0386	* 1.8766	* 1.4935	* 1.4908	* 3.0950
11	* 1.7281	* 1.3600	* 1.3016	* 1.3736	* 1.7792	* 1.4878	* 1.7470	* .7484
	* 1.5416	* 1.9486	* 2.0406	* 1.9693	* 1.5379	* 1.8235	* 1.5539	* 3.5759
12	* 1.4378	* 1.7829	* 1.4315	* 1.7791	* 1.5739	* 1.8327	* 1.1158	*
	* 1.8456	* 1.5030	* 1.8769	* 1.5380	* 1.7432	* 1.4988	* 2.4295	*
13	* 1.7822	* 1.5276	* 1.8154	* 1.4877	* 1.8326	* 1.7192	* .7773	*
	* 1.4993	* 1.7460	* 1.4937	* 1.8237	* 1.4989	* 1.5985	* 3.4814	*
14	* 1.2844	* 1.8106	* 1.8188	* 1.7469	* 1.1153	* .7773	*	*
	* 2.0626	* 1.4900	* 1.4909	* 1.5540	* 2.4306	* 3.4813	*	*
15	* .7115	* .9151	* .8606	* .7483	* F-SUB-Q			
	* 3.6889	* 2.8991	* 3.0953	* 3.5763	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 117 of 311

F-SUB-O & M-SUB-O VALUES (F-SUB-O OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.0901	* 1.6829	* 1.3451	* 1.6994	* 1.4185	* 1.7535	* 1.2679	* .7008
	* 2.2629	* 1.4695	* 1.8263	* 1.4508	* 1.7339	* 1.4121	* 1.9387	* 3.4784
9	* 1.6829	* 1.3174	* 1.6662	* 1.3409	* 1.7542	* 1.5077	* 1.7840	* .9075
	* 1.4695	* 1.8658	* 1.4794	* 1.8289	* 1.4137	* 1.6387	* 1.3991	* 2.7105
10	* 1.3451	* 1.6656	* 1.1541	* 1.2954	* 1.4122	* 1.7881	* 1.7929	* .8590
	* 1.8263	* 1.4799	* 2.1243	* 1.9034	* 1.7654	* 1.4057	* 1.4011	* 2.8721
11	* 1.6994	* 1.3411	* 1.2948	* 1.3569	* 1.7517	* 1.4689	* 1.7258	* .7499
	* 1.4508	* 1.8285	* 1.9043	* 1.8501	* 1.4485	* 1.7160	* 1.4620	* 3.3185
12	* 1.4185	* 1.7540	* 1.4119	* 1.7515	* 1.5541	* 1.8064	* 1.1107	*
	* 1.7339	* 1.4138	* 1.7656	* 1.4486	* 1.6360	* 1.4097	* 2.2670	*
13	* 1.7535	* 1.5074	* 1.7878	* 1.4688	* 1.8063	* 1.6978	* .7672	*
	* 1.4121	* 1.6391	* 1.4059	* 1.7162	* 1.4097	* 1.5006	* 3.2769	*
14	* 1.2679	* 1.7837	* 1.7927	* 1.7256	* 1.1102	* .7673	*	
	* 1.9387	* 1.3993	* 1.4013	* 1.4622	* 2.2680	* 3.2767	*	
15	* .7008	* .9076	* .8589	* .7498	* F-SUB-Q			
	* 3.4784	* 2.7103	* 2.8724	* 3.3189	* M-SUB-Q			

	H	G	F	E	D	C	B	A
8	1.0868	1.6953	1.3421	1.7102	1.4147	1.7660	1.2638	.6987
	2.1095	1.3579	1.7052	1.3470	1.6262	1.3114	1.8209	3.2700
9	1.6953	1.3135	1.6781	1.3366	1.7663	1.5067	1.7992	.9018
	1.3579	1.7426	1.3691	1.7145	1.3117	1.5332	1.2959	2.5528
10	1.3421	1.6775	1.1289	1.2801	1.4099	1.8032	1.8085	.8437
	1.7052	1.3696	2.0250	1.7906	1.6479	1.2995	1.2952	2.7349
11	1.7102	1.3369	1.2791	1.3537	1.7650	1.4685	1.7348	.7324
	1.3470	1.7140	1.7923	1.7331	1.3438	1.6031	1.3557	3.1683
12	1.4147	1.7660	1.4097	1.7648	1.5562	1.8214	1.0975	
	1.6262	1.3119	1.6481	1.3439	1.5231	1.3064	2.1489	
13	1.7660	1.5063	1.8029	1.4684	1.8213	1.7087	.7656	
	1.3114	1.5335	1.2996	1.6033	1.3065	1.3932	3.0774	
14	1.2638	1.7989	1.8083	1.7347	1.0970	.7656		
	1.8209	1.2961	1.2953	1.3558	2.1499	3.0773		
15	.6987	.9019	.8436	.7323	F-SUB-Q			
	3.2700	2.5526	2.7352	3.1687	M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 118 of 311

F-SUB-O & M-SUB-O VALUES (F-SUB-O OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.0716	* 1.6752	* 1.3247	* 1.6880	* 1.3956	* 1.7434	* 1.2463	* .6882
	* 2.0094	* 1.2937	* 1.6294	* 1.2888	* 1.5581	* 1.2549	* 1.7463	* 3.1432
9	* 1.6752	* 1.2961	* 1.6584	* 1.3184	* 1.7437	* 1.4874	* 1.7785	* .8898
	* 1.2937	* 1.6646	* 1.3065	* 1.6420	* 1.2545	* 1.4673	* 1.2373	* 2.4468
10	* 1.3247	* 1.6578	* 1.1141	* 1.2637	* 1.3912	* 1.7803	* 1.7875	* .8313
	* 1.6294	* 1.3069	* 1.9366	* 1.7101	* 1.5748	* 1.2406	* 1.2354	* 2.6235
11	* 1.6880	* 1.3188	* 1.2627	* 1.3362	* 1.7428	* 1.4503	* 1.7154	* .7215
	* 1.2888	* 1.6415	* 1.7129	* 1.6475	* 1.2772	* 1.5257	* 1.2903	* 3.0342
12	* 1.3956	* 1.7434	* 1.3910	* 1.7427	* 1.5381	* 1.8014	* 1.0827	*
	* 1.5581	* 1.2546	* 1.5750	* 1.2773	* 1.4443	* 1.2414	* 2.0458	*
13	* 1.7434	* 1.4871	* 1.7800	* 1.4501	* 1.8013	* 1.6909	* .7545	*
	* 1.2549	* 1.4676	* 1.2408	* 1.5259	* 1.2415	* 1.3257	* 2.9404	*
14	* 1.2463	* 1.7782	* 1.7873	* 1.7152	* 1.0822	* .7545	*	*
	* 1.7463	* 1.2375	* 1.2355	* 1.2904	* 2.0468	* 2.9403	*	*
15	* .6882	* .8899	* .8312	* .7214	* F-SUB-Q			
	* 3.1432	* 2.4466	* 2.6238	* 3.0345	* M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* 1.0369	* 1.6094	* 1.2855	* 1.6193	* 1.3528	* 1.6718	* 1.2083	* .6643
	* 1.9791	* 1.2830	* 1.6020	* 1.2820	* 1.5350	* 1.2490	* 1.7210	* 3.1147
9	* 1.6094	* 1.2582	* 1.5942	* 1.2790	* 1.6727	* 1.4410	* 1.7076	* .8657
	* 1.2830	* 1.6356	* 1.2961	* 1.6162	* 1.2476	* 1.4456	* 1.2288	* 2.4029
10	* 1.2855	* 1.5937	* 1.1045	* 1.2402	* 1.3483	* 1.7046	* 1.7149	* .8177
	* 1.6020	* 1.2965	* 1.8644	* 1.6706	* 1.5492	* 1.2346	* 1.2271	* 2.5476
11	* 1.6193	* 1.2794	* 1.2396	* 1.2971	* 1.6714	* 1.4061	* 1.6541	* .7134
	* 1.2820	* 1.6158	* 1.6714	* 1.6137	* 1.2644	* 1.4979	* 1.2738	* 2.9283
12	* 1.3528	* 1.6725	* 1.3481	* 1.6712	* 1.4901	* 1.7314	* 1.0609	*
	* 1.5350	* 1.2477	* 1.5494	* 1.2645	* 1.4145	* 1.2247	* 1.9851	*
13	* 1.6719	* 1.4407	* 1.7043	* 1.4059	* 1.7312	* 1.6301	* .7296	*
	* 1.2490	* 1.4460	* 1.2348	* 1.4981	* 1.2248	* 1.3031	* 2.8881	*
14	* 1.2083	* 1.7074	* 1.7147	* 1.6540	* 1.0604	* .7296	*	
	* 1.7210	* 1.2290	* 1.2272	* 1.2740	* 1.9860	* 2.8879	*	
15	* .6643	* .8658	* .8176	* .7133	* F-SUB-Q			
	* 3.1147	* 2.4027	* 2.5478	* 2.9281	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 119 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0004	* 1.5535	* 1.2421	* 1.5588	* 1.3057	* 1.6091	* 1.1641	* .6395
	* 1.9768	* 1.2798	* 1.5978	* 1.2833	* 1.5331	* 1.2502	* 1.7226	* 3.1242
9	* 1.5535	* 1.2162	* 1.5401	* 1.2354	* 1.6109	* 1.3927	* 1.6465	* .8316
	* 1.2798	* 1.6305	* 1.2923	* 1.6132	* 1.2477	* 1.4414	* 1.2269	* 2.4133
10	* 1.2421	* 1.5397	* 1.0523	* 1.1938	* 1.3050	* 1.6371	* 1.6504	* .7775
	* 1.5978	* 1.2927	* 1.8866	* 1.6653	* 1.5414	* 1.2370	* 1.2269	* 2.5841
11	* 1.5588	* 1.2357	* 1.1921	* 1.2535	* 1.6095	* 1.3603	* 1.5922	* .6762
	* 1.2833	* 1.6128	* 1.6682	* 1.6059	* 1.2613	* 1.4884	* 1.2730	* 2.9772
12	* 1.3057	* 1.6107	* 1.3048	* 1.6093	* 1.4418	* 1.6717	* 1.0125	*
	* 1.5331	* 1.2479	* 1.5416	* 1.2614	* 1.4039	* 1.2173	* 2.0000	*
13	* 1.6091	* 1.3923	* 1.6369	* 1.3602	* 1.6716	* 1.5729	* .7024	*
	* 1.2502	* 1.4418	* 1.2372	* 1.4886	* 1.2174	* 1.2964	* 2.8838	*
14	* 1.1641	* 1.6462	* 1.6502	* 1.5920	* 1.0120	* .7024	*	*
	* 1.7226	* 1.2271	* 1.2271	* 1.2731	* 2.0010	* 2.8837	*	*
15	* .6395	* .8316	* .7774	* .6761	* F-SUB-Q			
	* 3.1242	* 2.4131	* 2.5844	* 2.9775	* M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9188	* 1.4026	* 1.1377	* 1.4036	* 1.1940	* 1.4467	* 1.0640	* .5840
	* 2.0927	* 1.3774	* 1.6962	* 1.3854	* 1.6300	* 1.3513	* 1.8332	* 3.3325
9	* 1.4026	* 1.1154	* 1.3911	* 1.1312	* 1.4525	* 1.2768	* 1.4823	* .7594
	* 1.3774	* 1.7288	* 1.3906	* 1.7134	* 1.3452	* 1.5283	* 1.3236	* 2.5719
10	* 1.1377	* 1.3908	* .9742	* 1.1027	* 1.2038	* 1.4680	* 1.4838	* .7118
	* 1.6962	* 1.3909	* 1.9806	* 1.7553	* 1.6243	* 1.3396	* 1.3250	* 2.7467
11	* 1.4036	* 1.1315	* 1.1019	* 1.1528	* 1.4490	* 1.2504	* 1.4372	* .6199
	* 1.3854	* 1.7130	* 1.7583	* 1.6957	* 1.3591	* 1.5716	* 1.3693	* 3.1595
12	* 1.1940	* 1.4523	* 1.2036	* 1.4489	* 1.3225	* 1.5091	* .9215	*
	* 1.6300	* 1.3454	* 1.6246	* 1.3592	* 1.4848	* 1.3075	* 2.1342	*
13	* 1.4467	* 1.2765	* 1.4677	* 1.2503	* 1.5090	* 1.4213	* .6430	*
	* 1.3513	* 1.5287	* 1.3398	* 1.5717	* 1.3076	* 1.3909	* 3.0601	*
14	* 1.0640	* 1.4820	* 1.4836	* 1.4371	* .9211	* .6430	*	*
	* 1.8332	* 1.3239	* 1.3252	* 1.3694	* 2.1352	* 3.0601	*	*
15	* .5840	* .7594	* .7117	* .6198	* F-SUB-Q			
	* 3.3325	* 2.5718	* 2.7471	* 3.1600	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 120 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 250 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7687 *	* 1.1504 *	* .8912 *	* 1.1604 *	* .9339 *	* 1.1954 *	* .8393 *	* .4783 *
	* 2.4510 *	* 1.6432 *	* 2.1193 *	* 1.6383 *	* 2.0394 *	* 1.5988 *	* 2.2779 *	* 3.9920 *
9	* 1.1504 *	* .8762 *	* 1.1397 *	* .8874 *	* 1.2001 *	* 1.0190 *	* 1.2064 *	* .6144 *
	* 1.6432 *	* 2.1542 *	* 1.6613 *	* 2.1391 *	* 1.5909 *	* 1.8732 *	* 1.5901 *	* 3.1153 *
10	* .8912 *	* 1.1397 *	* .8255 *	* .9109 *	* .9943 *	* 1.2214 *	* 1.2062 *	* .5848 *
	* 2.1193 *	* 1.6612 *	* 2.2901 *	* 2.0854 *	* 1.9236 *	* 1.5724 *	* 1.5926 *	* 3.2760 *
11	* 1.1604 *	* .8876 *	* .9104 *	* .9221 *	* 1.2107 *	* 1.0037 *	* 1.1395 *	* .5051 *
	* 1.6383 *	* 2.1388 *	* 2.0865 *	* 2.0739 *	* 1.5883 *	* 1.9143 *	* 1.6887 *	* 3.7985 *
12	* .9339 *	* 1.2000 *	* .9942 *	* 1.2106 *	* 1.0833 *	* 1.2321 *	* .7426 *	
	* 2.0394 *	* 1.5911 *	* 1.9239 *	* 1.5884 *	* 1.7724 *	* 1.5642 *	* 2.5909 *	
13	* 1.1954 *	* 1.0188 *	* 1.2212 *	* 1.0036 *	* 1.2320 *	* 1.1292 *	* .5260 *	
	* 1.5988 *	* 1.8736 *	* 1.5726 *	* 1.9145 *	* 1.5643 *	* 1.7110 *	* 3.6620 *	
14	* .8393 *	* 1.2062 *	* 1.2060 *	* 1.1394 *	* .7423 *	* .5260 *		
	* 2.2779 *	* 1.5904 *	* 1.5928 *	* 1.6889 *	* 2.5919 *	* 3.6621 *		
15	* .4783 *	* .6144 *	* .5847 *	* .5051 *	F-SUB-Q			
	* 3.9920 *	* 3.1154 *	* 3.2767 *	* 3.7991 *	M-SUB-Q			

AT 75% POWER, 250 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5387 *	* .4857 *	* .4130 *	* .4946 *	* .4336 *	* .5083 *	* .3987 *	* .3306 *
	* 3.4399 *	* 3.8132 *	* 4.4877 *	* 3.7649 *	* 4.3136 *	* 3.6815 *	* 4.7027 *	* 5.6808 *
9	* .4857 *	* .4096 *	* .4812 *	* .4182 *	* .5116 *	* .4511 *	* .4779 *	* .2951 *
	* 3.8132 *	* 4.5249 *	* 3.8540 *	* 4.4565 *	* 3.6569 *	* 4.1478 *	* 3.9304 *	* 6.3732 *
10	* .4130 *	* .4814 *	* .4170 *	* .4123 *	* .4445 *	* .5170 *	* .4924 *	* .2865 *
	* 4.4877 *	* 3.8524 *	* 4.4503 *	* 4.5266 *	* 4.2199 *	* 3.6294 *	* 3.8191 *	* 6.5658 *
11	* .4946 *	* .4183 *	* .4122 *	* .4390 *	* .5156 *	* .4478 *	* .4557 *	* .2515 *
	* 3.7649 *	* 4.4553 *	* 4.5282 *	* 4.2788 *	* 3.6495 *	* 4.1966 *	* 4.1335 *	* 7.4958 *
12	* .4336 *	* .5116 *	* .4444 *	* .5155 *	* .4759 *	* .4925 *	* .3487 *	
	* 4.3136 *	* 3.6573 *	* 4.2206 *	* 3.6498 *	* 3.9523 *	* 3.8302 *	* 5.4111 *	
13	* .5083 *	* .4510 *	* .5169 *	* .4477 *	* .4925 *	* .4529 *	* .3653 *	
	* 3.6815 *	* 4.1485 *	* 3.6299 *	* 4.1972 *	* 3.8304 *	* 4.1734 *	* 5.1771 *	
14	* .3987 *	* .4778 *	* .4923 *	* .4557 *	* .3488 *			
	* 4.7027 *	* 3.9312 *	* 3.8197 *	* 4.1340 *	* 5.4096 *	* 5.1779 *		
15	* .3306 *	* .2951 *	* .2865 *	* .2514 *	F-SUB-Q			
	* 5.6808 *	* 6.3741 *	* 6.5670 *	* 7.4970 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 121 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5613 *	* .5618 *	* .5291 *	* .6265 *	* .5670 *	* .6384 *	* .5191 *	* .4729 *
	* 3.3736 *	* 3.8432 *	* 4.0715 *	* 3.4404 *	* 3.7961 *	* 3.3729 *	* 4.1372 *	* 4.5089 *
9	* .5618 *	* .5128 *	* .5970 *	* .5421 *	* .6361 *	* .5753 *	* .5835 *	* .3955 *
	* 3.8432 *	* 4.2037 *	* 3.6093 *	* 3.9696 *	* 3.3842 *	* 3.7368 *	* 3.6762 *	* 5.3903 *
10	* .5291 *	* .5971 *	* .5221 *	* .5198 *	* .5440 *	* .6107 *	* .5799 *	* .3762 *
	* 4.0715 *	* 3.6087 *	* 4.1307 *	* 4.1281 *	* 3.9335 *	* 3.5000 *	* 3.6851 *	* 5.6663 *
11	* .6265 *	* .5421 *	* .5195 *	* .4635 *	* .5405 *	* .4973 *	* .5173 *	* .3228 *
	* 3.4404 *	* 3.9693 *	* 4.1300 *	* 4.3792 *	* 3.7489 *	* 4.2311 *	* 4.0993 *	* 6.5302 *
12	* .5670 *	* .6361 *	* .5440 *	* .5405 *	* .4036 *	* .4383 *	* .3695 *	
	* 3.7961 *	* 3.3842 *	* 3.9336 *	* 3.7489 *	* 3.8904 *	* 3.8999 *	* 5.4067 *	
13	* .6384 *	* .5754 *	* .6107 *	* .4973 *	* .4383 *	* .3895 *	* .3818 *	
	* 3.3729 *	* 3.7366 *	* 3.4998 *	* 4.2312 *	* 3.8999 *	* 4.2168 *	* 4.7874 *	
14	* .5191 *	* .5838 *	* .5800 *	* .5173 *	* .3696 *	* .3816 *		
	* 4.1372 *	* 3.6745 *	* 3.6844 *	* 4.0991 *	* 5.4045 *	* 4.7889 *		
15	* .4729 *	* .3958 *	* .3763 *	* .3228 *	F-SUB-Q			
	* 4.5089 *	* 5.3862 *	* 5.6640 *	* 6.5295 *	M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7032 *	* 1.1441 *	* 1.0693 *	* 1.2765 *	* 1.1486 *	* 1.3058 *	* 1.0465 *	* .6240 *
	* 2.5605 *	* 1.9339 *	* 2.0640 *	* 1.7290 *	* 1.9165 *	* 1.6905 *	* 2.0998 *	* 3.4961 *
9	* 1.1441 *	* 1.0306 *	* 1.2207 *	* 1.0955 *	* 1.2966 *	* 1.1828 *	* 1.2738 *	* .7579 *
	* 1.9339 *	* 2.1424 *	* 1.8089 *	* 2.0128 *	* 1.6980 *	* 1.8614 *	* 1.7251 *	* 2.8780 *
10	* 1.0693 *	* 1.2206 *	* .9664 *	* 1.0368 *	* 1.0957 *	* 1.2544 *	* 1.2361 *	* .7111 *
	* 2.0640 *	* 1.8090 *	* 2.2794 *	* 2.1196 *	* 1.9978 *	* 1.7441 *	* 1.7670 *	* 3.0615 *
11	* 1.2765 *	* 1.0956 *	* 1.0362 *	* .9164 *	* 1.1084 *	* 1.0196 *	* 1.1300 *	* .6083 *
	* 1.7290 *	* 2.0126 *	* 2.1209 *	* 2.2363 *	* 1.8500 *	* 2.0799 *	* 1.9227 *	* 3.5457 *
12	* 1.1486 *	* 1.2966 *	* 1.0956 *	* 1.1083 *	* .8083 *	* .9569 *	* .7211 *	
	* 1.9165 *	* 1.6981 *	* 1.9979 *	* 1.8500 *	* 1.9838 *	* 1.8205 *	* 2.8061 *	
13	* 1.3058 *	* 1.1828 *	* 1.2544 *	* 1.0195 *	* .9569 *	* .8696 *	* .4979 *	
	* 1.6905 *	* 1.8614 *	* 1.7441 *	* 2.0799 *	* 1.8205 *	* 1.9712 *	* 3.7224 *	
14	* 1.0465 *	* 1.2742 *	* 1.2363 *	* 1.1301 *	* .7210 *	* .4979 *		
	* 2.0998 *	* 1.7245 *	* 1.7668 *	* 1.9227 *	* 2.8064 *	* 3.7226 *		
15	* .6240 *	* .7583 *	* .7113 *	* .6083 *	F-SUB-Q			
	* 3.4961 *	* 2.8765 *	* 3.0605 *	* 3.5454 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 122 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8205	* 1.3358	* 1.2344	* 1.4894	* 1.3325	* 1.5279	* 1.2163	* .7246
	* 2.2908	* 1.6844	* 1.8162	* 1.5029	* 1.6748	* 1.4625	* 1.8322	* 3.0534
9	* 1.3358	* 1.1814	* 1.4241	* 1.2643	* 1.5160	* 1.3801	* 1.5092	* .8852
	* 1.6844	* 1.9021	* 1.5766	* 1.7679	* 1.4724	* 1.6150	* 1.4729	* 2.4958
10	* 1.2344	* 1.4237	* 1.0946	* 1.1935	* 1.2635	* 1.4653	* 1.4672	* .8379
	* 1.8162	* 1.5770	* 2.0478	* 1.8693	* 1.7583	* 1.5147	* 1.5095	* 2.6320
11	* 1.4894	* 1.2644	* 1.1930	* 1.0548	* 1.2984	* 1.1838	* 1.3629	* .7158
	* 1.5029	* 1.7677	* 1.8701	* 1.9573	* 1.6147	* 1.8077	* 1.6198	* 3.0627
12	* 1.3325	* 1.5159	* 1.2635	* 1.2983	* .9637	* 1.1311	* .8671	*
	* 1.6748	* 1.4724	* 1.7583	* 1.6147	* 1.7334	* 1.5658	* 2.3647	*
13	* 1.5279	* 1.3800	* 1.4653	* 1.1838	* 1.1311	* 1.0471	* .5792	*
	* 1.4625	* 1.6152	* 1.5146	* 1.8077	* 1.5658	* 1.6629	* 3.2480	*
14	* 1.2163	* 1.5095	* 1.4673	* 1.3629	* .8670	* .5792	*	*
	* 1.8322	* 1.4726	* 1.5094	* 1.6198	* 2.3651	* 3.2479	*	*
15	* .7246	* .8856	* .8381	* .7158	* F-SUB-Q			
	* 3.0534	* 2.4949	* 2.6315	* 3.0625	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8755	* 1.4652	* 1.3156	* 1.6430	* 1.4279	* 1.6932	* 1.3006	* .7733
	* 2.1957	* 1.5625	* 1.7324	* 1.3848	* 1.5886	* 1.3396	* 1.7369	* 2.9006
9	* 1.4652	* 1.2522	* 1.5643	* 1.3481	* 1.6779	* 1.4871	* 1.6761	* .9435
	* 1.5625	* 1.8246	* 1.4573	* 1.6857	* 1.3519	* 1.5227	* 1.3465	* 2.3786
10	* 1.3156	* 1.5637	* 1.1479	* 1.2659	* 1.3556	* 1.6378	* 1.6369	* .8824
	* 1.7324	* 1.4578	* 1.9853	* 1.7923	* 1.6685	* 1.3780	* 1.3756	* 2.5420
11	* 1.6430	* 1.3483	* 1.2642	* 1.1229	* 1.4325	* 1.2747	* 1.5066	* .7488
	* 1.3848	* 1.6855	* 1.7935	* 1.8584	* 1.4759	* 1.7084	* 1.4863	* 2.9710
12	* 1.4279	* 1.6778	* 1.3555	* 1.4324	* 1.0421	* 1.2538	* .9282	*
	* 1.5886	* 1.3520	* 1.6686	* 1.4759	* 1.6308	* 1.4372	* 2.2504	*
13	* 1.6932	* 1.4869	* 1.6378	* 1.2746	* 1.2538	* 1.1640	* .6229	*
	* 1.3396	* 1.5229	* 1.3780	* 1.7084	* 1.4372	* 1.5327	* 3.0850	*
14	* 1.3006	* 1.6763	* 1.6370	* 1.5066	* .9280	* .6229	*	*
	* 1.7369	* 1.3464	* 1.3756	* 1.4863	* 2.2509	* 3.0849	*	*
15	* .7733	* .9437	* .8825	* .7488	* F-SUB-Q			
	* 2.9006	* 2.3780	* 2.5416	* 2.9709	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 123 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8856	* 1.4989	* 1.3309	* 1.6853	* 1.4486	* 1.7439	* 1.3188	* .7800
	* 2.2359	* 1.5632	* 1.7555	* 1.3809	* 1.5989	* 1.3279	* 1.7509	* 2.9415
9	* 1.4989	* 1.2619	* 1.5990	* 1.3638	* 1.7261	* 1.5138	* 1.7293	* .9564
	* 1.5632	* 1.8563	* 1.4606	* 1.7057	* 1.3414	* 1.5269	* 1.3305	* 2.3947
10	* 1.3309	* 1.5984	* 1.1522	* 1.2795	* 1.3773	* 1.6996	* 1.6954	* .8981
	* 1.7555	* 1.4611	* 2.0273	* 1.8154	* 1.6758	* 1.3523	* 1.3521	* 2.5460
11	* 1.6853	* 1.3640	* 1.2789	* 1.1403	* 1.4787	* 1.3011	* 1.5573	* .7606
	* 1.3809	* 1.7054	* 1.8161	* 1.8663	* 1.4585	* 1.7148	* 1.4697	* 2.9888
12	* 1.4486	* 1.7260	* 1.3772	* 1.4786	* 1.0708	* 1.2990	* .9528	*
	* 1.5989	* 1.3414	* 1.6759	* 1.4586	* 1.6340	* 1.4253	* 2.2508	*
13	* 1.7439	* 1.5136	* 1.6996	* 1.3011	* 1.2990	* 1.2071	* .6364	*
	* 1.3279	* 1.5271	* 1.3524	* 1.7149	* 1.4254	* 1.5212	* 3.1130	*
14	* 1.3188	* 1.7293	* 1.6955	* 1.5573	* .9525	* .6364	*	*
	* 1.7509	* 1.3305	* 1.3521	* 1.4697	* 2.2513	* 3.1129	*	*
15	* .7800	* .9566	* .8981	* .7606	* F-SUB-Q			
	* 2.9415	* 2.3943	* 2.5457	* 2.9888	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8870	* 1.5010	* 1.3243	* 1.6855	* 1.4428	* 1.7479	* 1.3135	* .7772
	* 2.3049	* 1.6012	* 1.8151	* 1.4168	* 1.6467	* 1.3565	* 1.7972	* 3.0167
9	* 1.5010	* 1.2539	* 1.5975	* 1.3565	* 1.7311	* 1.5106	* 1.7370	* .9543
	* 1.6012	* 1.9276	* 1.5049	* 1.7612	* 1.3729	* 1.5690	* 1.3579	* 2.4593
10	* 1.3243	* 1.5969	* 1.1462	* 1.2816	* 1.3765	* 1.7137	* 1.7083	* .9008
	* 1.8151	* 1.5054	* 2.1056	* 1.8655	* 1.7288	* 1.3802	* 1.3800	* 2.6066
11	* 1.6855	* 1.3567	* 1.2811	* 1.1450	* 1.4950	* 1.3079	* 1.5725	* .7653
	* 1.4168	* 1.7609	* 1.8662	* 1.9121	* 1.4885	* 1.7602	* 1.5061	* 3.0711
12	* 1.4428	* 1.7310	* 1.3764	* 1.4949	* 1.0863	* 1.3203	* .9671	*
	* 1.6467	* 1.3730	* 1.7289	* 1.4885	* 1.6765	* 1.4587	* 2.2964	*
13	* 1.7479	* 1.5104	* 1.7136	* 1.3079	* 1.3202	* 1.2304	* .6459	*
	* 1.3565	* 1.5693	* 1.3802	* 1.7603	* 1.4587	* 1.5585	* 3.2070	*
14	* 1.3135	* 1.7370	* 1.7083	* 1.5724	* .9669	* .6459	*	*
	* 1.7972	* 1.3579	* 1.3800	* 1.5061	* 2.2970	* 3.2068	*	*
15	* .7772	* .9544	* .9009	* .7652	* F-SUB-Q			
	* 3.0167	* 2.4589	* 2.6064	* 3.0711	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 124 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8935	* 1.5177	* 1.3219	* 1.6932	* 1.4378	* 1.7569	* 1.3082	* .7725
	* 2.3731	* 1.6259	* 1.8945	* 1.4659	* 1.7153	* 1.3989	* 1.8692	* 3.1436
9	* 1.5177	* 1.2529	* 1.6062	* 1.3515	* 1.7424	* 1.5087	* 1.7505	* .9527
	* 1.6259	* 2.0152	* 1.5592	* 1.8386	* 1.4168	* 1.6311	* 1.3990	* 2.5568
10	* 1.3219	* 1.6056	* 1.1387	* 1.2739	* 1.3791	* 1.7341	* 1.7272	* .8956
	* 1.8945	* 1.5598	* 2.2047	* 1.9591	* 1.8028	* 1.4220	* 1.4219	* 2.7259
11	* 1.6932	* 1.3518	* 1.2734	* 1.1594	* 1.5287	* 1.3252	* 1.5933	* .7621
	* 1.4659	* 1.8383	* 1.9599	* 1.9692	* 1.5207	* 1.8078	* 1.5600	* 3.2285
12	* 1.4378	* 1.7424	* 1.3790	* 1.5286	* 1.1145	* 1.3690	* .9814	*
	* 1.7153	* 1.4169	* 1.8030	* 1.5208	* 1.7242	* 1.4906	* 2.3744	*
13	* 1.7569	* 1.5085	* 1.7340	* 1.3251	* 1.3690	* 1.2807	* .6650	*
	* 1.3989	* 1.6313	* 1.4220	* 1.8079	* 1.4906	* 1.5946	* 3.2984	*
14	* 1.3082	* 1.7505	* 1.7271	* 1.5933	* .9811	* .6650	*	*
	* 1.8693	* 1.3990	* 1.4219	* 1.5601	* 2.3751	* 3.2982	*	*
15	* .7725	* .9528	* .8957	* .7621	* F-SUB-Q			
	* 3.1436	* 2.5565	* 2.7258	* 3.2286	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9251	* 1.5394	* 1.3185	* 1.6898	* 1.4280	* 1.7525	* 1.2985	* .7611
	* 2.4682	* 1.6782	* 2.0063	* 1.5447	* 1.8137	* 1.4708	* 1.9737	* 3.3434
9	* 1.5394	* 1.2547	* 1.6083	* 1.3439	* 1.7412	* 1.5007	* 1.7510	* .9437
	* 1.6782	* 2.1024	* 1.6455	* 1.9472	* 1.4904	* 1.7224	* 1.4696	* 2.7101
10	* 1.3185	* 1.6077	* 1.1333	* 1.2704	* 1.3805	* 1.7437	* 1.7341	* .8897
	* 2.0063	* 1.6461	* 2.3466	* 2.0782	* 1.9078	* 1.4937	* 1.4937	* 2.8862
11	* 1.6898	* 1.3441	* 1.2699	* 1.1843	* 1.5703	* 1.3492	* 1.6101	* .7598
	* 1.5447	* 1.9469	* 2.0790	* 2.0251	* 1.5608	* 1.8639	* 1.6214	* 3.4323
12	* 1.4280	* 1.7411	* 1.3804	* 1.5702	* 1.1990	* 1.4542	* 1.0064	*
	* 1.8137	* 1.4905	* 1.9079	* 1.5608	* 1.7765	* 1.5340	* 2.4420	*
13	* 1.7525	* 1.5005	* 1.7436	* 1.3491	* 1.4542	* 1.3574	* .6879	*
	* 1.4708	* 1.7226	* 1.4937	* 1.8640	* 1.5340	* 1.6453	* 3.4227	*
14	* 1.2985	* 1.7510	* 1.7340	* 1.6101	* 1.0061	* .6879	*	*
	* 1.9737	* 1.4696	* 1.4937	* 1.6214	* 2.4428	* 3.4225	*	*
15	* .7611	* .9438	* .8898	* .7598	* F-SUB-Q			
	* 3.3434	* 2.7097	* 2.8861	* 3.4324	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 125 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0033	* 1.5801	* 1.3212	* 1.6940	* 1.4221	* 1.7543	* 1.2917	* .7578 *
	* 2.5849	* 1.7482	* 2.1383	* 1.6367	* 1.9309	* 1.5558	* 2.0992	* 3.5517 *
9	* 1.5801	* 1.2714	* 1.6198	* 1.3409	* 1.7466	* 1.4971	* 1.7573	* .9400 *
	* 1.7482	* 2.2028	* 1.7456	* 2.0755	* 1.5771	* 1.8312	* 1.5536	* 2.8833 *
10	* 1.3212	* 1.6192	* 1.1336	* 1.2705	* 1.3880	* 1.7593	* 1.7468	* .8835 *
	* 2.1383	* 1.7463	* 2.4984	* 2.2147	* 2.0131	* 1.5793	* 1.5795	* 3.0860 *
11	* 1.6940	* 1.3412	* 1.2698	* 1.2447	* 1.6293	* 1.3831	* 1.6333	* .7594 *
	* 1.6367	* 2.0751	* 2.2162	* 2.1114	* 1.6185	* 1.9440	* 1.6849	* 3.6450 *
12	* 1.4221	* 1.7465	* 1.3879	* 1.6292	* 1.3344	* 1.5822	* 1.0365	*
	* 1.9309	* 1.5771	* 2.0132	* 1.6186	* 1.8501	* 1.5900	* 2.5504	*
13	* 1.7543	* 1.4969	* 1.7592	* 1.3830	* 1.5822	* 1.4618	* .7211	*
	* 1.5558	* 1.8315	* 1.5794	* 1.9441	* 1.5900	* 1.7061	* 3.5560	*
14	* 1.2917	* 1.7573	* 1.7467	* 1.6332	* 1.0362	* .7211	*	
	* 2.0992	* 1.5537	* 1.5795	* 1.6849	* 2.5511	* 3.5558	*	
15	* .7578	* .9402	* .8835	* .7594	* F-SUB-Q			
	* 3.5517	* 2.8829	* 3.0859	* 3.6451	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0631	* 1.5906	* 1.3116	* 1.6679	* 1.4030	* 1.7247	* 1.2743	* .7446 *
	* 2.7610	* 1.8584	* 2.2815	* 1.7791	* 2.0910	* 1.6891	* 2.2690	* 3.8524 *
9	* 1.5906	* 1.2755	* 1.6025	* 1.3269	* 1.7200	* 1.4781	* 1.7320	* .9329 *
	* 1.8584	* 2.3302	* 1.8609	* 2.2467	* 1.7127	* 1.9821	* 1.6851	* 3.1017 *
10	* 1.3116	* 1.6019	* 1.1448	* 1.2774	* 1.3802	* 1.7422	* 1.7272	* .8871 *
	* 2.2815	* 1.8613	* 2.6114	* 2.3277	* 2.1353	* 1.6815	* 1.6940	* 3.2867 *
11	* 1.6679	* 1.3271	* 1.2769	* 1.2832	* 1.6514	* 1.3993	* 1.6338	* .7698 *
	* 1.7791	* 2.2464	* 2.3285	* 2.2429	* 1.7273	* 2.0651	* 1.7784	* 3.7876 *
12	* 1.4030	* 1.7200	* 1.3801	* 1.6513	* 1.4309	* 1.6503	* 1.0662	*
	* 2.0910	* 1.7128	* 2.1354	* 1.7274	* 1.9698	* 1.6968	* 2.6799	*
13	* 1.7247	* 1.4779	* 1.7422	* 1.3993	* 1.6503	* 1.5296	* .7407	*
	* 1.6891	* 1.9824	* 1.6816	* 2.0652	* 1.6968	* 1.8151	* 3.7830	*
14	* 1.2743	* 1.7319	* 1.7272	* 1.6338	* 1.0659	* .7407	*	
	* 2.2690	* 1.6851	* 1.6940	* 1.7784	* 2.6807	* 3.7827	*	
15	* .7446	* .9330	* .8871	* .7697	* F-SUB-Q			
	* 3.8524	* 3.1013	* 3.2867	* 3.7877	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 126 of 311

	H	G	F	E	D	C	B	A
8	* 1.0906	* 1.6346	* 1.3139	* 1.6818	* 1.3951	* 1.7363	* 1.2649	* .7367 *
	* 2.8521	* 1.8901	* 2.3453	* 1.8286	* 2.2008	* 1.7679	* 2.4252	* 4.1664 *
9	* 1.6346	* 1.2894	* 1.6269	* 1.3219	* 1.7342	* 1.4747	* 1.7491	* .9238 *
	* 1.8901	* 2.3956	* 1.8951	* 2.3284	* 1.7724	* 2.0830	* 1.7573	* 3.3301 *
10	* 1.3139	* 1.6265	* 1.1332	* 1.2668	* 1.3877	* 1.7709	* 1.7526	* .8735 *
	* 2.3453	* 1.8955	* 2.7242	* 2.4372	* 2.2230	* 1.7389	* 1.7561	* 3.5264 *
11	* 1.6818	* 1.3222	* 1.2660	* 1.3228	* 1.7200	* 1.4308	* 1.6631	* .7587 *
	* 1.8286	* 2.3278	* 2.4385	* 2.3532	* 1.8126	* 2.1677	* 1.8585	* 4.0731 *
12	* 1.3951	* 1.7341	* 1.3876	* 1.7199	* 1.4957	* 1.7368	* 1.0864	* .7694 *
	* 2.2008	* 1.7724	* 2.2232	* 1.8127	* 2.0953	* 1.7980	* 2.8632	* 4.0571 *
13	* 1.7363	* 1.4745	* 1.7709	* 1.4307	* 1.7367	* 1.6138	* .7694	* .7694 *
	* 1.7679	* 2.0833	* 1.7389	* 2.1678	* 1.7980	* 1.9395	* 4.0574	* 4.0574 *
14	* 1.2649	* 1.7491	* 1.7526	* 1.6631	* 1.0860	* .7694	* .7694	* .7694 *
	* 2.4252	* 1.7574	* 1.7561	* 1.8585	* 2.8642	* 4.0571	* 4.0571	* 4.0571 *
15	* .7367	* .9239	* .8735	* .7587	* F-SUB-Q	* M-SUB-Q		
	* 4.1664	* 3.3296	* 3.5264	* 4.0732				

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 127 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0811	* 1.6159	* 1.2999	* 1.6576	* 1.3775	* 1.7110	* 1.2496	* .7277 *
	* 2.9167	* 1.9372	* 2.3953	* 1.8728	* 2.2484	* 1.8092	* 2.4723	* 4.2422 *
9	* 1.6159	* 1.2772	* 1.6058	* 1.3072	* 1.7097	* 1.4567	* 1.7257	* .9162 *
	* 1.9372	* 2.4485	* 1.9420	* 2.3767	* 1.8139	* 2.1267	* 1.7974	* 3.3853 *
10	* 1.2999	* 1.6055	* 1.1344	* 1.2660	* 1.3735	* 1.7500	* 1.7314	* .8730 *
	* 2.3953	* 1.9425	* 2.7522	* 2.4633	* 2.2720	* 1.7790	* 1.7965	* 3.5586 *
11	* 1.6576	* 1.3074	* 1.2655	* 1.3166	* 1.7073	* 1.4202	* 1.6510	* .7630 *
	* 1.8728	* 2.3762	* 2.4642	* 2.4030	* 1.8589	* 2.2171	* 1.8968	* 4.0956 *
12	* 1.3775	* 1.7097	* 1.3735	* 1.7073	* 1.4884	* 1.7260	* 1.0906	*
	* 2.2484	* 1.8140	* 2.2721	* 1.8590	* 2.1442	* 1.8447	* 2.9008	*
13	* 1.7110	* 1.4565	* 1.7500	* 1.4201	* 1.7259	* 1.6092	* .7671	*
	* 1.8092	* 2.1270	* 1.7790	* 2.2172	* 1.8447	* 1.9841	* 4.1507	*
14	* 1.2496	* 1.7257	* 1.7314	* 1.6510	* 1.0902	* .7672	*	
	* 2.4723	* 1.7975	* 1.7965	* 1.8968	* 2.9017	* 4.1504	*	
15	* .7277	* .9164	* .8730	* .7630	* F-SUB-Q			
	* 4.2422	* 3.3849	* 3.5586	* 4.0957	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0818	* 1.6319	* 1.2997	* 1.6709	* 1.3758	* 1.7243	* 1.2476	* .7260 *
	* 2.8956	* 1.9123	* 2.3750	* 1.8508	* 2.2392	* 1.7899	* 2.4560	* 4.1970 *
9	* 1.6319	* 1.2772	* 1.6203	* 1.3046	* 1.7232	* 1.4574	* 1.7419	* .9150 *
	* 1.9123	* 2.4297	* 1.9151	* 2.3632	* 1.7959	* 2.1180	* 1.7813	* 3.3687 *
10	* 1.2997	* 1.6200	* 1.1203	* 1.2519	* 1.3760	* 1.7687	* 1.7500	* .8630 *
	* 2.3750	* 1.9155	* 2.7606	* 2.4740	* 2.2719	* 1.7668	* 1.7829	* 3.5821 *
11	* 1.6709	* 1.3050	* 1.2511	* 1.3198	* 1.7278	* 1.4246	* 1.6622	* .7516 *
	* 1.8508	* 2.3625	* 2.4767	* 2.4083	* 1.8535	* 2.2254	* 1.8962	* 4.1508 *
12	* 1.3758	* 1.7232	* 1.3760	* 1.7278	* 1.4969	* 1.7475	* 1.0845	*
	* 2.2392	* 1.7959	* 2.2720	* 1.8535	* 2.1516	* 1.8396	* 2.9333	*
13	* 1.7243	* 1.4572	* 1.7687	* 1.4245	* 1.7475	* 1.6266	* .7726	*
	* 1.7899	* 2.1183	* 1.7668	* 2.2255	* 1.8396	* 1.9830	* 4.1364	*
14	* 1.2476	* 1.7418	* 1.7500	* 1.6622	* 1.0842	* .7727	*	
	* 2.4560	* 1.7813	* 1.7829	* 1.8962	* 2.9344	* 4.1361	*	
15	* .7260	* .9151	* .8630	* .7516	* F-SUB-Q			
	* 4.1970	* 3.3683	* 3.5820	* 4.1509	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 128 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0732	* 1.6323	* 1.2945	* 1.6695	* 1.3688	* 1.7228	* 1.2414	* .7189 *
	* 2.6952	* 1.7768	* 2.2214	* 1.7353	* 2.1045	* 1.6830	* 2.3132	* 3.9535 *
9	* 1.6323	* 1.2715	* 1.6198	* 1.2979	* 1.7218	* 1.4514	* 1.7424	* .9097 *
	* 1.7768	* 2.2638	* 1.7854	* 2.2182	* 1.6913	* 1.9960	* 1.6827	* 3.1657 *
10	* 1.2945	* 1.6195	* 1.1090	* 1.2452	* 1.3709	* 1.7707	* 1.7522	* .8556 *
	* 2.2214	* 1.7857	* 2.5899	* 2.3114	* 2.1333	* 1.6653	* 1.6817	* 3.3809 *
11	* 1.6695	* 1.2983	* 1.2445	* 1.3164	* 1.7301	* 1.4206	* 1.6628	* .7451 *
	* 1.7353	* 2.2175	* 2.3137	* 2.2429	* 1.7312	* 2.0816	* 1.7766	* 3.9003 *
12	* 1.3688	* 1.7218	* 1.3709	* 1.7301	* 1.4949	* 1.7505	* 1.0803	*
	* 2.1045	* 1.6913	* 2.1334	* 1.7312	* 2.0112	* 1.7211	* 2.7406	*
13	* 1.7228	* 1.4512	* 1.7707	* 1.4206	* 1.7505	* 1.6297	* .7696	*
	* 1.6830	* 1.9963	* 1.6652	* 2.0816	* 1.7211	* 1.8501	* 3.8494	*
14	* 1.2414	* 1.7423	* 1.7522	* 1.6629	* 1.0799	* .7697	*	
	* 2.3132	* 1.6827	* 1.6817	* 1.7766	* 2.7415	* 3.8491	*	
15	* .7189	* .9099	* .8556	* .7451	* F-SUB-Q			
	* 3.9535	* 3.1652	* 3.3808	* 3.9004	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0682	* 1.6274	* 1.2888	* 1.6634	* 1.3610	* 1.7165	* 1.2346	* .7150 *
	* 2.4978	* 1.6436	* 2.0580	* 1.6013	* 1.9474	* 1.5548	* 2.1429	* 3.6645 *
9	* 1.6274	* 1.2653	* 1.6145	* 1.2910	* 1.7156	* 1.4440	* 1.7367	* .9055 *
	* 1.6436	* 2.0987	* 1.6518	* 2.0516	* 1.5599	* 1.8449	* 1.5526	* 2.9267 *
10	* 1.2888	* 1.6142	* 1.1089	* 1.2386	* 1.3637	* 1.7656	* 1.7470	* .8547 *
	* 2.0580	* 1.6521	* 2.3893	* 2.1388	* 1.9781	* 1.5399	* 1.5552	* 3.1142 *
11	* 1.6634	* 1.2913	* 1.2382	* 1.3112	* 1.7252	* 1.4140	* 1.6586	* .7433 *
	* 1.6013	* 2.0510	* 2.1409	* 2.0737	* 1.5983	* 1.9267	* 1.6425	* 3.6103 *
12	* 1.3610	* 1.7155	* 1.3637	* 1.7252	* 1.4894	* 1.7459	* 1.0786	*
	* 1.9474	* 1.5599	* 1.9781	* 1.5983	* 1.8575	* 1.5873	* 2.5282	*
13	* 1.7165	* 1.4438	* 1.7656	* 1.4139	* 1.7459	* 1.6264	* .7666	*
	* 1.5548	* 1.8452	* 1.5398	* 1.9267	* 1.5874	* 1.7069	* 3.5606	*
14	* 1.2346	* 1.7367	* 1.7471	* 1.6587	* 1.0782	* .7667	*	
	* 2.1429	* 1.5526	* 1.5551	* 1.6424	* 2.5291	* 3.5603	*	
15	* .7150	* .9057	* .8547	* .7433	* F-SUB-Q			
	* 3.6646	* 2.9262	* 3.1142	* 3.6103	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 129 of 311

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.0608	* 1.6131	* 1.2806	* 1.6478	* 1.3511	* 1.7004	* 1.2259	* .7094
	* 2.3361	* 1.5390	* 1.9190	* 1.4981	* 1.8206	* 1.4564	* 2.0047	* 3.4343
9	* 1.6131	* 1.2569	* 1.5998	* 1.2830	* 1.6995	* 1.4335	* 1.7210	* .9038
	* 1.5390	* 1.9611	* 1.5452	* 1.9131	* 1.4594	* 1.7239	* 1.4514	* 2.7216
10	* 1.2806	* 1.5994	* 1.1150	* 1.2427	* 1.3534	* 1.7502	* 1.7317	* .8579
	* 1.9190	* 1.5455	* 2.2038	* 1.9855	* 1.8475	* 1.4381	* 1.4517	* 2.8766
11	* 1.6478	* 1.2833	* 1.2423	* 1.3034	* 1.7099	* 1.4038	* 1.6490	* .7501
	* 1.4981	* 1.9126	* 1.9865	* 1.9367	* 1.4954	* 1.8020	* 1.5341	* 3.3197
12	* 1.3511	* 1.6995	* 1.3534	* 1.7099	* 1.4792	* 1.7304	* 1.0804	*
	* 1.8206	* 1.4594	* 1.8475	* 1.4954	* 1.7336	* 1.4844	* 2.3442	*
13	* 1.7004	* 1.4333	* 1.7503	* 1.4038	* 1.7304	* 1.6158	* .7615	*
	* 1.4564	* 1.7241	* 1.4381	* 1.8021	* 1.4844	* 1.5921	* 3.3272	*
14	* 1.2259	* 1.7210	* 1.7318	* 1.6490	* 1.0800	* .7616	*	
	* 2.0047	* 1.4514	* 1.4517	* 1.5341	* 2.3450	* 3.3269	*	
15	* .7094	* .9040	* .8579	* .7500	F-SUB-Q			
	* 3.4343	* 2.7212	* 2.8766	* 3.3197	M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* 1.0672	* 1.6388	* 1.2884	* 1.6724	* 1.3581	* 1.7253	* 1.2314	* .7121
	* 2.1600	* 1.4120	* 1.7829	* 1.3813	* 1.6966	* 1.3442	* 1.8708	* 3.2097
9	* 1.6388	* 1.2637	* 1.6247	* 1.2880	* 1.7244	* 1.4431	* 1.7477	* .9047
	* 1.4120	* 1.8188	* 1.4203	* 1.7833	* 1.3460	* 1.6031	* 1.3367	* 2.5473
10	* 1.2884	* 1.6244	* 1.1020	* 1.2369	* 1.3615	* 1.7776	* 1.7593	* .8488
	* 1.7829	* 1.4206	* 2.0825	* 1.8545	* 1.7137	* 1.3214	* 1.3340	* 2.7219
11	* 1.6724	* 1.2885	* 1.2358	* 1.3102	* 1.7353	* 1.4130	* 1.6673	* .7384
	* 1.3813	* 1.7827	* 1.8560	* 1.7976	* 1.3728	* 1.6695	* 1.4139	* 3.1475
12	* 1.3581	* 1.7243	* 1.3614	* 1.7353	* 1.4915	* 1.7566	* 1.0748	*
	* 1.6966	* 1.3460	* 1.7137	* 1.3728	* 1.5965	* 1.3609	* 2.2022	*
13	* 1.7253	* 1.4429	* 1.7777	* 1.4130	* 1.7566	* 1.6357	* .7661	*
	* 1.3442	* 1.6033	* 1.3213	* 1.6695	* 1.3609	* 1.4625	* 3.0896	*
14	* 1.2314	* 1.7477	* 1.7594	* 1.6674	* 1.0744	* .7662	*	
	* 1.8708	* 1.3367	* 1.3340	* 1.4139	* 2.2029	* 3.0893	*	
15	* .7121	* .9049	* .8488	* .7383	* F-SUB-Q			
	* 3.2097	* 2.5469	* 2.7219	* 3.1475	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 130 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0658	* 1.6417	* 1.2882	* 1.6742	* 1.3569	* 1.7267	* 1.2297	* .7104 *
	* 2.0328	* 1.3290	* 1.6847	* 1.3051	* 1.6074	* 1.2708	* 1.7743	* 3.0501 *
9	* 1.6417	* 1.2632	* 1.6275	* 1.2869	* 1.7258	* 1.4428	* 1.7500	* .9040 *
	* 1.3290	* 1.7178	* 1.3392	* 1.6889	* 1.2717	* 1.5173	* 1.2616	* 2.4140 *
10	* 1.2882	* 1.6272	* 1.1013	* 1.2372	* 1.3604	* 1.7796	* 1.7620	* .8470 *
	* 1.6847	* 1.3395	* 1.9696	* 1.7531	* 1.6192	* 1.2455	* 1.2573	* 2.5814 *
11	* 1.6742	* 1.2874	* 1.2362	* 1.3095	* 1.7370	* 1.4123	* 1.6691	* .7366 *
	* 1.3051	* 1.6883	* 1.7543	* 1.6894	* 1.2867	* 1.5710	* 1.3308	* 2.9798 *
12	* 1.3569	* 1.7257	* 1.3604	* 1.7370	* 1.4921	* 1.7590	* 1.0733	*
	* 1.6074	* 1.2717	* 1.6192	* 1.2867	* 1.4952	* 1.2749	* 2.0722	*
13	* 1.7267	* 1.4425	* 1.7796	* 1.4122	* 1.7590	* 1.6376	* .7644	*
	* 1.2708	* 1.5175	* 1.2454	* 1.5710	* 1.2749	* 1.3704	* 2.9133	*
14	* 1.2297	* 1.7500	* 1.7620	* 1.6691	* 1.0729	* .7645	*	
	* 1.7743	* 1.2616	* 1.2573	* 1.3307	* 2.0729	* 2.9130	*	
15	* .7104	* .9041	* .8470	* .7365	* F-SUB-Q			
	* 3.0501	* 2.4135	* 2.5813	* 2.9798	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0494	* 1.6081	* 1.2727	* 1.6384	* 1.3397	* 1.6889	* 1.2137	* .6987 *
	* 1.9706	* 1.2946	* 1.6296	* 1.2747	* 1.5573	* 1.2418	* 1.7200	* 2.9698 *
9	* 1.6081	* 1.2485	* 1.5947	* 1.2727	* 1.6890	* 1.4237	* 1.7136	* .8957 *
	* 1.2946	* 1.6605	* 1.3056	* 1.6338	* 1.2416	* 1.4700	* 1.2303	* 2.3305 *
10	* 1.2727	* 1.5944	* 1.1099	* 1.2355	* 1.3428	* 1.7405	* 1.7243	* .8485 *
	* 1.6296	* 1.3059	* 1.8686	* 1.6856	* 1.5660	* 1.2147	* 1.2255	* 2.4641 *
11	* 1.6384	* 1.2731	* 1.2351	* 1.2939	* 1.7004	* 1.3933	* 1.6421	* .7411 *
	* 1.2747	* 1.6334	* 1.6863	* 1.6274	* 1.2480	* 1.5164	* 1.2892	* 2.8285 *
12	* 1.3397	* 1.6889	* 1.3427	* 1.7004	* 1.4717	* 1.7242	* 1.0710	*
	* 1.5573	* 1.2416	* 1.5660	* 1.2480	* 1.4393	* 1.2348	* 1.9762	*
13	* 1.6889	* 1.4235	* 1.7405	* 1.3933	* 1.7242	* 1.6095	* .7513	*
	* 1.2418	* 1.4702	* 1.2146	* 1.5163	* 1.2348	* 1.3240	* 2.8178	*
14	* 1.2137	* 1.7135	* 1.7243	* 1.6422	* 1.0706	* .7514	*	
	* 1.7200	* 1.2303	* 1.2255	* 1.2891	* 1.9768	* 2.8175	*	
15	* .6987	* .8958	* .8485	* .7411	* F-SUB-Q			
	* 2.9698	* 2.3300	* 2.4640	* 2.8284	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 131 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0317	* 1.5875	* 1.2545	* 1.6136	* 1.3194	* 1.6627	* 1.1929	* .6851 *
	* 1.9336	* 1.2620	* 1.5954	* 1.2488	* 1.5265	* 1.2170	* 1.6897	* 2.9273 *
9	* 1.5875	* 1.2309	* 1.5749	* 1.2526	* 1.6625	* 1.4038	* 1.6886	* .8769 *
	* 1.2620	* 1.6247	* 1.2741	* 1.6023	* 1.2167	* 1.4385	* 1.2034	* 2.2984 *
10	* 1.2545	* 1.5746	* 1.0805	* 1.2103	* 1.3256	* 1.7114	* 1.6983	* .8228 *
	* 1.5954	* 1.2743	* 1.8526	* 1.6550	* 1.5293	* 1.1898	* 1.1985	* 2.4529 *
11	* 1.6136	* 1.2531	* 1.2087	* 1.2750	* 1.6750	* 1.3742	* 1.6123	* .7159 *
	* 1.2488	* 1.6017	* 1.6567	* 1.5886	* 1.2168	* 1.4800	* 1.2642	* 2.8243 *
12	* 1.3194	* 1.6624	* 1.3255	* 1.6750	* 1.4526	* 1.7014	* 1.0419	*
	* 1.5265	* 1.2167	* 1.5286	* 1.2169	* 1.4008	* 1.2017	* 1.9549	*
13	* 1.6627	* 1.4036	* 1.7114	* 1.3741	* 1.7014	* 1.5831	* .7381	*
	* 1.2170	* 1.4387	* 1.1898	* 1.4799	* 1.2017	* 1.2931	* 2.7586	*
14	* 1.1929	* 1.6885	* 1.6983	* 1.6123	* 1.0415	* .7382	*	
	* 1.6897	* 1.2034	* 1.1985	* 1.2641	* 1.9555	* 2.7583	*	
15	* .6851	* .8771	* .8228	* .7159	* F-SUB-Q			
	* 2.9273	* 2.2979	* 2.4529	* 2.8242	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9682	* 1.4708	* 1.1764	* 1.4883	* 1.2347	* 1.5337	* 1.1156	* .6386 *
	* 2.0039	* 1.3236	* 1.6542	* 1.3160	* 1.5874	* 1.2832	* 1.7586	* 3.0606 *
9	* 1.4708	* 1.1552	* 1.4595	* 1.1739	* 1.5355	* 1.3162	* 1.5588	* .8176 *
	* 1.3236	* 1.6832	* 1.3358	* 1.6644	* 1.2812	* 1.4925	* 1.2671	* 2.4002 *
10	* 1.1764	* 1.4594	* 1.0193	* 1.1446	* 1.2499	* 1.5750	* 1.5657	* .7683 *
	* 1.6542	* 1.3360	* 1.9097	* 1.7034	* 1.5758	* 1.2561	* 1.2630	* 2.5574 *
11	* 1.4883	* 1.1743	* 1.1431	* 1.1985	* 1.5475	* 1.2914	* 1.4907	* .6693 *
	* 1.3160	* 1.6638	* 1.7056	* 1.6420	* 1.2785	* 1.5296	* 1.3283	* 2.9402 *
12	* 1.2347	* 1.5354	* 1.2498	* 1.5475	* 1.3632	* 1.5746	* .9694	*
	* 1.5874	* 1.2812	* 1.5758	* 1.2785	* 1.4490	* 1.2606	* 2.0412	*
13	* 1.5337	* 1.3160	* 1.5750	* 1.2913	* 1.5746	* 1.4642	* .6893	*
	* 1.2832	* 1.4927	* 1.2560	* 1.5296	* 1.2606	* 1.3576	* 2.8698	*
14	* 1.1156	* 1.5587	* 1.5657	* 1.4907	* .9690	* .6894	*	
	* 1.7586	* 1.2671	* 1.2629	* 1.3282	* 2.0419	* 2.8695	*	
15	* .6386	* .8177	* .7682	* .6692	* F-SUB-Q			
	* 3.0606	* 2.3998	* 2.5574	* 2.9402	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 132 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 350 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8280	* 1.2183	* .9522	* 1.2370	* .9971	* 1.2722	* .9012	* .5353
	* 2.2979	* 1.5661	* 2.0019	* 1.5493	* 1.9232	* 1.5122	* 2.1337	* 3.5797
9	* 1.2183	* .9372	* 1.2085	* .9500	* 1.2756	* 1.0844	* 1.2812	* .6760
	* 1.5661	* 2.0329	* 1.5813	* 2.0126	* 1.5075	* 1.7718	* 1.5055	* 2.8433
10	* .9522	* 1.2086	* .8854	* .9757	* 1.0608	* 1.3039	* 1.2801	* .6434
	* 2.0019	* 1.5811	* 2.1536	* 1.9607	* 1.8155	* 1.4821	* 1.5097	* 2.9909
11	* 1.2370	* .9502	* .9753	* .9867	* 1.2895	* 1.0680	* 1.2144	* .5570
	* 1.5493	* 2.0121	* 1.9616	* 1.9515	* 1.5013	* 1.8082	* 1.5942	* 3.4589
12	* .9971	* 1.2756	* 1.0608	* 1.2895	* 1.1489	* 1.2982	* .8000	*
	* 1.9232	* 1.5075	* 1.8155	* 1.5013	* 1.6822	* 1.4936	* 2.4181	*
13	* 1.2722	* 1.0842	* 1.3039	* 1.0680	* 1.2982	* 1.1944	* .5763	*
	* 1.5122	* 1.7721	* 1.4821	* 1.8082	* 1.4935	* 1.6267	* 3.3578	*
14	* .9012	* 1.2811	* 1.2800	* 1.2144	* .7998	* .5763	*	*
	* 2.1337	* 1.5056	* 1.5097	* 1.5941	* 2.4187	* 3.3578	*	*
15	* .5353	* .6761	* .6433	* .5570	* F-SUB-Q			
	* 3.5797	* 2.8429	* 2.9911	* 3.4589	* M-SUB-Q			

AT 75% POWER, 350 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5962	* .5450	* .4637	* .5556	* .4845	* .5700	* .4498	* .3847
	* 3.1338	* 3.4263	* 4.0262	* 3.3723	* 3.8797	* 3.2985	* 4.1846	* 4.8911
9	* .5450	* .4587	* .5406	* .4686	* .5731	* .5058	* .5397	* .3426
	* 3.4263	* 4.0678	* 3.4577	* 4.0010	* 3.2819	* 3.7177	* 3.4939	* 5.5046
10	* .4637	* .5408	* .4704	* .4659	* .4995	* .5794	* .5540	* .3321
	* 4.0262	* 3.4546	* 3.9742	* 4.0279	* 3.7735	* 3.2540	* 3.4087	* 5.6787
11	* .5556	* .4687	* .4658	* .4904	* .5764	* .5009	* .5167	* .2923
	* 3.3723	* 3.9997	* 4.0287	* 3.8499	* 3.2803	* 3.7698	* 3.6605	* 6.4644
12	* .4845	* .5731	* .4995	* .5764	* .5324	* .5513	* .3953	*
	* 3.8797	* 3.2820	* 3.7735	* 3.2801	* 3.5502	* 3.4364	* 4.7897	*
13	* .5700	* .5057	* .5793	* .5009	* .5513	* .5097	* .4164	*
	* 3.2985	* 3.7182	* 3.2540	* 3.7696	* 3.4362	* 3.7233	* 4.5544	*
14	* .4498	* .5396	* .5539	* .5167	* .3954	* .4163	*	*
	* 4.1846	* 3.4941	* 3.4086	* 3.6603	* 4.7883	* 4.5548	*	*
15	* .3847	* .3426	* .3321	* .2922	* F-SUB-Q			
	* 4.8911	* 5.5046	* 5.6790	* 6.4644	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 133 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6222 *	* .6402 *	* .6090 *	* .7208 *	* .6569 *	* .7395 *	* .6078 *	* .5702 *
	* 3.5899 *	* 3.4944 *	* 3.6848 *	* 3.1207 *	* 3.4245 *	* 3.0445 *	* 3.6947 *	* 3.9223 *
9	* .6402 *	* .5886 *	* .6856 *	* .6269 *	* .7345 *	* .6684 *	* .6846 *	* .4798 *
	* 3.4944 *	* 3.8067 *	* 3.2733 *	* 3.5825 *	* 3.0624 *	* 3.3631 *	* 3.2764 *	* 4.6580 *
10	* .6090 *	* .6857 *	* .6062 *	* .6047 *	* .6310 *	* .7086 *	* .6778 *	* .4553 *
	* 3.6848 *	* 3.2728 *	* 3.6992 *	* 3.6983 *	* 3.5412 *	* 3.1510 *	* 3.2979 *	* 4.9020 *
11	* .7208 *	* .6270 *	* .6045 *	* .5421 *	* .6256 *	* .5778 *	* .6087 *	* .3927 *
	* 3.1207 *	* 3.5821 *	* 3.6996 *	* 4.1075 *	* 3.5273 *	* 3.8154 *	* 3.6294 *	* 5.6089 *
12	* .6569 *	* .7345 *	* .6310 *	* .6256 *	* .4588 *	* .5124 *	* .4355 *	
	* 3.4245 *	* 3.0623 *	* 3.5412 *	* 3.5274 *	* 4.1447 *	* 4.1534 *	* 4.9624 *	
13	* .7395 *	* .6684 *	* .7087 *	* .5778 *	* .5124 *	* .4568 *	* .4539 *	
	* 3.0445 *	* 3.3629 *	* 3.1509 *	* 3.8154 *	* 4.1534 *	* 4.4729 *	* 4.6747 *	
14	* .6078 *	* .6849 *	* .6780 *	* .6088 *	* .4357 *	* .4538 *		
	* 3.6947 *	* 3.2750 *	* 3.2973 *	* 3.6292 *	* 4.9606 *	* 4.6762 *		
15	* .5702 *	* .4802 *	* .4555 *	* .3927 *	F-SUB-Q			
	* 3.9223 *	* 4.6548 *	* 4.9002 *	* 5.6084 *	M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7334 *	* 1.2187 *	* 1.1445 *	* 1.3768 *	* 1.2391 *	* 1.4189 *	* 1.1506 *	* .7148 *
	* 2.9256 *	* 1.8738 *	* 2.0001 *	* 1.6670 *	* 1.8518 *	* 1.6190 *	* 1.9907 *	* 3.1838 *
9	* 1.2187 *	* 1.1004 *	* 1.3097 *	* 1.1787 *	* 1.4066 *	* 1.2817 *	* 1.3889 *	* .8581 *
	* 1.8738 *	* 2.0767 *	* 1.7482 *	* 1.9439 *	* 1.6303 *	* 1.7890 *	* 1.6469 *	* 2.6524 *
10	* 1.1445 *	* 1.3096 *	* 1.0407 *	* 1.1240 *	* 1.1854 *	* 1.3678 *	* 1.3471 *	* .7991 *
	* 2.0001 *	* 1.7483 *	* 2.1955 *	* 2.0295 *	* 1.9194 *	* 1.6636 *	* 1.6883 *	* 2.8447 *
11	* 1.3768 *	* 1.1788 *	* 1.1235 *	* .9945 *	* 1.2021 *	* 1.1072 *	* 1.2327 *	* .6881 *
	* 1.6670 *	* 1.9436 *	* 2.0305 *	* 2.2819 *	* 1.8728 *	* 2.0298 *	* 1.8288 *	* 3.2614 *
12	* 1.2391 *	* 1.4066 *	* 1.1854 *	* 1.2020 *	* .8543 *	* 1.0398 *	* .7961 *	
	* 1.8518 *	* 1.6303 *	* 1.9194 *	* 1.8729 *	* 2.2762 *	* 2.0504 *	* 2.7746 *	
13	* 1.4189 *	* 1.2817 *	* 1.3680 *	* 1.1072 *	* 1.0398 *	* .9426 *	* .5623 *	
	* 1.6190 *	* 1.7890 *	* 1.6634 *	* 2.0298 *	* 2.0504 *	* 2.1673 *	* 3.7761 *	
14	* 1.1506 *	* 1.3893 *	* 1.3473 *	* 1.2327 *	* .7960 *	* .5622 *		
	* 1.9907 *	* 1.6464 *	* 1.6881 *	* 1.8287 *	* 2.7749 *	* 3.7763 *		
15	* .7148 *	* .8585 *	* .7993 *	* .6882 *	F-SUB-Q			
	* 3.1838 *	* 2.6513 *	* 2.8440 *	* 3.2612 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 134 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8355	* 1.3878	* 1.2767	* 1.5712	* 1.3890	* 1.6252	* 1.2918	* .8074
	* 2.5485	* 1.6700	* 1.8170	* 1.4755	* 1.6667	* 1.4262	* 1.7935	* 2.8535
9	* 1.3878	* 1.2188	* 1.4926	* 1.3142	* 1.6100	* 1.4422	* 1.6093	* .9710
	* 1.6700	* 1.9012	* 1.5539	* 1.7622	* 1.4371	* 1.6034	* 1.4331	* 2.3663
10	* 1.2767	* 1.4922	* 1.1423	* 1.2487	* 1.3220	* 1.5766	* 1.5687	* .9186
	* 1.8170	* 1.5542	* 2.0272	* 1.8499	* 1.7391	* 1.4572	* 1.4628	* 2.4948
11	* 1.5712	* 1.3144	* 1.2483	* 1.1050	* 1.3741	* 1.2413	* 1.4410	* .7888
	* 1.4755	* 1.7619	* 1.8504	* 2.0521	* 1.6580	* 1.8355	* 1.5825	* 2.8796
12	* 1.3890	* 1.6100	* 1.3220	* 1.3740	* .9921	* 1.2018	* .9291	*
	* 1.6667	* 1.4371	* 1.7391	* 1.6581	* 1.9310	* 1.6683	* 2.3932	*
13	* 1.6252	* 1.4422	* 1.5767	* 1.2412	* 1.2018	* 1.0976	* .6348	*
	* 1.4262	* 1.6035	* 1.4571	* 1.8356	* 1.6683	* 1.7850	* 3.2707	*
14	* 1.2918	* 1.6096	* 1.5689	* 1.4411	* .9290	* .6348	*	*
	* 1.7935	* 1.4329	* 1.4627	* 1.5824	* 2.3935	* 3.2706	*	*
15	* .8074	* .9714	* .9188	* .7888	* F-SUB-Q			
	* 2.8535	* 2.3656	* 2.4943	* 2.8795	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8792	* 1.4863	* 1.3281	* 1.6865	* 1.4509	* 1.7509	* 1.3468	* .8407
	* 2.2846	* 1.5815	* 1.7661	* 1.3895	* 1.6127	* 1.3365	* 1.7338	* 2.7637
9	* 1.4863	* 1.2616	* 1.5969	* 1.3673	* 1.7329	* 1.5137	* 1.7336	* 1.0101
	* 1.5815	* 1.8614	* 1.4688	* 1.7126	* 1.3493	* 1.5433	* 1.3429	* 2.2953
10	* 1.3281	* 1.5965	* 1.1713	* 1.2890	* 1.3809	* 1.7050	* 1.6965	* .9455
	* 1.7661	* 1.4692	* 2.0027	* 1.8127	* 1.6859	* 1.3626	* 1.3674	* 2.4507
11	* 1.6865	* 1.3676	* 1.2877	* 1.1462	* 1.4784	* 1.3011	* 1.5462	* .8052
	* 1.3895	* 1.7122	* 1.8136	* 1.9199	* 1.5147	* 1.7630	* 1.4884	* 2.8470
12	* 1.4509	* 1.7329	* 1.3809	* 1.4783	* 1.0527	* 1.2954	* .9681	*
	* 1.6127	* 1.3494	* 1.6859	* 1.5147	* 1.7122	* 1.4935	* 2.2730	*
13	* 1.7509	* 1.5136	* 1.7051	* 1.3011	* 1.2954	* 1.1878	* .6650	*
	* 1.3365	* 1.5435	* 1.3626	* 1.7630	* 1.4935	* 1.6043	* 3.0768	*
14	* 1.3468	* 1.7338	* 1.6965	* 1.5462	* .9679	* .6650	*	*
	* 1.7338	* 1.3428	* 1.3674	* 1.4884	* 2.2735	* 3.0767	*	*
15	* .8407	* 1.0104	* .9456	* .8052	* F-SUB-Q			
	* 2.7637	* 2.2948	* 2.4504	* 2.8470	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 135 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8772	* 1.4916	* 1.3182	* 1.6943	* 1.4425	* 1.7630	* 1.3385	* .8319
	* 2.2877	* 1.6068	* 1.8120	* 1.4072	* 1.6473	* 1.3480	* 1.7725	* 2.8392
9	* 1.4916	* 1.2480	* 1.6006	* 1.3564	* 1.7440	* 1.5081	* 1.7461	* 1.0033
	* 1.6068	* 1.9167	* 1.4913	* 1.7569	* 1.3609	* 1.5724	* 1.3515	* 2.3468
10	* 1.3182	* 1.6002	* 1.1547	* 1.2772	* 1.3735	* 1.7221	* 1.7123	* .9430
	* 1.8120	* 1.4917	* 2.0680	* 1.8606	* 1.7191	* 1.3647	* 1.3705	* 2.4894
11	* 1.6943	* 1.3567	* 1.2768	* 1.1392	* 1.4890	* 1.2968	* 1.5602	* .8005
	* 1.4072	* 1.7566	* 1.8611	* 1.9171	* 1.4911	* 1.7684	* 1.4958	* 2.9036
12	* 1.4425	* 1.7440	* 1.3734	* 1.4889	* 1.0596	* 1.3061	* .9712	*
	* 1.6473	* 1.3609	* 1.7191	* 1.4911	* 1.6964	* 1.4694	* 2.2657	*
13	* 1.7630	* 1.5080	* 1.7221	* 1.2967	* 1.3060	* 1.2010	* .6631	*
	* 1.3480	* 1.5726	* 1.3647	* 1.7684	* 1.4694	* 1.5730	* 3.0794	*
14	* 1.3385	* 1.7461	* 1.7123	* 1.5602	* .9710	* .6632	*	*
	* 1.7725	* 1.3514	* 1.3704	* 1.4958	* 2.2662	* 3.0793	*	*
15	* .8319	* 1.0035	* .9431	* .8005	* F-SUB-Q			
	* 2.8391	* 2.3464	* 2.4892	* 2.9036	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8649	* 1.4688	* 1.2927	* 1.6681	* 1.4143	* 1.7377	* 1.3123	* .8162
	* 2.3545	* 1.6522	* 1.8857	* 1.4545	* 1.7094	* 1.3893	* 1.8346	* 2.9350
9	* 1.4688	* 1.2214	* 1.5748	* 1.3297	* 1.7189	* 1.4801	* 1.7221	* .9849
	* 1.6522	* 2.0032	* 1.5475	* 1.8253	* 1.4052	* 1.6294	* 1.3929	* 2.4290
10	* 1.2927	* 1.5743	* 1.1313	* 1.2604	* 1.3486	* 1.7019	* 1.6910	* .9307
	* 1.8857	* 1.5479	* 2.1613	* 1.9228	* 1.7878	* 1.4082	* 1.4145	* 2.5681
11	* 1.6681	* 1.3299	* 1.2600	* 1.1204	* 1.4705	* 1.2753	* 1.5442	* .7933
	* 1.4545	* 1.8250	* 1.9233	* 1.9680	* 1.5240	* 1.8197	* 1.5481	* 3.0005
12	* 1.4143	* 1.7188	* 1.3486	* 1.4704	* 1.0491	* 1.2924	* .9642	*
	* 1.7094	* 1.4052	* 1.7878	* 1.5240	* 1.7386	* 1.5015	* 2.3137	*
13	* 1.7377	* 1.4799	* 1.7019	* 1.2752	* 1.2923	* 1.1909	* .6562	*
	* 1.3893	* 1.6296	* 1.4082	* 1.8197	* 1.5015	* 1.6027	* 3.1578	*
14	* 1.3123	* 1.7222	* 1.6910	* 1.5442	* .9639	* .6563	*	*
	* 1.8346	* 1.3929	* 1.4145	* 1.5481	* 2.3143	* 3.1576	*	*
15	* .8162	* .9851	* .9308	* .7933	* F-SUB-Q			
	* 2.9350	* 2.4286	* 2.5680	* 3.0005	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 136 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8525 *	* 1.4594 *	* 1.2737 *	* 1.6543 *	* 1.3920 *	* 1.7233 *	* 1.2907 *	* .8014 *
	* 2.4298 *	* 1.6830 *	* 1.9745 *	* 1.5109 *	* 1.7882 *	* 1.4405 *	* 1.9167 *	* 3.0716 *
9	* 1.4594 *	* 1.2035 *	* 1.5627 *	* 1.3084 *	* 1.7045 *	* 1.4586 *	* 1.7104 *	* .9704 *
	* 1.6830 *	* 2.0988 *	* 1.6081 *	* 1.9126 *	* 1.4594 *	* 1.7022 *	* 1.4437 *	* 2.5377 *
10	* 1.2737 *	* 1.5622 *	* 1.1105 *	* 1.2339 *	* 1.3304 *	* 1.6940 *	* 1.6822 *	* .9125 *
	* 1.9745 *	* 1.6085 *	* 2.2677 *	* 2.0295 *	* 1.8733 *	* 1.4607 *	* 1.4673 *	* 2.7002 *
11	* 1.6543 *	* 1.3086 *	* 1.2335 *	* 1.1094 *	* 1.4669 *	* 1.2639 *	* 1.5358 *	* .7755 *
	* 1.5109 *	* 1.9121 *	* 2.0301 *	* 2.0373 *	* 1.5671 *	* 1.8773 *	* 1.6142 *	* 3.1806 *
12	* 1.3920 *	* 1.7045 *	* 1.3304 *	* 1.4669 *	* 1.0406 *	* 1.2943 *	* .9550 *	
	* 1.7882 *	* 1.4594 *	* 1.8733 *	* 1.5671 *	* 1.7983 *	* 1.5440 *	* 2.4049 *	
13	* 1.7233 *	* 1.4585 *	* 1.6940 *	* 1.2639 *	* 1.2942 *	* 1.1976 *	* .6564 *	
	* 1.4405 *	* 1.7024 *	* 1.4607 *	* 1.8773 *	* 1.5440 *	* 1.6499 *	* 3.2648 *	
14	* 1.2907 *	* 1.7104 *	* 1.6822 *	* 1.5359 *	* .9548 *	* .6564 *		
	* 1.9167 *	* 1.4436 *	* 1.4673 *	* 1.6141 *	* 2.4055 *	* 3.2646 *		
15	* .8014 *	* .9705 *	* .9125 *	* .7755 *	F-SUB-Q			
	* 3.0716 *	* 2.5373 *	* 2.7000 *	* 3.1805 *	M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8453 *	* 1.4532 *	* 1.2589 *	* 1.6359 *	* 1.3709 *	* 1.7028 *	* 1.2707 *	* .7838 *
	* 2.5187 *	* 1.7377 *	* 2.0896 *	* 1.5937 *	* 1.8921 *	* 1.5176 *	* 2.0253 *	* 3.2672 *
9	* 1.4532 *	* 1.1914 *	* 1.5491 *	* 1.2903 *	* 1.6856 *	* 1.4379 *	* 1.6938 *	* .9531 *
	* 1.7377 *	* 2.1794 *	* 1.6969 *	* 2.0252 *	* 1.5389 *	* 1.7996 *	* 1.5196 *	* 2.6920 *
10	* 1.2589 *	* 1.5486 *	* 1.0944 *	* 1.2180 *	* 1.3160 *	* 1.6829 *	* 1.6695 *	* .8982 *
	* 2.0896 *	* 1.6974 *	* 2.4103 *	* 2.1538 *	* 1.9844 *	* 1.5384 *	* 1.5453 *	* 2.8623 *
11	* 1.6359 *	* 1.2905 *	* 1.2176 *	* 1.1080 *	* 1.4696 *	* 1.2606 *	* 1.5303 *	* .7645 *
	* 1.5937 *	* 2.0248 *	* 2.1543 *	* 2.0966 *	* 1.6114 *	* 1.9382 *	* 1.6817 *	* 3.3866 *
12	* 1.3709 *	* 1.6856 *	* 1.3160 *	* 1.4696 *	* 1.0474 *	* 1.3056 *	* .9578 *	
	* 1.8921 *	* 1.5389 *	* 1.9844 *	* 1.6114 *	* 1.8550 *	* 1.5922 *	* 2.4758 *	
13	* 1.7028 *	* 1.4377 *	* 1.6830 *	* 1.2606 *	* 1.3056 *	* 1.2169 *	* .6610 *	
	* 1.5176 *	* 1.7998 *	* 1.5384 *	* 1.9382 *	* 1.5922 *	* 1.7047 *	* 3.3889 *	
14	* 1.2707 *	* 1.6938 *	* 1.6696 *	* 1.5303 *	* .9575 *	* .6610 *		
	* 2.0253 *	* 1.5195 *	* 1.5453 *	* 1.6816 *	* 2.4765 *	* 3.3886 *		
15	* .7838 *	* .9532 *	* .8983 *	* .7645 *	F-SUB-Q			
	* 3.2672 *	* 2.6914 *	* 2.8620 *	* 3.3865 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 137 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8651	* 1.4709	* 1.2549	* 1.6305	* 1.3583	* 1.6940	* 1.2578	* .7763
	* 2.6268	* 1.8069	* 2.2216	* 1.6872	* 2.0115	* 1.6053	* 2.1512	* 3.4683
9	* 1.4709	* 1.1928	* 1.5504	* 1.2813	* 1.6791	* 1.4264	* 1.6889	* .9443
	* 1.8069	* 2.2772	* 1.7943	* 2.1543	* 1.6290	* 1.9115	* 1.6063	* 2.8615
10	* 1.2549	* 1.5500	* 1.0907	* 1.2134	* 1.3127	* 1.6845	* 1.6697	* .8879
	* 2.2216	* 1.7947	* 2.5487	* 2.2838	* 2.0904	* 1.6279	* 1.6344	* 3.0545
11	* 1.6305	* 1.2816	* 1.2122	* 1.1260	* 1.5003	* 1.2763	* 1.5390	* .7589
	* 1.6872	* 2.1538	* 2.2849	* 2.1832	* 1.6712	* 2.0200	* 1.7478	* 3.6004
12	* 1.3583	* 1.6792	* 1.3127	* 1.5003	* 1.0956	* 1.3593	* .9737	*
	* 2.0115	* 1.6289	* 2.0903	* 1.6712	* 1.9288	* 1.6498	* 2.5830	*
13	* 1.6940	* 1.4262	* 1.6845	* 1.2763	* 1.3593	* 1.2762	* .6824	*
	* 1.6053	* 1.9117	* 1.6278	* 2.0200	* 1.6498	* 1.7662	* 3.5171	*
14	* 1.2578	* 1.6890	* 1.6697	* 1.5390	* .9735	* .6824	*	*
	* 2.1512	* 1.6062	* 1.6343	* 1.7477	* 2.5837	* 3.5169	*	*
15	* .7763	* .9445	* .8880	* .7589	* F-SUB-Q			
	* 3.4683	* 2.8607	* 3.0540	* 3.6002	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9412	* 1.4836	* 1.2463	* 1.6049	* 1.3384	* 1.6635	* 1.2392	* .7625
	* 2.7852	* 1.9074	* 2.3491	* 1.8258	* 2.1704	* 1.7361	* 2.3168	* 3.7455
9	* 1.4836	* 1.1949	* 1.5348	* 1.2680	* 1.6517	* 1.4063	* 1.6619	* .9361
	* 1.9074	* 2.3947	* 1.9019	* 2.3213	* 1.7626	* 2.0619	* 1.7368	* 3.0677
10	* 1.2463	* 1.5345	* 1.1008	* 1.2192	* 1.3061	* 1.6657	* 1.6482	* .8902
	* 2.3491	* 1.9023	* 2.6474	* 2.3894	* 2.2066	* 1.7270	* 1.7474	* 3.2431
11	* 1.6049	* 1.2682	* 1.2189	* 1.1597	* 1.5267	* 1.2928	* 1.5414	* .7700
	* 1.8258	* 2.3209	* 2.3900	* 2.3109	* 1.7780	* 2.1376	* 1.8354	* 3.7207
12	* 1.3384	* 1.6517	* 1.3062	* 1.5267	* 1.2281	* 1.4517	* 1.0067	*
	* 2.1704	* 1.7626	* 2.2065	* 1.7780	* 2.0464	* 1.7552	* 2.7034	*
13	* 1.6635	* 1.4061	* 1.6658	* 1.2928	* 1.4517	* 1.3482	* .7062	*
	* 1.7361	* 2.0621	* 1.7269	* 2.1376	* 1.7552	* 1.8712	* 3.7271	*
14	* 1.2392	* 1.6619	* 1.6483	* 1.5414	* 1.0064	* .7063	*	*
	* 2.3168	* 1.7367	* 1.7472	* 1.8353	* 2.7041	* 3.7268	*	*
15	* .7625	* .9362	* .8903	* .7700	* F-SUB-Q			
	* 3.7455	* 3.0664	* 3.2424	* 3.7204	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 138 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0231	* 1.5360	* 1.2571	* 1.6218	* 1.3392	* 1.6769	* 1.2379	* .7611 *
	* 2.7937	* 1.8934	* 2.3503	* 1.8312	* 2.2242	* 1.7760	* 2.4114	* 3.9256 *
9	* 1.5360	* 1.2195	* 1.5600	* 1.2708	* 1.6678	* 1.4098	* 1.6802	* .9323 *
	* 1.8934	* 2.3929	* 1.8918	* 2.3368	* 1.7821	* 2.1112	* 1.7683	* 3.1993 *
10	* 1.2571	* 1.5596	* 1.0966	* 1.2170	* 1.3181	* 1.6912	* 1.6719	* .8801 *
	* 2.3503	* 1.8923	* 2.6870	* 2.4288	* 2.2380	* 1.7472	* 1.7698	* 3.3829 *
11	* 1.6218	* 1.2712	* 1.2158	* 1.2201	* 1.5915	* 1.3305	* 1.5684	* .7608 *
	* 1.8312	* 2.3362	* 2.4312	* 2.3575	* 1.8178	* 2.1815	* 1.8710	* 3.8837 *
12	* 1.3392	* 1.6678	* 1.3181	* 1.5915	* 1.3438	* 1.5702	* 1.0310	*
	* 2.2242	* 1.7820	* 2.2380	* 1.8177	* 2.1185	* 1.8084	* 2.8007	*
13	* 1.6769	* 1.4096	* 1.6913	* 1.3305	* 1.5702	* 1.4548	* .7403	*
	* 1.7760	* 2.1114	* 1.7471	* 2.1815	* 1.8083	* 1.9427	* 3.8535	*
14	* 1.2379	* 1.6802	* 1.6720	* 1.5685	* 1.0307	* .7404	*	
	* 2.4114	* 1.7682	* 1.7697	* 1.8709	* 2.8015	* 3.8532	*	
15	* .7611	* .9325	* .8801	* .7608	* F-SUB-Q			
	* 3.9256	* 3.1988	* 3.3827	* 3.8837	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0552	* 1.5592	* 1.2590	* 1.6202	* 1.3324	* 1.6715	* 1.2307	* .7548 *
	* 2.8040	* 1.8941	* 2.3532	* 1.8316	* 2.2288	* 1.7771	* 2.4150	* 3.9389 *
9	* 1.5592	* 1.2324	* 1.5658	* 1.2677	* 1.6647	* 1.4040	* 1.6782	* .9282 *
	* 1.8941	* 2.3975	* 1.8921	* 2.3411	* 1.7839	* 2.1154	* 1.7711	* 3.2056 *
10	* 1.2590	* 1.5654	* 1.1014	* 1.2201	* 1.3207	* 1.6954	* 1.6742	* .8778 *
	* 2.3532	* 1.8926	* 2.6898	* 2.4320	* 2.2479	* 1.7521	* 1.7746	* 3.3897 *
11	* 1.6202	* 1.2681	* 1.2185	* 1.2507	* 1.6222	* 1.3504	* 1.5812	* .7625 *
	* 1.8316	* 2.3405	* 2.4352	* 2.3713	* 1.8284	* 2.1967	* 1.8787	* 3.9001 *
12	* 1.3324	* 1.6648	* 1.3207	* 1.6222	* 1.3945	* 1.6264	* 1.0520	*
	* 2.2288	* 1.7838	* 2.2478	* 1.8283	* 2.1351	* 1.8238	* 2.8199	*
13	* 1.6715	* 1.4038	* 1.6954	* 1.3504	* 1.6264	* 1.5134	* .7599	*
	* 1.7771	* 2.1156	* 1.7521	* 2.1966	* 1.8238	* 1.9602	* 3.8963	*
14	* 1.2307	* 1.6782	* 1.6743	* 1.5813	* 1.0517	* .7600	*	
	* 2.4150	* 1.7710	* 1.7745	* 1.8786	* 2.8207	* 3.8960	*	
15	* .7548	* .9284	* .8779	* .7625	* F-SUB-Q			
	* 3.9389	* 3.2051	* 3.3895	* 3.9001	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 139 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0605	* 1.5556	* 1.2520	* 1.6026	* 1.3185	* 1.6503	* 1.2180	* .7475 *
	* 2.8376	* 1.9206	* 2.3795	* 1.8570	* 2.2544	* 1.8014	* 2.4397	* 3.9747 *
9	* 1.5556	* 1.2312	* 1.5536	* 1.2585	* 1.6454	* 1.3897	* 1.6593	* .9229 *
	* 1.9206	* 2.4255	* 1.9184	* 2.3654	* 1.8087	* 2.1401	* 1.7954	* 3.2272 *
10	* 1.2520	* 1.5533	* 1.1102	* 1.2217	* 1.3134	* 1.6808	* 1.6586	* .8805 *
	* 2.3795	* 1.9189	* 2.6880	* 2.4438	* 2.2752	* 1.7768	* 1.7996	* 3.3865 *
11	* 1.6026	* 1.2588	* 1.2214	* 1.2584	* 1.6267	* 1.3513	* 1.5794	* .7716 *
	* 1.8570	* 2.3649	* 2.4444	* 2.3991	* 1.8574	* 2.2267	* 1.8985	* 3.8796 *
12	* 1.3185	* 1.6454	* 1.3134	* 1.6267	* 1.4077	* 1.6373	* 1.0671	*
	* 2.2544	* 1.8087	* 2.2751	* 1.8573	* 2.1633	* 1.8530	* 2.8291	*
13	* 1.6503	* 1.3896	* 1.6809	* 1.3513	* 1.6374	* 1.5320	* .7677	*
	* 1.8014	* 2.1403	* 1.7767	* 2.2267	* 1.8530	* 1.9842	* 3.9450	*
14	* 1.2180	* 1.6593	* 1.6587	* 1.5795	* 1.0668	* .7678	*	
	* 2.4397	* 1.7954	* 1.7995	* 1.8984	* 2.8298	* 3.9447	*	
15	* .7475	* .9231	* .8805	* .7716	* F-SUB-Q			
	* 3.9747	* 3.2267	* 3.3863	* 3.8795	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0679	* 1.5758	* 1.2552	* 1.6159	* 1.3176	* 1.6621	* 1.2164	* .7459 *
	* 2.8507	* 1.9175	* 2.3855	* 1.8492	* 2.2564	* 1.7889	* 2.4287	* 3.9466 *
9	* 1.5758	* 1.2368	* 1.5707	* 1.2578	* 1.6580	* 1.3906	* 1.6746	* .9222 *
	* 1.9175	* 2.4349	* 1.9130	* 2.3765	* 1.8012	* 2.1433	* 1.7857	* 3.2306 *
10	* 1.2552	* 1.5708	* 1.0998	* 1.2169	* 1.3173	* 1.6982	* 1.6758	* .8709 *
	* 2.3855	* 1.9134	* 2.7290	* 2.4641	* 2.2904	* 1.7721	* 1.7932	* 3.4335 *
11	* 1.6159	* 1.2582	* 1.2155	* 1.2675	* 1.6530	* 1.3603	* 1.5915	* .7605 *
	* 1.8492	* 2.3758	* 2.4669	* 2.4196	* 1.8585	* 2.2431	* 1.9074	* 3.9692 *
12	* 1.3176	* 1.6581	* 1.3174	* 1.6531	* 1.4227	* 1.6669	* 1.0661	*
	* 2.2564	* 1.8012	* 2.2903	* 1.8584	* 2.1767	* 1.8515	* 2.8739	*
13	* 1.6621	* 1.3905	* 1.6983	* 1.3603	* 1.6669	* 1.5575	* .7784	*
	* 1.7889	* 2.1435	* 1.7720	* 2.2431	* 1.8515	* 1.9882	* 3.9561	*
14	* 1.2164	* 1.6747	* 1.6759	* 1.5916	* 1.0658	* .7785	*	
	* 2.4287	* 1.7857	* 1.7931	* 1.9073	* 2.8747	* 3.9557	*	
15	* .7459	* .9223	* .8709	* .7605	* F-SUB-Q			
	* 3.9466	* 3.2301	* 3.4333	* 3.9691	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 140 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0641	* 1.5799	* 1.2537	* 1.6158	* 1.3117	* 1.6606	* 1.2109	* .7397 *
	* 2.7117	* 1.8245	* 2.2811	* 1.7775	* 2.1737	* 1.7264	* 2.3459	* 3.8058 *
9	* 1.5799	* 1.2350	* 1.5737	* 1.2533	* 1.6571	* 1.3854	* 1.6753	* .9178 *
	* 1.8245	* 2.3190	* 1.8267	* 2.2802	* 1.7383	* 2.0681	* 1.7305	* 3.1067 *
10	* 1.2537	* 1.5737	* 1.0938	* 1.2130	* 1.3148	* 1.7002	* 1.6779	* .8646 *
	* 2.2811	* 1.8266	* 2.6116	* 2.3535	* 2.2083	* 1.7194	* 1.7408	* 3.3166 *
11	* 1.6158	* 1.2537	* 1.2117	* 1.2679	* 1.6594	* 1.3595	* 1.5938	* .7559 *
	* 1.7775	* 2.2795	* 2.3556	* 2.3162	* 1.7905	* 2.1610	* 1.8401	* 3.8193 *
12	* 1.3117	* 1.6571	* 1.3149	* 1.6595	* 1.4251	* 1.6749	* 1.0655	*
	* 2.1737	* 1.7382	* 2.2083	* 1.7904	* 2.0986	* 1.7889	* 2.7630	*
13	* 1.6606	* 1.3853	* 1.7004	* 1.3596	* 1.6749	* 1.5659	* .7793	*
	* 1.7264	* 2.0683	* 1.7193	* 2.1609	* 1.7889	* 1.9178	* 3.7845	*
14	* 1.2109	* 1.6753	* 1.6780	* 1.5939	* 1.0652	* .7794	*	
	* 2.3459	* 1.7305	* 1.7407	* 1.8399	* 2.7638	* 3.7841	*	
15	* .7397	* .9180	* .8647	* .7559	* F-SUB-Q			
	* 3.8058	* 3.1061	* 3.3165	* 3.8192	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0620	* 1.5785	* 1.2508	* 1.6118	* 1.3053	* 1.6551	* 1.2052	* .7367 *
	* 2.5211	* 1.6934	* 2.1201	* 1.6469	* 2.0222	* 1.6056	* 2.1852	* 3.5403 *
9	* 1.5785	* 1.2318	* 1.5716	* 1.2484	* 1.6520	* 1.3791	* 1.6704	* .9147 *
	* 1.6934	* 2.1559	* 1.6954	* 2.1157	* 1.6132	* 1.9231	* 1.6064	* 2.8847 *
10	* 1.2508	* 1.5716	* 1.0943	* 1.2121	* 1.3097	* 1.6961	* 1.6735	* .8645 *
	* 2.1201	* 1.6954	* 2.4197	* 2.1825	* 2.0549	* 1.5977	* 1.6181	* 3.0656 *
11	* 1.6118	* 1.2488	* 1.2108	* 1.2656	* 1.6577	* 1.3553	* 1.5919	* .7556 *
	* 1.6469	* 2.1150	* 2.1846	* 2.1495	* 1.6616	* 2.0088	* 1.7081	* 3.5425 *
12	* 1.3053	* 1.6521	* 1.3098	* 1.6577	* 1.4229	* 1.6737	* 1.0667	*
	* 2.0222	* 1.6131	* 2.0548	* 1.6615	* 1.9457	* 1.6568	* 2.5566	*
13	* 1.6551	* 1.3790	* 1.6963	* 1.3553	* 1.6737	* 1.5668	* .7789	*
	* 1.6056	* 1.9233	* 1.5975	* 2.0088	* 1.6568	* 1.7738	* 3.5069	*
14	* 1.2052	* 1.6705	* 1.6736	* 1.5921	* 1.0664	* .7789	*	
	* 2.1852	* 1.6064	* 1.6179	* 1.7080	* 2.5574	* 3.5066	*	
15	* .7367	* .9149	* .8645	* .7556	* F-SUB-Q			
	* 3.5403	* 2.8842	* 3.0655	* 3.5424	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 141 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0579	* 1.5693	* 1.2459	* 1.6007	* 1.2980	* 1.6426	* 1.1990	* .7331 *
	* 2.3622	* 1.5897	* 1.9828	* 1.5457	* 1.8974	* 1.5092	* 2.0510	* 3.3248 *
9	* 1.5693	* 1.2273	* 1.5621	* 1.2437	* 1.6399	* 1.3712	* 1.6577	* .9151 *
	* 1.5897	* 2.0207	* 1.5898	* 1.9791	* 1.5144	* 1.8037	* 1.5076	* 2.6915 *
10	* 1.2459	* 1.5621	* 1.1041	* 1.2141	* 1.3035	* 1.6843	* 1.6613	* .8705 *
	* 1.9828	* 1.5901	* 2.2367	* 2.0298	* 1.9229	* 1.4960	* 1.5146	* 2.8379 *
11	* 1.6007	* 1.2441	* 1.2125	* 1.2614	* 1.6471	* 1.3484	* 1.5871	* .7655 *
	* 1.5457	* 1.9785	* 2.0321	* 2.0108	* 1.5593	* 1.8823	* 1.5972	* 3.2553 *
12	* 1.2980	* 1.6400	* 1.3036	* 1.6471	* 1.4178	* 1.6629	* 1.0722	* .7765 *
	* 1.8974	* 1.5143	* 1.9228	* 1.5592	* 1.8196	* 1.5534	* 2.3731	* .7764 *
13	* 1.6426	* 1.3711	* 1.6844	* 1.3485	* 1.6629	* 1.5619	* 1.6572	* 3.2817 *
	* 1.5092	* 1.8039	* 1.4959	* 1.8823	* 1.5534	* 1.6572	* 3.2817 *	
14	* 1.1990	* 1.6578	* 1.6614	* 1.5872	* 1.0719	* .7765		
	* 2.0510	* 1.5075	* 1.5145	* 1.5971	* 2.3738	* 3.2814		
15	* .7331	* .9153	* .8706	* .7656	* F-SUB-Q			
	* 3.3248	* 2.6911	* 2.8377	* 3.2553	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0674	* 1.5959	* 1.2565	* 1.6266	* 1.3072	* 1.6686	* 1.2069	* .7378 *
	* 2.1891	* 1.4657	* 1.8481	* 1.4316	* 1.7744	* 1.3989	* 1.9200	* 3.1144 *
9	* 1.5959	* 1.2366	* 1.5882	* 1.2512	* 1.6659	* 1.3826	* 1.6856	* .9182 *
	* 1.4657	* 1.8800	* 1.4685	* 1.8513	* 1.4027	* 1.6837	* 1.3938	* 2.5239 *
10	* 1.2565	* 1.5883	* 1.0956	* 1.2165	* 1.3130	* 1.7122	* 1.6892	* .8640 *
	* 1.8481	* 1.4685	* 2.1170	* 1.9039	* 1.7909	* 1.3805	* 1.3978	* 2.6892 *
11	* 1.6266	* 1.2516	* 1.2154	* 1.2707	* 1.6740	* 1.3599	* 1.6053	* .7547 *
	* 1.4316	* 1.8506	* 1.9053	* 1.8698	* 1.4374	* 1.7478	* 1.4782	* 3.0971 *
12	* 1.3072	* 1.6659	* 1.3131	* 1.6741	* 1.4311	* 1.6907	* 1.0689	* .7837 *
	* 1.7744	* 1.4027	* 1.7909	* 1.4373	* 1.6822	* 1.4289	* 2.2317	* .7836 *
13	* 1.6686	* 1.3825	* 1.7124	* 1.3600	* 1.6907	* 1.5824	* 1.5271	* 3.0504 *
	* 1.3989	* 1.6839	* 1.3804	* 1.7477	* 1.4289	* 1.5271	* 3.0504	
14	* 1.2069	* 1.6857	* 1.6894	* 1.6054	* 1.0686	* .7837		
	* 1.9200	* 1.3937	* 1.3977	* 1.4781	* 2.2324	* 3.0501		
15	* .7378	* .9184	* .8640	* .7547	* F-SUB-Q			
	* 3.1144	* 2.5234	* 2.6890	* 3.0970	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 142 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0729	* 1.6082	* 1.2637	* 1.6385	* 1.3138	* 1.6802	* 1.2126	* .7411 *
	* 2.0456	* 1.3729	* 1.7414	* 1.3516	* 1.6802	* 1.3213	* 1.8188	* 2.9530 *
9	* 1.6082	* 1.2435	* 1.6004	* 1.2577	* 1.6776	* 1.3902	* 1.6976	* .9235 *
	* 1.3729	* 1.7685	* 1.3800	* 1.7520	* 1.3241	* 1.5928	* 1.3144	* 2.3869 *
10	* 1.2637	* 1.6004	* 1.1020	* 1.2242	* 1.3201	* 1.7246	* 1.7014	* .8680 *
	* 1.7414	* 1.3799	* 1.9954	* 1.7977	* 1.6892	* 1.2998	* 1.3165	* 2.5446 *
11	* 1.6385	* 1.2582	* 1.2233	* 1.2779	* 1.6862	* 1.3674	* 1.6164	* .7580 *
	* 1.3516	* 1.7513	* 1.7989	* 1.7436	* 1.3327	* 1.6363	* 1.3884	* 2.9252 *
12	* 1.3138	* 1.6777	* 1.3201	* 1.6863	* 1.4402	* 1.7029	* 1.0743	*
	* 1.6802	* 1.3241	* 1.6891	* 1.3327	* 1.5569	* 1.3229	* 2.0827	*
13	* 1.6802	* 1.3901	* 1.7248	* 1.3675	* 1.7030	* 1.5935	* .7870	*
	* 1.3213	* 1.5930	* 1.2997	* 1.6363	* 1.3229	* 1.4142	* 2.8400	*
14	* 1.2126	* 1.6977	* 1.7015	* 1.6165	* 1.0740	* .7871	*	
	* 1.8188	* 1.3144	* 1.3164	* 1.3883	* 2.0834	* 2.8397	*	
15	* .7411	* .9237	* .8680	* .7580	* F-SUB-Q			
	* 2.9530	* 2.3863	* 2.5444	* 2.9251	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0684	* 1.5969	* 1.2628	* 1.6269	* 1.3126	* 1.6678	* 1.2113	* .7383 *
	* 1.9429	* 1.3072	* 1.6493	* 1.2896	* 1.6003	* 1.2656	* 1.7384	* 2.8428 *
9	* 1.5969	* 1.2438	* 1.5894	* 1.2592	* 1.6658	* 1.3882	* 1.6840	* .9266 *
	* 1.3072	* 1.6734	* 1.3141	* 1.6607	* 1.2655	* 1.5176	* 1.2593	* 2.2733 *
10	* 1.2628	* 1.5894	* 1.1215	* 1.2340	* 1.3202	* 1.7117	* 1.6878	* .8806 *
	* 1.6493	* 1.3140	* 1.8563	* 1.6889	* 1.5982	* 1.2398	* 1.2579	* 2.3939 *
11	* 1.6269	* 1.2596	* 1.2328	* 1.2785	* 1.6745	* 1.3657	* 1.6131	* .7735 *
	* 1.2896	* 1.6602	* 1.6905	* 1.6475	* 1.2670	* 1.5487	* 1.3153	* 2.7269 *
12	* 1.3126	* 1.6658	* 1.3202	* 1.6745	* 1.4394	* 1.6904	* 1.0857	*
	* 1.6003	* 1.2655	* 1.5981	* 1.2670	* 1.4708	* 1.2581	* 1.9495	*
13	* 1.6678	* 1.3881	* 1.7118	* 1.3657	* 1.6904	* 1.5873	* .7830	*
	* 1.2656	* 1.5177	* 1.2398	* 1.5487	* 1.2580	* 1.3408	* 2.7017	*
14	* 1.2113	* 1.6841	* 1.6880	* 1.6133	* 1.0854	* .7831	*	
	* 1.7384	* 1.2593	* 1.2578	* 1.3152	* 1.9501	* 2.7014	*	
15	* .7383	* .9268	* .8806	* .7735	* F-SUB-Q			
	* 2.8428	* 2.2728	* 2.3938	* 2.7268	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 143 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0666	* 1.6030	* 1.2642	* 1.6324	* 1.3139	* 1.6734	* 1.2105	* .7361
	* 1.8643	* 1.2461	* 1.5775	* 1.2300	* 1.5308	* 1.2066	* 1.6661	* 2.7350
9	* 1.6030	* 1.2445	* 1.5958	* 1.2588	* 1.6718	* 1.3920	* 1.6904	* .9224
	* 1.2461	* 1.6013	* 1.2526	* 1.5909	* 1.2061	* 1.4487	* 1.1999	* 2.1892
10	* 1.2642	* 1.5959	* 1.1086	* 1.2308	* 1.3236	* 1.7169	* 1.6935	* .8679
	* 1.5775	* 1.2525	* 1.7989	* 1.6224	* 1.5247	* 1.1817	* 1.1989	* 2.3278
11	* 1.6324	* 1.2592	* 1.2302	* 1.2803	* 1.6817	* 1.3694	* 1.6091	* .7584
	* 1.2300	* 1.5903	* 1.6232	* 1.5744	* 1.2059	* 1.4777	* 1.2613	* 2.6661
12	* 1.3139	* 1.6719	* 1.3236	* 1.6818	* 1.4426	* 1.6984	* 1.0725	*
	* 1.5308	* 1.2061	* 1.5246	* 1.2059	* 1.4034	* 1.1968	* 1.8891	*
13	* 1.6734	* 1.3919	* 1.7170	* 1.3695	* 1.6984	* 1.5860	* .7812	*
	* 1.2066	* 1.4489	* 1.1816	* 1.4777	* 1.1968	* 1.2828	* 2.5938	*
14	* 1.2105	* 1.6904	* 1.6936	* 1.6092	* 1.0722	* .7813	*	*
	* 1.6661	* 1.1999	* 1.1988	* 1.2612	* 1.8897	* 2.5936	*	*
15	* .7361	* .9226	* .8679	* .7584	* F-SUB-Q			
	* 2.7350	* 2.1888	* 2.3277	* 2.6660	* M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0221	* 1.5221	* 1.2144	* 1.5457	* 1.2601	* 1.5859	* 1.1603	* .7026
	* 1.8842	* 1.2694	* 1.5904	* 1.2568	* 1.5450	* 1.2315	* 1.6834	* 2.7798
9	* 1.5221	* 1.1960	* 1.5128	* 1.2086	* 1.5861	* 1.3393	* 1.6046	* .8806
	* 1.2694	* 1.6138	* 1.2786	* 1.6044	* 1.2298	* 1.4570	* 1.2228	* 2.2230
10	* 1.2144	* 1.5130	* 1.0694	* 1.1910	* 1.2788	* 1.6261	* 1.6057	* .8288
	* 1.5904	* 1.2784	* 1.8062	* 1.6254	* 1.5269	* 1.2064	* 1.2226	* 2.3633
11	* 1.5457	* 1.2091	* 1.1898	* 1.2330	* 1.5981	* 1.3198	* 1.5267	* .7263
	* 1.2568	* 1.6038	* 1.6270	* 1.5820	* 1.2267	* 1.4835	* 1.2862	* 2.7001
12	* 1.2601	* 1.5861	* 1.2789	* 1.5981	* 1.3879	* 1.6161	* 1.0216	*
	* 1.5450	* 1.2298	* 1.5269	* 1.2267	* 1.4108	* 1.2161	* 1.9210	*
13	* 1.5859	* 1.3391	* 1.6262	* 1.3198	* 1.6161	* 1.5045	* .7464	*
	* 1.2315	* 1.4572	* 1.2063	* 1.4834	* 1.2160	* 1.3081	* 2.6314	*
14	* 1.1603	* 1.6046	* 1.6058	* 1.5268	* 1.0213	* .7465	*	*
	* 1.6834	* 1.2228	* 1.2225	* 1.2861	* 1.9216	* 2.6312	*	*
15	* .7026	* .8808	* .8289	* .7263	* F-SUB-Q			
	* 2.7798	* 2.2226	* 2.3633	* 2.7001	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 144 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 460 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9012 *	* 1.3009 *	* 1.0259 *	* 1.3194 *	* 1.0625 *	* 1.3517 *	* .9747 *	* .6074 *
	* 2.0903 *	* 1.4508 *	* 1.8391 *	* 1.4374 *	* 1.7892 *	* 1.4101 *	* 1.9584 *	* 3.1498 *
9	* 1.3009 *	* 1.0120 *	* 1.2931 *	* 1.0209 *	* 1.3535 *	* 1.1503 *	* 1.3613 *	* .7514 *
	* 1.4508 *	* 1.8633 *	* 1.4611 *	* 1.8554 *	* 1.4065 *	* 1.6565 *	* 1.4058 *	* 2.5501 *
10	* 1.0259 *	* 1.2934 *	* .9599 *	* 1.0527 *	* 1.1284 *	* 1.3808 *	* 1.3547 *	* .7146 *
	* 1.8391 *	* 1.4607 *	* 1.9680 *	* 1.7976 *	* 1.6899 *	* 1.3860 *	* 1.4145 *	* 2.6824 *
11	* 1.3194 *	* 1.0212 *	* 1.0520 *	* 1.0560 *	* 1.3664 *	* 1.1365 *	* 1.2938 *	* .6223 *
	* 1.4374 *	* 1.8549 *	* 1.7995 *	* 1.8036 *	* 1.3999 *	* 1.6820 *	* 1.4826 *	* 3.0844 *
12	* 1.0625 *	* 1.3535 *	* 1.1284 *	* 1.3664 *	* 1.2161 *	* 1.3736 *	* .8728 *	
	* 1.7892 *	* 1.4065 *	* 1.6899 *	* 1.3999 *	* 1.5711 *	* 1.3958 *	* 2.1980 *	
13	* 1.3517 *	* 1.1502 *	* 1.3808 *	* 1.1365 *	* 1.3736 *	* 1.2766 *	* .6430 *	
	* 1.4101 *	* 1.6567 *	* 1.3859 *	* 1.6820 *	* 1.3958 *	* 1.5063 *	* 2.9894 *	
14	* .9747 *	* 1.3613 *	* 1.3548 *	* 1.2938 *	* .8725 *	* .6430 *		
	* 1.9584 *	* 1.4058 *	* 1.4144 *	* 1.4826 *	* 2.1985 *	* 2.9894 *		
15	* .6074 *	* .7515 *	* .7145 *	* .6223 *	F-SUB-Q			
	* 3.1498 *	* 2.5498 *	* 2.6825 *	* 3.0844 *	M-SUB-Q			

AT 75% POWER, 460 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6757 *	* .6257 *	* .5362 *	* .6345 *	* .5537 *	* .6476 *	* .5181 *	* .4597 *
	* 2.7437 *	* 2.9625 *	* 3.4587 *	* 2.9344 *	* 3.3736 *	* 2.8888 *	* 3.6219 *	* 4.1017 *
9	* .6257 *	* .5312 *	* .6214 *	* .5367 *	* .6504 *	* .5770 *	* .6188 *	* .4085 *
	* 2.9625 *	* 3.4887 *	* 2.9859 *	* 3.4723 *	* 2.8750 *	* 3.2438 *	* 3.0366 *	* 4.6185 *
10	* .5362 *	* .6216 *	* .5464 *	* .5371 *	* .5702 *	* .6571 *	* .6324 *	* .3955 *
	* 3.4587 *	* 2.9848 *	* 3.3984 *	* 3.4740 *	* 3.2850 *	* 2.8523 *	* 2.9734 *	* 4.7700 *
11	* .6345 *	* .5368 *	* .5370 *	* .5586 *	* .6541 *	* .5723 *	* .5962 *	* .3501 *
	* 2.9344 *	* 3.4713 *	* 3.4745 *	* 3.3552 *	* 2.8700 *	* 3.2803 *	* 3.1583 *	* 5.3984 *
12	* .5537 *	* .6504 *	* .5702 *	* .6541 *	* .6052 *	* .6292 *	* .4606 *	
	* 3.3736 *	* 2.8750 *	* 3.2851 *	* 2.8700 *	* 3.1007 *	* 2.9919 *	* 4.0950 *	
13	* .6476 *	* .5769 *	* .6571 *	* .5723 *	* .6292 *	* .5877 *	* .4898 *	
	* 2.8888 *	* 3.2441 *	* 2.8523 *	* 3.2803 *	* 2.9919 *	* 3.2103 *	* 3.8635 *	
14	* .5181 *	* .6188 *	* .6324 *	* .5962 *	* .4606 *	* .4897 *		
	* 3.6219 *	* 3.0367 *	* 2.9733 *	* 3.1582 *	* 4.0946 *	* 3.8639 *		
15	* .4597 *	* .4085 *	* .3955 *	* .3501 *	F-SUB-Q			
	* 4.1017 *	* 4.6184 *	* 4.7702 *	* 5.3985 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 145 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6235 *	* .5824 *	* .5514 *	* .6327 *	* .5600 *	* .6136 *	* .4968 *	* .4082 *
	* 3.1911 *	* 3.9753 *	* 4.2121 *	* 3.6657 *	* 4.1425 *	* 3.7658 *	* 4.6386 *	* 5.6099 *
9	* .5824 *	* .5400 *	* .6187 *	* .5550 *	* .6242 *	* .5645 *	* .5365 *	* .3394 *
	* 3.9754 *	* 4.2991 *	* 3.7483 *	* 4.1793 *	* 3.7089 *	* 4.0975 *	* 4.2790 *	* 6.7342 *
10	* .5514 *	* .6187 *	* .5582 *	* .5233 *	* .5354 *	* .5825 *	* .5366 *	* .3218 *
	* 4.2121 *	* 3.7485 *	* 4.1614 *	* 4.4187 *	* 4.3015 *	* 3.9360 *	* 4.2624 *	* 7.0924 *
11	* .6327 *	* .5551 *	* .5223 *	* .4588 *	* .5118 *	* .4810 *	* .4625 *	* .2707 *
	* 3.6657 *	* 4.1787 *	* 4.4270 *	* 4.5339 *	* 4.0368 *	* 4.5294 *	* 4.9063 *	* 8.3438 *
12	* .5600 *	* .6240 *	* .5353 *	* .5116 *	* .3902 *	* .3862 *	* .3300 *	
	* 4.1425 *	* 3.7096 *	* 4.3024 *	* 4.0371 *	* 4.2593 *	* 4.2832 *	* 5.9979 *	
13	* .6136 *	* .5645 *	* .5824 *	* .4809 *	* .3862 *	* .3327 *	* .3269 *	
	* 3.7658 *	* 4.0980 *	* 3.9366 *	* 4.5298 *	* 4.2835 *	* 4.7019 *	* 5.3963 *	
14	* .4968 *	* .5367 *	* .5367 *	* .4625 *	* .3301 *	* .3267 *		
	* 4.6386 *	* 4.2771 *	* 4.2620 *	* 4.9067 *	* 5.9950 *	* 5.3983 *		
15	* .4082 *	* .3396 *	* .3220 *	* .2707 *	F-SUB-Q			
	* 5.6099 *	* 6.7289 *	* 7.0898 *	* 8.3439 *	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7889 *	* 1.3062 *	* 1.1253 *	* 1.4011 *	* 1.1413 *	* 1.3643 *	* 1.0095 *	* .5606 *
	* 2.5143 *	* 1.8239 *	* 2.1394 *	* 1.7192 *	* 2.1089 *	* 1.7598 *	* 2.3710 *	* 4.2258 *
9	* 1.3062 *	* 1.1009 *	* 1.4137 *	* 1.1269 *	* 1.3872 *	* 1.1833 *	* 1.3084 *	* .7093 *
	* 1.8239 *	* 2.1874 *	* 1.7022 *	* 2.1343 *	* 1.7308 *	* 2.0302 *	* 1.8223 *	* 3.3384 *
10	* 1.1253 *	* 1.4131 *	* 1.1031 *	* 1.1496 *	* 1.1519 *	* 1.2769 *	* 1.2579 *	* .6691 *
	* 2.1394 *	* 1.7031 *	* 2.1771 *	* 2.0860 *	* 2.0747 *	* 1.8633 *	* 1.8830 *	* 3.5308 *
11	* 1.4011 *	* 1.1263 *	* 1.1468 *	* .9776 *	* 1.1349 *	* 1.0048 *	* 1.1236 *	* .5594 *
	* 1.7192 *	* 2.1353 *	* 2.0910 *	* 2.2995 *	* 1.8895 *	* 2.2101 *	* 2.0887 *	* 4.1804 *
12	* 1.1413 *	* 1.3867 *	* 1.1512 *	* 1.1345 *	* .8257 *	* .9407 *	* .6940 *	
	* 2.1089 *	* 1.7312 *	* 2.0755 *	* 1.8898 *	* 2.0001 *	* 1.8176 *	* 2.9552 *	
13	* 1.3643 *	* 1.1832 *	* 1.2766 *	* 1.0045 *	* .9406 *	* .8401 *	* .4461 *	
	* 1.7598 *	* 2.0305 *	* 1.8637 *	* 2.2103 *	* 1.8177 *	* 1.9886 *	* 4.0913 *	
14	* 1.0095 *	* 1.3087 *	* 1.2580 *	* 1.1235 *	* .6939 *	* .4461 *		
	* 2.3710 *	* 1.8218 *	* 1.8829 *	* 2.0889 *	* 2.9558 *	* 4.0916 *		
15	* .5606 *	* .7096 *	* .6693 *	* .5594 *	F-SUB-Q			
	* 4.2257 *	* 3.3368 *	* 3.5300 *	* 4.1805 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 146 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8548	* 1.3802	* 1.3119	* 1.4615	* 1.3203	* 1.4376	* 1.1422	* .6392
	* 2.3575	* 1.7967	* 1.8883	* 1.6928	* 1.8699	* 1.7150	* 2.1529	* 3.8033
9	* 1.3802	* 1.2726	* 1.4548	* 1.3177	* 1.4531	* 1.3470	* 1.4027	* .7968
	* 1.7967	* 1.9457	* 1.7026	* 1.8757	* 1.6985	* 1.8248	* 1.7457	* 3.0476
10	* 1.3119	* 1.4526	* 1.2460	* 1.3741	* 1.3376	* 1.3706	* 1.3204	* .7440
	* 1.8883	* 1.7050	* 1.9842	* 1.7942	* 1.8353	* 1.7882	* 1.8475	* 3.2556
11	* 1.4615	* 1.3168	* 1.3702	* 1.1807	* 1.2676	* 1.1248	* 1.2831	* .6348
	* 1.6928	* 1.8769	* 1.7992	* 2.0663	* 1.8024	* 2.0005	* 1.8697	* 3.7885
12	* 1.3203	* 1.4527	* 1.3366	* 1.2668	* .9394	* 1.0070	* .8137	*
	* 1.8699	* 1.6989	* 1.8366	* 1.8024	* 1.8060	* 1.8083	* 2.6057	*
13	* 1.4376	* 1.3468	* 1.3702	* 1.1244	* 1.0068	* .9794	* .5059	*
	* 1.7150	* 1.8252	* 1.7887	* 2.0008	* 1.8084	* 1.7683	* 3.7355	*
14	* 1.1422	* 1.4029	* 1.3203	* 1.2829	* .8134	* .5058	*	*
	* 2.1529	* 1.7456	* 1.8476	* 1.8700	* 2.6063	* 3.7355	*	*
15	* .6392	* .7970	* .7441	* .6348	* F-SUB-Q			
	* 3.8033	* 3.0468	* 3.2552	* 3.7888	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9025	* 1.4853	* 1.4248	* 1.5716	* 1.4331	* 1.5448	* 1.2399	* .6779
	* 2.3575	* 1.7320	* 1.7972	* 1.6269	* 1.7794	* 1.6486	* 2.0395	* 3.6856
9	* 1.4853	* 1.3809	* 1.5717	* 1.4380	* 1.5627	* 1.4420	* 1.5124	* .8297
	* 1.7320	* 1.8575	* 1.6291	* 1.7772	* 1.6324	* 1.7601	* 1.6745	* 3.0223
10	* 1.4248	* 1.5690	* 1.3045	* 1.4872	* 1.4290	* 1.4680	* 1.4041	* .7589
	* 1.7972	* 1.6319	* 1.9591	* 1.7114	* 1.7750	* 1.7279	* 1.7987	* 3.2556
11	* 1.5716	* 1.4363	* 1.4826	* 1.2988	* 1.3802	* 1.2040	* 1.3942	* .6525
	* 1.6269	* 1.7781	* 1.7166	* 1.9531	* 1.7384	* 1.9390	* 1.7742	* 3.7885
12	* 1.4331	* 1.5622	* 1.4278	* 1.3793	* 1.0139	* 1.0983	* .8687	*
	* 1.7794	* 1.6329	* 1.7765	* 1.7384	* 1.7615	* 1.7433	* 2.5454	*
13	* 1.5448	* 1.4417	* 1.4674	* 1.2037	* 1.0980	* 1.0846	* .5419	*
	* 1.6486	* 1.7605	* 1.7285	* 1.9393	* 1.7435	* 1.6787	* 3.6527	*
14	* 1.2399	* 1.5124	* 1.4039	* 1.3939	* .8683	* .5418	*	*
	* 2.0395	* 1.6744	* 1.7990	* 1.7745	* 2.5466	* 3.6527	*	*
15	* .6779	* .8298	* .7590	* .6524	* F-SUB-Q			
	* 3.6856	* 3.0218	* 3.2552	* 3.7888	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 147 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9149	* 1.5243	* 1.4482	* 1.6151	* 1.4768	* 1.5874	* 1.2637	* .6798
	* 2.4973	* 1.7687	* 1.8507	* 1.6562	* 1.8051	* 1.6757	* 2.0911	* 3.8405
9	* 1.5243	* 1.3984	* 1.6130	* 1.4627	* 1.6062	* 1.4749	* 1.5535	* .8364
	* 1.7687	* 1.9205	* 1.6603	* 1.8281	* 1.6598	* 1.7965	* 1.7009	* 3.1299
10	* 1.4482	* 1.6102	* 1.3207	* 1.5154	* 1.4544	* 1.5074	* 1.4455	* .7655
	* 1.8507	* 1.6633	* 2.0242	* 1.7565	* 1.8239	* 1.7559	* 1.8211	* 3.4125
11	* 1.6151	* 1.4614	* 1.5106	* 1.3355	* 1.4231	* 1.2355	* 1.4432	* .6592
	* 1.6562	* 1.8297	* 1.7621	* 1.9889	* 1.7702	* 1.9834	* 1.7994	* 3.9315
12	* 1.4768	* 1.6057	* 1.4530	* 1.4221	* 1.0511	* 1.1414	* .8961	*
	* 1.8051	* 1.6603	* 1.8255	* 1.7702	* 1.8074	* 1.7750	* 2.6035	*
13	* 1.5874	* 1.4745	* 1.5068	* 1.2351	* 1.1411	* 1.1405	* .5561	*
	* 1.6757	* 1.7970	* 1.7566	* 1.9838	* 1.7752	* 1.6952	* 3.7731	*
14	* 1.2637	* 1.5534	* 1.4452	* 1.4428	* .8955	* .5561	*	*
	* 2.0911	* 1.7010	* 1.8215	* 1.7998	* 2.6049	* 3.7732	*	*
15	* .6798	* .8365	* .7654	* .6590	* F-SUB-Q			
	* 3.8405	* 3.1296	* 3.4126	* 3.9324	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9186	* 1.5375	* 1.4550	* 1.6307	* 1.4868	* 1.6035	* 1.2692	* .6792
	* 2.6375	* 1.8565	* 1.9450	* 1.7249	* 1.8859	* 1.7426	* 2.1820	* 4.0313
9	* 1.5375	* 1.4012	* 1.6255	* 1.4683	* 1.6223	* 1.4885	* 1.5708	* .8382
	* 1.8565	* 2.0287	* 1.7385	* 1.9167	* 1.7280	* 1.8705	* 1.7645	* 3.2791
10	* 1.4550	* 1.6226	* 1.3265	* 1.5226	* 1.4638	* 1.5253	* 1.4663	* .7718
	* 1.9450	* 1.7416	* 2.1281	* 1.8440	* 1.9095	* 1.8286	* 1.8908	* 3.5612
11	* 1.6307	* 1.4672	* 1.5176	* 1.3472	* 1.4420	* 1.2548	* 1.4703	* .6655
	* 1.7249	* 1.9175	* 1.8500	* 2.0815	* 1.8497	* 2.0759	* 1.8675	* 4.1224
12	* 1.4868	* 1.6218	* 1.4623	* 1.4409	* 1.0725	* 1.1671	* .9166	*
	* 1.8859	* 1.7285	* 1.9113	* 1.8498	* 1.8949	* 1.8582	* 2.7180	*
13	* 1.6035	* 1.4881	* 1.5245	* 1.2543	* 1.1667	* 1.1767	* .5683	*
	* 1.7426	* 1.8710	* 1.8295	* 2.0764	* 1.8584	* 1.7695	* 3.9789	*
14	* 1.2692	* 1.5707	* 1.4659	* .9161	* .5683	*		*
	* 2.1820	* 1.7647	* 1.8913	* 1.8679	* 2.7193	* 3.9790	*	*
15	* .6792	* .8382	* .7717	* .6653	* F-SUB-Q			
	* 4.0313	* 3.2790	* 3.5616	* 4.1235	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 148 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9281	* 1.5655	* 1.4724	* 1.6593	* 1.5044	* 1.6333	* 1.2827	* .6847
	* 2.7712	* 1.9544	* 2.0598	* 1.8146	* 1.9954	* 1.8293	* 2.3051	* 4.2745
9	* 1.5655	* 1.4155	* 1.6533	* 1.4848	* 1.6520	* 1.5134	* 1.6018	* .8481
	* 1.9544	* 2.1530	* 1.8313	* 2.0302	* 1.8164	* 1.9682	* 1.8492	* 3.4651
10	* 1.4724	* 1.6502	* 1.3332	* 1.5429	* 1.4862	* 1.5582	* 1.4997	* .7752
	* 2.0598	* 1.8347	* 2.2711	* 1.9523	* 2.0203	* 1.9199	* 1.9817	* 3.7966
11	* 1.6593	* 1.4836	* 1.5378	* 1.3692	* 1.4765	* 1.2873	* 1.5134	* .6726
	* 1.8146	* 2.0311	* 1.9588	* 2.2036	* 1.9336	* 2.1744	* 1.9306	* 4.3923
12	* 1.5044	* 1.6514	* 1.4847	* 1.4754	* 1.1002	* 1.2083	* .9381	*
	* 1.9954	* 1.8170	* 2.0223	* 1.9338	* 1.9853	* 1.9376	* 2.8670	*
13	* 1.6333	* 1.5129	* 1.5574	* 1.2867	* 1.2080	* 1.2290	* .5895	*
	* 1.8293	* 1.9688	* 1.9208	* 2.1749	* 1.9379	* 1.8421	* 4.1689	*
14	* 1.2827	* 1.6015	* 1.4993	* 1.5128	* .9374	* .5895	*	*
	* 2.3051	* 1.8495	* 1.9823	* 1.9311	* 2.8688	* 4.1690	*	*
15	* .6847	* .8480	* .7751	* .6723	* F-SUB-Q			
	* 4.2745	* 3.4651	* 3.7971	* 4.3936	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9331	* 1.5877	* 1.4864	* 1.6775	* 1.5172	* 1.6523	* 1.2925	* .6831
	* 2.9895	* 2.1059	* 2.2309	* 1.9570	* 2.1579	* 1.9656	* 2.4808	* 4.6362
9	* 1.5877	* 1.4284	* 1.6723	* 1.4975	* 1.6713	* 1.5307	* 1.6242	* .8512
	* 2.1059	* 2.3366	* 1.9788	* 2.1979	* 1.9559	* 2.1154	* 1.9793	* 3.7360
10	* 1.4864	* 1.6692	* 1.3415	* 1.5606	* 1.5068	* 1.5833	* 1.5253	* .7795
	* 2.2309	* 1.9825	* 2.4715	* 2.1144	* 2.1844	* 2.0600	* 2.1178	* 4.0865
11	* 1.6775	* 1.4963	* 1.5553	* 1.3926	* 1.5098	* 1.3205	* 1.5524	* .6795
	* 1.9570	* 2.1989	* 2.1216	* 2.3491	* 2.0396	* 2.2941	* 2.0345	* 4.7185
12	* 1.5172	* 1.6707	* 1.5052	* 1.5087	* 1.1365	* 1.2529	* .9668	*
	* 2.1579	* 1.9565	* 2.1866	* 2.0397	* 2.1013	* 2.0491	* 3.0301	*
13	* 1.6523	* 1.5302	* 1.5825	* 1.3199	* 1.2525	* 1.2893	* .6106	*
	* 1.9656	* 2.1161	* 2.0610	* 2.2947	* 2.0495	* 1.9542	* 4.4618	*
14	* 1.2925	* 1.6238	* 1.5248	* 1.5518	* .9661	* .6105	*	*
	* 2.4808	* 1.9798	* 2.1185	* 2.0352	* 3.0322	* 4.4620	*	*
15	* .6831	* .8511	* .7794	* .6792	* F-SUB-Q			
	* 4.6362	* 3.7361	* 4.0873	* 4.7201	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 149 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9642 *	* 1.6268 *	* 1.5091 *	* 1.7047 *	* 1.5364 *	* 1.6794 *	* 1.3067 *	* .6911 *
	* 3.2734 *	* 2.2645 *	* 2.4101 *	* 2.0943 *	* 2.3151 *	* 2.0958 *	* 2.6509 *	* 4.9420 *
9	* 1.6268 *	* 1.4532 *	* 1.7029 *	* 1.5183 *	* 1.6995 *	* 1.5547 *	* 1.6543 *	* .8614 *
	* 2.2645 *	* 2.5373 *	* 2.1291 *	* 2.3641 *	* 2.0884 *	* 2.2601 *	* 2.1066 *	* 3.9960 *
10	* 1.5091 *	* 1.6998 *	* 1.3573 *	* 1.5900 *	* 1.5388 *	* 1.6188 *	* 1.5589 *	* .7867 *
	* 2.4101 *	* 2.1331 *	* 2.6805 *	* 2.2783 *	* 2.3456 *	* 2.1998 *	* 2.2582 *	* 4.3958 *
11	* 1.7047 *	* 1.5170 *	* 1.5846 *	* 1.4300 *	* 1.5637 *	* 1.3716 *	* 1.6056 *	* .6911 *
	* 2.0943 *	* 2.3650 *	* 2.2860 *	* 2.5328 *	* 2.1915 *	* 2.4636 *	* 2.1792 *	* 5.0813 *
12	* 1.5364 *	* 1.6989 *	* 1.5371 *	* 1.5625 *	* 1.2098 *	* 1.3297 *	* 1.0073 *	
	* 2.3151 *	* 2.0890 *	* 2.3480 *	* 2.1917 *	* 2.2646 *	* 2.1953 *	* 3.2625 *	
13	* 1.6794 *	* 1.5541 *	* 1.6179 *	* 1.3709 *	* 1.3293 *	* 1.3890 *	* .6479 *	
	* 2.0958 *	* 2.2608 *	* 2.2009 *	* 2.4643 *	* 2.1957 *	* 2.0839 *	* 4.7691 *	
14	* 1.3067 *	* 1.6538 *	* 1.5583 *	* 1.6050 *	* 1.0066 *	* .6478 *		
	* 2.6509 *	* 2.1072 *	* 2.2590 *	* 2.1799 *	* 3.2648 *	* 4.7692 *		
15	* .6911 *	* .8613 *	* .7865 *	* .6908 *	F-SUB-Q			
	* 4.9420 *	* 3.9962 *	* 4.3968 *	* 5.0831 *	M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0231 *	* 1.6411 *	* 1.5122 *	* 1.6964 *	* 1.5334 *	* 1.6705 *	* 1.3038 *	* .6834 *
	* 3.6684 *	* 2.5274 *	* 2.6746 *	* 2.3186 *	* 2.5525 *	* 2.3093 *	* 2.9072 *	* 5.4601 *
9	* 1.6411 *	* 1.4628 *	* 1.6991 *	* 1.5187 *	* 1.6921 *	* 1.5513 *	* 1.6512 *	* .8629 *
	* 2.5274 *	* 2.8195 *	* 2.3702 *	* 2.6138 *	* 2.3048 *	* 2.4838 *	* 2.3107 *	* 4.3520 *
10	* 1.5122 *	* 1.6960 *	* 1.3741 *	* 1.5968 *	* 1.5508 *	* 1.6234 *	* 1.5629 *	* .7994 *
	* 2.6746 *	* 2.3745 *	* 2.9484 *	* 2.5292 *	* 2.5864 *	* 2.4186 *	* 2.4708 *	* 4.7202 *
11	* 1.6964 *	* 1.5174 *	* 1.5915 *	* 1.4527 *	* 1.5974 *	* 1.4109 *	* 1.6310 *	* .7080 *
	* 2.3186 *	* 2.6147 *	* 2.5377 *	* 2.8093 *	* 2.4455 *	* 2.7419 *	* 2.4087 *	* 5.4480 *
12	* 1.5334 *	* 1.6914 *	* 1.5491 *	* 1.5962 *	* 1.3554 *	* 1.4364 *	* 1.0567 *	
	* 2.5525 *	* 2.3055 *	* 2.5889 *	* 2.4456 *	* 2.5215 *	* 2.4475 *	* 3.5816 *	
13	* 1.6705 *	* 1.5508 *	* 1.6224 *	* 1.4103 *	* 1.4360 *	* 1.5017 *	* .6811 *	
	* 2.3093 *	* 2.4846 *	* 2.4198 *	* 2.7427 *	* 2.4480 *	* 2.3157 *	* 5.3021 *	
14	* 1.3038 *	* 1.6506 *	* 1.5623 *	* 1.6303 *	* 1.0560 *	* .6810 *		
	* 2.9072 *	* 2.3114 *	* 2.4717 *	* 2.4095 *	* 3.5837 *	* 5.3023 *		
15	* .6834 *	* .8627 *	* .7991 *	* .7077 *	F-SUB-Q			
	* 5.4601 *	* 4.3524 *	* 4.7214 *	* 5.4500 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 150 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1270	* 1.7085	* 1.5468	* 1.7389	* 1.5615	* 1.7124	* 1.3245	* .6957
	* 3.8477	* 2.6359	* 2.8913	* 2.4821	* 2.7481	* 2.4647	* 3.1153	* 5.8145
9	* 1.7085	* 1.5023	* 1.7474	* 1.5496	* 1.7373	* 1.5871	* 1.6961	* .8747
	* 2.6359	* 3.0025	* 2.5431	* 2.8196	* 2.4646	* 2.6602	* 2.4614	* 4.6833
10	* 1.5468	* 1.7442	* 1.3896	* 1.6393	* 1.5969	* 1.6780	* 1.6113	* .8015
	* 2.8913	* 2.5476	* 3.2229	* 2.7243	* 2.7887	* 2.5875	* 2.6402	* 5.1553
11	* 1.7389	* 1.5483	* 1.6338	* 1.5075	* 1.6791	* 1.4908	* 1.7067	* .7162
	* 2.4821	* 2.8205	* 2.7334	* 2.9866	* 2.6308	* 2.9759	* 2.6143	* 5.9660
12	* 1.5615	* 1.7359	* 1.5951	* 1.6779	* 1.5542	* 1.6065	* 1.1065	*
	* 2.7481	* 2.4653	* 2.7914	* 2.6310	* 2.7363	* 2.6600	* 3.9548	*
13	* 1.7124	* 1.5865	* 1.6770	* 1.4901	* 1.6062	* 1.6631	* .7327	*
	* 2.4647	* 2.6611	* 2.5888	* 2.9772	* 2.6606	* 2.5294	* 5.8127	*
14	* 1.3245	* 1.6954	* 1.6106	* 1.7060	* 1.1056	* .7326	*	*
	* 3.1153	* 2.4621	* 2.6412	* 2.6153	* 3.9578	* 5.8129	*	*
15	* .6957	* .8746	* .8012	* .7159	* F-SUB-Q			
	* 5.8144	* 4.6837	* 5.1567	* 5.9682	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1731	* 1.7384	* 1.5601	* 1.7513	* 1.5698	* 1.7243	* 1.3301	* .6958
	* 4.0100	* 2.7247	* 2.9400	* 2.5560	* 2.8405	* 2.5760	* 3.3195	* 6.3123
9	* 1.7384	* 1.5222	* 1.7638	* 1.5601	* 1.7533	* 1.5989	* 1.7124	* .8791
	* 2.7247	* 3.1101	* 2.5949	* 2.8975	* 2.5595	* 2.7942	* 2.6284	* 5.0887
10	* 1.5601	* 1.7625	* 1.4013	* 1.6578	* 1.6189	* 1.7017	* 1.6322	* .8070
	* 2.9400	* 2.5996	* 3.2899	* 2.7956	* 2.9002	* 2.7283	* 2.8297	* 5.6109
11	* 1.7513	* 1.5588	* 1.6522	* 1.5365	* 1.7255	* 1.5370	* 1.7492	* .7264
	* 2.5560	* 2.8986	* 2.8050	* 3.0798	* 2.7073	* 3.0623	* 2.7033	* 6.5368
12	* 1.5698	* 1.7517	* 1.6172	* 1.7253	* 1.6529	* 1.6999	* 1.1455	*
	* 2.8405	* 2.5604	* 2.9033	* 2.7075	* 2.8181	* 2.7403	* 4.1004	*
13	* 1.7243	* 1.5983	* 1.7006	* 1.5363	* 1.6996	* 1.7609	* .7643	*
	* 2.5760	* 2.7953	* 2.7300	* 3.0637	* 2.7410	* 2.6315	* 6.0952	*
14	* 1.3301	* 1.7117	* 1.6314	* 1.7484	* 1.1446	* .7643	*	*
	* 3.3195	* 2.6294	* 2.8310	* 2.7045	* 4.1038	* 6.0956	*	*
15	* .6958	* .8789	* .8067	* .7260	* F-SUB-Q			
	* 6.3123	* 5.0897	* 5.6131	* 6.5393	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 151 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1774	* 1.7304	* 1.5522	* 1.7364	* 1.5589	* 1.7086	* 1.3216	* .6889
	* 4.1717	* 2.8013	* 2.9556	* 2.5774	* 2.8582	* 2.5961	* 3.3327	* 6.3583
9	* 1.7304	* 1.5183	* 1.7508	* 1.5514	* 1.7440	* 1.5884	* 1.7019	* .8759
	* 2.8013	* 3.1261	* 2.6153	* 2.9153	* 2.5806	* 2.8117	* 2.6466	* 5.1032
10	* 1.5522	* 1.7498	* 1.4056	* 1.6522	* 1.6166	* 1.6950	* 1.6267	* .8134
	* 2.9556	* 2.6200	* 3.2819	* 2.8099	* 2.9161	* 2.7493	* 2.8476	* 5.5725
11	* 1.7365	* 1.5495	* 1.6467	* 1.5378	* 1.7499	* 1.5483	* 1.7564	* .7353
	* 2.5774	* 2.9164	* 2.8193	* 3.1902	* 2.8231	* 3.1838	* 2.8094	* 6.5408
12	* 1.5589	* 1.7425	* 1.6149	* 1.7497	* 1.6850	* 1.7277	* 1.1697	*
	* 2.8582	* 2.5815	* 2.9192	* 2.8233	* 2.9383	* 2.8620	* 4.2235	*
13	* 1.7086	* 1.5877	* 1.6940	* 1.5476	* 1.7273	* 1.7979	* .7777	*
	* 2.5961	* 2.8129	* 2.7510	* 3.1853	* 2.8627	* 2.7494	* 6.3508	*
14	* 1.3216	* 1.7012	* 1.6260	* 1.7556	* 1.1689	* .7777	*	*
	* 3.3327	* 2.6478	* 2.8491	* 2.8108	* 4.2265	* 6.3513	*	*
15	* .6889	* .8758	* .8130	* .7350	* F-SUB-Q			
	* 6.3583	* 5.1044	* 5.5749	* 6.5444	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1858	* 1.7552	* 1.5633	* 1.7587	* 1.5687	* 1.7316	* 1.3289	* .6938
	* 3.9861	* 2.6918	* 2.8899	* 2.5092	* 2.7996	* 2.5275	* 3.2679	* 6.2104
9	* 1.7552	* 1.5285	* 1.7744	* 1.5622	* 1.7702	* 1.6056	* 1.7280	* .8821
	* 2.6918	* 3.0565	* 2.5440	* 2.8555	* 2.5129	* 2.7476	* 2.5769	* 4.9995
10	* 1.5633	* 1.7734	* 1.4011	* 1.6681	* 1.6350	* 1.7235	* 1.6558	* .8081
	* 2.8899	* 2.5485	* 3.2446	* 2.7497	* 2.8578	* 2.6795	* 2.7779	* 5.5404
11	* 1.7587	* 1.5601	* 1.6625	* 1.5581	* 1.7939	* 1.5789	* 1.7969	* .7344
	* 2.5092	* 2.8566	* 2.7588	* 3.0486	* 2.6808	* 3.0286	* 2.6648	* 6.4349
12	* 1.5687	* 1.7687	* 1.6335	* 1.7938	* 1.7239	* 1.7771	* 1.1814	*
	* 2.7996	* 2.5137	* 2.8609	* 2.6810	* 2.8045	* 2.7082	* 4.0381	*
13	* 1.7316	* 1.6049	* 1.7224	* 1.5783	* 1.7767	* 1.8567	* .7990	*
	* 2.5275	* 2.7488	* 2.6812	* 3.0300	* 2.7088	* 2.5943	* 5.9540	*
14	* 1.3289	* 1.7272	* 1.6550	* 1.7960	* 1.1804	* .7989	*	*
	* 3.2679	* 2.5781	* 2.7793	* 2.6660	* 4.0416	* 5.9544	*	*
15	* .6938	* .8819	* .8077	* .7340	* F-SUB-Q			
	* 6.2104	* 5.0007	* 5.5429	* 6.4381	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 152 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1713	* 1.7507	* 1.5552	* 1.7537	* 1.5603	* 1.7286	* 1.3225	* .6868 *
	* 3.6724	* 2.4546	* 2.6763	* 2.3273	* 2.6047	* 2.3477	* 3.0448	* 5.8039 *
9	* 1.7507	* 1.5191	* 1.7697	* 1.5546	* 1.7688	* 1.6019	* 1.7285	* .8770 *
	* 2.4546	* 2.8228	* 2.3525	* 2.6525	* 2.3318	* 2.5547	* 2.3909	* 4.6466 *
10	* 1.5552	* 1.7687	* 1.3891	* 1.6622	* 1.6332	* 1.7242	* 1.6614	* .8017 *
	* 2.6763	* 2.3566	* 3.0120	* 2.5470	* 2.6466	* 2.4773	* 2.5668	* 5.1517 *
11	* 1.7537	* 1.5525	* 1.6566	* 1.5595	* 1.8037	* 1.5861	* 1.8065	* .7301 *
	* 2.3273	* 2.6533	* 2.5553	* 2.7813	* 2.4396	* 2.7614	* 2.4230	* 5.9229 *
12	* 1.5603	* 1.7673	* 1.6317	* 1.8036	* 1.7332	* 1.7904	* 1.1832	*
	* 2.6047	* 2.3326	* 2.6493	* 2.4398	* 2.5547	* 2.4656	* 3.6955	*
13	* 1.7286	* 1.6012	* 1.7230	* 1.5855	* 1.7899	* 1.8771	* .8015	*
	* 2.3477	* 2.5558	* 2.4789	* 2.7627	* 2.4662	* 2.3611	* 5.4594	*
14	* 1.3225	* 1.7277	* 1.6606	* 1.8056	* 1.1821	* .8014	*	*
	* 3.0448	* 2.3920	* 2.5681	* 2.4242	* 3.6987	* 5.4598	*	*
15	* .6868	* .8768	* .8014	* .7297	* F-SUB-Q			
	* 5.8039	* 4.6476	* 5.1541	* 5.9260	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1551	* 1.7300	* 1.5360	* 1.7335	* 1.5415	* 1.7105	* 1.3073	* .6784 *
	* 3.3878	* 2.2574	* 2.4305	* 2.1147	* 2.3686	* 2.1344	* 2.7738	* 5.2987 *
9	* 1.7300	* 1.4991	* 1.7492	* 1.5361	* 1.7516	* 1.5851	* 1.7131	* .8675 *
	* 2.2574	* 2.5633	* 2.1346	* 2.4106	* 2.1186	* 2.3218	* 2.1727	* 4.2337 *
10	* 1.5360	* 1.7482	* 1.3759	* 1.6444	* 1.6184	* 1.7087	* 1.6498	* .7947 *
	* 2.4305	* 2.1383	* 2.7287	* 2.3075	* 2.3978	* 2.2470	* 2.3283	* 4.6830 *
11	* 1.7335	* 1.5341	* 1.6389	* 1.5484	* 1.7934	* 1.5764	* 1.7954	* .7244 *
	* 2.1147	* 2.4113	* 2.3150	* 2.5575	* 2.2471	* 2.5475	* 2.2337	* 5.4464 *
12	* 1.5415	* 1.7501	* 1.6169	* 1.7933	* 1.7241	* 1.7817	* 1.1780	*
	* 2.3686	* 2.1195	* 2.4004	* 2.2473	* 2.3522	* 2.2721	* 3.4053	*
13	* 1.7105	* 1.5844	* 1.7076	* 1.5758	* 1.7813	* 1.8717	* .7971	*
	* 2.1344	* 2.3228	* 2.2484	* 2.5488	* 2.2727	* 2.1745	* 5.0450	*
14	* 1.3073	* 1.7123	* 1.6490	* 1.7944	* 1.1769	* .7970	*	*
	* 2.7738	* 2.1738	* 2.3295	* 2.2348	* 3.4083	* 5.0453	*	*
15	* .6784	* .8673	* .7943	* .7240	* F-SUB-Q			
	* 5.2987	* 4.2347	* 4.6852	* 5.4496	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 153 of 311

F-SUB-O & M-SUB-O VALUES (F-SUB-O OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* 1.1292	* 1.6895	* 1.5036	* 1.6935	* 1.5096	* 1.6728	* 1.2820	* .6631
	* 3.1389	* 2.0931	* 2.2438	* 1.9593	* 2.1903	* 1.9789	* 2.5669	* 4.9288
9	* 1.6895	* 1.4667	* 1.7087	* 1.5049	* 1.7142	* 1.5527	* 1.6784	* .8543
	* 2.0931	* 2.3645	* 1.9747	* 2.2270	* 1.9628	* 2.1480	* 2.0130	* 3.9035
10	* 1.5036	* 1.7077	* 1.3588	* 1.6116	* 1.5879	* 1.6727	* 1.6186	* .7897
	* 2.2438	* 1.9780	* 2.4960	* 2.1256	* 2.2082	* 2.0772	* 2.1508	* 4.2758
11	* 1.6935	* 1.5029	* 1.6063	* 1.5228	* 1.7604	* 1.5486	* 1.7618	* .7204
	* 1.9593	* 2.2277	* 2.1324	* 2.3654	* 2.0895	* 2.3606	* 2.0712	* 4.9528
12	* 1.5096	* 1.7127	* 1.5864	* 1.7603	* 1.6964	* 1.7489	* 1.1673	*
	* 2.1903	* 1.9636	* 2.2106	* 2.0896	* 2.1840	* 2.1187	* 3.1402	*
13	* 1.6728	* 1.5521	* 1.6716	* 1.5480	* 1.7484	* 1.8408	* .7835	*
	* 1.9789	* 2.1489	* 2.0785	* 2.3618	* 2.1192	* 2.0274	* 4.7118	*
14	* 1.2820	* 1.6775	* 1.6178	* 1.7609	* 1.1664	* .7834	*	*
	* 2.5669	* 2.0140	* 2.1519	* 2.0722	* 3.1427	* 4.7122	*	*
15	* .6631	* .8541	* .7894	* .7200	* F-SUB-Q			
	* 4.9288	* 3.9046	* 4.2779	* 4.9557	* M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* 1.1209	* 1.6910	* 1.4943	* 1.6950	* 1.5008	* 1.6762	* 1.2736	* .6609
	* 2.8797	* 1.8860	* 2.0565	* 1.7875	* 2.0116	* 1.8058	* 2.3649	* 4.5319
9	* 1.6910	* 1.4561	* 1.7105	* 1.4955	* 1.7169	* 1.5504	* 1.6825	* .8470
	* 1.8860	* 2.1647	* 1.7966	* 2.0439	* 1.7902	* 1.9651	* 1.8334	* 3.6031
10	* 1.4943	* 1.7095	* 1.3369	* 1.6059	* 1.5829	* 1.6769	* 1.6228	* .7714
	* 2.0565	* 1.7997	* 2.3126	* 1.9392	* 2.0142	* 1.8883	* 1.9576	* 4.0018
11	* 1.6950	* 1.4936	* 1.6005	* 1.5168	* 1.7660	* 1.5487	* 1.7692	* .7045
	* 1.7875	* 2.0445	* 1.9455	* 2.1393	* 1.9011	* 2.1572	* 1.8721	* 4.6064
12	* 1.5008	* 1.7155	* 1.5815	* 1.7659	* 1.6960	* 1.7572	* 1.1508	
	* 2.0116	* 1.7909	* 2.0164	* 1.9012	* 1.9863	* 1.9228	* 2.9183	
13	* 1.6762	* 1.5497	* 1.6758	* 1.5481	* 1.7568	* 1.8515	* .7828	
	* 1.8058	* 1.9660	* 1.8895	* 2.1583	* 1.9232	* 1.8393	* 4.3093	
14	* 1.2736	* 1.6816	* 1.6219	* 1.7683	* 1.1497	* .7828	*	
	* 2.3649	* 1.8344	* 1.9587	* 1.8731	* 2.9211	* 4.3096	*	
15	* .6609	* .8468	* .7711	* .7041	* F-SUB-Q			
	* 4.5319	* 3.6040	* 4.0038	* 4.6091	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 154 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1001	* 1.6624	* 1.4677	* 1.6666	* 1.4745	* 1.6489	* 1.2513	* .6496 *
	* 2.6513	* 1.7581	* 1.9245	* 1.6766	* 1.8887	* 1.6954	* 2.2256	* 4.2691 *
9	* 1.6624	* 1.4298	* 1.6818	* 1.4700	* 1.6897	* 1.5246	* 1.6559	* .8331 *
	* 1.7581	* 2.0187	* 1.6795	* 1.9165	* 1.6788	* 1.8439	* 1.7184	* 3.3856 *
10	* 1.4677	* 1.6809	* 1.3151	* 1.5809	* 1.5583	* 1.6505	* 1.5968	* .7574 *
	* 1.9245	* 1.6823	* 2.1609	* 1.8070	* 1.8751	* 1.7635	* 1.8306	* 3.7615 *
11	* 1.6666	* 1.4681	* 1.5757	* 1.4929	* 1.7397	* 1.5240	* 1.7420	* .6918 *
	* 1.6766	* 1.9170	* 1.8128	* 1.9952	* 1.7531	* 1.9990	* 1.7428	* 4.2950 *
12	* 1.4745	* 1.6883	* 1.5569	* 1.7395	* 1.6713	* 1.7309	* 1.1307	*
	* 1.8887	* 1.6794	* 1.8771	* 1.7532	* 1.8315	* 1.7779	* 2.7009	*
13	* 1.6489	* 1.5239	* 1.6494	* 1.5234	* 1.7305	* 1.8238	* .7691	*
	* 1.6954	* 1.8447	* 1.7646	* 2.0001	* 1.7783	* 1.7076	* 4.0094	*
14	* 1.2513	* 1.6550	* 1.5960	* 1.7411	* 1.1297	* .7691	*	*
	* 2.2256	* 1.7193	* 1.8316	* 1.7437	* 2.7035	* 4.0097	*	*
15	* .6496	* .8329	* .7571	* .6914	* F-SUB-Q			
	* 4.2691	* 3.3864	* 3.7634	* 4.2976	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0648	* 1.5980	* 1.4210	* 1.6015	* 1.4277	* 1.5851	* 1.2128	* .6264 *
	* 2.5491	* 1.6754	* 1.8459	* 1.6272	* 1.8200	* 1.6473	* 2.1477	* 4.1463 *
9	* 1.5980	* 1.3854	* 1.6163	* 1.4249	* 1.6265	* 1.4710	* 1.5927	* .8102 *
	* 1.6754	* 1.9228	* 1.6236	* 1.8403	* 1.6291	* 1.7832	* 1.6677	* 3.2530 *
10	* 1.4210	* 1.6154	* 1.2920	* 1.5322	* 1.5110	* 1.5880	* 1.5347	* .7474 *
	* 1.8459	* 1.6263	* 2.0423	* 1.7289	* 1.7895	* 1.7020	* 1.7692	* 3.5569 *
11	* 1.6015	* 1.4230	* 1.5273	* 1.4474	* 1.6750	* 1.4704	* 1.6731	* .6822 *
	* 1.6272	* 1.8416	* 1.7344	* 1.8960	* 1.6877	* 1.9250	* 1.6775	* 4.0285 *
12	* 1.4277	* 1.6252	* 1.5096	* 1.6749	* 1.6181	* 1.6641	* 1.1056	*
	* 1.8200	* 1.6297	* 1.7914	* 1.6878	* 1.7498	* 1.7114	* 2.5668	*
13	* 1.5851	* 1.4703	* 1.5870	* 1.4698	* 1.6637	* 1.7497	* .7401	*
	* 1.6473	* 1.7840	* 1.7031	* 1.9259	* 1.7118	* 1.6427	* 3.8576	*
14	* 1.2128	* 1.5919	* 1.5339	* 1.6722	* 1.1047	* .7400	*	*
	* 2.1477	* 1.6686	* 1.7702	* 1.6784	* 2.5689	* 3.8579	*	*
15	* .6264	* .8100	* .7470	* .6818	* F-SUB-Q			
	* 4.1463	* 3.2538	* 3.5587	* 4.0308	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 155 of 311

F-SUB-O & M-SUB-O VALUES (F-SUB-O OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	1.0521	1.5696	1.3956	1.5697	1.4012	1.5559	1.1887	.6157
	2.3760	1.5906	1.7642	1.5657	1.7491	1.5847	2.0716	3.9962
9	1.5696	1.3625	1.5854	1.3979	1.5960	1.4439	1.5627	.7941
	1.5906	1.8252	1.5568	1.7651	1.5666	1.7134	1.6004	3.1362
10	1.3956	1.5847	1.2576	1.5034	1.4858	1.5612	1.5020	.7236
	1.7642	1.5592	1.9713	1.6531	1.7024	1.6225	1.6956	3.4657
11	1.5697	1.3960	1.4987	1.4169	1.6430	1.4420	1.6369	.6591
	1.5657	1.7662	1.6582	1.8152	1.6123	1.8191	1.5969	3.9130
12	1.4012	1.5948	1.4846	1.6429	1.5922	1.6341	1.0697	
	1.7491	1.5672	1.7041	1.6115	1.6713	1.6395	2.4781	
13	1.5559	1.4433	1.5603	1.4414	1.6337	1.7079	.7251	
	1.5847	1.7142	1.6235	1.8200	1.6399	1.5862	3.7186	
14	1.1887	1.5619	1.5012	1.6361	1.0688	.7250		
	2.0716	1.6013	1.6966	1.5978	2.4804	3.7190		
15	.6157	.7940	.7232	.6588	F-SUB-Q			
	3.9962	3.1369	3.4674	3.9153	M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* 1.0217	* 1.4906	* 1.3245	* 1.4869	* 1.3229	* 1.4774	* 1.1307	* .5824
	* 2.3086	* 1.5810	* 1.7637	* 1.5779	* 1.7736	* 1.5948	* 2.0854	* 4.0545
9	* 1.4906	* 1.3032	* 1.5004	* 1.3186	* 1.5103	* 1.3715	* 1.4831	* .7587
	* 1.5810	* 1.8027	* 1.5638	* 1.7734	* 1.5769	* 1.7239	* 1.6134	* 3.1426
10	* 1.3245	* 1.4999	* 1.1887	* 1.4049	* 1.4059	* 1.4876	* 1.4358	* .6977
	* 1.7637	* 1.5643	* 1.9794	* 1.6841	* 1.7087	* 1.6180	* 1.6816	* 3.4356
11	* 1.4869	* 1.3174	* 1.4009	* 1.3323	* 1.5601	* 1.3695	* 1.5316	* .6296
	* 1.5779	* 1.7749	* 1.6889	* 1.8445	* 1.5932	* 1.8115	* 1.6174	* 3.8940
12	* 1.3229	* 1.5092	* 1.4048	* 1.5600	* 1.5234	* 1.5525	* 1.0080	*
	* 1.7736	* 1.5773	* 1.7103	* 1.5933	* 1.6355	* 1.6167	* 2.4831	*
13	* 1.4774	* 1.3709	* 1.4868	* 1.3690	* 1.5522	* 1.6005	* .6883	*
	* 1.5948	* 1.7247	* 1.6190	* 1.8124	* 1.6170	* 1.5888	* 3.6825	*
14	* 1.1307	* 1.4823	* 1.4351	* 1.5308	* 1.0072	* .6883	*	
	* 2.0854	* 1.6142	* 1.6825	* 1.6182	* 2.4851	* 3.6830	*	
15	* .5824	* .7585	* .6974	* .6293	* F-SUB-Q			
	* 4.0545	* 3.1434	* 3.4374	* 3.8962	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 156 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9170	* 1.4194	* 1.0946	* 1.3893	* 1.0969	* 1.3706	* .9600	* .4979
	* 2.4647	* 1.5925	* 2.0584	* 1.6280	* 2.0620	* 1.6619	* 2.3817	* 4.6060
9	* 1.4194	* 1.0746	* 1.4267	* 1.0753	* 1.4131	* 1.1845	* 1.3639	* .6541
	* 1.5925	* 2.0984	* 1.5830	* 2.0991	* 1.6214	* 1.9278	* 1.6937	* 3.5319
10	* 1.0946	* 1.4264	* 1.0429	* 1.1664	* 1.1919	* 1.3765	* 1.3542	* .6201
	* 2.0584	* 1.5833	* 2.1661	* 1.9569	* 1.9449	* 1.6906	* 1.7196	* 3.7505
11	* 1.3893	* 1.0751	* 1.1636	* 1.1364	* 1.4231	* 1.1888	* 1.3072	* .5423
	* 1.6280	* 2.0997	* 1.9614	* 2.0904	* 1.6728	* 2.0120	* 1.8235	* 4.3602
12	* 1.0969	* 1.4123	* 1.1911	* 1.4228	* 1.3188	* 1.4769	* .8625	*
	* 2.0620	* 1.6220	* 1.9464	* 1.6732	* 1.8121	* 1.6333	* 2.7923	*
13	* 1.3706	* 1.1839	* 1.3758	* 1.1884	* 1.4766	* 1.3519	* .5955	*
	* 1.6619	* 1.9287	* 1.6915	* 2.0127	* 1.6336	* 1.8010	* 4.0893	*
14	* .9600	* 1.3632	* 1.3535	* 1.3065	* .8619	* .5954	*	*
	* 2.3817	* 1.6946	* 1.7205	* 1.8244	* 2.7943	* 4.0900	*	*
15	* .4979	* .6539	* .6197	* .5421	* F-SUB-Q			
	* 4.6060	* 3.5330	* 3.7525	* 4.3627	* M-SUB-Q			

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6788	* .5804	* .5103	* .5795	* .5090	* .5712	* .4483	* .3442
	* 3.2243	* 3.7571	* 4.2774	* 3.7707	* 4.3126	* 3.8609	* 4.9497	* 6.4943
9	* .5804	* .5060	* .5773	* .5044	* .5872	* .5260	* .5186	* .3061
	* 3.7571	* 4.3139	* 3.7809	* 4.3477	* 3.7712	* 4.1982	* 4.3110	* 7.3610
10	* .5103	* .5774	* .5152	* .4943	* .5247	* .5829	* .5372	* .2984
	* 4.2774	* 3.7792	* 4.2495	* 4.4926	* 4.2784	* 3.8510	* 4.1938	* 7.5585
11	* .5795	* .5045	* .4939	* .5344	* .6009	* .5309	* .4939	* .2627
	* 3.7708	* 4.3476	* 4.4962	* 4.3062	* 3.8305	* 4.3283	* 4.6329	* 8.7312
12	* .5090	* .5869	* .5245	* .6008	* .5636	* .5658	* .3962	*
	* 4.3126	* 3.7726	* 4.2807	* 3.8311	* 4.1022	* 4.1195	* 5.8928	*
13	* .5712	* .5258	* .5826	* .5308	* .5657	* .5146	* .4126	*
	* 3.8609	* 4.1996	* 3.8530	* 4.3304	* 4.1203	* 4.5606	* 5.7276	*
14	* .4483	* .5184	* .5369	* .4937	* .3963	* .4125	*	*
	* 4.9497	* 4.3133	* 4.1960	* 4.6352	* 5.8917	* 5.7292	*	*
15	* .3442	* .3060	* .2982	* .2626	* F-SUB-Q			
	* 6.4943	* 7.3646	* 7.5624	* 8.7360	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 157 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5437 *	* .5133 *	* .4792 *	* .5554 *	* .4883 *	* .5429 *	* .4375 *	* .3623 *
	* 3.5899 *	* 4.4169 *	* 4.8069 *	* 4.1401 *	* 4.6977 *	* 4.2169 *	* 5.2185 *	* 6.2583 *
9	* .5133 *	* .4700 *	* .5421 *	* .4834 *	* .5494 *	* .4950 *	* .4765 *	* .3019 *
	* 4.4169 *	* 4.9054 *	* 4.2437 *	* 4.7560 *	* 4.1676 *	* 4.6315 *	* 4.7766 *	* 7.4994 *
10	* .4792 *	* .5421 *	* .4843 *	* .4538 *	* .4675 *	* .5145 *	* .4764 *	* .2868 *
	* 4.8069 *	* 4.2439 *	* 4.7598 *	* 5.0535 *	* 4.8797 *	* 4.4158 *	* 4.7565 *	* 7.8922 *
11	* .5554 *	* .4836 *	* .4529 *	* .3975 *	* .4500 *	* .4209 *	* .4119 *	* .2416 *
	* 4.1401 *	* 4.7541 *	* 5.0625 *	* 5.0948 *	* 4.4962 *	* 5.0586 *	* 5.4723 *	* 9.2790 *
12	* .4883 *	* .5493 *	* .4674 *	* .4499 *	* .3413 *	* .3439 *	* .2923 *	
	* 4.6977 *	* 4.1682 *	* 4.8806 *	* 4.4966 *	* 4.7383 *	* 4.7453 *	* 6.6545 *	
13	* .5429 *	* .4949 *	* .5144 *	* .4209 *	* .3439 *	* .2976 *	* .2907 *	
	* 4.2169 *	* 4.6320 *	* 4.4164 *	* 5.0590 *	* 4.7456 *	* 5.2004 *	* 5.9861 *	
14	* .4375 *	* .4767 *	* .4765 *	* .4119 *	* .2924 *	* .2906 *		
	* 5.2185 *	* 4.7746 *	* 4.7561 *	* 5.4727 *	* 6.6514 *	* 5.9883 *		
15	* .3623 *	* .3021 *	* .2869 *	* .2416 *	* F-SUB-Q			
	* 6.2583 *	* 7.4937 *	* 7.8895 *	* 9.2790 *	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7140 *	* 1.1796 *	* 1.0243 *	* 1.2632 *	* 1.0407 *	* 1.2379 *	* .9108 *	* .5102 *
	* 2.7287 *	* 1.9803 *	* 2.3347 *	* 1.8917 *	* 2.2889 *	* 1.9239 *	* 2.6074 *	* 4.6046 *
9	* 1.1796 *	* .9955 *	* 1.2648 *	* 1.0235 *	* 1.2524 *	* 1.0717 *	* 1.1876 *	* .6445 *
	* 1.9803 *	* 2.4025 *	* 1.8913 *	* 2.3325 *	* 1.8992 *	* 2.2165 *	* 1.9922 *	* 3.6462 *
10	* 1.0243 *	* 1.2643 *	* .9771 *	* 1.0173 *	* 1.0320 *	* 1.1602 *	* 1.1449 *	* .6078 *
	* 2.3347 *	* 1.8919 *	* 2.4420 *	* 2.3414 *	* 2.2919 *	* 2.0352 *	* 2.0531 *	* 3.8532 *
11	* 1.2632 *	* 1.0231 *	* 1.0149 *	* .8627 *	* 1.0186 *	* .9028 *	* 1.0218 *	* .5088 *
	* 1.8917 *	* 2.3335 *	* 2.3468 *	* 2.5349 *	* 2.0538 *	* 2.3999 *	* 2.2585 *	* 4.5678 *
12	* 1.0407 *	* 1.2522 *	* 1.0317 *	* 1.0183 *	* .7441 *	* .8579 *	* .6288 *	
	* 2.2888 *	* 1.8996 *	* 2.2927 *	* 2.0540 *	* 2.1855 *	* 1.9768 *	* 3.2133 *	
13	* 1.2379 *	* 1.0715 *	* 1.1600 *	* .9025 *	* .8578 *	* .7678 *	* .4070 *	
	* 1.9239 *	* 2.2168 *	* 2.0356 *	* 2.4002 *	* 1.9769 *	* 2.1632 *	* 4.4361 *	
14	* .9108 *	* 1.1880 *	* 1.1450 *	* 1.0217 *	* .6287 *	* .4069 *		
	* 2.6074 *	* 1.9918 *	* 2.0531 *	* 2.2587 *	* 3.2139 *	* 4.4365 *		
15	* .5102 *	* .6448 *	* .6079 *	* .5088 *	* F-SUB-Q			
	* 4.6046 *	* 3.6446 *	* 3.8523 *	* 4.5679 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 158 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8140	* 1.3118	* 1.2426	* 1.3866	* 1.2543	* 1.3714	* 1.0849	* .5990
	* 2.4723	* 1.8843	* 1.9808	* 1.7719	* 1.9518	* 1.7854	* 2.2446	* 4.0300
9	* 1.3118	* 1.2018	* 1.3651	* 1.2423	* 1.3798	* 1.2752	* 1.3405	* .7503
	* 1.8843	* 2.0517	* 1.8080	* 1.9738	* 1.7766	* 1.9137	* 1.8142	* 3.2135
10	* 1.2426	* 1.3645	* 1.1245	* 1.2361	* 1.2233	* 1.2957	* 1.2634	* .7034
	* 1.9808	* 1.8087	* 2.1876	* 1.9849	* 1.9946	* 1.8804	* 1.9208	* 3.4218
11	* 1.3866	* 1.2415	* 1.2328	* 1.0627	* 1.1645	* 1.0601	* 1.2206	* .5976
	* 1.7719	* 1.9750	* 1.9901	* 2.1837	* 1.8992	* 2.0900	* 1.9459	* 4.0088
12	* 1.2543	* 1.3795	* 1.2225	* 1.1639	* .8836	* .9646	* .7642	*
	* 1.9518	* 1.7770	* 1.9959	* 1.8993	* 1.9155	* 1.8762	* 2.7397	*
13	* 1.3714	* 1.2750	* 1.2953	* 1.0598	* .9645	* .9314	* .4772	*
	* 1.7854	* 1.9140	* 1.8808	* 2.0903	* 1.8764	* 1.8537	* 3.9268	*
14	* 1.0849	* 1.3407	* 1.2633	* 1.2204	* .7639	* .4771	*	*
	* 2.2446	* 1.8140	* 1.9209	* 1.9461	* 2.7403	* 3.9268	*	*
15	* .5990	* .7505	* .7035	* .5975	* F-SUB-Q			
	* 4.0300	* 3.2126	* 3.4213	* 4.0091	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8827	* 1.4559	* 1.3605	* 1.5371	* 1.3945	* 1.5218	* 1.2014	* .6506
	* 2.4124	* 1.7612	* 1.8731	* 1.6560	* 1.8190	* 1.6663	* 2.0941	* 3.8332
9	* 1.4559	* 1.3159	* 1.5141	* 1.3633	* 1.5303	* 1.4070	* 1.4924	* .8057
	* 1.7612	* 1.9413	* 1.6876	* 1.8627	* 1.6597	* 1.7954	* 1.6872	* 3.0993
10	* 1.3605	* 1.5135	* 1.2006	* 1.3591	* 1.3352	* 1.4345	* 1.3954	* .7419
	* 1.8731	* 1.6886	* 2.1192	* 1.8650	* 1.8932	* 1.7625	* 1.8046	* 3.3647
11	* 1.5371	* 1.3626	* 1.3552	* 1.1799	* 1.2982	* 1.1721	* 1.3641	* .6327
	* 1.6560	* 1.8633	* 1.8703	* 2.0714	* 1.7827	* 1.9686	* 1.7977	* 3.9354
12	* 1.3945	* 1.5299	* 1.3342	* 1.2974	* .9741	* 1.0857	* .8363	*
	* 1.8190	* 1.6600	* 1.8946	* 1.7828	* 1.8215	* 1.7539	* 2.6176	*
13	* 1.5218	* 1.4067	* 1.4340	* 1.1717	* 1.0855	* 1.0622	* .5247	*
	* 1.6663	* 1.7957	* 1.7631	* 1.9689	* 1.7541	* 1.7110	* 3.7483	*
14	* 1.2014	* 1.4925	* 1.3953	* 1.3638	* .8359	* .5246	*	*
	* 2.0941	* 1.6872	* 1.8048	* 1.7980	* 2.6187	* 3.7483	*	*
15	* .6506	* .8059	* .7419	* .6326	* F-SUB-Q			
	* 3.8332	* 3.0986	* 3.3645	* 3.9360	* M-SUB-Q			

CNEI-0400-25
Appendix A, Rev. 19
Page 159 of 311

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

	H	G	F	E	D	C	B	A
8	* .9126 *	* 1.5263 *	* 1.4098 *	* 1.6124 *	* 1.4471 *	* 1.5988 *	* 1.2471 *	* .6682 *
	* 2.4905 *	* 1.7649 *	* 1.8980 *	* 1.6566 *	* 1.8398 *	* 1.6635 *	* 2.1146 *	* 3.9136 *
9	* 1.5263 *	* 1.3587 *	* 1.5863 *	* 1.4118 *	* 1.6064 *	* 1.4732 *	* 1.5726 *	* .8322 *
	* 1.7649 *	* 1.9743 *	* 1.6911 *	* 1.8876 *	* 1.6586 *	* 1.7989 *	* 1.6792 *	* 3.1499 *
10	* 1.4098 *	* 1.5855 *	* 1.2370 *	* 1.4066 *	* 1.3851 *	* 1.5077 *	* 1.4737 *	* .7674 *
	* 1.8980 *	* 1.6919 *	* 2.1591 *	* 1.8911 *	* 1.9172 *	* 1.7615 *	* 1.7947 *	* 3.4171 *
11	* 1.6124 *	* 1.4114 *	* 1.4024 *	* 1.2233 *	* 1.3638 *	* 1.2293 *	* 1.4444 *	* .6548 *
	* 1.6566 *	* 1.8882 *	* 1.8966 *	* 2.0924 *	* 1.7822 *	* 1.9732 *	* 1.7886 *	* 4.0034 *
12	* 1.4471 *	* 1.6060 *	* 1.3840 *	* 1.3629 *	* 1.0277 *	* 1.1547 *	* .8816 *	
	* 1.8398 *	* 1.6590 *	* 1.9187 *	* 1.7822 *	* 1.8346 *	* 1.7472 *	* 2.6285 *	
13	* 1.5988 *	* 1.4728 *	* 1.5071 *	* 1.2289 *	* 1.1544 *	* 1.1412 *	* .5506 *	
	* 1.6635 *	* 1.7993 *	* 1.7621 *	* 1.9735 *	* 1.7474 *	* 1.6949 *	* 3.7982 *	
14	* 1.2471 *	* 1.5724 *	* 1.4734 *	* 1.4440 *	* .8811 *	* .5506 *		
	* 2.1146 *	* 1.6793 *	* 1.7950 *	* 1.7890 *	* 2.6300 *	* 3.7983 *		
15	* .6682 *	* .8323 *	* .7674 *	* .6547 *	F-SUB-Q			
	* 3.9136 *	* 3.1495 *	* 3.4171 *	* 4.0041 *	M-SUB-Q			

	H	G	F	E	D	C	B	A
8	* .9331 *	* 1.5669 *	* 1.4398 *	* 1.6552 *	* 1.4788 *	* 1.6442 *	* 1.2754 *	* .6807 *
	* 2.5966 *	* 1.8340 *	* 1.9831 *	* 1.7197 *	* 1.9193 *	* 1.7224 *	* 2.2005 *	* 4.0898 *
9	* 1.5669 *	* 1.3841 *	* 1.6271 *	* 1.4412 *	* 1.6508 *	* 1.5142 *	* 1.6225 *	* .8504 *
	* 1.8340 *	* 2.0687 *	* 1.7588 *	* 1.9725 *	* 1.7195 *	* 1.8640 *	* 1.7325 *	* 3.2835 *
10	* 1.4398 *	* 1.6263 *	* 1.2615 *	* 1.4335 *	* 1.4166 *	* 1.5540 *	* 1.5251 *	* .7896 *
	* 1.9831 *	* 1.7596 *	* 2.2607 *	* 1.9809 *	* 2.0013 *	* 1.8225 *	* 1.8487 *	* 3.5413 *
11	* 1.6552 *	* 1.4407 *	* 1.4293 *	* 1.2509 *	* 1.4052 *	* 1.2688 *	* 1.4991 *	* .6743 *
	* 1.7197 *	* 1.9731 *	* 1.9868 *	* 2.1649 *	* 1.8395 *	* 2.0379 *	* 1.8324 *	* 4.1568 *
12	* 1.4788 *	* 1.6504 *	* 1.4154 *	* 1.4043 *	* 1.0675 *	* 1.2044 *	* .9198 *	
	* 1.9193 *	* 1.7199 *	* 2.0030 *	* 1.8396 *	* 1.9004 *	* 1.8035 *	* 2.7077 *	
13	* 1.6442 *	* 1.5138 *	* 1.5533 *	* 1.2683 *	* 1.2041 *	* 1.2006 *	* .5740 *	
	* 1.7224 *	* 1.8645 *	* 1.8232 *	* 2.0383 *	* 1.8036 *	* 1.7444 *	* 3.9481 *	
14	* 1.2754 *	* 1.6223 *	* 1.5247 *	* 1.4987 *	* .9194 *	* .5740 *		
	* 2.2005 *	* 1.7328 *	* 1.8492 *	* 1.8328 *	* 2.7089 *	* 3.9482 *		
15	* .6807 *	* .8504 *	* .7895 *	* .6742 *	F-SUB-Q			
	* 4.0898 *	* 3.2833 *	* 3.5416 *	* 4.1578 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 160 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9575	* 1.6195	* 1.4763	* 1.7075	* 1.5160	* 1.6989	* 1.3076	* .6964 *
	* 2.7063	* 1.9058	* 2.0991	* 1.8010	* 2.0216	* 1.7958	* 2.3080	* 4.2946 *
9	* 1.6195	* 1.4175	* 1.6793	* 1.4765	* 1.7050	* 1.5619	* 1.6819	* .8736 *
	* 1.9058	* 2.1948	* 1.8497	* 2.0831	* 1.7962	* 1.9473	* 1.7990	* 3.4375 *
10	* 1.4763	* 1.6785	* 1.2834	* 1.4700	* 1.4573	* 1.6115	* 1.5849	* .8056 *
	* 2.0991	* 1.8506	* 2.4132	* 2.0974	* 2.1091	* 1.8992	* 1.9189	* 3.7360 *
11	* 1.7075	* 1.4760	* 1.4656	* 1.2871	* 1.4627	* 1.3194	* 1.5667	* .6924 *
	* 1.8010	* 2.0838	* 2.1036	* 2.2548	* 1.9063	* 2.1146	* 1.8753	* 4.3756 *
12	* 1.5160	* 1.7046	* 1.4561	* 1.4621	* 1.1144	* 1.2701	* .9568	*
	* 2.0216	* 1.7967	* 2.1109	* 1.9064	* 1.9742	* 1.8619	* 2.8327	*
13	* 1.6989	* 1.5615	* 1.6107	* 1.3189	* 1.2697	* 1.2787	* .6063	*
	* 1.7958	* 1.9478	* 1.9000	* 2.1151	* 1.8621	* 1.8011	* 4.1053	*
14	* 1.3076	* 1.6816	* 1.5844	* 1.5662	* .9561	* .6062	*	*
	* 2.3080	* 1.7994	* 1.9195	* 1.8758	* 2.8346	* 4.1054	*	*
15	* .6964	* .8736	* .8055	* .6922	* F-SUB-Q			
	* 4.2946	* 3.4374	* 3.7365	* 4.3769	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9795	* 1.6646	* 1.5067	* 1.7452	* 1.5449	* 1.7382	* 1.3324	* .7029 *
	* 2.9019	* 2.0246	* 2.2569	* 1.9265	* 2.1624	* 1.9118	* 2.4614	* 4.6135 *
9	* 1.6646	* 1.4476	* 1.7201	* 1.5049	* 1.7445	* 1.5977	* 1.7266	* .8873 *
	* 2.0246	* 2.3447	* 1.9839	* 2.2386	* 1.9163	* 2.0739	* 1.9070	* 3.6713 *
10	* 1.5067	* 1.7192	* 1.3045	* 1.5013	* 1.4932	* 1.6573	* 1.6325	* .8203 *
	* 2.2569	* 1.9848	* 2.6084	* 2.2576	* 2.2626	* 2.0191	* 2.0310	* 3.9825 *
11	* 1.7452	* 1.5044	* 1.4967	* 1.3240	* 1.5215	* 1.3722	* 1.6266	* .7084 *
	* 1.9265	* 2.2393	* 2.2646	* 2.3693	* 1.9999	* 2.2195	* 1.9650	* 4.6561 *
12	* 1.5449	* 1.7440	* 1.4919	* 1.5207	* 1.1755	* 1.3437	* 1.0016	*
	* 2.1624	* 1.9167	* 2.2645	* 2.0000	* 2.0784	* 1.9593	* 2.9753	*
13	* 1.7382	* 1.5972	* 1.6566	* 1.3716	* 1.3433	* 1.3696	* .6391	*
	* 1.9118	* 2.0744	* 2.0200	* 2.2201	* 1.9595	* 1.8979	* 4.3642	*
14	* 1.3324	* 1.7261	* 1.6320	* 1.6260	* 1.0009	* .6391	*	*
	* 2.4614	* 1.9074	* 2.0316	* 1.9656	* 2.9773	* 4.3643	*	*
15	* .7029	* .8873	* .8201	* .7081	* F-SUB-Q			
	* 4.6135	* 3.6714	* 3.9832	* 4.6575	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 161 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0399	* 1.7249	* 1.5420	* 1.7875	* 1.5760	* 1.7812	* 1.3581	* .7170 *
	* 3.1714	* 2.1685	* 2.4273	* 2.0510	* 2.3072	* 2.0284	* 2.6178	* 4.8944 *
9	* 1.7249	* 1.4863	* 1.7695	* 1.5363	* 1.7883	* 1.6358	* 1.7745	* .9058 *
	* 2.1685	* 2.5253	* 2.1283	* 2.3968	* 2.0363	* 2.2052	* 2.0184	* 3.9062 *
10	* 1.5420	* 1.7686	* 1.3291	* 1.5401	* 1.5359	* 1.7093	* 1.6839	* .8353 *
	* 2.4273	* 2.1293	* 2.8175	* 2.4227	* 2.4195	* 2.1451	* 2.1532	* 4.2592 *
11	* 1.7875	* 1.5358	* 1.5354	* 1.3718	* 1.5984	* 1.4406	* 1.6978	* .7269 *
	* 2.0510	* 2.3975	* 2.4301	* 2.5491	* 2.1415	* 2.3796	* 2.0985	* 4.9784 *
12	* 1.5760	* 1.7878	* 1.5346	* 1.5976	* 1.3014	* 1.4574	* 1.0567	*
	* 2.3072	* 2.0368	* 2.4216	* 2.1418	* 2.2348	* 2.0912	* 3.1948	*
13	* 1.7812	* 1.6351	* 1.7085	* 1.4400	* 1.4570	* 1.5054	* .6876	*
	* 2.0284	* 2.2061	* 2.1461	* 2.3802	* 2.0914	* 2.0183	* 4.6530	*
14	* 1.3581	* 1.7739	* 1.6833	* 1.6972	* 1.0559	* .6875	*	
	* 2.6178	* 2.0189	* 2.1539	* 2.0991	* 3.1970	* 4.6531	*	
15	* .7170	* .9057	* .8351	* .7266	* F-SUB-Q			
	* 4.8944	* 3.9064	* 4.2601	* 4.9801	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1185	* 1.7535	* 1.5543	* 1.7890	* 1.5819	* 1.7824	* 1.3634	* .7140 *
	* 3.5470	* 2.4199	* 2.6832	* 2.2554	* 2.5202	* 2.2200	* 2.8514	* 5.3617 *
9	* 1.7535	* 1.5109	* 1.7804	* 1.5439	* 1.7908	* 1.6419	* 1.7818	* .9135 *
	* 2.4199	* 2.8125	* 2.3604	* 2.6333	* 2.2321	* 2.4075	* 2.1998	* 4.2236 *
10	* 1.5543	* 1.7795	* 1.3528	* 1.5542	* 1.5555	* 1.7234	* 1.7002	* .8541 *
	* 2.6832	* 2.3625	* 3.0863	* 2.6752	* 2.6498	* 2.3422	* 2.3401	* 4.5434 *
11	* 1.7890	* 1.5435	* 1.5495	* 1.4116	* 1.6474	* 1.4948	* 1.7358	* .7492 *
	* 2.2554	* 2.6339	* 2.6830	* 2.8244	* 2.3845	* 2.6425	* 2.3112	* 5.3132 *
12	* 1.5819	* 1.7903	* 1.5541	* 1.6466	* 1.4717	* 1.6002	* 1.1167	*
	* 2.5202	* 2.2327	* 2.6520	* 2.3849	* 2.4869	* 2.3275	* 3.5001	*
13	* 1.7824	* 1.6413	* 1.7226	* 1.4942	* 1.5998	* 1.6389	* .7278	*
	* 2.2200	* 2.4083	* 2.3433	* 2.6432	* 2.3278	* 2.2411	* 5.1637	*
14	* 1.3634	* 1.7812	* 1.6996	* 1.7351	* 1.1160	* .7277	*	
	* 2.8514	* 2.2004	* 2.3409	* 2.3120	* 3.5021	* 5.1639	*	
15	* .7140	* .9134	* .8538	* .7489	* F-SUB-Q			
	* 5.3617	* 4.2239	* 4.5445	* 5.3151	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 162 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2201	* 1.8261	* 1.5924	* 1.8378	* 1.6135	* 1.8319	* 1.3885	* .7284 *
	* 3.7270	* 2.5299	* 2.8923	* 2.4117	* 2.7096	* 2.3659	* 3.0525	* 5.7105 *
9	* 1.8261	* 1.5594	* 1.8385	* 1.5759	* 1.8413	* 1.6831	* 1.8365	* .9284 *
	* 2.5299	* 2.9619	* 2.5241	* 2.8391	* 2.3837	* 2.5762	* 2.3381	* 4.5384 *
10	* 1.5924	* 1.8376	* 1.3687	* 1.5956	* 1.6009	* 1.7822	* 1.7585	* .8591 *
	* 2.8923	* 2.5289	* 3.3637	* 2.8784	* 2.8553	* 2.4997	* 2.4955	* 4.9504 *
11	* 1.8378	* 1.5754	* 1.5908	* 1.4893	* 1.7455	* 1.5719	* 1.8184	* .7588 *
	* 2.4117	* 2.8398	* 2.8870	* 3.0602	* 2.5878	* 2.8882	* 2.5139	* 5.7969 *
12	* 1.6135	* 1.8408	* 1.5995	* 1.7454	* 1.6531	* 1.7619	* 1.1656	*
	* 2.7096	* 2.3843	* 2.8577	* 2.5879	* 2.7180	* 2.5373	* 3.8659	*
13	* 1.8319	* 1.6824	* 1.7813	* 1.5712	* 1.7615	* 1.7933	* .7789	*
	* 2.3659	* 2.5772	* 2.5005	* 2.8890	* 2.5376	* 2.4456	* 5.6598	*
14	* 1.3885	* 1.8358	* 1.7578	* 1.8176	* 1.1647	* .7788	*	
	* 3.0525	* 2.3388	* 2.4964	* 2.5147	* 3.8687	* 5.6600	*	
15	* .7284	* .9283	* .8588	* .7585	* F-SUB-Q			
	* 5.7105	* 4.5388	* 4.9517	* 5.7990	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2454	* 1.8528	* 1.6096	* 1.8509	* 1.6220	* 1.8457	* 1.3955	* .7292 *
	* 3.8620	* 2.6009	* 2.8914	* 2.4396	* 2.7699	* 2.4264	* 3.1890	* 6.0798 *
9	* 1.8528	* 1.5776	* 1.8576	* 1.5852	* 1.8558	* 1.6959	* 1.8556	* .9339 *
	* 2.6009	* 3.0536	* 2.5251	* 2.8684	* 2.4312	* 2.6563	* 2.4524	* 4.8338 *
10	* 1.6096	* 1.8570	* 1.3783	* 1.6106	* 1.6193	* 1.8048	* 1.7827	* .8656 *
	* 2.8914	* 2.5263	* 3.3833	* 2.9118	* 2.9252	* 2.5910	* 2.6224	* 5.2806 *
11	* 1.8509	* 1.5844	* 1.6057	* 1.5348	* 1.8122	* 1.6186	* 1.8589	* .7689 *
	* 2.4396	* 2.8691	* 2.9206	* 3.1318	* 2.6486	* 2.9651	* 2.5959	* 6.2727 *
12	* 1.6220	* 1.8552	* 1.6179	* 1.8121	* 1.7219	* 1.8351	* 1.2002	*
	* 2.7699	* 2.4318	* 2.9278	* 2.6488	* 2.7847	* 2.6119	* 4.0086	*
13	* 1.8457	* 1.6951	* 1.8038	* 1.6180	* 1.8347	* 1.8747	* .8063	*
	* 2.4264	* 2.6574	* 2.5924	* 2.9661	* 2.6124	* 2.5477	* 5.9407	*
14	* 1.3955	* 1.8549	* 1.7819	* 1.8581	* 1.1993	* .8063	*	
	* 3.1890	* 2.4533	* 2.6236	* 2.5970	* 4.0117	* 5.9410	*	
15	* .7292	* .9338	* .8653	* .7685	* F-SUB-Q			
	* 6.0798	* 4.8345	* 5.2823	* 6.2757	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 163 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2405 *	* 1.8377 *	* 1.5998 *	* 1.8309 *	* 1.6082 *	* 1.8269 *	* 1.3854 *	* .7219 *
	* 4.0032 *	* 2.6699 *	* 2.9093 *	* 2.4617 *	* 2.7879 *	* 2.4462 *	* 3.2025 *	* 6.1199 *
9	* 1.8377 *	* 1.5680 *	* 1.8398 *	* 1.5721 *	* 1.8369 *	* 1.6832 *	* 1.8419 *	* .9300 *
	* 2.6699 *	* 3.0852 *	* 2.5462 *	* 2.8885 *	* 2.4523 *	* 2.6724 *	* 2.4680 *	* 4.8471 *
10	* 1.5998 *	* 1.8392 *	* 1.3789 *	* 1.6000 *	* 1.6120 *	* 1.7933 *	* 1.7749 *	* .8713 *
	* 2.9093 *	* 2.5475 *	* 3.3788 *	* 2.9313 *	* 2.9443 *	* 2.6113 *	* 2.6384 *	* 5.2454 *
11	* 1.8309 *	* 1.5712 *	* 1.5952 *	* 1.5446 *	* 1.8240 *	* 1.6306 *	* 1.8594 *	* .7767 *
	* 2.4617 *	* 2.8892 *	* 2.9401 *	* 3.2351 *	* 2.7497 *	* 3.0705 *	* 2.6850 *	* 6.2407 *
12	* 1.6082 *	* 1.8364 *	* 1.6106 *	* 1.8239 *	* 1.7394 *	* 1.8500 *	* 1.2202 *	
	* 2.7879 *	* 2.4530 *	* 2.9470 *	* 2.7499 *	* 2.8899 *	* 2.7160 *	* 4.1065 *	
13	* 1.8269 *	* 1.6826 *	* 1.7924 *	* 1.6301 *	* 1.8496 *	* 1.8977 *	* .8151 *	
	* 2.4462 *	* 2.6734 *	* 2.6128 *	* 3.0716 *	* 2.7166 *	* 2.6481 *	* 6.1609 *	
14	* 1.3854 *	* 1.8411 *	* 1.7741 *	* 1.8586 *	* 1.2193 *	* .8150 *		
	* 3.2025 *	* 2.4690 *	* 2.6397 *	* 2.6862 *	* 4.1094 *	* 6.1612 *		
15	* .7218 *	* .9298 *	* .8710 *	* .7764 *	* F-SUB-Q			
	* 6.1199 *	* 4.8478 *	* 5.2473 *	* 6.2438 *	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2422 *	* 1.8550 *	* 1.6036 *	* 1.8465 *	* 1.6112 *	* 1.8450 *	* 1.3882 *	* .7243 *
	* 3.7904 *	* 2.5330 *	* 2.8355 *	* 2.3894 *	* 2.7234 *	* 2.3736 *	* 3.1300 *	* 5.9619 *
9	* 1.8550 *	* 1.5702 *	* 1.8563 *	* 1.5738 *	* 1.8549 *	* 1.6929 *	* 1.8652 *	* .9333 *
	* 2.5330 *	* 2.9874 *	* 2.4653 *	* 2.8213 *	* 2.3804 *	* 2.6065 *	* 2.3959 *	* 4.7332 *
10	* 1.6036 *	* 1.8557 *	* 1.3671 *	* 1.6059 *	* 1.6200 *	* 1.8153 *	* 1.7989 *	* .8632 *
	* 2.8355 *	* 2.4665 *	* 3.3292 *	* 2.8611 *	* 2.8782 *	* 2.5369 *	* 2.5643 *	* 5.1953 *
11	* 1.8465 *	* 1.5735 *	* 1.6011 *	* 1.5601 *	* 1.8573 *	* 1.6531 *	* 1.8931 *	* .7721 *
	* 2.3894 *	* 2.8219 *	* 2.8695 *	* 3.0561 *	* 2.5857 *	* 2.8954 *	* 2.5186 *	* 6.0948 *
12	* 1.6112 *	* 1.8540 *	* 1.6186 *	* 1.8572 *	* 1.7666 *	* 1.8900 *	* 1.2237 *	
	* 2.7234 *	* 2.3811 *	* 2.8809 *	* 2.5859 *	* 2.7337 *	* 2.5461 *	* 3.8964 *	
13	* 1.8450 *	* 1.6921 *	* 1.8143 *	* 1.6526 *	* 1.8896 *	* 1.9460 *	* .8309 *	
	* 2.3736 *	* 2.6076 *	* 2.5384 *	* 2.8964 *	* 2.5466 *	* 2.4764 *	* 5.7329 *	
14	* 1.3882 *	* 1.8644 *	* 1.7980 *	* 1.8923 *	* 1.2227 *	* .8309 *		
	* 3.1300 *	* 2.3969 *	* 2.5655 *	* 2.5197 *	* 3.8996 *	* 5.7332 *		
15	* .7243 *	* .9331 *	* .8628 *	* .7717 *	* F-SUB-Q			
	* 5.9619 *	* 4.7341 *	* 5.1974 *	* 6.0978 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 164 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2202	* 1.8390	* 1.5855	* 1.8313	* 1.5935	* 1.8324	* 1.3745	* .7134 *
	* 3.5296	* 2.3359	* 2.6062	* 2.1974	* 2.5146	* 2.1864	* 2.8920	* 5.5233 *
9	* 1.8390	* 1.5507	* 1.8404	* 1.5558	* 1.8432	* 1.6788	* 1.8571	* .9236 *
	* 2.3359	* 2.7571	* 2.2575	* 2.5992	* 2.1904	* 2.4052	* 2.2028	* 4.3611 *
10	* 1.5855	* 1.8398	* 1.3466	* 1.5892	* 1.6055	* 1.8060	* 1.7929	* .8524 *
	* 2.6062	* 2.2586	* 3.0664	* 2.6257	* 2.6416	* 2.3253	* 2.3492	* 4.7893 *
11	* 1.8313	* 1.5555	* 1.5844	* 1.5524	* 1.8551	* 1.6482	* 1.8918	* .7634 *
	* 2.1974	* 2.5997	* 2.6335	* 2.8144	* 2.3764	* 2.6668	* 2.3150	* 5.6679 *
12	* 1.5935	* 1.8423	* 1.6040	* 1.8550	* 1.7634	* 1.8931	* 1.2176	*
	* 2.5146	* 2.1910	* 2.6439	* 2.3766	* 2.5156	* 2.3400	* 3.5995	*
13	* 1.8324	* 1.6780	* 1.8050	* 1.6476	* 1.8928	* 1.9538	* .8276	*
	* 2.1864	* 2.4063	* 2.3266	* 2.6678	* 2.3405	* 2.2748	* 5.3068	*
14	* 1.3745	* 1.8562	* 1.7920	* 1.8910	* 1.2166	* .8276	*	*
	* 2.8920	* 2.2039	* 2.3504	* 2.3161	* 3.6026	* 5.3072	*	*
15	* .7134	* .9234	* .8521	* .7630	* F-SUB-Q			
	* 5.5233	* 4.3621	* 4.7915	* 5.6708	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1939	* 1.8031	* 1.5535	* 1.7973	* 1.5625	* 1.8001	* 1.3493	* .7001 *
	* 3.2981	* 2.1707	* 2.4077	* 2.0304	* 2.3259	* 2.0207	* 2.6772	* 5.1217 *
9	* 1.8031	* 1.5180	* 1.8048	* 1.5251	* 1.8116	* 1.6492	* 1.8277	* .9074 *
	* 2.1707	* 2.5464	* 2.0830	* 2.4030	* 2.0237	* 2.2222	* 2.0329	* 4.0371 *
10	* 1.5535	* 1.8043	* 1.3220	* 1.5596	* 1.5777	* 1.7766	* 1.7661	* .8392 *
	* 2.4077	* 2.0839	* 2.8268	* 2.4212	* 2.4358	* 2.1440	* 2.1652	* 4.4236 *
11	* 1.7973	* 1.5248	* 1.5549	* 1.5291	* 1.8300	* 1.6252	* 1.8661	* .7520 *
	* 2.0304	* 2.4034	* 2.4283	* 2.6257	* 2.2160	* 2.4891	* 2.1592	* 5.2244 *
12	* 1.5625	* 1.8108	* 1.5766	* 1.8299	* 1.7399	* 1.8701	* 1.2031	*
	* 2.3259	* 2.0243	* 2.4380	* 2.2161	* 2.3451	* 2.1823	* 3.3561	*
13	* 1.8001	* 1.6484	* 1.7756	* 1.6246	* 1.8699	* 1.9327	* .8167	*
	* 2.0207	* 2.2232	* 2.1452	* 2.4900	* 2.1828	* 2.1201	* 4.9614	*
14	* 1.3493	* 1.8268	* 1.7652	* 1.8652	* 1.2021	* .8166	*	*
	* 2.6772	* 2.0339	* 2.1664	* 2.1602	* 3.3590	* 4.9618	*	*
15	* .7001	* .9072	* .8388	* .7516	* F-SUB-Q			
	* 5.1217	* 4.0381	* 4.4257	* 5.2274	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 165 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1552 *	* 1.7431 *	* 1.5055 *	* 1.7393 *	* 1.5156 *	* 1.7435 *	* 1.3109 *	* .6783 *
	* 3.1043 *	* 2.0434 *	* 2.2638 *	* 1.9161 *	* 2.1903 *	* 1.9076 *	* 2.5219 *	* 4.8447 *
9	* 1.7431 *	* 1.4704 *	* 1.7452 *	* 1.4790 *	* 1.7558 *	* 1.6015 *	* 1.7733 *	* .8856 *
	* 2.0434 *	* 2.3925 *	* 1.9624 *	* 2.2610 *	* 1.9095 *	* 2.0913 *	* 1.9152 *	* 3.7877 *
10	* 1.5055 *	* 1.7447 *	* 1.2930 *	* 1.5134 *	* 1.5332 *	* 1.7228 *	* 1.7152 *	* .8261 *
	* 2.2638 *	* 1.9634 *	* 2.6337 *	* 2.2728 *	* 2.2856 *	* 2.0179 *	* 2.0359 *	* 4.1121 *
11	* 1.7393 *	* 1.4787 *	* 1.5089 *	* 1.4891 *	* 1.7790 *	* 1.5823 *	* 1.8134 *	* .7411 *
	* 1.9161 *	* 2.2613 *	* 2.2793 *	* 2.4675 *	* 2.0920 *	* 2.3467 *	* 2.0324 *	* 4.8365 *
12	* 1.5156 *	* 1.7549 *	* 1.5321 *	* 1.7789 *	* 1.6950 *	* 1.8186 *	* 1.1820 *	
	* 2.1903 *	* 1.9100 *	* 2.2877 *	* 2.0922 *	* 2.2113 *	* 2.0658 *	* 3.1380 *	
13	* 1.7435 *	* 1.6007 *	* 1.7218 *	* 1.5817 *	* 1.8184 *	* 1.8820 *	* .7955 *	
	* 1.9076 *	* 2.0923 *	* 2.0190 *	* 2.3475 *	* 2.0663 *	* 2.0053 *	* 4.6972 *	
14	* 1.3109 *	* 1.7724 *	* 1.7143 *	* 1.8125 *	* 1.1811 *	* .7954 *		
	* 2.5219 *	* 1.9162 *	* 2.0370 *	* 2.0334 *	* 3.1404 *	* 4.6975 *		
15	* .6783 *	* .8853 *	* .8257 *	* .7407 *	F-SUB-Q			
	* 4.8447 *	* 3.7887 *	* 4.1141 *	* 4.8394 *	M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1311 *	* 1.7208 *	* 1.4755 *	* 1.7179 *	* 1.4869 *	* 1.7239 *	* 1.2853 *	* .6669 *
	* 2.9013 *	* 1.8817 *	* 2.1202 *	* 1.7850 *	* 2.0552 *	* 1.7772 *	* 2.3720 *	* 4.5502 *
9	* 1.7208 *	* 1.4395 *	* 1.7233 *	* 1.4495 *	* 1.7358 *	* 1.5748 *	* 1.7557 *	* .8666 *
	* 1.8817 *	* 2.2385 *	* 1.8227 *	* 2.1204 *	* 1.7781 *	* 1.9576 *	* 1.7808 *	* 3.5690 *
10	* 1.4755 *	* 1.7228 *	* 1.2525 *	* 1.4872 *	* 1.5077 *	* 1.7042 *	* 1.6972 *	* .7970 *
	* 2.1202 *	* 1.8235 *	* 2.4936 *	* 2.1196 *	* 2.1322 *	* 1.8733 *	* 1.8912 *	* 3.9264 *
11	* 1.7179 *	* 1.4493 *	* 1.4828 *	* 1.4634 *	* 1.7613 *	* 1.5585 *	* 1.7980 *	* .7153 *
	* 1.7850 *	* 2.1207 *	* 2.1258 *	* 2.3089 *	* 1.9368 *	* 2.1890 *	* 1.8695 *	* 4.5964 *
12	* 1.4869 *	* 1.7349 *	* 1.5066 *	* 1.7612 *	* 1.6720 *	* 1.8041 *	* 1.1493 *	
	* 2.0552 *	* 1.7786 *	* 2.1342 *	* 1.9369 *	* 2.0467 *	* 1.9072 *	* 2.9702 *	
13	* 1.7239 *	* 1.5740 *	* 1.7032 *	* 1.5579 *	* 1.8038 *	* 1.8694 *	* .7841 *	
	* 1.7772 *	* 1.9585 *	* 1.8744 *	* 2.1898 *	* 1.9077 *	* 1.8515 *	* 4.3766 *	
14	* 1.2853 *	* 1.7548 *	* 1.6963 *	* 1.7971 *	* 1.1483 *	* .7840 *		
	* 2.3720 *	* 1.7817 *	* 1.8922 *	* 1.8705 *	* 2.9729 *	* 4.3769 *		
15	* .6669 *	* .8664 *	* .7966 *	* .7149 *	F-SUB-Q			
	* 4.5502 *	* 3.5700 *	* 3.9283 *	* 4.5991 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 166 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0906	* 1.6624	* 1.4244	* 1.6606	* 1.4368	* 1.6673	* 1.2418	* .6446 *
	* 2.7318	* 1.7956	* 2.0319	* 1.7145	* 1.9763	* 1.7084	* 2.2850	* 4.3875 *
9	* 1.6624	* 1.3890	* 1.6654	* 1.4001	* 1.6793	* 1.5232	* 1.6993	* .8383 *
	* 1.7956	* 2.1384	* 1.7432	* 2.0356	* 1.7077	* 1.8801	* 1.7086	* 3.4328 *
10	* 1.4244	* 1.6649	* 1.2109	* 1.4402	* 1.4600	* 1.6494	* 1.6421	* .7697 *
	* 2.0319	* 1.7439	* 2.3853	* 2.0220	* 2.0338	* 1.7914	* 1.8106	* 3.7783 *
11	* 1.6606	* 1.3999	* 1.4360	* 1.4171	* 1.7070	* 1.5090	* 1.7416	* .6910 *
	* 1.7145	* 2.0358	* 2.0279	* 2.1718	* 1.8254	* 2.0655	* 1.7775	* 4.3905 *
12	* 1.4368	* 1.6785	* 1.4589	* 1.7069	* 1.6208	* 1.7481	* 1.1113	* .7581 *
	* 1.9763	* 1.7081	* 2.0357	* 1.8255	* 1.9294	* 1.8027	* 2.8082	* 4.1621 *
13	* 1.6673	* 1.5224	* 1.6485	* 1.5084	* 1.7478	* 1.8122	* 1.7569	* 4.1621 *
	* 1.7084	* 1.8811	* 1.7925	* 2.0663	* 1.8031	* 1.7569	* 4.1621	* .7581 *
14	* 1.2418	* 1.6984	* 1.6412	* 1.7407	* 1.1103	* .7581	* 4.1624	* 4.1624 *
	* 2.2850	* 1.7095	* 1.8116	* 1.7785	* 2.8108	* 4.1624	* 4.1624	* .7581 *
15	* .6446	* .8381	* .7693	* .6906	* F-SUB-Q			
	* 4.3875	* 3.4337	* 3.7802	* 4.3931	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0306	* 1.5623	* 1.3494	* 1.5617	* 1.3620	* 1.5679	* 1.1783	* .6090 *
	* 2.7005	* 1.7583	* 2.0027	* 1.7101	* 1.9570	* 1.7064	* 2.2651	* 4.3740 *
9	* 1.5623	* 1.3166	* 1.5657	* 1.3281	* 1.5807	* 1.4411	* 1.5982	* .7982 *
	* 1.7583	* 2.0785	* 1.7287	* 2.0109	* 1.7034	* 1.8644	* 1.7036	* 3.3885 *
10	* 1.3494	* 1.5653	* 1.1663	* 1.3691	* 1.3878	* 1.5534	* 1.5442	* .7429 *
	* 2.0027	* 1.7294	* 2.3130	* 1.9842	* 1.9933	* 1.7769	* 1.7994	* 3.6737 *
11	* 1.5617	* 1.3279	* 1.3652	* 1.3472	* 1.6102	* 1.4310	* 1.6374	* .6676 *
	* 1.7101	* 2.0111	* 1.9898	* 2.1300	* 1.7991	* 2.0278	* 1.7592	* 4.2257 *
12	* 1.3620	* 1.5799	* 1.3868	* 1.6101	* 1.5372	* 1.6446	* 1.0657	* .7154 *
	* 1.9570	* 1.7038	* 1.9950	* 1.7992	* 1.8877	* 1.7781	* 2.7303	* 4.0957 *
13	* 1.5679	* 1.4405	* 1.5525	* 1.4305	* 1.6443	* 1.7028	* .7154	* 4.0957 *
	* 1.7064	* 1.8652	* 1.7779	* 2.0286	* 1.7785	* 1.7312	* 4.0957	* .7154 *
14	* 1.1783	* 1.5973	* 1.5434	* 1.6366	* 1.0649	* .7154	* 4.0960	* 4.0960 *
	* 2.2651	* 1.7045	* 1.8003	* 1.7601	* 2.7325	* 4.0960	* 4.0960	* .7154 *
15	* .6090	* .7980	* .7425	* .6673	* F-SUB-Q			
	* 4.3740	* 3.3893	* 3.6756	* 4.2281	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 167 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9851	* 1.4886	* 1.2869	* 1.4870	* 1.3000	* 1.4941	* 1.1219	* .5817
	* 2.6180	* 1.7266	* 1.9797	* 1.7015	* 1.9435	* 1.6986	* 2.2592	* 4.3560
9	* 1.4886	* 1.2564	* 1.4914	* 1.2666	* 1.5069	* 1.3729	* 1.5218	* .7598
	* 1.7266	* 2.0385	* 1.7079	* 1.9950	* 1.6938	* 1.8545	* 1.6941	* 3.3786
10	* 1.2869	* 1.4911	* 1.1059	* 1.3109	* 1.3295	* 1.4832	* 1.4680	* .6985
	* 1.9797	* 1.7085	* 2.3015	* 1.9529	* 1.9576	* 1.7553	* 1.7859	* 3.7022
11	* 1.4870	* 1.2665	* 1.3072	* 1.2869	* 1.5363	* 1.3657	* 1.5577	* .6269
	* 1.7015	* 1.9952	* 1.9584	* 2.0907	* 1.7810	* 1.9995	* 1.7292	* 4.2404
12	* 1.3000	* 1.5062	* 1.3286	* 1.5362	* 1.4706	* 1.5671	* 1.0025	*
	* 1.9435	* 1.6942	* 1.9592	* 1.7811	* 1.8681	* 1.7645	* 2.7336	*
13	* 1.4941	* 1.3723	* 1.4824	* 1.3652	* 1.5668	* 1.6168	* .6817	*
	* 1.6986	* 1.8552	* 1.7562	* 2.0004	* 1.7649	* 1.7229	* 4.0693	*
14	* 1.1219	* 1.5210	* 1.4673	* 1.5570	* 1.0016	* .6817	*	*
	* 2.2592	* 1.6950	* 1.7869	* 1.7301	* 2.7361	* 4.0697	*	*
15	* .5817	* .7596	* .6982	* .6265	* F-SUB-Q			
	* 4.3560	* 3.3794	* 3.7040	* 4.2427	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9157	* 1.3539	* 1.1802	* 1.3520	* 1.1933	* 1.3603	* 1.0277	* .5318
	* 2.6627	* 1.8027	* 2.0559	* 1.7928	* 2.0311	* 1.7892	* 2.3695	* 4.5867
9	* 1.3539	* 1.1550	* 1.3544	* 1.1603	* 1.3748	* 1.2513	* 1.3830	* .6987
	* 1.8027	* 2.1072	* 1.7923	* 2.0857	* 1.7828	* 1.9505	* 1.7856	* 3.5282
10	* 1.1802	* 1.3543	* 1.0179	* 1.1935	* 1.2221	* 1.3567	* 1.3457	* .6469
	* 2.0559	* 1.7927	* 2.3812	* 2.0495	* 2.0320	* 1.8316	* 1.8596	* 3.8335
11	* 1.3520	* 1.1602	* 1.1904	* 1.1841	* 1.4031	* 1.2459	* 1.4038	* .5774
	* 1.7928	* 2.0858	* 2.0548	* 2.1479	* 1.8341	* 2.0590	* 1.8250	* 4.3998
12	* 1.1933	* 1.3742	* 1.2213	* 1.4030	* 1.3549	* 1.4266	* .9121	*
	* 2.0311	* 1.7832	* 2.0336	* 1.8342	* 1.9051	* 1.8229	* 2.8429	*
13	* 1.3603	* 1.2508	* 1.3560	* 1.2454	* 1.4263	* 1.4573	* .6245	*
	* 1.7892	* 1.9513	* 1.8326	* 2.0599	* 1.8233	* 1.8105	* 4.2121	*
14	* 1.0277	* 1.3823	* 1.3450	* 1.4032	* .9113	* .6244	*	*
	* 2.3695	* 1.7865	* 1.8606	* 1.8258	* 2.8453	* 4.2126	*	*
15	* .5318	* .6985	* .6466	* .5771	* F-SUB-Q			
	* 4.5867	* 3.5291	* 3.8354	* 4.4022	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 168 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 50 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7841	* 1.2126	* .9287	* 1.1896	* .9402	* 1.1930	* .8329	* .4388
	* 2.9949	* 1.9356	* 2.5160	* 1.9691	* 2.4972	* 1.9771	* 2.8419	* 5.4062
9	* 1.2126	* .9119	* 1.2090	* .9109	* 1.2172	* 1.0221	* 1.1970	* .5768
	* 1.9356	* 2.5661	* 1.9370	* 2.5710	* 1.9456	* 2.3129	* 1.9997	* 4.1470
10	* .9287	* 1.2088	* .8713	* .9638	* 1.0107	* 1.1986	* 1.1920	* .5479
	* 2.5160	* 1.9373	* 2.6889	* 2.4539	* 2.3787	* 2.0134	* 2.0263	* 4.3985
11	* 1.1896	* .9109	* .9617	* .9605	* 1.2262	* 1.0228	* 1.1407	* .4775
	* 1.9691	* 2.5712	* 2.4592	* 2.5644	* 2.0189	* 2.4244	* 2.1677	* 5.1391
12	* .9402	* 1.2166	* 1.0102	* 1.2259	* 1.1243	* 1.2782	* .7469	*
	* 2.4972	* 1.9462	* 2.3800	* 2.0194	* 2.2046	* 1.9586	* 3.3438	*
13	* 1.1930	* 1.0216	* 1.1980	* 1.0225	* 1.2780	* 1.1720	* .5187	*
	* 1.9771	* 2.3140	* 2.0144	* 2.4252	* 1.9590	* 2.1573	* 4.8746	*
14	* .8329	* 1.1964	* 1.1915	* 1.1402	* .7464	* .5186	*	*
	* 2.8419	* 2.0007	* 2.0273	* 2.1687	* 3.3461	* 4.8754	*	*
15	* .4388	* .5767	* .5476	* .4773	* F-SUB-Q			
	* 5.4062	* 4.1483	* 4.4007	* 5.1419	* M-SUB-Q			

AT 50% POWER, 50 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5572	* .4823	* .4193	* .4817	* .4250	* .4829	* .3792	* .2955
	* 4.0813	* 4.6973	* 5.4047	* 4.7042	* 5.3817	* 4.7320	* 6.0628	* 7.8258
9	* .4823	* .4158	* .4775	* .4165	* .4925	* .4397	* .4435	* .2641
	* 4.6973	* 5.4502	* 4.7427	* 5.4645	* 4.6586	* 5.2044	* 5.2267	* 8.8431
10	* .4193	* .4777	* .4220	* .4065	* .4369	* .4921	* .4595	* .2572
	* 5.4047	* 4.7407	* 5.3846	* 5.6665	* 5.3290	* 4.7358	* 5.0878	* 9.0884
11	* .4817	* .4165	* .4063	* .4404	* .5016	* .4430	* .4223	* .2263
	* 4.7042	* 5.4639	* 5.6705	* 5.4191	* 4.7649	* 5.4022	* 5.6324	* 10.5241
12	* .4250	* .4923	* .4367	* .5015	* .4691	* .4775	* .3349	*
	* 5.3817	* 4.6601	* 5.3315	* 4.7655	* 5.1128	* 5.0662	* 7.2309	*
13	* .4829	* .4396	* .4919	* .4429	* .4774	* .4359	* .3497	*
	* 4.7320	* 5.2060	* 4.7380	* 5.4045	* 5.0671	* 5.5903	* 7.0127	*
14	* .3792	* .4433	* .4593	* .4221	* .3349	* .3496	*	*
	* 6.0628	* 5.2293	* 5.0903	* 5.6350	* 7.2292	* 7.0146	*	*
15	* .2955	* .2640	* .2571	* .2262	* F-SUB-Q			
	* 7.8258	* 8.8470	* 9.0928	* 10.5296	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 169 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5021 *	* .4900 *	* .4557 *	* .5403 *	* .4775 *	* .5411 *	* .4335 *	* .3681 *
	* 4.0759 *	* 4.8606 *	* 5.2374 *	* 4.4183 *	* 4.9885 *	* 4.4007 *	* 5.4782 *	* 6.4102 *
9	* .4900 *	* .4428 *	* .5194 *	* .4637 *	* .5425 *	* .4836 *	* .4817 *	* .3074 *
	* 4.8606 *	* 5.3842 *	* 4.5927 *	* 5.1490 *	* 4.3895 *	* 4.9281 *	* 4.9119 *	* 7.6632 *
10	* .4557 *	* .5195 *	* .4537 *	* .4358 *	* .4547 *	* .5117 *	* .4801 *	* .2923 *
	* 5.2374 *	* 4.5925 *	* 5.2637 *	* 5.4532 *	* 5.2022 *	* 4.6107 *	* 4.9077 *	* 8.0512 *
11	* .5403 *	* .4639 *	* .4355 *	* .3798 *	* .4423 *	* .4091 *	* .4170 *	* .2462 *
	* 4.4183 *	* 5.1467 *	* 5.4561 *	* 5.5323 *	* 4.7788 *	* 5.4208 *	* 5.6014 *	* 9.4504 *
12	* .4775 *	* .5424 *	* .4546 *	* .4422 *	* .3276 *	* .3427 *	* .2896 *	
	* 4.9885 *	* 4.3898 *	* 5.2031 *	* 4.7791 *	* 5.0351 *	* 4.9958 *	* 7.0496 *	
13	* .5411 *	* .4836 *	* .5117 *	* .4090 *	* .3427 *	* .2972 *	* .2878 *	
	* 4.4007 *	* 4.9284 *	* 4.6109 *	* 5.4211 *	* 4.9960 *	* 5.4427 *	* 6.3205 *	
14	* .4335 *	* .4819 *	* .4802 *	* .4170 *	* .2897 *	* .2877 *		
	* 5.4782 *	* 4.9095 *	* 4.9071 *	* 5.6015 *	* 7.0465 *	* 6.3226 *		
15	* .3681 *	* .3077 *	* .2924 *	* .2462 *	F-SUB-Q			
	* 6.4102 *	* 7.6572 *	* 8.0480 *	* 9.4499 *	M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6696 *	* 1.1186 *	* 1.0084 *	* 1.2273 *	* 1.0511 *	* 1.2315 *	* .9178 *	* .5234 *
	* 2.9932 *	* 2.1909 *	* 2.4518 *	* 2.0180 *	* 2.3465 *	* 2.0062 *	* 2.6788 *	* 4.6601 *
9	* 1.1186 *	* .9686 *	* 1.1974 *	* 1.0172 *	* 1.2322 *	* 1.0804 *	* 1.1900 *	* .6559 *
	* 2.1909 *	* 2.5491 *	* 2.0655 *	* 2.4289 *	* 2.0017 *	* 2.2810 *	* 2.0625 *	* 3.7183 *
10	* 1.0084 *	* 1.1970 *	* .9210 *	* .9679 *	* 1.0130 *	* 1.1575 *	* 1.1470 *	* .6172 *
	* 2.4518 *	* 2.0661 *	* 2.6770 *	* 2.5422 *	* 2.4156 *	* 2.1124 *	* 2.1251 *	* 3.9399 *
11	* 1.2273 *	* 1.0169 *	* .9659 *	* .8241 *	* .9996 *	* .8992 *	* 1.0246 *	* .5168 *
	* 2.0180 *	* 2.4296 *	* 2.5447 *	* 2.6869 *	* 2.1726 *	* 2.5157 *	* 2.3642 *	* 4.6560 *
12	* 1.0511 *	* 1.2321 *	* 1.0128 *	* .9994 *	* .7142 *	* .8438 *	* .6234 *	
	* 2.3465 *	* 2.0020 *	* 2.4160 *	* 2.1728 *	* 2.3235 *	* 2.0951 *	* 3.3869 *	
13	* 1.2315 *	* 1.0804 *	* 1.1574 *	* .8991 *	* .8437 *	* .7547 *	* .4062 *	
	* 2.0062 *	* 2.2811 *	* 2.1126 *	* 2.5159 *	* 2.0951 *	* 2.2864 *	* 4.6255 *	
14	* .9178 *	* 1.1904 *	* 1.1471 *	* 1.0246 *	* .6233 *	* .4062 *		
	* 2.6788 *	* 2.0619 *	* 2.1249 *	* 2.3642 *	* 3.3874 *	* 4.6258 *		
15	* .5234 *	* .6562 *	* .6174 *	* .5168 *	F-SUB-Q			
	* 4.6601 *	* 3.7165 *	* 3.9388 *	* 4.6559 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 170 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7866	* 1.3058	* 1.2286	* 1.4175	* 1.2914	* 1.4288	* 1.1391	* .6262
	* 2.6363	* 1.9465	* 2.0674	* 1.7907	* 1.9578	* 1.7722	* 2.2133	* 3.9947
9	* 1.3058	* 1.1810	* 1.3656	* 1.2405	* 1.4227	* 1.3246	* 1.4105	* .7841
	* 1.9465	* 2.1492	* 1.8619	* 2.0420	* 1.7801	* 1.9055	* 1.7834	* 3.1851
10	* 1.2286	* 1.3648	* 1.0792	* 1.1749	* 1.2081	* 1.3400	* 1.3273	* .7385
	* 2.0674	* 1.8631	* 2.3484	* 2.1512	* 2.0787	* 1.8782	* 1.8879	* 3.3747
11	* 1.4175	* 1.2404	* 1.1723	* 1.0126	* 1.1849	* 1.0956	* 1.2682	* .6220
	* 1.7907	* 2.0422	* 2.1559	* 2.2796	* 1.9337	* 2.1116	* 1.9624	* 3.9750
12	* 1.2914	* 1.4226	* 1.2078	* 1.1846	* .8626	* .9995	* .7755	*
	* 1.9578	* 1.7803	* 2.0792	* 1.9338	* 1.9901	* 1.8842	* 2.8061	*
13	* 1.4288	* 1.3245	* 1.3398	* 1.0954	* .9994	* .9375	* .4870	*
	* 1.7722	* 1.9056	* 1.8785	* 2.1118	* 1.8842	* 1.9000	* 3.9820	*
14	* 1.1391	* 1.4108	* 1.3273	* 1.2681	* .7753	* .4870	*	*
	* 2.2133	* 1.7831	* 1.8879	* 1.9625	* 2.8067	* 3.9820	*	*
15	* .6262	* .7843	* .7387	* .6220	* F-SUB-Q			
	* 3.9947	* 3.1840	* 3.3740	* 3.9750	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8645	* 1.4708	* 1.3479	* 1.5953	* 1.4226	* 1.6128	* 1.2544	* .6877
	* 2.5164	* 1.7854	* 1.9436	* 1.6418	* 1.8330	* 1.6191	* 2.0684	* 3.7441
9	* 1.4708	* 1.2897	* 1.5401	* 1.3609	* 1.6037	* 1.4741	* 1.6016	* .8563
	* 1.7854	* 2.0318	* 1.7032	* 1.9202	* 1.6295	* 1.7650	* 1.6189	* 3.0075
10	* 1.3479	* 1.5390	* 1.1605	* 1.2914	* 1.3293	* 1.5120	* 1.5036	* .7952
	* 1.9436	* 1.7043	* 2.2540	* 2.0158	* 1.9508	* 1.7191	* 1.7212	* 3.2357
11	* 1.5953	* 1.3607	* 1.2884	* 1.1089	* 1.3384	* 1.2133	* 1.4415	* .6682
	* 1.6418	* 1.9203	* 2.0205	* 2.1459	* 1.7724	* 1.9603	* 1.7824	* 3.8201
12	* 1.4226	* 1.6035	* 1.3289	* 1.3380	* .9651	* 1.1437	* .8570	*
	* 1.8330	* 1.6297	* 1.9513	* 1.7725	* 1.8556	* 1.7176	* 2.6408	*
13	* 1.6128	* 1.4738	* 1.5117	* 1.2130	* 1.1435	* 1.0835	* .5403	*
	* 1.6191	* 1.7654	* 1.7195	* 1.9606	* 1.7177	* 1.7222	* 3.7462	*
14	* 1.2544	* 1.6017	* 1.5035	* 1.4414	* .8567	* .5402	*	*
	* 2.0684	* 1.6187	* 1.7213	* 1.7827	* 2.6416	* 3.7462	*	*
15	* .6877	* .8565	* .7953	* .6682	* F-SUB-Q			
	* 3.7441	* 3.0067	* 3.2353	* 3.8204	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 171 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9076	* 1.5467	* 1.3981	* 1.6785	* 1.4810	* 1.7019	* 1.3063	* .7103
	* 2.5649	* 1.7760	* 1.9577	* 1.6281	* 1.8344	* 1.5982	* 2.0708	* 3.7817
9	* 1.5467	* 1.3329	* 1.6216	* 1.4110	* 1.6896	* 1.5417	* 1.6965	* .8900
	* 1.7760	* 2.0548	* 1.6889	* 1.9340	* 1.6115	* 1.7571	* 1.5900	* 3.0135
10	* 1.3981	* 1.6205	* 1.1914	* 1.3339	* 1.3845	* 1.5992	* 1.6002	* .8286
	* 1.9577	* 1.6901	* 2.2926	* 2.0379	* 1.9505	* 1.6879	* 1.6802	* 3.2305
11	* 1.6785	* 1.4108	* 1.3307	* 1.1464	* 1.4182	* 1.2737	* 1.5327	* .6952
	* 1.6281	* 1.9341	* 2.0427	* 2.1503	* 1.7499	* 1.9575	* 1.7431	* 3.8179
12	* 1.4810	* 1.6894	* 1.3841	* 1.4178	* 1.0363	* 1.2222	* .9052	*
	* 1.8344	* 1.6117	* 1.9511	* 1.7500	* 1.8503	* 1.6858	* 2.6296	*
13	* 1.7019	* 1.5413	* 1.5989	* 1.2734	* 1.2221	* 1.1682	* .5684	*
	* 1.5982	* 1.7575	* 1.6882	* 1.9577	* 1.6859	* 1.6939	* 3.7613	*
14	* 1.3063	* 1.6965	* 1.6000	* 1.5324	* .9049	* .5684	*	*
	* 2.0708	* 1.5900	* 1.6804	* 1.7434	* 2.6305	* 3.7613	*	*
15	* .7103	* .8902	* .8286	* .6951	* F-SUB-Q			
	* 3.7817	* 3.0130	* 3.2304	* 3.8184	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9330	* 1.5819	* 1.4209	* 1.7172	* 1.5100	* 1.7464	* 1.3330	* .7233
	* 2.6659	* 1.8358	* 2.0302	* 1.6719	* 1.8897	* 1.6344	* 2.1250	* 3.8879
9	* 1.5819	* 1.3513	* 1.6579	* 1.4340	* 1.7315	* 1.5766	* 1.7465	* .9089
	* 1.8358	* 2.1416	* 1.7420	* 2.0001	* 1.6517	* 1.8036	* 1.6196	* 3.0948
10	* 1.4209	* 1.6567	* 1.2080	* 1.3516	* 1.4144	* 1.6485	* 1.6562	* .8510
	* 2.0302	* 1.7433	* 2.3930	* 2.1188	* 2.0116	* 1.7192	* 1.7053	* 3.3043
11	* 1.7172	* 1.4339	* 1.3484	* 1.1690	* 1.4630	* 1.3090	* 1.5843	* .7149
	* 1.6719	* 2.0002	* 2.1239	* 2.2159	* 1.7945	* 2.0163	* 1.7649	* 3.8820
12	* 1.5100	* 1.7312	* 1.4139	* 1.4625	* 1.0789	* 1.2691	* .9381	*
	* 1.8897	* 1.6519	* 2.0122	* 1.7947	* 1.9059	* 1.7253	* 2.6957	*
13	* 1.7464	* 1.5762	* 1.6482	* 1.3087	* 1.2689	* 1.2204	* .5887	*
	* 1.6344	* 1.8040	* 1.7195	* 2.0166	* 1.7254	* 1.7397	* 3.8898	*
14	* 1.3330	* 1.7464	* 1.6560	* 1.5840	* .9377	* .5887	*	*
	* 2.1250	* 1.6198	* 1.7055	* 1.7652	* 2.6968	* 3.8898	*	*
15	* .7233	* .9090	* .8510	* .7147	* F-SUB-Q			
	* 3.8879	* 3.0944	* 3.3044	* 3.8827	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 172 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9481	* 1.6178	* 1.4422	* 1.7568	* 1.5369	* 1.7912	* 1.3570	* .7353
	* 2.7770	* 1.9072	* 2.1331	* 1.7302	* 1.9605	* 1.6829	* 2.2078	* 4.0453
9	* 1.6178	* 1.3689	* 1.6968	* 1.4555	* 1.7741	* 1.6098	* 1.7976	* .9277
	* 1.9072	* 2.2622	* 1.8200	* 2.0894	* 1.7024	* 1.8640	* 1.6590	* 3.1955
10	* 1.4422	* 1.6956	* 1.2176	* 1.3707	* 1.4428	* 1.6986	* 1.7146	* .8638
	* 2.1331	* 1.8213	* 2.5328	* 2.2277	* 2.0802	* 1.7553	* 1.7317	* 3.4234
11	* 1.7568	* 1.4554	* 1.3674	* 1.1915	* 1.5086	* 1.3436	* 1.6368	* .7259
	* 1.7302	* 2.0894	* 2.2314	* 2.3119	* 1.8586	* 2.1010	* 1.8070	* 4.0383
12	* 1.5369	* 1.7738	* 1.4423	* 1.5082	* 1.1094	* 1.3178	* .9619	*
	* 1.9605	* 1.7029	* 2.0809	* 1.8587	* 1.9831	* 1.7795	* 2.8212	*
13	* 1.7912	* 1.6094	* 1.6982	* 1.3432	* 1.3176	* 1.2729	* .6091	*
	* 1.6829	* 1.8645	* 1.7556	* 2.1013	* 1.7797	* 1.7967	* 4.0481	*
14	* 1.3570	* 1.7973	* 1.7143	* 1.6365	* .9615	* .6091	*	*
	* 2.2078	* 1.6592	* 1.7320	* 1.8073	* 2.8224	* 4.0480	*	*
15	* .7353	* .9278	* .8637	* .7258	* F-SUB-Q			
	* 4.0453	* 3.1953	* 3.4237	* 4.0390	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9501	* 1.6371	* 1.4534	* 1.7776	* 1.5516	* 1.8158	* 1.3705	* .7364
	* 2.9824	* 2.0257	* 2.2640	* 1.8287	* 2.0751	* 1.7718	* 2.3225	* 4.2820
9	* 1.6371	* 1.3777	* 1.7173	* 1.4670	* 1.7974	* 1.6288	* 1.8275	* .9345
	* 2.0257	* 2.4076	* 1.9210	* 2.2182	* 1.7945	* 1.9674	* 1.7402	* 3.3780
10	* 1.4534	* 1.7161	* 1.2204	* 1.3808	* 1.4610	* 1.7293	* 1.7509	* .8719
	* 2.2640	* 1.9224	* 2.7003	* 2.3650	* 2.2075	* 1.8450	* 1.8172	* 3.6221
11	* 1.7776	* 1.4669	* 1.3775	* 1.2084	* 1.5401	* 1.3691	* 1.6727	* .7332
	* 1.8287	* 2.2183	* 2.3707	* 2.4351	* 1.9567	* 2.2120	* 1.9085	* 4.3069
12	* 1.5516	* 1.7971	* 1.4604	* 1.5396	* 1.1340	* 1.3549	* .9838	*
	* 2.0751	* 1.7950	* 2.2083	* 1.9568	* 2.0948	* 1.8738	* 2.9706	*
13	* 1.8158	* 1.6283	* 1.7289	* 1.3687	* 1.3546	* 1.3147	* .6235	*
	* 1.7718	* 1.9679	* 1.8454	* 2.2124	* 1.8740	* 1.9014	* 4.3172	*
14	* 1.3705	* 1.8272	* 1.7506	* 1.6723	* .9833	* .6235	*	*
	* 2.3225	* 1.7405	* 1.8176	* 1.9089	* 2.9720	* 4.3172	*	*
15	* .7364	* .9345	* .8718	* .7331	* F-SUB-Q			
	* 4.2820	* 3.3779	* 3.6225	* 4.3078	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 173 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9629	* 1.6630	* 1.4675	* 1.8014	* 1.5669	* 1.8421	* 1.3836	* .7445
	* 3.2653	* 2.1812	* 2.4555	* 1.9717	* 2.2434	* 1.9046	* 2.5023	* 4.5996
9	* 1.6630	* 1.3909	* 1.7438	* 1.4804	* 1.8233	* 1.6485	* 1.8590	* .9449
	* 2.1812	* 2.6156	* 2.0716	* 2.4047	* 1.9309	* 2.1221	* 1.8653	* 3.6384
10	* 1.4674	* 1.7425	* 1.2301	* 1.3964	* 1.4820	* 1.7626	* 1.7892	* .8794
	* 2.4555	* 2.0732	* 2.9347	* 2.5649	* 2.3902	* 1.9807	* 1.9472	* 3.9191
11	* 1.8014	* 1.4803	* 1.3931	* 1.2343	* 1.5797	* 1.4011	* 1.7132	* .7422
	* 1.9717	* 2.4048	* 2.5710	* 2.6295	* 2.1033	* 2.3829	* 2.0441	* 4.6437
12	* 1.5669	* 1.8230	* 1.4814	* 1.5792	* 1.1677	* 1.4038	* 1.0088	*
	* 2.2434	* 1.9314	* 2.3911	* 2.1035	* 2.2620	* 2.0050	* 3.2054	*
13	* 1.8421	* 1.6480	* 1.7622	* 1.4007	* 1.4035	* 1.3715	* .6470	*
	* 1.9046	* 2.1227	* 1.9812	* 2.3834	* 2.0052	* 2.0336	* 4.6288	*
14	* 1.3836	* 1.8587	* 1.7887	* 1.7128	* 1.0081	* .6470	*	*
	* 2.5023	* 1.8656	* 1.9476	* 2.0445	* 3.2076	* 4.6289	*	*
15	* .7445	* .9449	* .8793	* .7420	* F-SUB-Q			
	* 4.5996	* 3.6383	* 3.9196	* 4.6447	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9716	* 1.6620	* 1.4639	* 1.7885	* 1.5602	* 1.8294	* 1.3786	* .7372
	* 3.6522	* 2.4348	* 2.7438	* 2.1922	* 2.4788	* 2.1090	* 2.7584	* 5.0900
9	* 1.6620	* 1.3903	* 1.7346	* 1.4748	* 1.8140	* 1.6433	* 1.8522	* .9464
	* 2.4348	* 2.9393	* 2.3284	* 2.6707	* 2.1357	* 2.3412	* 2.0588	* 3.9773
10	* 1.4639	* 1.7333	* 1.2435	* 1.3970	* 1.4851	* 1.7615	* 1.7886	* .8908
	* 2.7438	* 2.3301	* 3.2687	* 2.8338	* 2.6380	* 2.1786	* 2.1420	* 4.2355
11	* 1.7885	* 1.4748	* 1.3959	* 1.2565	* 1.5986	* 1.4233	* 1.7250	* .7583
	* 2.1922	* 2.6706	* 2.8360	* 2.9227	* 2.3511	* 2.6558	* 2.2570	* 5.0219
12	* 1.5602	* 1.8135	* 1.4845	* 1.5981	* 1.2160	* 1.4479	* 1.0436	*
	* 2.4788	* 2.1362	* 2.6389	* 2.3513	* 2.5265	* 2.2388	* 3.5264	*
13	* 1.8294	* 1.6428	* 1.7611	* 1.4229	* 1.4476	* 1.4261	* .6696	*
	* 2.1090	* 2.3418	* 2.1791	* 2.6563	* 2.2391	* 2.2697	* 5.1455	*
14	* 1.3786	* 1.8517	* 1.7881	* 1.7246	* 1.0430	* .6696	*	*
	* 2.7584	* 2.0592	* 2.1425	* 2.2575	* 3.5283	* 5.1460	*	*
15	* .7372	* .9463	* .8907	* .7581	* F-SUB-Q			
	* 5.0900	* 3.9774	* 4.2362	* 5.0232	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 174 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0363	* 1.7245	* 1.4873	* 1.8243	* 1.5800	* 1.8668	* 1.3943	* .7466 *
	* 3.7972	* 2.5126	* 3.0182	* 2.3918	* 2.7209	* 2.2911	* 3.0132	* 5.5336 *
9	* 1.7245	* 1.4243	* 1.7809	* 1.4941	* 1.8578	* 1.6695	* 1.8997	* .9555 *
	* 2.5126	* 3.0877	* 2.5298	* 2.9382	* 2.3252	* 2.5617	* 2.2315	* 4.3598 *
10	* 1.4873	* 1.7796	* 1.2460	* 1.4206	* 1.5178	* 1.8090	* 1.8435	* .8923 *
	* 3.0182	* 2.5312	* 3.6172	* 3.1436	* 2.9028	* 2.3714	* 2.3239	* 4.6957 *
11	* 1.8243	* 1.4941	* 1.4173	* 1.3112	* 1.6732	* 1.4843	* 1.7885	* .7617 *
	* 2.3918	* 2.9381	* 3.1509	* 3.1330	* 2.5259	* 2.8723	* 2.4573	* 5.5960 *
12	* 1.5800	* 1.8573	* 1.5172	* 1.6727	* 1.3504	* 1.5963	* 1.0861	*
	* 2.7209	* 2.3258	* 2.9038	* 2.5261	* 2.7302	* 2.4223	* 3.8828	*
13	* 1.8668	* 1.6690	* 1.8085	* 1.4839	* 1.5960	* 1.5646	* .7140	*
	* 2.2911	* 2.5625	* 2.3720	* 2.8729	* 2.4226	* 2.4837	* 5.6857	*
14	* 1.3943	* 1.8993	* 1.8430	* 1.7880	* 1.0855	* .7140	*	
	* 3.0132	* 2.2320	* 2.3244	* 2.4579	* 3.8849	* 5.6865	*	
15	* .7466	* .9555	* .8921	* .7615	* F-SUB-Q			
	* 5.5336	* 4.3599	* 4.6965	* 5.5974	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1102	* 1.7711	* 1.4965	* 1.8320	* 1.5828	* 1.8746	* 1.3962	* .7453 *
	* 3.9757	* 2.6126	* 3.0188	* 2.4153	* 2.7738	* 2.3436	* 3.1301	* 5.8492 *
9	* 1.7711	* 1.4491	* 1.7988	* 1.4984	* 1.8710	* 1.6761	* 1.9162	* .9587 *
	* 2.6126	* 3.2196	* 2.5369	* 2.9673	* 2.3786	* 2.6315	* 2.3300	* 4.6119 *
10	* 1.4965	* 1.7978	* 1.2559	* 1.4321	* 1.5350	* 1.8294	* 1.8674	* .8972 *
	* 3.0188	* 2.5388	* 3.6349	* 3.1832	* 2.9868	* 2.4730	* 2.4367	* 4.9740 *
11	* 1.8320	* 1.4985	* 1.4287	* 1.3874	* 1.7277	* 1.5348	* 1.8270	* .7712 *
	* 2.4153	* 2.9672	* 3.1907	* 3.2460	* 2.6152	* 2.9776	* 2.5620	* 6.0178 *
12	* 1.5828	* 1.8704	* 1.5345	* 1.7272	* 1.5313	* 1.7476	* 1.1315	*
	* 2.7738	* 2.3789	* 2.9880	* 2.6155	* 2.8303	* 2.5089	* 4.0236	*
13	* 1.8746	* 1.6755	* 1.8288	* 1.5344	* 1.7474	* 1.6978	* .7529	*
	* 2.3436	* 2.6323	* 2.4737	* 2.9782	* 2.5093	* 2.5786	* 5.9229	*
14	* 1.3962	* 1.9157	* 1.8669	* 1.8265	* 1.1309	* .7529	*	
	* 3.1301	* 2.3307	* 2.4374	* 2.5627	* 4.0258	* 5.9229	*	
15	* .7453	* .9587	* .8970	* .7710	* F-SUB-Q			
	* 5.8492	* 4.6123	* 4.9753	* 6.0198	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 175 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1686	* 1.7864	* 1.4903	* 1.8138	* 1.5702	* 1.8557	* 1.3857	* .7385 *
	* 4.1345	* 2.7200	* 3.0801	* 2.4712	* 2.8312	* 2.3958	* 3.1879	* 5.9627 *
9	* 1.7864	* 1.4562	* 1.7891	* 1.4878	* 1.8557	* 1.6648	* 1.9045	* .9558 *
	* 2.7200	* 3.2979	* 2.5951	* 3.0305	* 2.4323	* 2.6843	* 2.3794	* 4.6858 *
10	* 1.4903	* 1.7881	* 1.2679	* 1.4293	* 1.5340	* 1.8277	* 1.8621	* .9030 *
	* 3.0801	* 2.5970	* 3.6811	* 3.2425	* 3.0489	* 2.5239	* 2.4888	* 5.0163 *
11	* 1.8138	* 1.4879	* 1.4282	* 1.4327	* 1.7608	* 1.5625	* 1.8374	* .7832 *
	* 2.4712	* 3.0304	* 3.2452	* 3.3813	* 2.7424	* 3.1122	* 2.6621	* 6.0617 *
12	* 1.5702	* 1.8552	* 1.5335	* 1.7606	* 1.6266	* 1.8296	* 1.1671	*
	* 2.8312	* 2.4327	* 3.0501	* 2.7426	* 2.9671	* 2.6347	* 4.1639	*
13	* 1.8557	* 1.6642	* 1.8272	* 1.5620	* 1.8294	* 1.7743	* .7795	*
	* 2.3958	* 2.6852	* 2.5247	* 3.1129	* 2.6351	* 2.7116	* 6.1880	*
14	* 1.3857	* 1.9039	* 1.8615	* 1.8369	* 1.1664	* .7795	*	
	* 3.1879	* 2.3801	* 2.4896	* 2.6630	* 4.1662	* 6.1880	*	
15	* .7385	* .9557	* .9028	* .7829	* F-SUB-Q			
	* 5.9627	* 4.6863	* 5.0177	* 6.0637	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1898	* 1.8242	* 1.5021	* 1.8316	* 1.5741	* 1.8759	* 1.3883	* .7404 *
	* 3.9035	* 2.5529	* 2.9956	* 2.3967	* 2.7680	* 2.3280	* 3.1196	* 5.8115 *
9	* 1.8242	* 1.4699	* 1.8153	* 1.4918	* 1.8796	* 1.6733	* 1.9335	* .9599 *
	* 2.5529	* 3.1570	* 2.5054	* 2.9563	* 2.3630	* 2.6250	* 2.3164	* 4.5791 *
10	* 1.5021	* 1.8143	* 1.2581	* 1.4360	* 1.5479	* 1.8600	* 1.8972	* .8977 *
	* 2.9956	* 2.5072	* 3.6065	* 3.1665	* 2.9857	* 2.4599	* 2.4227	* 4.9608 *
11	* 1.8316	* 1.4918	* 1.4335	* 1.4664	* 1.8274	* 1.5978	* 1.8768	* .7801 *
	* 2.3967	* 2.9562	* 3.1737	* 3.1974	* 2.5843	* 2.9462	* 2.5122	* 5.9892 *
12	* 1.5741	* 1.8790	* 1.5473	* 1.8272	* 1.6832	* 1.9064	* 1.1847	*
	* 2.7680	* 2.3634	* 2.9868	* 2.5845	* 2.8118	* 2.4753	* 3.9605	*
13	* 1.8759	* 1.6728	* 1.8595	* 1.5974	* 1.9062	* 1.8525	* .8050	*
	* 2.3280	* 2.6259	* 2.4607	* 2.9466	* 2.4757	* 2.5435	* 5.7909	*
14	* 1.3883	* 1.9329	* 1.8966	* 1.8763	* 1.1840	* .8050	*	
	* 3.1196	* 2.3171	* 2.4235	* 2.5128	* 3.9628	* 5.7909	*	
15	* .7404	* .9598	* .8975	* .7799	* F-SUB-Q			
	* 5.8115	* 4.5796	* 4.9622	* 5.9910	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 176 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1809	* 1.8231	* 1.4941	* 1.8226	* 1.5616	* 1.8682	* 1.3774	* .7309 *
	* 3.6199	* 2.3458	* 2.7428	* 2.1991	* 2.5523	* 2.1410	* 2.8794	* 5.3802 *
9	* 1.8231	* 1.4618	* 1.8097	* 1.4796	* 1.8737	* 1.6631	* 1.9322	* .9527 *
	* 2.3458	* 2.9122	* 2.2847	* 2.7164	* 2.1697	* 2.4187	* 2.1264	* 4.2167 *
10	* 1.4941	* 1.8087	* 1.2432	* 1.4268	* 1.5417	* 1.8634	* 1.9004	* .8899 *
	* 2.7428	* 2.2864	* 3.3038	* 2.8964	* 2.7370	* 2.2524	* 2.2144	* 4.5700 *
11	* 1.8226	* 1.4797	* 1.4247	* 1.4721	* 1.8459	* 1.6070	* 1.8844	* .7751 *
	* 2.1991	* 2.7163	* 2.9030	* 2.9399	* 2.3704	* 2.7110	* 2.3068	* 5.5199 *
12	* 1.5616	* 1.8732	* 1.5411	* 1.8457	* 1.6979	* 1.9310	* 1.1881	*
	* 2.5523	* 2.1703	* 2.7380	* 2.3706	* 2.5834	* 2.2695	* 3.6540	*
13	* 1.8682	* 1.6625	* 1.8628	* 1.6067	* 1.9308	* 1.8808	* .8106	*
	* 2.1410	* 2.4195	* 2.2531	* 2.7114	* 2.2699	* 2.3335	* 5.3519	*
14	* 1.3774	* 1.9316	* 1.8998	* 1.8838	* 1.1872	* .8105	*	
	* 2.8794	* 2.1271	* 2.2151	* 2.3074	* 3.6566	* 5.3520	*	
15	* .7309	* .9526	* .8897	* .7748	* F-SUB-Q			
	* 5.3802	* 4.2171	* 4.5713	* 5.5218	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1645	* 1.7988	* 1.4727	* 1.7956	* 1.5374	* 1.8416	* 1.3567	* .7199 *
	* 3.3672	* 2.1792	* 2.5281	* 2.0272	* 2.3563	* 1.9742	* 2.6597	* 4.9763 *
9	* 1.7988	* 1.4403	* 1.7842	* 1.4566	* 1.8482	* 1.6393	* 1.9094	* .9397 *
	* 2.1792	* 2.6939	* 2.1029	* 2.5064	* 1.9993	* 2.2304	* 1.9580	* 3.8935 *
10	* 1.4727	* 1.7832	* 1.2293	* 1.4071	* 1.5215	* 1.8446	* 1.8797	* .8798 *
	* 2.5281	* 2.1044	* 3.0459	* 2.6669	* 2.5211	* 2.0721	* 2.0362	* 4.2110 *
11	* 1.7956	* 1.4567	* 1.4049	* 1.4598	* 1.8350	* 1.5953	* 1.8678	* .7675 *
	* 2.0272	* 2.5063	* 2.6729	* 2.7353	* 2.2041	* 2.5221	* 2.1418	* 5.0770 *
12	* 1.5374	* 1.8476	* 1.5209	* 1.8348	* 1.6874	* 1.9222	* 1.1832	*
	* 2.3563	* 1.9999	* 2.5221	* 2.2043	* 2.4023	* 2.1099	* 3.3933	*
13	* 1.8416	* 1.6387	* 1.8440	* 1.5949	* 1.9219	* 1.8755	* .8068	*
	* 1.9742	* 2.2312	* 2.0728	* 2.5226	* 2.1102	* 2.1693	* 4.9873	*
14	* 1.3567	* 1.9088	* 1.8791	* 1.8673	* 1.1824	* .8068	*	
	* 2.6597	* 1.9587	* 2.0370	* 2.1425	* 3.3954	* 4.9873	*	
15	* .7199	* .9396	* .8795	* .7672	* F-SUB-Q			
	* 4.9763	* 3.8940	* 4.2123	* 5.0788	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 177 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1347	* 1.7478	* 1.4361	* 1.7461	* 1.4986	* 1.7899	* 1.3236	* .7010 *
	* 3.1551	* 2.0474	* 2.3700	* 1.9073	* 2.2131	* 1.8582	* 2.4989	* 4.6913 *
9	* 1.7478	* 1.4040	* 1.7333	* 1.4196	* 1.7969	* 1.5987	* 1.8601	* .9215 *
	* 2.0474	* 2.5235	* 1.9772	* 2.3525	* 1.8817	* 2.0938	* 1.8403	* 3.6418 *
10	* 1.4361	* 1.7324	* 1.2141	* 1.3738	* 1.4845	* 1.8009	* 1.8312	* .8686 *
	* 2.3700	* 1.9786	* 2.8229	* 2.4951	* 2.3611	* 1.9439	* 1.9120	* 3.9105 *
11	* 1.7461	* 1.4197	* 1.3728	* 1.4300	* 1.7948	* 1.5623	* 1.8252	* .7615 *
	* 1.9073	* 2.3523	* 2.4985	* 2.5638	* 2.0769	* 2.3692	* 2.0084	* 4.6826 *
12	* 1.4986	* 1.7963	* 1.4839	* 1.7946	* 1.6533	* 1.8794	* 1.1683	*
	* 2.2131	* 1.8822	* 2.3620	* 2.0771	* 2.2593	* 1.9921	* 3.1655	*
13	* 1.7899	* 1.5981	* 1.8003	* 1.5620	* 1.8791	* 1.8376	* .7922	*
	* 1.8582	* 2.0945	* 1.9446	* 2.3699	* 1.9924	* 2.0461	* 4.7000	*
14	* 1.3236	* 1.8595	* 1.8306	* 1.8246	* 1.1676	* .7922	*	
	* 2.4989	* 1.8410	* 1.9127	* 2.0090	* 3.1674	* 4.7000	*	
15	* .7010	* .9214	* .8683	* .7613	* F-SUB-Q			
	* 4.6913	* 3.6423	* 3.9118	* 4.6844	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1150	* 1.7320	* 1.4117	* 1.7283	* 1.4726	* 1.7733	* 1.2999	* .6896 *
	* 2.9452	* 1.8804	* 2.2197	* 1.7768	* 2.0780	* 1.7315	* 2.3508	* 4.4127 *
9	* 1.7320	* 1.3791	* 1.7177	* 1.3945	* 1.7807	* 1.5743	* 1.8469	* .9031 *
	* 1.8804	* 2.3425	* 1.8344	* 2.2069	* 1.7509	* 1.9612	* 1.7086	* 3.4336 *
10	* 1.4117	* 1.7168	* 1.1725	* 1.3518	* 1.4612	* 1.7860	* 1.8196	* .8414 *
	* 2.2197	* 1.8357	* 2.6748	* 2.3332	* 2.2080	* 1.8059	* 1.7716	* 3.7274 *
11	* 1.7283	* 1.3946	* 1.3489	* 1.4086	* 1.7824	* 1.5424	* 1.8120	* .7356 *
	* 1.7768	* 2.2067	* 2.3385	* 2.3982	* 1.9192	* 2.2058	* 1.8444	* 4.4615 *
12	* 1.4726	* 1.7801	* 1.4607	* 1.7823	* 1.6353	* 1.8711	* 1.1397	*
	* 2.0780	* 1.7514	* 2.2089	* 1.9194	* 2.0908	* 1.8381	* 2.9938	*
13	* 1.7733	* 1.5737	* 1.7854	* 1.5421	* 1.8708	* 1.8320	* .7819	*
	* 1.7315	* 1.9620	* 1.8065	* 2.2065	* 1.8384	* 1.8877	* 4.3862	*
14	* 1.2999	* 1.8463	* 1.8190	* 1.8114	* 1.1389	* .7819	*	
	* 2.3508	* 1.7092	* 1.7723	* 1.8450	* 2.9960	* 4.3863	*	
15	* .6896	* .9030	* .8411	* .7353	* F-SUB-Q			
	* 4.4127	* 3.4340	* 3.7287	* 4.4632	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 178 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0775 *	* 1.6751 *	* 1.3660 *	* 1.6731 *	* 1.4246 *	* 1.7163 *	* 1.2573 *	* .6670 *
	* 2.7726 *	* 1.7890 *	* 2.1290 *	* 1.7085 *	* 2.0013 *	* 1.6666 *	* 2.2676 *	* 4.2628 *
9	* 1.6751 *	* 1.3340 *	* 1.6621 *	* 1.3491 *	* 1.7228 *	* 1.5242 *	* 1.7895 *	* .8745 *
	* 1.7890 *	* 2.2352 *	* 1.7572 *	* 2.1216 *	* 1.6839 *	* 1.8865 *	* 1.6404 *	* 3.3078 *
10	* 1.3660 *	* 1.6612 *	* 1.1349 *	* 1.3115 *	* 1.4154 *	* 1.7302 *	* 1.7616 *	* .8134 *
	* 2.1290 *	* 1.7584 *	* 2.5612 *	* 2.2300 *	* 2.1130 *	* 1.7320 *	* 1.6990 *	* 3.5929 *
11	* 1.6731 *	* 1.3493 *	* 1.3084 *	* 1.3659 *	* 1.7294 *	* 1.4958 *	* 1.7574 *	* .7116 *
	* 1.7085 *	* 2.1214 *	* 2.2351 *	* 2.2600 *	* 1.8137 *	* 2.0890 *	* 1.7592 *	* 4.2714 *
12	* 1.4246 *	* 1.7222 *	* 1.4149 *	* 1.7293 *	* 1.5873 *	* 1.8149 *	* 1.1042 *	
	* 2.0013 *	* 1.6844 *	* 2.1138 *	* 1.8139 *	* 1.9736 *	* 1.7421 *	* 2.8323 *	
13	* 1.7163 *	* 1.5236 *	* 1.7296 *	* 1.4954 *	* 1.8146 *	* 1.7805 *	* .7576 *	
	* 1.6666 *	* 1.8872 *	* 1.7326 *	* 2.0894 *	* 1.7424 *	* 1.7915 *	* 4.1744 *	
14	* 1.2573 *	* 1.7889 *	* 1.7610 *	* 1.7569 *	* 1.1034 *	* .7576 *		
	* 2.2676 *	* 1.6410 *	* 1.6996 *	* 1.7598 *	* 2.8345 *	* 4.1745 *		
15	* .6670 *	* .8744 *	* .8131 *	* .7113 *	* F-SUB-Q			
	* 4.2628 *	* 3.3082 *	* 3.5942 *	* 4.2731 *	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0177 *	* 1.5687 *	* 1.2946 *	* 1.5719 *	* 1.3492 *	* 1.6116 *	* 1.1914 *	* .6296 *
	* 2.7486 *	* 1.7798 *	* 2.1050 *	* 1.7109 *	* 1.9902 *	* 1.6718 *	* 2.2572 *	* 4.2655 *
9	* 1.5687 *	* 1.2646 *	* 1.5583 *	* 1.2793 *	* 1.6172 *	* 1.4423 *	* 1.6784 *	* .8313 *
	* 1.7798 *	* 2.1829 *	* 1.7533 *	* 2.1034 *	* 1.6851 *	* 1.8764 *	* 1.6435 *	* 3.2798 *
10	* 1.2946 *	* 1.5575 *	* 1.0983 *	* 1.2468 *	* 1.3417 *	* 1.6241 *	* 1.6474 *	* .7820 *
	* 2.1050 *	* 1.7544 *	* 2.4863 *	* 2.1956 *	* 2.0821 *	* 1.7304 *	* 1.7025 *	* 3.5184 *
11	* 1.5719 *	* 1.2794 *	* 1.2445 *	* 1.2974 *	* 1.6277 *	* 1.4177 *	* 1.6523 *	* .6874 *
	* 1.7109 *	* 2.1032 *	* 2.2006 *	* 2.2231 *	* 1.7943 *	* 2.0555 *	* 1.7409 *	* 4.1270 *
12	* 1.3492 *	* 1.6167 *	* 1.3412 *	* 1.6275 *	* 1.5032 *	* 1.7018 *	* 1.0586 *	
	* 1.9902 *	* 1.6857 *	* 2.0829 *	* 1.7945 *	* 1.9386 *	* 1.7280 *	* 2.7619 *	
13	* 1.6116 *	* 1.4418 *	* 1.6235 *	* 1.4174 *	* 1.7015 *	* 1.6736 *	* .7163 *	
	* 1.6718 *	* 1.8771 *	* 1.7311 *	* 2.0560 *	* 1.7283 *	* 1.7696 *	* 4.1114 *	
14	* 1.1914 *	* 1.6778 *	* 1.6468 *	* 1.6518 *	* 1.0579 *	* .7163 *		
	* 2.2572 *	* 1.6442 *	* 1.7032 *	* 1.7415 *	* 2.7637 *	* 4.1115 *		
15	* .6296 *	* .8312 *	* .7817 *	* .6872 *	* F-SUB-Q			
	* 4.2655 *	* 3.2804 *	* 3.5197 *	* 4.1287 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 179 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9616	* 1.4763	* 1.2233	* 1.4814	* 1.2742	* 1.5186	* 1.1231	* .5946
	* 2.7126	* 1.7641	* 2.1074	* 1.7250	* 2.0043	* 1.6876	* 2.2807	* 4.3090
9	* 1.4763	* 1.1955	* 1.4678	* 1.2091	* 1.5248	* 1.3629	* 1.5807	* .7821
	* 1.7641	* 2.1656	* 1.7580	* 2.1127	* 1.6970	* 1.8875	* 1.6560	* 3.3186
10	* 1.2233	* 1.4671	* 1.0266	* 1.1864	* 1.2720	* 1.5245	* 1.5467	* .7276
	* 2.1074	* 1.7591	* 2.5066	* 2.1817	* 2.0749	* 1.7426	* 1.7161	* 3.5946
11	* 1.4814	* 1.2093	* 1.1837	* 1.2281	* 1.5359	* 1.3411	* 1.5554	* .6385
	* 1.7250	* 2.1124	* 2.1866	* 2.2165	* 1.8051	* 2.0494	* 1.7392	* 4.2018
12	* 1.2742	* 1.5243	* 1.2715	* 1.5357	* 1.4232	* 1.6025	* .9884	*
	* 2.0043	* 1.6976	* 2.0757	* 1.8053	* 1.9433	* 1.7405	* 2.8010	*
13	* 1.5186	* 1.3624	* 1.5240	* 1.3408	* 1.6023	* 1.5784	* .6759	*
	* 1.6876	* 1.8882	* 1.7432	* 2.0501	* 1.7407	* 1.7776	* 4.1362	*
14	* 1.1231	* 1.5802	* 1.5462	* 1.5549	* .9877	* .6759	*	*
	* 2.2807	* 1.6567	* 1.7168	* 1.7399	* 2.8029	* 4.1361	*	*
15	* .5946	* .7820	* .7273	* .6383	* F-SUB-Q			
	* 4.3090	* 3.3195	* 3.5962	* 4.2035	* M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8691	* 1.3066	* 1.0986	* 1.3128	* 1.1439	* 1.3459	* 1.0071	* .5331
	* 2.8464	* 1.8993	* 2.2442	* 1.8707	* 2.1477	* 1.8316	* 2.4502	* 4.6376
9	* 1.3066	* 1.0757	* 1.2989	* 1.0864	* 1.3544	* 1.2244	* 1.3993	* .7021
	* 1.8993	* 2.2989	* 1.8987	* 2.2588	* 1.8345	* 2.0203	* 1.7958	* 3.5601
10	* 1.0986	* 1.2985	* .9350	* 1.0703	* 1.1535	* 1.3526	* 1.3706	* .6560
	* 2.2442	* 1.8992	* 2.6318	* 2.3180	* 2.1892	* 1.8809	* 1.8603	* 3.8345
11	* 1.3128	* 1.0865	* 1.0692	* 1.1086	* 1.3667	* 1.2079	* 1.3777	* .5754
	* 1.8707	* 2.2585	* 2.3230	* 2.3261	* 1.9173	* 2.1592	* 1.8757	* 4.4714
12	* 1.1439	* 1.3541	* 1.1531	* 1.3666	* 1.2812	* 1.4167	* .8812	*
	* 2.1477	* 1.8351	* 2.1900	* 1.9174	* 2.0419	* 1.8676	* 2.9812	*
13	* 1.3459	* 1.2239	* 1.3521	* 1.2076	* 1.4165	* 1.3949	* .6073	*
	* 1.8316	* 2.0210	* 1.8816	* 2.1599	* 1.8679	* 1.9183	* 4.3922	*
14	* 1.0071	* 1.3989	* 1.3701	* 1.3773	* .8806	* .6072	*	*
	* 2.4502	* 1.7966	* 1.8610	* 1.8763	* 2.9833	* 4.3924	*	*
15	* .5331	* .7020	* .6558	* .5752	* F-SUB-Q			
	* 4.6376	* 3.5607	* 3.8360	* 4.4732	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 180 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7176 *	* 1.0961 *	* .8410 *	* 1.0936 *	* .8757 *	* 1.1237 *	* .7857 *	* .4294 *
	* 3.3339 *	* 2.1830 *	* 2.8289 *	* 2.1775 *	* 2.7238 *	* 2.1324 *	* 3.0605 *	* 5.6089 *
9	* 1.0961 *	* .8262 *	* 1.0865 *	* .8333 *	* 1.1315 *	* .9573 *	* 1.1368 *	* .5607 *
	* 2.1830 *	* 2.8860 *	* 2.1939 *	* 2.8576 *	* 2.1233 *	* 2.5070 *	* 2.1400 *	* 4.3346 *
10	* .8410 *	* 1.0864 *	* .7785 *	* .8599 *	* .9356 *	* 1.1435 *	* 1.1386 *	* .5337 *
	* 2.8289 *	* 2.1940 *	* 3.0625 *	* 2.8113 *	* 2.6149 *	* 2.1489 *	* 2.1578 *	* 4.5912 *
11	* 1.0936 *	* .8333 *	* .8593 *	* .8735 *	* 1.1448 *	* .9505 *	* 1.0761 *	* .4622 *
	* 2.1775 *	* 2.8574 *	* 2.8137 *	* 2.8640 *	* 2.1995 *	* 2.6485 *	* 2.3234 *	* 5.3963 *
12	* .8757 *	* 1.1313 *	* .9353 *	* 1.1446 *	* 1.0315 *	* 1.1822 *	* .6991 *	
	* 2.7238 *	* 2.1238 *	* 2.6158 *	* 2.1999 *	* 2.4406 *	* 2.1509 *	* 3.6265 *	
13	* 1.1237 *	* .9570 *	* 1.1432 *	* .9503 *	* 1.1821 *	* 1.0860 *	* .4897 *	
	* 2.1324 *	* 2.5078 *	* 2.1496 *	* 2.6493 *	* 2.1512 *	* 2.3635 *	* 5.2438 *	
14	* .7857 *	* 1.1365 *	* 1.1383 *	* 1.0758 *	* .6987 *	* .4897 *		
	* 3.0605 *	* 2.1408 *	* 2.1585 *	* 2.3242 *	* 3.6286 *	* 5.2445 *		
15	* .4294 *	* .5606 *	* .5335 *	* .4621 *	F-SUB-Q			
	* 5.6089 *	* 4.3355 *	* 4.5930 *	* 5.3984 *	M-SUB-Q			

AT 50% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .4940 *	* .4374 *	* .3747 *	* .4432 *	* .3914 *	* .4543 *	* .3563 *	* .2865 *
	* 4.6984 *	* 5.2830 *	* 6.1664 *	* 5.2112 *	* 5.9435 *	* 5.1158 *	* 6.5602 *	* 8.2006 *
9	* .4374 *	* .3715 *	* .4330 *	* .3777 *	* .4588 *	* .4062 *	* .4247 *	* .2567 *
	* 5.2830 *	* 6.2199 *	* 5.3310 *	* 6.1325 *	* 5.0818 *	* 5.7306 *	* 5.5542 *	* 9.2510 *
10	* .3747 *	* .4332 *	* .3767 *	* .3695 *	* .4015 *	* .4629 *	* .4391 *	* .2496 *
	* 6.1664 *	* 5.3288 *	* 6.1466 *	* 6.3447 *	* 5.8948 *	* 5.1225 *	* 5.4212 *	* 9.5232 *
11	* .4432 *	* .3777 *	* .3693 *	* .3992 *	* .4655 *	* .4065 *	* .4045 *	* .2192 *
	* 5.2112 *	* 6.1313 *	* 6.3481 *	* 6.0776 *	* 5.2324 *	* 5.9691 *	* 5.9883 *	* 11.0537 *
12	* .3914 *	* .4587 *	* .4014 *	* .4655 *	* .4305 *	* .4455 *	* .3130 *	
	* 5.9436 *	* 5.0829 *	* 5.8967 *	* 5.2331 *	* 5.6627 *	* 5.5195 *	* 7.8570 *	
13	* .4543 *	* .4061 *	* .4627 *	* .4064 *	* .4455 *	* .4087 *	* .3274 *	
	* 5.1158 *	* 5.7320 *	* 5.1242 *	* 5.9709 *	* 5.5202 *	* 6.0624 *	* 7.6091 *	
14	* .3563 *	* .4245 *	* .4390 *	* .4044 *	* .3131 *	* .3274 *		
	* 6.5602 *	* 5.5562 *	* 5.4230 *	* 5.9903 *	* 7.8550 *	* 7.6108 *		
15	* .2865 *	* .2566 *	* .2495 *	* .2191 *	F-SUB-Q			
	* 8.2006 *	* 9.2541 *	* 9.5268 *	* 11.0580 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 181 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .4973 *	* .4931 *	* .4628 *	* .5676 *	* .5076 *	* .5604 *	* .3973 *	* .3198 *
	* 4.1500 *	* 4.7864 *	* 5.1218 *	* 4.2744 *	* 4.7618 *	* 4.1884 *	* 5.2043 *	* 5.9403 *
9	* .4931 *	* .4331 *	* .5127 *	* .4840 *	* .5769 *	* .5084 *	* .5053 *	* .3291 *
	* 4.7864 *	* 5.2966 *	* 4.4978 *	* 5.0019 *	* 4.2007 *	* 4.6833 *	* 4.6055 *	* 7.0804 *
10	* .4628 *	* .5128 *	* .3936 *	* .4521 *	* .4909 *	* .5583 *	* .5247 *	* .3170 *
	* 5.1218 *	* 4.4973 *	* 5.2110 *	* 5.2620 *	* 4.9724 *	* 4.3747 *	* 4.6106 *	* 7.4380 *
11	* .5676 *	* .4842 *	* .4519 *	* .3987 *	* .4903 *	* .4532 *	* .4732 *	* .2824 *
	* 4.2744 *	* 5.0012 *	* 5.2641 *	* 5.3855 *	* 4.5957 *	* 5.2005 *	* 5.0069 *	* 8.3717 *
12	* .5076 *	* .5768 *	* .4909 *	* .4903 *	* .3582 *	* .3970 *	* .3338 *	
	* 4.7618 *	* 4.2008 *	* 4.9729 *	* 4.5959 *	* 4.8200 *	* 4.7783 *	* 6.7512 *	
13	* .5604 *	* .5084 *	* .5583 *	* .4531 *	* .3970 *	* .3497 *	* .3376 *	
	* 4.1884 *	* 4.6832 *	* 4.3748 *	* 5.2006 *	* 4.7784 *	* 5.1819 *	* 6.0347 *	
14	* .3973 *	* .5054 *	* .5247 *	* .4732 *	* .3339 *	* .3375 *		
	* 5.2043 *	* 4.6036 *	* 4.6100 *	* 5.0069 *	* 6.7491 *	* 6.0367 *		
15	* .3198 *	* .3292 *	* .3170 *	* .2825 *	F-SUB-Q			
	* 5.9403 *	* 7.0763 *	* 7.4353 *	* 8.3715 *	M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6606 *	* 1.1007 *	* 1.0211 *	* 1.2593 *	* 1.1192 *	* 1.2552 *	* .8338 *	* .4704 *
	* 3.0498 *	* 2.2456 *	* 2.4243 *	* 2.0102 *	* 2.2492 *	* 1.9624 *	* 2.5314 *	* 4.3906 *
9	* 1.1007 *	* .9482 *	* 1.1481 *	* 1.0584 *	* 1.2829 *	* 1.1325 *	* 1.2167 *	* .6740 *
	* 2.2456 *	* 2.5213 *	* 2.0995 *	* 2.3700 *	* 1.9728 *	* 2.1985 *	* 2.0077 *	* 3.5405 *
10	* 1.0211 *	* 1.1481 *	* .7732 *	* .9661 *	* 1.0731 *	* 1.2397 *	* 1.2199 *	* .6535 *
	* 2.4243 *	* 2.0998 *	* 2.7088 *	* 2.5283 *	* 2.3642 *	* 2.0448 *	* 2.0621 *	* 3.7598 *
11	* 1.2593 *	* 1.0585 *	* .9658 *	* .8531 *	* 1.0832 *	* .9955 *	* 1.1247 *	* .5758 *
	* 2.0102 *	* 2.3700 *	* 2.5302 *	* 2.6243 *	* 2.1364 *	* 2.4423 *	* 2.2059 *	* 4.2906 *
12	* 1.1192 *	* 1.2828 *	* 1.0730 *	* 1.0831 *	* .7650 *	* .9405 *	* .6988 *	
	* 2.2492 *	* 1.9729 *	* 2.3645 *	* 2.1365 *	* 2.2932 *	* 2.0759 *	* 3.3146 *	
13	* 1.2552 *	* 1.1325 *	* 1.2397 *	* .9954 *	* .9405 *	* .8479 *	* .4658 *	
	* 1.9624 *	* 2.1985 *	* 2.0447 *	* 2.4424 *	* 2.0759 *	* 2.2559 *	* 4.4841 *	
14	* .8338 *	* 1.2169 *	* 1.2199 *	* 1.1247 *	* .6987 *	* .4658 *		
	* 2.5314 *	* 2.0071 *	* 2.0619 *	* 2.2059 *	* 3.3150 *	* 4.4843 *		
15	* .4704 *	* .6742 *	* .6536 *	* .5758 *	F-SUB-Q			
	* 4.3906 *	* 3.5388 *	* 3.7588 *	* 4.2905 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 182 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7878	* 1.3190	* 1.2329	* 1.4955	* 1.3533	* 1.5107	* 1.1020	* .6200 *
	* 2.6958	* 1.9546	* 2.0965	* 1.7569	* 1.9306	* 1.7130	* 2.1497	* 3.7875 *
9	* 1.3190	* 1.1461	* 1.3797	* 1.2738	* 1.5178	* 1.3917	* 1.4938	* .8297 *
	* 1.9546	* 2.1948	* 1.8347	* 2.0461	* 1.7280	* 1.8607	* 1.7192	* 3.0332 *
10	* 1.2329	* 1.3795	* .9904	* 1.1863	* 1.2827	* 1.4516	* 1.4694	* .8001 *
	* 2.0965	* 1.8353	* 2.3920	* 2.1824	* 2.0441	* 1.8039	* 1.7771	* 3.2042 *
11	* 1.4955	* 1.2739	* 1.1857	* 1.0263	* 1.2984	* 1.1986	* 1.3944	* .6955 *
	* 1.7569	* 2.0461	* 2.1836	* 2.2633	* 1.8854	* 2.0665	* 1.8339	* 3.6657 *
12	* 1.3533	* 1.5177	* 1.2826	* 1.2982	* .9290	* 1.1218	* .8623	*
	* 1.9306	* 1.7281	* 2.0444	* 1.8855	* 1.9707	* 1.8021	* 2.7534	*
13	* 1.5107	* 1.3915	* 1.4515	* 1.1985	* 1.1217	* 1.0436	* .5532	*
	* 1.7130	* 1.8609	* 1.8040	* 2.0666	* 1.8022	* 1.8797	* 3.8643	*
14	* 1.1020	* 1.4939	* 1.4694	* 1.3943	* .8621	* .5532	*	
	* 2.1497	* 1.7189	* 1.7770	* 1.8340	* 2.7539	* 3.8642	*	
15	* .6200	* .8300	* .8002	* .6955	* F-SUB-Q			
	* 3.7875	* 3.0322	* 3.2036	* 3.6657	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8647	* 1.4979	* 1.3607	* 1.6979	* 1.4967	* 1.7383	* 1.3032	* .7305 *
	* 2.5830	* 1.8040	* 1.9920	* 1.6140	* 1.8247	* 1.5652	* 2.0269	* 3.5740 *
9	* 1.4979	* 1.2681	* 1.5878	* 1.4020	* 1.7310	* 1.5577	* 1.7245	* .9282 *
	* 1.8040	* 2.1003	* 1.6900	* 1.9440	* 1.5808	* 1.7442	* 1.5654	* 2.8787 *
10	* 1.3607	* 1.5870	* 1.1243	* 1.2987	* 1.4112	* 1.6628	* 1.6895	* .8733 *
	* 1.9920	* 1.6908	* 2.3160	* 2.0792	* 1.9334	* 1.6420	* 1.6112	* 3.0853 *
11	* 1.6979	* 1.4021	* 1.2980	* 1.1287	* 1.4670	* 1.3167	* 1.5774	* .7446 *
	* 1.6140	* 1.9439	* 2.0811	* 2.1450	* 1.7316	* 1.9423	* 1.6735	* 3.5412 *
12	* 1.4967	* 1.7308	* 1.4110	* 1.4668	* 1.0260	* 1.2644	* .9391	*
	* 1.8247	* 1.5809	* 1.9337	* 1.7317	* 1.8467	* 1.6418	* 2.6094	*
13	* 1.7383	* 1.5575	* 1.6627	* 1.3166	* 1.2643	* 1.1784	* .6034	*
	* 1.5652	* 1.7445	* 1.6421	* 1.9424	* 1.6419	* 1.7176	* 3.6526	*
14	* 1.3032	* 1.7246	* 1.6895	* 1.5773	* .9389	* .6034	*	
	* 2.0269	* 1.5652	* 1.6112	* 1.6736	* 2.6101	* 3.6525	*	
15	* .7305	* .9284	* .8734	* .7445	* F-SUB-Q			
	* 3.5740	* 2.8780	* 3.0849	* 3.5413	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 183 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8948	* 1.5737	* 1.4129	* 1.7851	* 1.5566	* 1.8439	* 1.3855	* .7743
	* 2.6507	* 1.8139	* 2.0288	* 1.6146	* 1.8443	* 1.5545	* 2.0506	* 3.6414
9	* 1.5737	* 1.3246	* 1.6807	* 1.4528	* 1.8285	* 1.6290	* 1.8363	* .9730
	* 1.8139	* 2.1478	* 1.6987	* 1.9780	* 1.5700	* 1.7560	* 1.5486	* 2.9093
10	* 1.4129	* 1.6798	* 1.1906	* 1.3506	* 1.4638	* 1.7680	* 1.7930	* .9130
	* 2.0288	* 1.6996	* 2.3798	* 2.1188	* 1.9504	* 1.6123	* 1.5852	* 3.1031
11	* 1.7851	* 1.4530	* 1.3498	* 1.1708	* 1.5383	* 1.3622	* 1.6579	* .7685
	* 1.6146	* 1.9778	* 2.1200	* 2.1659	* 1.7141	* 1.9591	* 1.6534	* 3.5674
12	* 1.5566	* 1.8282	* 1.4636	* 1.5381	* 1.0701	* 1.3223	* .9732	*
	* 1.8443	* 1.5702	* 1.9507	* 1.7143	* 1.8577	* 1.6298	* 2.6216	*
13	* 1.8439	* 1.6287	* 1.7678	* 1.3621	* 1.3222	* 1.2308	* .6194	*
	* 1.5545	* 1.7564	* 1.6125	* 1.9592	* 1.6299	* 1.7102	* 3.7021	*
14	* 1.3855	* 1.8363	* 1.7929	* 1.6577	* .9728	* .6194	*	*
	* 2.0506	* 1.5485	* 1.5853	* 1.6534	* 2.6224	* 3.7020	*	*
15	* .7743	* .9732	* .9130	* .7684	* F-SUB-Q			
	* 3.6414	* 2.9087	* 3.1029	* 3.5675	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9060	* 1.5979	* 1.4278	* 1.8131	* 1.5748	* 1.8838	* 1.4116	* .7895
	* 2.7753	* 1.8966	* 2.1270	* 1.6754	* 1.9185	* 1.6037	* 2.1278	* 3.7808
9	* 1.5979	* 1.3389	* 1.7098	* 1.4667	* 1.8626	* 1.6525	* 1.8776	* .9893
	* 1.8966	* 2.2634	* 1.7736	* 2.0679	* 1.6183	* 1.8238	* 1.5949	* 3.0194
10	* 1.4278	* 1.7088	* 1.2121	* 1.3697	* 1.4799	* 1.8104	* 1.8331	* .9311
	* 2.1270	* 1.7747	* 2.5044	* 2.2048	* 2.0144	* 1.6391	* 1.6148	* 3.1949
11	* 1.8131	* 1.4668	* 1.3689	* 1.1843	* 1.5633	* 1.3756	* 1.6870	* .7796
	* 1.6754	* 2.0677	* 2.2060	* 2.2492	* 1.7671	* 2.0370	* 1.6998	* 3.6799
12	* 1.5748	* 1.8623	* 1.4797	* 1.5630	* 1.0873	* 1.3408	* .9870	*
	* 1.9185	* 1.6185	* 2.0147	* 1.7672	* 1.9305	* 1.6868	* 2.7099	*
13	* 1.8838	* 1.6521	* 1.8102	* 1.3754	* 1.3406	* 1.2464	* .6246	*
	* 1.6037	* 1.8241	* 1.6392	* 2.0372	* 1.6869	* 1.7765	* 3.8640	*
14	* 1.4116	* 1.8776	* 1.8330	* 1.6869	* .9867	* .6246	*	*
	* 2.1278	* 1.5950	* 1.6149	* 1.6999	* 2.7108	* 3.8639	*	*
15	* .7895	* .9894	* .9311	* .7795	* F-SUB-Q			
	* 3.7808	* 3.0189	* 3.1948	* 3.6801	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 184 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9084 *	* 1.6162 *	* 1.4324 *	* 1.8336 *	* 1.5816 *	* 1.9120 *	* 1.4205 *	* .7945 *
	* 2.9197 *	* 1.9654 *	* 2.2369 *	* 1.7345 *	* 1.9964 *	* 1.6497 *	* 2.2144 *	* 3.9383 *
9	* 1.6162 *	* 1.3420 *	* 1.7295 *	* 1.4702 *	* 1.8878 *	* 1.6631 *	* 1.9072 *	* .9966 *
	* 1.9654 *	* 2.3981 *	* 1.8554 *	* 2.1615 *	* 1.6694 *	* 1.8902 *	* 1.6338 *	* 3.1229 *
10	* 1.4324 *	* 1.7285 *	* 1.2071 *	* 1.3674 *	* 1.4863 *	* 1.8418 *	* 1.8633 *	* .9320 *
	* 2.2369 *	* 1.8565 *	* 2.6628 *	* 2.3115 *	* 2.1045 *	* 1.6863 *	* 1.6611 *	* 3.3266 *
11	* 1.8336 *	* 1.4703 *	* 1.3666 *	* 1.1900 *	* 1.5818 *	* 1.3839 *	* 1.7073 *	* .7778 *
	* 1.7345 *	* 2.1612 *	* 2.3128 *	* 2.3674 *	* 1.8418 *	* 2.1444 *	* 1.7716 *	* 3.8854 *
12	* 1.5816 *	* 1.8876 *	* 1.4860 *	* 1.5816 *	* 1.0962 *	* 1.3585 *	* .9885 *	
	* 1.9964 *	* 1.6696 *	* 2.1048 *	* 1.8419 *	* 2.0284 *	* 1.7589 *	* 2.8628 *	
13	* 1.9120 *	* 1.6627 *	* 1.8416 *	* 1.3837 *	* 1.3583 *	* 1.2640 *	* .6297 *	
	* 1.6497 *	* 1.8906 *	* 1.6865 *	* 2.1446 *	* 1.7590 *	* 1.8543 *	* 4.0563 *	
14	* 1.4205 *	* 1.9071 *	* 1.8632 *	* 1.7071 *	* .9881 *	* .6297 *		
	* 2.2144 *	* 1.6339 *	* 1.6612 *	* 1.7717 *	* 2.8638 *	* 4.0562 *		
15	* .7945 *	* .9967 *	* .9320 *	* .7777 *	F-SUB-Q			
	* 3.9383 *	* 3.1225 *	* 3.3266 *	* 3.8856 *	M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9030 *	* 1.6132 *	* 1.4223 *	* 1.8277 *	* 1.5710 *	* 1.9102 *	* 1.4124 *	* .7846 *
	* 3.1501 *	* 2.1012 *	* 2.3995 *	* 1.8523 *	* 2.1376 *	* 1.7527 *	* 2.3563 *	* 4.2114 *
9	* 1.6132 *	* 1.3316 *	* 1.7237 *	* 1.4590 *	* 1.8849 *	* 1.6541 *	* 1.9068 *	* .9874 *
	* 2.1012 *	* 2.5733 *	* 1.9804 *	* 2.3198 *	* 1.7790 *	* 2.0197 *	* 1.7344 *	* 3.3393 *
10	* 1.4223 *	* 1.7227 *	* 1.1935 *	* 1.3563 *	* 1.4776 *	* 1.8447 *	* 1.8649 *	* .9244 *
	* 2.3995 *	* 1.9816 *	* 2.8609 *	* 2.4849 *	* 2.2479 *	* 1.7823 *	* 1.7586 *	* 3.5614 *
11	* 1.8277 *	* 1.4591 *	* 1.3555 *	* 1.1863 *	* 1.5817 *	* 1.3795 *	* 1.7061 *	* .7698 *
	* 1.8523 *	* 2.3195 *	* 2.4863 *	* 2.5127 *	* 1.9484 *	* 2.2774 *	* 1.8875 *	* 4.1617 *
12	* 1.5710 *	* 1.8846 *	* 1.4774 *	* 1.5814 *	* 1.1041 *	* 1.3628 *	* .9861 *	
	* 2.1376 *	* 1.7793 *	* 2.2482 *	* 1.9485 *	* 2.1591 *	* 1.8681 *	* 3.0367 *	
13	* 1.9102 *	* 1.6538 *	* 1.8444 *	* 1.3793 *	* 1.3627 *	* 1.2706 *	* .6268 *	
	* 1.7527 *	* 2.0201 *	* 1.7824 *	* 2.2776 *	* 1.8682 *	* 1.9776 *	* 4.3501 *	
14	* 1.4124 *	* 1.9066 *	* 1.8647 *	* 1.7059 *	* .9857 *	* .6268 *		
	* 2.3563 *	* 1.7345 *	* 1.7587 *	* 1.8877 *	* 3.0379 *	* 4.3499 *		
15	* .7846 *	* .9875 *	* .9244 *	* .7698 *	F-SUB-Q			
	* 4.2114 *	* 3.3389 *	* 3.5615 *	* 4.1620 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 185 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9094 *	* 1.6117 *	* 1.4110 *	* 1.8214 *	* 1.5582 *	* 1.9063 *	* 1.4010 *	* .7797 *
	* 3.4557 *	* 2.2821 *	* 2.6217 *	* 1.9957 *	* 2.3071 *	* 1.8826 *	* 2.5599 *	* 4.5698 *
9	* 1.6117 *	* 1.3206 *	* 1.7184 *	* 1.4463 *	* 1.8807 *	* 1.6428 *	* 1.9036 *	* .9799 *
	* 2.2821 *	* 2.8196 *	* 2.1558 *	* 2.5151 *	* 1.9066 *	* 2.1767 *	* 1.8554 *	* 3.5987 *
10	* 1.4110 *	* 1.7173 *	* 1.1815 *	* 1.3428 *	* 1.4673 *	* 1.8453 *	* 1.8637 *	* .9134 *
	* 2.6217 *	* 2.1571 *	* 3.1351 *	* 2.6966 *	* 2.4284 *	* 1.9057 *	* 1.8782 *	* 3.8374 *
11	* 1.8214 *	* 1.4465 *	* 1.3420 *	* 1.1829 *	* 1.5816 *	* 1.3750 *	* 1.7033 *	* .7598 *
	* 1.9957 *	* 2.5146 *	* 2.6980 *	* 2.7286 *	* 2.1020 *	* 2.4706 *	* 2.0407 *	* 4.5347 *
12	* 1.5582 *	* 1.8805 *	* 1.4670 *	* 1.5813 *	* 1.1182 *	* 1.3733 *	* .9816 *	
	* 2.3071 *	* 1.9068 *	* 2.4287 *	* 2.1022 *	* 2.3458 *	* 2.0147 *	* 3.2979 *	
13	* 1.9063 *	* 1.6424 *	* 1.8451 *	* 1.3747 *	* 1.3732 *	* 1.2811 *	* .6283 *	
	* 1.8826 *	* 2.1771 *	* 1.9059 *	* 2.4708 *	* 2.0148 *	* 2.1317 *	* 4.6958 *	
14	* 1.4010 *	* 1.9034 *	* 1.8635 *	* 1.7031 *	* .9811 *	* .6283 *		
	* 2.5599 *	* 1.8556 *	* 1.8783 *	* 2.0409 *	* 3.2991 *	* 4.6956 *		
15	* .7797 *	* .9799 *	* .9134 *	* .7598 *	F-SUB-Q			
	* 4.5698 *	* 3.5984 *	* 3.8375 *	* 4.5351 *	M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8986 *	* 1.5753 *	* 1.3821 *	* 1.7766 *	* 1.5252 *	* 1.8604 *	* 1.3727 *	* .7600 *
	* 3.8807 *	* 2.5503 *	* 2.9101 *	* 2.2263 *	* 2.5615 *	* 2.0891 *	* 2.8088 *	* 5.0193 *
9	* 1.5753 *	* 1.2935 *	* 1.6763 *	* 1.4172 *	* 1.8360 *	* 1.6086 *	* 1.8592 *	* .9645 *
	* 2.5503 *	* 3.1448 *	* 2.4040 *	* 2.7931 *	* 2.1248 *	* 2.4128 *	* 2.0584 *	* 3.9437 *
10	* 1.3821 *	* 1.6753 *	* 1.1764 *	* 1.3309 *	* 1.4414 *	* 1.8053 *	* 1.8225 *	* .9088 *
	* 2.9101 *	* 2.4054 *	* 3.4509 *	* 2.9663 *	* 2.7019 *	* 2.1261 *	* 2.0936 *	* 4.1787 *
11	* 1.7766 *	* 1.4173 *	* 1.3301 *	* 1.1658 *	* 1.5526 *	* 1.3518 *	* 1.6712 *	* .7603 *
	* 2.2263 *	* 2.7927 *	* 2.9679 *	* 3.0470 *	* 2.3573 *	* 2.7625 *	* 2.2843 *	* 4.9604 *
12	* 1.5252 *	* 1.8358 *	* 1.4412 *	* 1.5523 *	* 1.1153 *	* 1.3547 *	* .9779 *	
	* 2.5615 *	* 2.1250 *	* 2.7022 *	* 2.3575 *	* 2.6276 *	* 2.2594 *	* 3.6401 *	
13	* 1.8604 *	* 1.6082 *	* 1.8051 *	* 1.3515 *	* 1.3546 *	* 1.2637 *	* .6201 *	
	* 2.0891 *	* 2.4133 *	* 2.1264 *	* 2.7627 *	* 2.2595 *	* 2.3893 *	* 5.2450 *	
14	* 1.3727 *	* 1.8590 *	* 1.8223 *	* 1.6710 *	* .9775 *	* .6201 *		
	* 2.8088 *	* 2.0586 *	* 2.0938 *	* 2.2844 *	* 3.6415 *	* 5.2448 *		
15	* .7600 *	* .9646 *	* .9087 *	* .7602 *	F-SUB-Q			
	* 5.0193 *	* 3.9434 *	* 4.1789 *	* 4.9608 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 186 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8943	* 1.5842	* 1.3759	* 1.7838	* 1.5177	* 1.8701	* 1.3650	* .7570 *
	* 4.0324	* 2.6248	* 3.2465	* 2.4614	* 2.8550	* 2.3004	* 3.1157	* 5.5404 *
9	* 1.5842	* 1.2873	* 1.6844	* 1.4084	* 1.8455	* 1.6043	* 1.8705	* .9560 *
	* 2.6248	* 3.3218	* 2.6337	* 3.1212	* 2.3463	* 2.6823	* 2.2655	* 4.3920 *
10	* 1.3759	* 1.6834	* 1.1501	* 1.3123	* 1.4344	* 1.8208	* 1.8362	* .8927 *
	* 3.2465	* 2.6347	* 3.8410	* 3.3473	* 3.0275	* 2.3459	* 2.3093	* 4.7068 *
11	* 1.7838	* 1.4086	* 1.3116	* 1.1655	* 1.5626	* 1.3537	* 1.6799	* .7442 *
	* 2.4614	* 3.1207	* 3.3491	* 3.2676	* 2.5293	* 2.9795	* 2.5336	* 5.6256 *
12	* 1.5177	* 1.8453	* 1.4341	* 1.5623	* 1.1154	* 1.3738	* .9718	*
	* 2.8550	* 2.3466	* 3.0280	* 2.5295	* 2.8530	* 2.4528	* 4.0033	*
13	* 1.8701	* 1.6040	* 1.8206	* 1.3535	* 1.3736	* 1.2834	* .6253	*
	* 2.3004	* 2.6829	* 2.3461	* 2.9800	* 2.4530	* 2.6217	* 5.7878	*
14	* 1.3650	* 1.8703	* 1.8360	* 1.6797	* .9714	* .6253	*	
	* 3.1157	* 2.2658	* 2.3095	* 2.5338	* 4.0050	* 5.7876	*	
15	* .7570	* .9560	* .8926	* .7441	* F-SUB-Q			
	* 5.5404	* 4.3917	* 4.7070	* 5.6261	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8854	* 1.5750	* 1.3630	* 1.7699	* 1.5018	* 1.8559	* 1.3507	* .7472 *
	* 4.2263	* 2.7342	* 3.2457	* 2.4831	* 2.9059	* 2.3572	* 3.2259	* 5.8221 *
9	* 1.5750	* 1.2753	* 1.6727	* 1.3942	* 1.8325	* 1.5895	* 1.8590	* .9469 *
	* 2.7342	* 3.4688	* 2.6590	* 3.1496	* 2.3978	* 2.7517	* 2.3695	* 4.6287 *
10	* 1.3630	* 1.6717	* 1.1400	* 1.3022	* 1.4235	* 1.8142	* 1.8283	* .8854 *
	* 3.2457	* 2.6605	* 3.9007	* 3.4032	* 3.1170	* 2.4515	* 2.4275	* 4.9694 *
11	* 1.7699	* 1.3944	* 1.3014	* 1.1625	* 1.5603	* 1.3499	* 1.6759	* .7402 *
	* 2.4831	* 3.1492	* 3.4050	* 3.3952	* 2.6283	* 3.0978	* 2.6406	* 6.0372 *
12	* 1.5018	* 1.8323	* 1.4233	* 1.5601	* 1.1166	* 1.3802	* .9733	*
	* 2.9059	* 2.3981	* 3.1176	* 2.6285	* 2.9709	* 2.5542	* 4.1662	*
13	* 1.8559	* 1.5892	* 1.8139	* 1.3496	* 1.3801	* 1.2928	* .6277	*
	* 2.3572	* 2.7523	* 2.4519	* 3.0983	* 2.5544	* 2.7345	* 6.0531	*
14	* 1.3507	* 1.8588	* 1.8281	* 1.6757	* .9729	* .6278	*	
	* 3.2259	* 2.3698	* 2.4278	* 2.6409	* 4.1680	* 6.0529	*	
15	* .7472	* .9470	* .8853	* .7401	* F-SUB-Q			
	* 5.8221	* 4.6285	* 4.9700	* 6.0385	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 187 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8814	* 1.5553	* 1.3455	* 1.7392	* 1.4791	* 1.8231	* 1.3308	* .7354
	* 4.4061	* 2.8618	* 3.3027	* 2.5368	* 2.9609	* 2.4064	* 3.2809	* 5.9245
9	* 1.5553	* 1.2606	* 1.6467	* 1.3755	* 1.8021	* 1.5664	* 1.8303	* .9371
	* 2.8618	* 3.5637	* 2.7133	* 3.2061	* 2.4491	* 2.8034	* 2.4179	* 4.6951
10	* 1.3455	* 1.6458	* 1.1432	* 1.2993	* 1.4106	* 1.7914	* 1.8048	* .8841
	* 3.3027	* 2.7148	* 3.9197	* 3.4349	* 3.1662	* 2.5027	* 2.4784	* 5.0032
11	* 1.7392	* 1.3757	* 1.2986	* 1.1607	* 1.5524	* 1.3455	* 1.6646	* .7446
	* 2.5368	* 3.2058	* 3.4368	* 3.5492	* 2.7662	* 3.2440	* 2.7469	* 6.0679
12	* 1.4791	* 1.8018	* 1.4104	* 1.5522	* 1.1269	* 1.3867	* .9840	*
	* 2.9609	* 2.4495	* 3.1667	* 2.7664	* 3.1232	* 2.6929	* 4.3256	*
13	* 1.8231	* 1.5661	* 1.7911	* 1.3453	* 1.3866	* 1.3049	* .6338	*
	* 2.4064	* 2.8040	* 2.5031	* 3.2445	* 2.6931	* 2.8802	* 6.3489	*
14	* 1.3308	* 1.8300	* 1.8046	* 1.6644	* .9835	* .6339	*	*
	* 3.2809	* 2.4183	* 2.4788	* 2.7473	* 4.3275	* 6.3486	*	*
15	* .7354	* .9371	* .8841	* .7445	* F-SUB-Q			
	* 5.9245	* 4.6950	* 5.0038	* 6.0690	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8981	* 1.5878	* 1.3513	* 1.7574	* 1.4799	* 1.8414	* 1.3304	* .7357
	* 4.1756	* 2.7058	* 3.2459	* 2.4838	* 2.9272	* 2.3622	* 3.2466	* 5.8434
9	* 1.5878	* 1.2702	* 1.6699	* 1.3765	* 1.8222	* 1.5710	* 1.8545	* .9388
	* 2.7058	* 3.4428	* 2.6460	* 3.1646	* 2.4038	* 2.7709	* 2.3765	* 4.6416
10	* 1.3513	* 1.6690	* 1.1321	* 1.2932	* 1.4180	* 1.8234	* 1.8348	* .8771
	* 3.2459	* 2.6474	* 3.8988	* 3.4220	* 3.1423	* 2.4582	* 2.4356	* 5.0039
11	* 1.7574	* 1.3768	* 1.2925	* 1.1867	* 1.5928	* 1.3752	* 1.6973	* .7399
	* 2.4838	* 3.1642	* 3.4238	* 3.3833	* 2.6217	* 3.1104	* 2.6473	* 6.0956
12	* 1.4799	* 1.8220	* 1.4177	* 1.5925	* 1.1740	* 1.4649	* 1.0034	*
	* 2.9272	* 2.4041	* 3.1429	* 2.6219	* 2.9746	* 2.5483	* 4.1508	*
13	* 1.8414	* 1.5707	* 1.8231	* 1.3750	* 1.4648	* 1.3834	* .6618	*
	* 2.3622	* 2.7715	* 2.4586	* 3.1108	* 2.5484	* 2.7196	* 5.9572	*
14	* 1.3304	* 1.8542	* 1.8346	* 1.6971	* 1.0029	* .6619	*	*
	* 3.2466	* 2.3768	* 2.4359	* 2.6475	* 4.1526	* 5.9569	*	*
15	* .7357	* .9389	* .8770	* .7398	* F-SUB-Q			
	* 5.8434	* 4.6414	* 5.0045	* 6.0966	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 188 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9535	* 1.6234	* 1.3556	* 1.7620	* 1.4763	* 1.8440	* 1.3263	* .7301
	* 3.8058	* 2.4452	* 2.9619	* 2.2809	* 2.7099	* 2.1866	* 3.0120	* 5.4202
9	* 1.6234	* 1.2873	* 1.6834	* 1.3755	* 1.8279	* 1.5698	* 1.8637	* .9369
	* 2.4452	* 3.1243	* 2.4061	* 2.9069	* 2.2173	* 2.5669	* 2.1961	* 4.2882
10	* 1.3556	* 1.6826	* 1.1338	* 1.2966	* 1.4270	* 1.8420	* 1.8518	* .8745
	* 2.9619	* 2.4073	* 3.5502	* 3.1339	* 2.8866	* 2.2599	* 2.2419	* 4.6250
11	* 1.7620	* 1.3759	* 1.2959	* 1.2357	* 1.6465	* 1.4117	* 1.7261	* .7413
	* 2.2809	* 2.9062	* 3.1354	* 3.0675	* 2.3720	* 2.8215	* 2.3965	* 5.5988
12	* 1.4762	* 1.8277	* 1.4267	* 1.6463	* 1.3002	* 1.5864	* 1.0363	*
	* 2.7099	* 2.2175	* 2.8871	* 2.3721	* 2.6985	* 2.3086	* 3.7780	*
13	* 1.8440	* 1.5695	* 1.8417	* 1.4115	* 1.5863	* 1.4904	* .6929	*
	* 2.1866	* 2.5675	* 2.2603	* 2.8219	* 2.3087	* 2.4658	* 5.4389	*
14	* 1.3263	* 1.8634	* 1.8516	* 1.7259	* 1.0358	* .6929	*	*
	* 3.0120	* 2.1964	* 2.2422	* 2.3967	* 3.7797	* 5.4387	*	*
15	* .7301	* .9370	* .8744	* .7412	* F-SUB-Q			
	* 5.4202	* 4.2880	* 4.6255	* 5.5996	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0293	* 1.6684	* 1.3596	* 1.7602	* 1.4709	* 1.8389	* 1.3205	* .7271
	* 3.4750	* 2.2290	* 2.6751	* 2.0602	* 2.4529	* 1.9769	* 2.7289	* 4.9163
9	* 1.6684	* 1.3071	* 1.6927	* 1.3739	* 1.8265	* 1.5661	* 1.8646	* .9354
	* 2.2290	* 2.8524	* 2.1697	* 2.6289	* 2.0031	* 2.3217	* 1.9836	* 3.8832
10	* 1.3596	* 1.6919	* 1.1432	* 1.3036	* 1.4356	* 1.8515	* 1.8597	* .8767
	* 2.6751	* 2.1709	* 3.2069	* 2.8259	* 2.6078	* 2.0385	* 2.0224	* 4.1763
11	* 1.7602	* 1.3742	* 1.3030	* 1.3038	* 1.7045	* 1.4486	* 1.7495	* .7490
	* 2.0602	* 2.6285	* 2.8275	* 2.8082	* 2.1713	* 2.5858	* 2.1893	* 5.0408
12	* 1.4709	* 1.8263	* 1.4353	* 1.7042	* 1.4537	* 1.7161	* 1.0735	*
	* 2.4529	* 2.0034	* 2.6082	* 2.1715	* 2.4708	* 2.1136	* 3.4569	*
13	* 1.8389	* 1.5657	* 1.8512	* 1.4484	* 1.7159	* 1.6004	* .7269	*
	* 1.9769	* 2.3222	* 2.0388	* 2.5862	* 2.1137	* 2.2579	* 4.9891	*
14	* 1.3205	* 1.8643	* 1.8595	* 1.7493	* 1.0730	* .7269	*	*
	* 2.7289	* 1.9839	* 2.0226	* 2.1895	* 3.4585	* 4.9889	*	*
15	* .7271	* .9355	* .8766	* .7489	* F-SUB-Q			
	* 4.9163	* 3.8830	* 4.1768	* 5.0416	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 189 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0733	* 1.6850	* 1.3564	* 1.7426	* 1.4589	* 1.8172	* 1.3093	* .7198 *
	* 3.1885	* 2.0512	* 2.4534	* 1.8985	* 2.2554	* 1.8233	* 2.5104	* 4.5367 *
9	* 1.6850	* 1.3169	* 1.6857	* 1.3665	* 1.8084	* 1.5541	* 1.8481	* .9336 *
	* 2.0512	* 2.6167	* 1.9949	* 2.4122	* 1.8457	* 2.1343	* 1.8264	* 3.5559 *
10	* 1.3564	* 1.6851	* 1.1614	* 1.3122	* 1.4348	* 1.8416	* 1.8496	* .8817 *
	* 2.4534	* 1.9960	* 2.8931	* 2.5699	* 2.3885	* 1.8745	* 1.8594	* 3.7974 *
11	* 1.7426	* 1.3667	* 1.3115	* 1.3415	* 1.7368	* 1.4703	* 1.7569	* .7607 *
	* 1.8985	* 2.4118	* 2.5712	* 2.5840	* 2.0113	* 2.3800	* 2.0134	* 4.5532 *
12	* 1.4589	* 1.8081	* 1.4346	* 1.7367	* 1.5274	* 1.7830	* 1.1034	*
	* 2.2554	* 1.8460	* 2.3889	* 2.0115	* 2.2820	* 1.9605	* 3.1652	*
13	* 1.8172	* 1.5537	* 1.8413	* 1.4701	* 1.7829	* 1.6661	* .7489	*
	* 1.8233	* 2.1348	* 1.8748	* 2.3803	* 1.9606	* 2.0908	* 4.6248	*
14	* 1.3093	* 1.8478	* 1.8493	* 1.7567	* 1.1029	* .7489	*	
	* 2.5104	* 1.8267	* 1.8596	* 2.0136	* 3.1666	* 4.6245	*	
15	* .7198	* .9336	* .8816	* .7606	* F-SUB-Q			
	* 4.5367	* 3.5558	* 3.7978	* 4.5539	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0937	* 1.7233	* 1.3640	* 1.7630	* 1.4611	* 1.8363	* 1.3096	* .7205 *
	* 2.9200	* 1.8458	* 2.2498	* 1.7286	* 2.0746	* 1.6619	* 2.3136	* 4.1836 *
9	* 1.7233	* 1.3312	* 1.7137	* 1.3698	* 1.8296	* 1.5598	* 1.8728	* .9323 *
	* 1.8458	* 2.3715	* 1.8107	* 2.2187	* 1.6808	* 1.9589	* 1.6609	* 3.2857 *
10	* 1.3640	* 1.7131	* 1.1477	* 1.3070	* 1.4455	* 1.8711	* 1.8785	* .8711 *
	* 2.2498	* 1.8117	* 2.6978	* 2.3703	* 2.1911	* 1.7007	* 1.6866	* 3.5474 *
11	* 1.7630	* 1.3701	* 1.3063	* 1.3690	* 1.7943	* 1.4955	* 1.7872	* .7507 *
	* 1.7286	* 2.2181	* 2.3726	* 2.3757	* 1.8277	* 2.1751	* 1.8170	* 4.2608 *
12	* 1.4611	* 1.8293	* 1.4453	* 1.7942	* 1.5737	* 1.8482	* 1.1137	*
	* 2.0746	* 1.6810	* 2.1915	* 1.8279	* 2.0781	* 1.7777	* 2.9392	*
13	* 1.8364	* 1.5594	* 1.8708	* 1.4953	* 1.8481	* 1.7286	* .7685	*
	* 1.6619	* 1.9593	* 1.7010	* 2.1754	* 1.7778	* 1.8997	* 4.2428	*
14	* 1.3096	* 1.8725	* 1.8783	* 1.7870	* 1.1131	* .7686	*	
	* 2.3136	* 1.6612	* 1.6868	* 1.8172	* 2.9407	* 4.2427	*	
15	* .7205	* .9324	* .8710	* .7506	* F-SUB-Q			
	* 4.1836	* 3.2856	* 3.5479	* 4.2615	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 190 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0898	* 1.7167	* 1.3553	* 1.7460	* 1.4453	* 1.8164	* 1.2944	* .7117 *
	* 2.6904	* 1.7157	* 2.1091	* 1.6247	* 1.9540	* 1.5646	* 2.1826	* 3.9551 *
9	* 1.7167	* 1.3239	* 1.7034	* 1.3568	* 1.8116	* 1.5441	* 1.8564	* .9230 *
	* 1.7157	* 2.2139	* 1.6929	* 2.0855	* 1.5796	* 1.8431	* 1.5596	* 3.0964 *
10	* 1.3553	* 1.7028	* 1.1400	* 1.2976	* 1.4347	* 1.8556	* 1.8643	* .8618 *
	* 2.1091	* 1.6937	* 2.5257	* 2.2184	* 2.0521	* 1.5938	* 1.5802	* 3.3436 *
11	* 1.7460	* 1.3572	* 1.2970	* 1.3683	* 1.7953	* 1.4915	* 1.7800	* .7447 *
	* 1.6247	* 2.0849	* 2.2205	* 2.1943	* 1.6932	* 2.0210	* 1.6982	* 3.9913 *
12	* 1.4453	* 1.8114	* 1.4345	* 1.7952	* 1.5781	* 1.8547	* 1.1126	*
	* 1.9540	* 1.5798	* 2.0525	* 1.6934	* 1.9229	* 1.6487	* 2.7252	*
13	* 1.8164	* 1.5437	* 1.8553	* 1.4913	* 1.8546	* 1.7382	* .7701	*
	* 1.5646	* 1.8435	* 1.5941	* 2.0213	* 1.6488	* 1.7655	* 3.9552	*
14	* 1.2944	* 1.8561	* 1.8641	* 1.7798	* 1.1120	* .7701	*	*
	* 2.1826	* 1.5598	* 1.5805	* 1.6984	* 2.7265	* 3.9551	*	*
15	* .7117	* .9231	* .8617	* .7446	* F-SUB-Q			
	* 3.9551	* 3.0963	* 3.3440	* 3.9920	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0596	* 1.6550	* 1.3195	* 1.6772	* 1.4026	* 1.7425	* 1.2557	* .6878 *
	* 2.6052	* 1.6665	* 2.0358	* 1.5920	* 1.8979	* 1.5369	* 2.1230	* 3.8680 *
9	* 1.6550	* 1.2901	* 1.6418	* 1.3193	* 1.7396	* 1.4974	* 1.7837	* .8993 *
	* 1.6665	* 2.1147	* 1.6466	* 2.0189	* 1.5482	* 1.7902	* 1.5274	* 2.9989 *
10	* 1.3195	* 1.6413	* 1.1340	* 1.2787	* 1.3949	* 1.7797	* 1.7912	* .8493 *
	* 2.0358	* 1.6473	* 2.3806	* 2.1230	* 1.9758	* 1.5592	* 1.5449	* 3.1991 *
11	* 1.6772	* 1.3195	* 1.2781	* 1.3366	* 1.7325	* 1.4542	* 1.7222	* .7390 *
	* 1.5920	* 2.0186	* 2.1241	* 2.1148	* 1.6492	* 1.9564	* 1.6381	* 3.7692 *
12	* 1.4026	* 1.7394	* 1.3947	* 1.7324	* 1.5395	* 1.7950	* 1.0973	*
	* 1.8979	* 1.5484	* 1.9761	* 1.6493	* 1.8503	* 1.5993	* 2.6039	*
13	* 1.7425	* 1.4970	* 1.7794	* 1.4541	* 1.7949	* 1.6893	* .7513	*
	* 1.5369	* 1.7907	* 1.5595	* 1.9567	* 1.5995	* 1.7044	* 3.8153	*
14	* 1.2557	* 1.7834	* 1.7910	* 1.7220	* 1.0968	* .7513	*	*
	* 2.1230	* 1.5276	* 1.5451	* 1.6383	* 2.6052	* 3.8151	*	*
15	* .6878	* .8993	* .8492	* .7389	* F-SUB-Q			
	* 3.8680	* 2.9988	* 3.1996	* 3.7699	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 191 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0235	* 1.5979	* 1.2753	* 1.6131	* 1.3522	* 1.6744	* 1.2083	* .6617
	* 2.5252	* 1.6146	* 1.9978	* 1.5739	* 1.8745	* 1.5227	* 2.1035	* 3.8404
9	* 1.5979	* 1.2476	* 1.5859	* 1.2735	* 1.6735	* 1.4455	* 1.7173	* .8632
	* 1.6146	* 2.0562	* 1.6131	* 1.9894	* 1.5300	* 1.7650	* 1.5080	* 2.9789
10	* 1.2753	* 1.5854	* 1.0809	* 1.2275	* 1.3509	* 1.7078	* 1.7221	* .8071
	* 1.9978	* 1.6138	* 2.3645	* 2.0895	* 1.9334	* 1.5393	* 1.5237	* 3.2062
11	* 1.6131	* 1.2739	* 1.2265	* 1.2939	* 1.6710	* 1.4093	* 1.6578	* .7009
	* 1.5739	* 1.9889	* 2.0932	* 2.0685	* 1.6290	* 1.9031	* 1.6068	* 3.7723
12	* 1.3522	* 1.6732	* 1.3506	* 1.6708	* 1.4925	* 1.7364	* 1.0493	*
	* 1.8745	* 1.5302	* 1.9337	* 1.6292	* 1.8220	* 1.5778	* 2.5860	*
13	* 1.6744	* 1.4451	* 1.7076	* 1.4091	* 1.7363	* 1.6338	* .7257	*
	* 1.5227	* 1.7654	* 1.5396	* 1.9034	* 1.5779	* 1.6830	* 3.7762	*
14	* 1.2083	* 1.7170	* 1.7218	* 1.6577	* 1.0488	* .7257	*	*
	* 2.1035	* 1.5082	* 1.5239	* 1.6070	* 2.5873	* 3.7761	*	*
15	* .6617	* .8633	* .8070	* .7008	* F-SUB-Q			
	* 3.8404	* 2.9787	* 3.2067	* 3.7729	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9386	* 1.4394	* 1.1657	* 1.4485	* 1.2331	* 1.5003	* 1.1013	* .6029
	* 2.6191	* 1.7120	* 2.0988	* 1.6856	* 1.9799	* 1.6362	* 2.2261	* 4.0735
9	* 1.4394	* 1.1420	* 1.4290	* 1.1634	* 1.5045	* 1.3214	* 1.5408	* .7863
	* 1.7120	* 2.1509	* 1.7144	* 2.0955	* 1.6392	* 1.8587	* 1.6161	* 3.1548
10	* 1.1657	* 1.4287	* .9974	* 1.1327	* 1.2438	* 1.5266	* 1.5433	* .7371
	* 2.0988	* 1.7147	* 2.4504	* 2.1764	* 2.0145	* 1.6508	* 1.6312	* 3.3838
11	* 1.4485	* 1.1637	* 1.1318	* 1.1884	* 1.5019	* 1.2936	* 1.4928	* .6413
	* 1.6856	* 2.0950	* 2.1802	* 2.1415	* 1.7180	* 1.9782	* 1.7101	* 3.9673
12	* 1.2331	* 1.5043	* 1.2436	* 1.5017	* 1.3672	* 1.5650	* .9539	*
	* 1.9799	* 1.6394	* 2.0149	* 1.7181	* 1.8842	* 1.6632	* 2.7117	*
13	* 1.5003	* 1.3211	* 1.5263	* 1.2935	* 1.5649	* 1.4745	* .6641	*
	* 1.6362	* 1.8591	* 1.6511	* 1.9785	* 1.6633	* 1.7816	* 3.9442	*
14	* 1.1013	* 1.5405	* 1.5431	* 1.4927	* .9534	* .6641	*	*
	* 2.2261	* 1.6164	* 1.6315	* 1.7103	* 2.7130	* 3.9442	*	*
15	* .6029	* .7863	* .7370	* .6412	* F-SUB-Q			
	* 4.0735	* 3.1547	* 3.3843	* 3.9680	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 192 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 250 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7819	* 1.1744	* .9086	* 1.1902	* .9591	* 1.2321	* .8652	* .4915
	* 3.0456	* 2.0284	* 2.6066	* 1.9904	* 2.4733	* 1.9341	* 2.7632	* 4.8739
9	* 1.1744	* .8929	* 1.1646	* .9086	* 1.2353	* 1.0487	* 1.2463	* .6330
	* 2.0284	* 2.6584	* 2.0366	* 2.6075	* 1.9331	* 2.2747	* 1.9390	* 3.8160
10	* .9086	* 1.1647	* .8416	* .9319	* 1.0223	* 1.2620	* 1.2466	* .6025
	* 2.6066	* 2.0366	* 2.8175	* 2.5746	* 2.3743	* 1.9316	* 1.9556	* 4.0415
11	* 1.1902	* .9087	* .9313	* .9463	* 1.2478	* 1.0336	* 1.1772	* .5202
	* 1.9904	* 2.6071	* 2.5762	* 2.6010	* 1.9937	* 2.3970	* 2.1033	* 4.7489
12	* .9591	* 1.2352	* 1.0221	* 1.2477	* 1.1149	* 1.2711	* .7651	*
	* 2.4733	* 1.9333	* 2.3747	* 1.9938	* 2.2299	* 1.9739	* 3.2720	*
13	* 1.2321	* 1.0485	* 1.2618	* 1.0335	* 1.2710	* 1.1658	* .5411	*
	* 1.9341	* 2.2752	* 1.9319	* 2.3973	* 1.9740	* 2.1702	* 4.6777	*
14	* .8652	* 1.2461	* 1.2465	* 1.1771	* .7648	* .5411	*	*
	* 2.7632	* 1.9393	* 1.9558	* 2.1035	* 3.2733	* 4.6779	*	*
15	* .4915	* .6329	* .6023	* .5201	* F-SUB-Q			
	* 4.8739	* 3.8161	* 4.0422	* 4.7497	* M-SUB-Q			

AT 50% POWER, 250 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5437	* .4899	* .4167	* .5010	* .4409	* .5170	* .4061	* .3364
	* 4.2584	* 4.7044	* 5.5284	* 4.5947	* 5.2546	* 4.4786	* 5.7321	* 6.9594
9	* .4899	* .4132	* .4855	* .4238	* .5201	* .4587	* .4873	* .3008
	* 4.7044	* 5.5760	* 4.7403	* 5.4429	* 4.4628	* 5.0534	* 4.8173	* 7.8570
10	* .4167	* .4857	* .4210	* .4177	* .4519	* .5264	* .5023	* .2920
	* 5.5284	* 4.7384	* 5.4808	* 5.5820	* 5.2030	* 4.4774	* 4.7107	* 8.1005
11	* .5010	* .4240	* .4176	* .4462	* .5247	* .4558	* .4648	* .2562
	* 4.5947	* 5.4415	* 5.5841	* 5.3875	* 4.5992	* 5.2580	* 5.1688	* 9.3873
12	* .4409	* .5200	* .4518	* .5246	* .4841	* .5017	* .3552	*
	* 5.2546	* 4.4633	* 5.2037	* 4.5996	* 4.9879	* 4.8503	* 6.8558	*
13	* .5170	* .4587	* .5263	* .4557	* .5017	* .4617	* .3721	*
	* 4.4786	* 5.0543	* 4.4780	* 5.2587	* 4.8506	* 5.3059	* 6.6210	*
14	* .4061	* .4872	* .5022	* .4647	* .3553	* .3720	*	*
	* 5.7321	* 4.8182	* 4.7114	* 5.1695	* 6.8540	* 6.6220	*	*
15	* .3364	* .3007	* .2920	* .2561	* F-SUB-Q			
	* 6.9594	* 7.8581	* 8.1019	* 9.3889	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 193 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5124 *	* .5183 *	* .4914 *	* .6117 *	* .5510 *	* .6058 *	* .4224 *	* .3443 *
	* 3.9973 *	* 4.5179 *	* 4.8002 *	* 3.9851 *	* 4.3944 *	* 3.8574 *	* 4.7654 *	* 5.2946 *
9	* .5183 *	* .4533 *	* .5418 *	* .5200 *	* .6276 *	* .5543 *	* .5597 *	* .3703 *
	* 4.5179 *	* 4.9819 *	* 4.2222 *	* 4.6499 *	* 3.8834 *	* 4.3021 *	* 4.1857 *	* 6.2879 *
10	* .4914 *	* .5420 *	* .4084 *	* .4931 *	* .5448 *	* .6211 *	* .5856 *	* .3618 *
	* 4.8002 *	* 4.2219 *	* 4.8930 *	* 4.8602 *	* 4.5279 *	* 3.9757 *	* 4.1991 *	* 6.6077 *
11	* .6117 *	* .5201 *	* .4930 *	* .4427 *	* .5564 *	* .5171 *	* .5430 *	* .3305 *
	* 3.9851 *	* 4.6495 *	* 4.8626 *	* 5.0123 *	* 4.2380 *	* 4.6741 *	* 4.4715 *	* 7.3236 *
12	* .5510 *	* .6276 *	* .5448 *	* .5564 *	* .4044 *	* .4676 *	* .3925 *	
	* 4.3944 *	* 3.8833 *	* 4.5277 *	* 4.2381 *	* 4.4147 *	* 4.3873 *	* 6.0244 *	
13	* .6058 *	* .5543 *	* .6211 *	* .5171 *	* .4676 *	* .4197 *	* .4066 *	
	* 3.8574 *	* 4.3019 *	* 3.9756 *	* 4.6740 *	* 4.3874 *	* 4.7442 *	* 5.5035 *	
14	* .4224 *	* .5597 *	* .5856 *	* .5430 *	* .3926 *	* .4065 *		
	* 4.7654 *	* 4.1836 *	* 4.1981 *	* 4.4714 *	* 6.0220 *	* 5.5052 *		
15	* .3443 *	* .3704 *	* .3619 *	* .3305 *	F-SUB-Q			
	* 5.2946 *	* 6.2838 *	* 6.6049 *	* 7.3233 *	M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6559 *	* 1.0928 *	* 1.0261 *	* 1.2897 *	* 1.1524 *	* 1.2831 *	* .8279 *	* .4718 *
	* 2.9965 *	* 2.2250 *	* 2.3810 *	* 1.9596 *	* 2.1737 *	* 1.8883 *	* 2.3781 *	* 4.0400 *
9	* 1.0928 *	* .9394 *	* 1.1442 *	* 1.0841 *	* 1.3262 *	* 1.1780 *	* 1.2523 *	* .7143 *
	* 2.2250 *	* 2.4861 *	* 2.0702 *	* 2.3068 *	* 1.9081 *	* 2.0961 *	* 1.9202 *	* 3.2990 *
10	* 1.0261 *	* 1.1444 *	* .7488 *	* .9970 *	* 1.1315 *	* 1.3172 *	* 1.2873 *	* .7034 *
	* 2.3810 *	* 2.0704 *	* 2.6542 *	* 2.4449 *	* 2.2708 *	* 1.9445 *	* 1.9693 *	* 3.5128 *
11	* 1.2897 *	* 1.0843 *	* .9968 *	* .9025 *	* 1.1746 *	* 1.0914 *	* 1.2204 *	* .6384 *
	* 1.9596 *	* 2.3067 *	* 2.4465 *	* 2.5277 *	* 2.0489 *	* 2.3031 *	* 2.0742 *	* 3.9468 *
12	* 1.1524 *	* 1.3262 *	* 1.1315 *	* 1.1746 *	* .8247 *	* 1.0466 *	* .7844 *	
	* 2.1737 *	* 1.9082 *	* 2.2709 *	* 2.0490 *	* 2.2073 *	* 2.0062 *	* 3.1379 *	
13	* 1.2831 *	* 1.1779 *	* 1.3172 *	* 1.0914 *	* 1.0466 *	* .9578 *	* .5404 *	
	* 1.8883 *	* 2.0961 *	* 1.9444 *	* 2.3031 *	* 2.0062 *	* 2.1756 *	* 4.2147 *	
14	* .8279 *	* 1.2524 *	* 1.2874 *	* 1.2204 *	* .7843 *	* .5403 *		
	* 2.3781 *	* 1.9195 *	* 1.9690 *	* 2.0742 *	* 3.1383 *	* 4.2149 *		
15	* .4718 *	* .7144 *	* .7035 *	* .6384 *	F-SUB-Q			
	* 4.0400 *	* 3.2972 *	* 3.5116 *	* 3.9466 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 194 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7702 *	* 1.2952 *	* 1.2039 *	* 1.5266 *	* 1.3566 *	* 1.5271 *	* 1.0117 *	* .5660 *
	* 2.6932 *	* 1.9444 *	* 2.1031 *	* 1.7094 *	* 1.9044 *	* 1.6414 *	* 2.0841 *	* 3.5429 *
9	* 1.2952 *	* 1.0954 *	* 1.3572 *	* 1.2707 *	* 1.5719 *	* 1.3920 *	* 1.5196 *	* .8463 *
	* 1.9444 *	* 2.2122 *	* 1.8093 *	* 2.0354 *	* 1.6579 *	* 1.8256 *	* 1.6463 *	* 2.8684 *
10	* 1.2039 *	* 1.3572 *	* .8909 *	* 1.1896 *	* 1.3196 *	* 1.5542 *	* 1.5502 *	* .8359 *
	* 2.1031 *	* 1.8098 *	* 2.3888 *	* 2.1568 *	* 2.0029 *	* 1.6927 *	* 1.6855 *	* 3.0255 *
11	* 1.5266 *	* 1.2710 *	* 1.1894 *	* 1.0516 *	* 1.3904 *	* 1.2757 *	* 1.4843 *	* .7589 *
	* 1.7094 *	* 2.0352 *	* 2.1577 *	* 2.2190 *	* 1.7945 *	* 2.0220 *	* 1.7550 *	* 3.4186 *
12	* 1.3566 *	* 1.5719 *	* 1.3196 *	* 1.3904 *	* .9840 *	* 1.2353 *	* .9473 *	
	* 1.9044 *	* 1.6579 *	* 2.0030 *	* 1.7946 *	* 1.9341 *	* 1.7304 *	* 2.6649 *	
13	* 1.5271 *	* 1.3919 *	* 1.5542 *	* 1.2757 *	* 1.2353 *	* 1.1528 *	* .6292 *	
	* 1.6414 *	* 1.8257 *	* 1.6927 *	* 2.0221 *	* 1.7305 *	* 1.8399 *	* 3.6862 *	
14	* 1.0117 *	* 1.5196 *	* 1.5503 *	* 1.4843 *	* .9471 *	* .6292 *		
	* 2.0841 *	* 1.6460 *	* 1.6853 *	* 1.7550 *	* 2.6653 *	* 3.6861 *		
15	* .5660 *	* .8464 *	* .8359 *	* .7589 *	F-SUB-Q			
	* 3.5429 *	* 2.8673 *	* 3.0248 *	* 3.4186 *	M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8315 *	* 1.4418 *	* 1.3027 *	* 1.7049 *	* 1.4741 *	* 1.7224 *	* 1.1135 *	* .6334 *
	* 2.6154 *	* 1.8287 *	* 2.0326 *	* 1.5944 *	* 1.8288 *	* 1.5217 *	* 1.9993 *	* 3.4034 *
9	* 1.4418 *	* 1.1838 *	* 1.5183 *	* 1.3727 *	* 1.7625 *	* 1.5232 *	* 1.7114 *	* .9184 *
	* 1.8287 *	* 2.1540 *	* 1.6971 *	* 1.9647 *	* 1.5409 *	* 1.7426 *	* 1.5228 *	* 2.7633 *
10	* 1.3027 *	* 1.5181 *	* .9553 *	* 1.2728 *	* 1.4281 *	* 1.7566 *	* 1.7480 *	* .8972 *
	* 2.0326 *	* 1.6977 *	* 2.3506 *	* 2.1025 *	* 1.9236 *	* 1.5582 *	* 1.5537 *	* 2.9531 *
11	* 1.7049 *	* 1.3731 *	* 1.2726 *	* 1.1310 *	* 1.5392 *	* 1.3757 *	* 1.6472 *	* .7991 *
	* 1.5944 *	* 1.9644 *	* 2.1039 *	* 2.1337 *	* 1.6609 *	* 1.9356 *	* 1.6324 *	* 3.3583 *
12	* 1.4741 *	* 1.7624 *	* 1.4281 *	* 1.5392 *	* 1.0654 *	* 1.3688 *	* 1.0113 *	
	* 1.8288 *	* 1.5410 *	* 1.9238 *	* 1.6610 *	* 1.8424 *	* 1.6079 *	* 2.5667 *	
13	* 1.7224 *	* 1.5230 *	* 1.7565 *	* 1.3757 *	* 1.3687 *	* 1.2717 *	* .6723 *	
	* 1.5217 *	* 1.7428 *	* 1.5582 *	* 1.9357 *	* 1.6080 *	* 1.7164 *	* 3.5406 *	
14	* 1.1135 *	* 1.7115 *	* 1.7480 *	* 1.6472 *	* 1.0111 *	* .6723 *		
	* 1.9993 *	* 1.5226 *	* 1.5536 *	* 1.6324 *	* 2.5673 *	* 3.5405 *		
15	* .6334 *	* .9185 *	* .8972 *	* .7991 *	F-SUB-Q			
	* 3.4034 *	* 2.7625 *	* 2.9526 *	* 3.3583 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 195 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8545	* 1.5011	* 1.3450	* 1.7739	* 1.5214	* 1.8206	* 1.2290	* .7078
	* 2.7162	* 1.8688	* 2.0987	* 1.6212	* 1.8761	* 1.5373	* 2.0532	* 3.5120
9	* 1.5011	* 1.2253	* 1.5929	* 1.4123	* 1.8399	* 1.5832	* 1.8151	* .9646
	* 1.8688	* 2.2329	* 1.7337	* 2.0267	* 1.5584	* 1.7809	* 1.5330	* 2.8319
10	* 1.3450	* 1.5926	* 1.0320	* 1.3144	* 1.4642	* 1.8433	* 1.8342	* .9305
	* 2.0987	* 1.7344	* 2.4454	* 2.1613	* 1.9663	* 1.5574	* 1.5559	* 3.0103
11	* 1.7739	* 1.4126	* 1.3140	* 1.1613	* 1.5906	* 1.4028	* 1.7053	* .8159
	* 1.6212	* 2.0263	* 2.1622	* 2.1845	* 1.6736	* 1.9809	* 1.6432	* 3.4350
12	* 1.5214	* 1.8398	* 1.4642	* 1.5906	* 1.0943	* 1.4037	* 1.0304	*
	* 1.8761	* 1.5585	* 1.9663	* 1.6736	* 1.8819	* 1.6258	* 2.6155	*
13	* 1.8206	* 1.5830	* 1.8433	* 1.4028	* 1.4036	* 1.2997	* .6778	*
	* 1.5373	* 1.7812	* 1.5575	* 1.9810	* 1.6258	* 1.7362	* 3.6372	*
14	* 1.2290	* 1.8151	* 1.8342	* 1.7052	* 1.0301	* .6778	*	*
	* 2.0532	* 1.5330	* 1.5559	* 1.6432	* 2.6162	* 3.6370	*	*
15	* .7078	* .9647	* .9306	* .8159	* F-SUB-Q			
	* 3.5120	* 2.8314	* 3.0100	* 3.4350	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8671	* 1.5289	* 1.3660	* 1.7980	* 1.5420	* 1.8744	* 1.3443	* .7800
	* 2.8677	* 1.9617	* 2.2234	* 1.7028	* 1.9734	* 1.6087	* 2.1567	* 3.6825
9	* 1.5289	* 1.2525	* 1.6386	* 1.4280	* 1.8690	* 1.6161	* 1.8732	* .9994
	* 1.9617	* 2.3773	* 1.8316	* 2.1388	* 1.6274	* 1.8715	* 1.6002	* 2.9734
10	* 1.3660	* 1.6380	* 1.1217	* 1.3388	* 1.4740	* 1.8744	* 1.8680	* .9552
	* 2.2234	* 1.8324	* 2.5957	* 2.2685	* 2.0560	* 1.6072	* 1.6077	* 3.1357
11	* 1.7980	* 1.4283	* 1.3384	* 1.1745	* 1.6001	* 1.4010	* 1.7174	* .8223
	* 1.7028	* 2.1383	* 2.2693	* 2.2935	* 1.7512	* 2.0843	* 1.7176	* 3.5932
12	* 1.5420	* 1.8689	* 1.4739	* 1.6001	* 1.1006	* 1.3995	* 1.0304	*
	* 1.9734	* 1.6274	* 2.0561	* 1.7512	* 1.9799	* 1.7063	* 2.7335	*
13	* 1.8744	* 1.6159	* 1.8743	* 1.4009	* 1.3995	* 1.2908	* .6719	*
	* 1.6087	* 1.8717	* 1.6072	* 2.0843	* 1.7064	* 1.8239	* 3.8381	*
14	* 1.3443	* 1.8732	* 1.8680	* 1.7173	* 1.0301	* .6719	*	*
	* 2.1567	* 1.6002	* 1.6077	* 1.7176	* 2.7343	* 3.8379	*	*
15	* .7800	* .9995	* .9552	* .8223	* F-SUB-Q			
	* 3.6825	* 2.9730	* 3.1355	* 3.5932	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 196 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8723	* 1.5553	* 1.3792	* 1.8206	* 1.5538	* 1.9174	* 1.4029	* .8150
	* 3.0372	* 2.0490	* 2.3568	* 1.7809	* 2.0751	* 1.6734	* 2.2669	* 3.8768
9	* 1.5553	* 1.2766	* 1.6774	* 1.4360	* 1.8966	* 1.6361	* 1.9165	* 1.0209
	* 2.0490	* 2.5378	* 1.9320	* 2.2550	* 1.6981	* 1.9608	* 1.6592	* 3.1064
10	* 1.3792	* 1.6768	* 1.1623	* 1.3416	* 1.4773	* 1.8993	* 1.8951	* .9625
	* 2.3568	* 1.9328	* 2.7822	* 2.4042	* 2.1724	* 1.6772	* 1.6761	* 3.2990
11	* 1.8206	* 1.4362	* 1.3411	* 1.1805	* 1.6044	* 1.3958	* 1.7233	* .8153
	* 1.7809	* 2.2546	* 2.4051	* 2.4356	* 1.8453	* 2.2133	* 1.8169	* 3.8469
12	* 1.5538	* 1.8966	* 1.4772	* 1.6043	* 1.0970	* 1.3967	* 1.0184	*
	* 2.0751	* 1.6981	* 2.1725	* 1.8453	* 2.0998	* 1.7982	* 2.9134	*
13	* 1.9174	* 1.6359	* 1.8993	* 1.3958	* 1.3967	* 1.2841	* .6658	*
	* 1.6734	* 1.9611	* 1.6772	* 2.2134	* 1.7982	* 1.9240	* 4.0650	*
14	* 1.4029	* 1.9165	* 1.8951	* 1.7233	* 1.0181	* .6658	*	*
	* 2.2669	* 1.6592	* 1.6761	* 1.8169	* 2.9142	* 4.0647	*	*
15	* .8150	* 1.0210	* .9625	* .8153	* F-SUB-Q			
	* 3.8768	* 3.1060	* 3.2988	* 3.8469	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8654	* 1.5584	* 1.3767	* 1.8177	* 1.5467	* 1.9214	* 1.4101	* .8160
	* 3.2782	* 2.1965	* 2.5420	* 1.9153	* 2.2379	* 1.7929	* 2.4291	* 4.1724
9	* 1.5584	* 1.2793	* 1.6838	* 1.4291	* 1.8951	* 1.6316	* 1.9202	* 1.0180
	* 2.1965	* 2.7363	* 2.0752	* 2.4355	* 1.8237	* 2.1112	* 1.7768	* 3.3454
10	* 1.3767	* 1.6831	* 1.1647	* 1.3339	* 1.4662	* 1.8954	* 1.8918	* .9579
	* 2.5420	* 2.0760	* 3.0031	* 2.6022	* 2.3410	* 1.7946	* 1.7958	* 3.5564
11	* 1.8177	* 1.4294	* 1.3334	* 1.1736	* 1.5919	* 1.3796	* 1.7105	* .8035
	* 1.9153	* 2.4350	* 2.6032	* 2.5968	* 1.9651	* 2.3636	* 1.9554	* 4.1551
12	* 1.5467	* 1.8950	* 1.4661	* 1.5918	* 1.0858	* 1.3798	* 1.0041	*
	* 2.2379	* 1.8237	* 2.3410	* 1.9651	* 2.2461	* 1.9212	* 3.1050	*
13	* 1.9214	* 1.6314	* 1.8954	* 1.3795	* 1.3797	* 1.2655	* .6525	*
	* 1.7929	* 2.1115	* 1.7946	* 2.3637	* 1.9213	* 2.0617	* 4.3759	*
14	* 1.4101	* 1.9202	* 1.8918	* 1.7104	* 1.0037	* .6525	*	*
	* 2.4291	* 1.7768	* 1.7958	* 1.9554	* 3.1060	* 4.3757	*	*
15	* .8160	* 1.0181	* .9579	* .8035	* F-SUB-Q			
	* 4.1724	* 3.3449	* 3.5562	* 4.1552	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 197 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8612 *	* 1.5576 *	* 1.3682 *	* 1.8116 *	* 1.5334 *	* 1.9160 *	* 1.4019 *	* .8137 *
	* 3.5876 *	* 2.3899 *	* 2.7904 *	* 2.0808 *	* 2.4357 *	* 1.9446 *	* 2.6566 *	* 4.5486 *
9	* 1.5576 *	* 1.2733 *	* 1.6829 *	* 1.4170 *	* 1.8884 *	* 1.6192 *	* 1.9138 *	* 1.0107 *
	* 2.3899 *	* 3.0048 *	* 2.2661 *	* 2.6590 *	* 1.9716 *	* 2.2955 *	* 1.9194 *	* 3.6389 *
10	* 1.3682 *	* 1.6822 *	* 1.1564 *	* 1.3195 *	* 1.4516 *	* 1.8866 *	* 1.8828 *	* .9452 *
	* 2.7904 *	* 2.2670 *	* 3.2988 *	* 2.8459 *	* 2.5470 *	* 1.9351 *	* 1.9329 *	* 3.8683 *
11	* 1.8116 *	* 1.4173 *	* 1.3190 *	* 1.1641 *	* 1.5790 *	* 1.3635 *	* 1.6957 *	* .7903 *
	* 2.0808 *	* 2.6584 *	* 2.8468 *	* 2.8247 *	* 2.1273 *	* 2.5703 *	* 2.1306 *	* 4.5509 *
12	* 1.5334 *	* 1.8883 *	* 1.4515 *	* 1.5789 *	* 1.0745 *	* 1.3667 *	* .9885 *	
	* 2.4357 *	* 1.9717 *	* 2.5471 *	* 2.1274 *	* 2.4435 *	* 2.0785 *	* 3.3801 *	
13	* 1.9160 *	* 1.6189 *	* 1.8865 *	* 1.3634 *	* 1.3666 *	* 1.2526 *	* .6445 *	
	* 1.9446 *	* 2.2958 *	* 1.9351 *	* 2.5704 *	* 2.0785 *	* 2.2306 *	* 4.7350 *	
14	* 1.4019 *	* 1.9138 *	* 1.8827 *	* 1.6956 *	* .9882 *	* .6446 *		
	* 2.6566 *	* 1.9194 *	* 1.9329 *	* 2.1306 *	* 3.3812 *	* 4.7347 *		
15	* .8137 *	* 1.0108 *	* .9452 *	* .7903 *	* F-SUB-Q			
	* 4.5486 *	* 3.6383 *	* 3.8682 *	* 4.5510 *	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8512 *	* 1.5238 *	* 1.3426 *	* 1.7651 *	* 1.4987 *	* 1.8659 *	* 1.3724 *	* .7944 *
	* 4.0034 *	* 2.6514 *	* 3.1003 *	* 2.3243 *	* 2.7088 *	* 2.1634 *	* 2.9271 *	* 5.0188 *
9	* 1.5238 *	* 1.2489 *	* 1.6425 *	* 1.3883 *	* 1.8390 *	* 1.5824 *	* 1.8637 *	* .9937 *
	* 2.6514 *	* 3.3466 *	* 2.5356 *	* 2.9557 *	* 2.2025 *	* 2.5497 *	* 2.1356 *	* 3.9950 *
10	* 1.3426 *	* 1.6418 *	* 1.1508 *	* 1.3076 *	* 1.4275 *	* 1.8369 *	* 1.8325 *	* .9384 *
	* 3.1003 *	* 2.5367 *	* 3.6471 *	* 3.1301 *	* 2.8298 *	* 2.1674 *	* 2.1623 *	* 4.2215 *
11	* 1.7651 *	* 1.3885 *	* 1.3071 *	* 1.1427 *	* 1.5430 *	* 1.3321 *	* 1.6563 *	* .7864 *
	* 2.3243 *	* 2.9550 *	* 3.1312 *	* 3.1491 *	* 2.3845 *	* 2.8707 *	* 2.3916 *	* 4.9977 *
12	* 1.4987 *	* 1.8389 *	* 1.4275 *	* 1.5429 *	* 1.0661 *	* 1.3317 *	* .9776 *	
	* 2.7088 *	* 2.2025 *	* 2.8298 *	* 2.3845 *	* 2.7325 *	* 2.3295 *	* 3.7246 *	
13	* 1.8659 *	* 1.5821 *	* 1.8369 *	* 1.3320 *	* 1.3316 *	* 1.2222 *	* .6302 *	
	* 2.1634 *	* 2.5501 *	* 2.1674 *	* 2.8708 *	* 2.3295 *	* 2.4914 *	* 5.2787 *	
14	* 1.3724 *	* 1.8636 *	* 1.8325 *	* 1.6562 *	* .9773 *	* .6302 *		
	* 2.9271 *	* 2.1357 *	* 2.1623 *	* 2.3916 *	* 3.7257 *	* 5.2783 *		
15	* .7944 *	* .9938 *	* .9384 *	* .7864 *	* F-SUB-Q			
	* 5.0188 *	* 3.9944 *	* 4.2214 *	* 4.9978 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 198 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8540	* 1.5295	* 1.3311	* 1.7652	* 1.4841	* 1.8648	* 1.3585	* .7867
	* 4.1367	* 2.7158	* 3.3673	* 2.5498	* 3.0155	* 2.3873	* 3.2511	* 5.5560
9	* 1.5295	* 1.2404	* 1.6451	* 1.3741	* 1.8379	* 1.5694	* 1.8628	* .9794
	* 2.7158	* 3.4571	* 2.7138	* 3.2718	* 2.4364	* 2.8394	* 2.3569	* 4.4589
10	* 1.3311	* 1.6445	* 1.1259	* 1.2813	* 1.4057	* 1.8374	* 1.8323	* .9168
	* 3.3673	* 2.7150	* 3.9298	* 3.4826	* 3.1396	* 2.4006	* 2.3934	* 4.7625
11	* 1.7652	* 1.3744	* 1.2808	* 1.1364	* 1.5431	* 1.3237	* 1.6487	* .7640
	* 2.5499	* 3.2712	* 3.4839	* 3.3489	* 2.5417	* 3.0551	* 2.6056	* 5.6897
12	* 1.4841	* 1.8378	* 1.4056	* 1.5430	* 1.0718	* 1.3370	* .9624	*
	* 3.0155	* 2.4365	* 3.1398	* 2.5418	* 2.9486	* 2.5095	* 4.0472	*
13	* 1.8648	* 1.5691	* 1.8374	* 1.3236	* 1.3369	* 1.2317	* .6285	*
	* 2.3873	* 2.8398	* 2.4007	* 3.0553	* 2.5096	* 2.7085	* 5.7498	*
14	* 1.3585	* 1.8627	* 1.8323	* 1.6487	* .9620	* .6285	*	*
	* 3.2511	* 2.3569	* 2.3934	* 2.6057	* 4.0485	* 5.7494	*	*
15	* .7867	* .9795	* .9168	* .7640	* F-SUB-Q			
	* 5.5560	* 4.4583	* 4.7625	* 5.6898	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8498	* 1.5160	* 1.3132	* 1.7426	* 1.4605	* 1.8392	* 1.3371	* .7728
	* 4.3197	* 2.8242	* 3.3807	* 2.5356	* 3.0068	* 2.3933	* 3.2827	* 5.6758
9	* 1.5160	* 1.2244	* 1.6262	* 1.3539	* 1.8134	* 1.5455	* 1.8382	* .9644
	* 2.8242	* 3.6023	* 2.7406	* 3.2601	* 2.4343	* 2.8471	* 2.4089	* 4.5748
10	* 1.3132	* 1.6256	* 1.1121	* 1.2639	* 1.3852	* 1.8151	* 1.8093	* .9039
	* 3.3807	* 2.7416	* 4.0187	* 3.5168	* 3.2115	* 2.4567	* 2.4607	* 4.8950
11	* 1.7426	* 1.3541	* 1.2634	* 1.1249	* 1.5288	* 1.3076	* 1.6294	* .7532
	* 2.5356	* 3.2595	* 3.5181	* 3.4789	* 2.6434	* 3.1768	* 2.7046	* 5.9419
12	* 1.4605	* 1.8134	* 1.3851	* 1.5287	* 1.0696	* 1.3291	* .9533	*
	* 3.0068	* 2.4344	* 3.2117	* 2.6434	* 3.0708	* 2.6159	* 4.2114	*
13	* 1.8392	* 1.5453	* 1.8151	* 1.3075	* 1.3290	* 1.2262	* .6226	*
	* 2.3933	* 2.8475	* 2.4568	* 3.1769	* 2.6159	* 2.8258	* 6.0123	*
14	* 1.3371	* 1.8382	* 1.8092	* 1.6293	* .9529	* .6227	*	*
	* 3.2827	* 2.4090	* 2.4608	* 2.7046	* 4.2129	* 6.0119	*	*
15	* .7728	* .9645	* .9039	* .7532	* F-SUB-Q			
	* 5.6758	* 4.5743	* 4.8950	* 5.9422	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 199 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8412	* 1.4871	* 1.2907	* 1.7036	* 1.4304	* 1.7961	* 1.3102	* .7577
	* 4.5124	* 2.9625	* 3.4219	* 2.5802	* 3.0537	* 2.4359	* 3.3280	* 5.7486
9	* 1.4871	* 1.2029	* 1.5916	* 1.3287	* 1.7723	* 1.5136	* 1.7970	* .9489
	* 2.9625	* 3.7029	* 2.7849	* 3.3053	* 2.4782	* 2.8916	* 2.4515	* 4.6242
10	* 1.2907	* 1.5910	* 1.1049	* 1.2537	* 1.3678	* 1.7763	* 1.7701	* .8960
	* 3.4219	* 2.7860	* 4.0244	* 3.5319	* 3.2392	* 2.5020	* 2.5062	* 4.9157
11	* 1.7036	* 1.3289	* 1.2533	* 1.1084	* 1.4997	* 1.2855	* 1.6018	* .7510
	* 2.5802	* 3.3047	* 3.5331	* 3.6505	* 2.7907	* 3.3431	* 2.8131	* 5.9509
12	* 1.4304	* 1.7722	* 1.3677	* 1.4996	* 1.0607	* 1.3083	* .9483	*
	* 3.0537	* 2.4782	* 3.2393	* 2.7908	* 3.2346	* 2.7635	* 4.3880	*
13	* 1.7961	* 1.5134	* 1.7762	* 1.2854	* 1.3083	* 1.2091	* .6159	*
	* 2.4359	* 2.8920	* 2.5020	* 3.3433	* 2.7636	* 2.9790	* 6.3207	*
14	* 1.3102	* 1.7969	* 1.7701	* 1.6018	* .9480	* .6159	*	*
	* 3.3280	* 2.4516	* 2.5062	* 2.8131	* 4.3895	* 6.3203	*	*
15	* .7577	* .9490	* .8960	* .7510	* F-SUB-Q			
	* 5.7486	* 4.6237	* 4.9157	* 5.9511	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8374	* 1.4971	* 1.2846	* 1.7092	* 1.4216	* 1.8005	* 1.3016	* .7527
	* 4.3923	* 2.8784	* 3.4121	* 2.5593	* 3.0585	* 2.4229	* 3.3351	* 5.7506
9	* 1.4971	* 1.1994	* 1.5994	* 1.3205	* 1.7774	* 1.5068	* 1.8043	* .9435
	* 2.8784	* 3.6764	* 2.7535	* 3.3061	* 2.4640	* 2.8949	* 2.4395	* 4.6312
10	* 1.2846	* 1.5989	* 1.0884	* 1.2345	* 1.3537	* 1.7869	* 1.7807	* .8822
	* 3.4121	* 2.7545	* 4.0458	* 3.5696	* 3.2680	* 2.4889	* 2.4929	* 4.9764
11	* 1.7092	* 1.3208	* 1.2341	* 1.1081	* 1.5132	* 1.2864	* 1.6074	* .7378
	* 2.5593	* 3.3054	* 3.5708	* 3.5912	* 2.7420	* 3.3113	* 2.8039	* 6.0512
12	* 1.4216	* 1.7773	* 1.3536	* 1.5131	* 1.0594	* 1.3250	* .9431	*
	* 3.0585	* 2.4641	* 3.2681	* 2.7420	* 3.1854	* 2.7116	* 4.3513	*
13	* 1.8005	* 1.5066	* 1.7869	* 1.2863	* 1.3249	* 1.2295	* .6225	*
	* 2.4229	* 2.8953	* 2.4889	* 3.3114	* 2.7116	* 2.9137	* 6.1196	*
14	* 1.3016	* 1.8042	* 1.7807	* 1.6075	* .9428	* .6225	*	*
	* 3.3351	* 2.4396	* 2.4929	* 2.8039	* 4.3528	* 6.1191	*	*
15	* .7527	* .9436	* .8822	* .7378	* F-SUB-Q			
	* 5.7506	* 4.6306	* 4.9764	* 6.0514	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 200 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8361	* 1.5032	* 1.2811	* 1.7066	* 1.4125	* 1.7953	* 1.2927	* .7444
	* 3.9298	* 2.5662	* 3.1746	* 2.4062	* 2.9035	* 2.3066	* 3.1770	* 5.4631
9	* 1.5032	* 1.1978	* 1.6006	* 1.3138	* 1.7740	* 1.4986	* 1.8025	* .9374
	* 2.5662	* 3.2904	* 2.5576	* 3.1036	* 2.3354	* 2.7548	* 2.3239	* 4.3905
10	* 1.2811	* 1.6000	* 1.0808	* 1.2290	* 1.3500	* 1.7898	* 1.7831	* .8746
	* 3.1746	* 2.5585	* 3.7528	* 3.3271	* 3.0598	* 2.3600	* 2.3676	* 4.7230
11	* 1.7066	* 1.3141	* 1.2286	* 1.1136	* 1.5261	* 1.2919	* 1.6143	* .7338
	* 2.4062	* 3.1029	* 3.3319	* 3.2089	* 2.4473	* 2.9646	* 2.5225	* 5.6218
12	* 1.4125	* 1.7739	* 1.3499	* 1.5261	* 1.0700	* 1.3463	* .9501	*
	* 2.9035	* 2.3354	* 3.0599	* 2.4472	* 2.8502	* 2.4236	* 3.9049	*
13	* 1.7953	* 1.4984	* 1.7898	* 1.2919	* 1.3463	* 1.2557	* .6313	*
	* 2.3066	* 2.7552	* 2.3599	* 2.9647	* 2.4236	* 2.6069	* 5.5039	*
14	* 1.2927	* 1.8025	* 1.7831	* 1.6143	* .9498	* .6314	*	*
	* 3.1770	* 2.3239	* 2.3676	* 2.5224	* 3.9063	* 5.5034	*	*
15	* .7444	* .9375	* .8746	* .7338	* F-SUB-Q			
	* 5.4631	* 4.3899	* 4.7230	* 5.6220	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8522	* 1.5197	* 1.2836	* 1.7060	* 1.4077	* 1.7911	* 1.2873	* .7418
	* 3.5238	* 2.2961	* 2.8044	* 2.1255	* 2.5720	* 2.0406	* 2.8179	* 4.8492
9	* 1.5197	* 1.2044	* 1.6060	* 1.3129	* 1.7724	* 1.4946	* 1.8016	* .9358
	* 2.2961	* 2.9483	* 2.2562	* 2.7449	* 2.0644	* 2.4393	* 2.0557	* 3.8922
10	* 1.2836	* 1.6054	* 1.0902	* 1.2345	* 1.3534	* 1.7952	* 1.7867	* .8773
	* 2.8044	* 2.2570	* 3.3080	* 2.9333	* 2.7223	* 2.0840	* 2.0917	* 4.1706
11	* 1.7060	* 1.3132	* 1.2341	* 1.1339	* 1.5550	* 1.3107	* 1.6288	* .7388
	* 2.1255	* 2.7442	* 2.9368	* 2.8871	* 2.2025	* 2.6712	* 2.2663	* 5.0266
12	* 1.4077	* 1.7723	* 1.3534	* 1.5550	* 1.1093	* 1.3963	* .9729	*
	* 2.5720	* 2.0645	* 2.7224	* 2.2025	* 2.5667	* 2.1830	* 3.5126	*
13	* 1.7911	* 1.4944	* 1.7952	* 1.3107	* 1.3963	* 1.3072	* .6521	*
	* 2.0406	* 2.4396	* 2.0839	* 2.6713	* 2.1830	* 2.3482	* 4.9680	*
14	* 1.2873	* 1.8015	* 1.7867	* 1.6288	* .9726	* .6521	*	*
	* 2.8179	* 2.0557	* 2.0917	* 2.2662	* 3.5138	* 4.9676	*	*
15	* .7418	* .9360	* .8773	* .7388	* F-SUB-Q			
	* 4.8492	* 3.8916	* 4.1707	* 5.0268	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 201 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9078	* 1.5463	* 1.2903	* 1.7014	* 1.4046	* 1.7818	* 1.2834	* .7393
	* 3.1697	* 2.0708	* 2.5114	* 1.9124	* 2.3117	* 1.8384	* 2.5349	* 4.3713
9	* 1.5463	* 1.2221	* 1.6099	* 1.3151	* 1.7663	* 1.4918	* 1.7959	* .9396
	* 2.0708	* 2.6517	* 2.0262	* 2.4608	* 1.8582	* 2.1922	* 1.8509	* 3.4841
10	* 1.2903	* 1.6093	* 1.1122	* 1.2540	* 1.3663	* 1.7979	* 1.7870	* .8870
	* 2.5114	* 2.0269	* 2.9259	* 2.6136	* 2.4292	* 1.8721	* 1.8802	* 3.7096
11	* 1.7014	* 1.3154	* 1.2536	* 1.1743	* 1.5988	* 1.3424	* 1.6486	* .7559
	* 1.9124	* 2.4602	* 2.6144	* 2.6056	* 2.0017	* 2.4125	* 2.0437	* 4.4353
12	* 1.4046	* 1.7663	* 1.3663	* 1.5988	* 1.2227	* 1.4935	* 1.0128	*
	* 2.3117	* 1.8583	* 2.4293	* 2.0017	* 2.3252	* 1.9866	* 3.1543	*
13	* 1.7818	* 1.4916	* 1.7979	* 1.3424	* 1.4935	* 1.3921	* .6830	*
	* 1.8384	* 2.1926	* 1.8721	* 2.4126	* 1.9866	* 2.1331	* 4.5169	*
14	* 1.2834	* 1.7959	* 1.7871	* 1.6487	* 1.0125	* .6831	*	*
	* 2.5349	* 1.8510	* 1.8801	* 2.0437	* 3.1554	* 4.5165	*	*
15	* .7393	* .9397	* .8870	* .7559	* F-SUB-Q			
	* 4.3714	* 3.4836	* 3.7097	* 4.4354	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9960	* 1.6246	* 1.3149	* 1.7406	* 1.4207	* 1.8176	* 1.2957	* .7463
	* 2.8493	* 1.8304	* 2.2521	* 1.7022	* 2.0795	* 1.6390	* 2.2853	* 3.9472
9	* 1.6246	* 1.2603	* 1.6586	* 1.3322	* 1.8051	* 1.5118	* 1.8371	* .9471
	* 1.8304	* 2.3608	* 1.7993	* 2.2132	* 1.6548	* 1.9685	* 1.6474	* 3.1508
10	* 1.3149	* 1.6579	* 1.1177	* 1.2626	* 1.3915	* 1.8480	* 1.8348	* .8851
	* 2.2521	* 1.7998	* 2.6621	* 2.3536	* 2.1858	* 1.6614	* 1.6692	* 3.3910
11	* 1.7406	* 1.3325	* 1.2623	* 1.2605	* 1.6940	* 1.3989	* 1.7008	* .7557
	* 1.7022	* 2.2127	* 2.3557	* 2.3493	* 1.7823	* 2.1640	* 1.8139	* 4.0588
12	* 1.4207	* 1.8051	* 1.3915	* 1.6939	* 1.3830	* 1.6568	* 1.0510	*
	* 2.0795	* 1.6548	* 2.1859	* 1.7823	* 2.0781	* 1.7682	* 2.8759	*
13	* 1.8176	* 1.5115	* 1.8480	* 1.3989	* 1.6568	* 1.5317	* .7274	*
	* 1.6390	* 1.9688	* 1.6614	* 2.1641	* 1.7682	* 1.9038	* 4.0624	*
14	* 1.2957	* 1.8371	* 1.8349	* 1.7009	* 1.0506	* .7275	*	*
	* 2.2853	* 1.6474	* 1.6692	* 1.8139	* 2.8770	* 4.0620	*	*
15	* .7463	* .9472	* .8851	* .7557	* F-SUB-Q			
	* 3.9472	* 3.1503	* 3.3911	* 4.0589	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 202 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0696	* 1.6769	* 1.3309	* 1.7557	* 1.4281	* 1.8284	* 1.3002	* .7485 *
	* 2.5628	* 1.6604	* 2.0591	* 1.5584	* 1.9109	* 1.5038	* 2.1041	* 3.6422 *
9	* 1.6769	* 1.2900	* 1.6833	* 1.3426	* 1.8190	* 1.5209	* 1.8521	* .9526 *
	* 1.6604	* 2.1528	* 1.6403	* 2.0296	* 1.5160	* 1.8072	* 1.5087	* 2.8980 *
10	* 1.3309	* 1.6827	* 1.1342	* 1.2782	* 1.4101	* 1.8701	* 1.8553	* .8903 *
	* 2.0591	* 1.6409	* 2.4308	* 2.1489	* 1.9967	* 1.5164	* 1.5246	* 3.1193 *
11	* 1.7557	* 1.3430	* 1.2779	* 1.3184	* 1.7537	* 1.4413	* 1.7328	* .7645 *
	* 1.5584	* 2.0291	* 2.1506	* 2.1228	* 1.6122	* 1.9660	* 1.6573	* 3.7100 *
12	* 1.4281	* 1.8189	* 1.4100	* 1.7537	* 1.4891	* 1.7615	* 1.0861	*
	* 1.9109	* 1.5160	* 1.9968	* 1.6122	* 1.8802	* 1.6028	* 2.6085	*
13	* 1.8284	* 1.5206	* 1.8701	* 1.4412	* 1.7615	* 1.6294	* .7595	*
	* 1.5038	* 1.8075	* 1.5164	* 1.9661	* 1.6029	* 1.7300	* 3.7025	*
14	* 1.3002	* 1.8520	* 1.8553	* 1.7328	* 1.0857	* .7596	*	
	* 2.1041	* 1.5088	* 1.5246	* 1.6573	* 2.6095	* 3.7022	*	
15	* .7485	* .9528	* .8903	* .7645	* F-SUB-Q			
	* 3.6422	* 2.8976	* 3.1193	* 3.7102	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0808	* 1.6719	* 1.3272	* 1.7284	* 1.4169	* 1.7956	* 1.2884	* .7394 *
	* 2.4192	* 1.5713	* 1.9335	* 1.4829	* 1.8055	* 1.4346	* 1.9920	* 3.4645 *
9	* 1.6719	* 1.2956	* 1.6667	* 1.3370	* 1.7897	* 1.5083	* 1.8229	* .9489 *
	* 1.5713	* 2.0065	* 1.5511	* 1.9106	* 1.4430	* 1.7075	* 1.4354	* 2.7308 *
10	* 1.3272	* 1.6664	* 1.1561	* 1.2931	* 1.4076	* 1.8436	* 1.8287	* .8975 *
	* 1.9335	* 1.5517	* 2.2300	* 2.0053	* 1.8689	* 1.4382	* 1.4468	* 2.9038 *
11	* 1.7284	* 1.3373	* 1.2927	* 1.3360	* 1.7605	* 1.4498	* 1.7264	* .7775 *
	* 1.4829	* 1.9101	* 2.0060	* 1.9943	* 1.5262	* 1.8543	* 1.5527	* 3.4141 *
12	* 1.4169	* 1.7896	* 1.4075	* 1.7604	* 1.5164	* 1.7801	* 1.1087	*
	* 1.8055	* 1.4431	* 1.8690	* 1.5262	* 1.7635	* 1.5130	* 2.4290	*
13	* 1.7956	* 1.5081	* 1.8436	* 1.4497	* 1.7801	* 1.6559	* .7690	*
	* 1.4346	* 1.7078	* 1.4382	* 1.8544	* 1.5130	* 1.6264	* 3.4886	*
14	* 1.2884	* 1.8228	* 1.8288	* 1.7265	* 1.1083	* .7691	*	
	* 1.9920	* 1.4355	* 1.4468	* 1.5527	* 2.4299	* 3.4883	*	
15	* .7394	* .9491	* .8975	* .7775	* F-SUB-Q			
	* 3.4645	* 2.7304	* 2.9038	* 3.4142	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 203 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0749	* 1.6644	* 1.3148	* 1.7076	* 1.3986	* 1.7711	* 1.2686	* .7267 *
	* 2.2898	* 1.4787	* 1.8471	* 1.4233	* 1.7362	* 1.3797	* 1.9220	* 3.3553 *
9	* 1.6644	* 1.2877	* 1.6557	* 1.3204	* 1.7657	* 1.4909	* 1.8007	* .9317 *
	* 1.4787	* 1.9006	* 1.4766	* 1.8354	* 1.3870	* 1.6389	* 1.3772	* 2.6439 *
10	* 1.3148	* 1.6555	* 1.1328	* 1.2696	* 1.3956	* 1.8204	* 1.8078	* .8734 *
	* 1.8471	* 1.4771	* 2.1541	* 1.9202	* 1.7828	* 1.3770	* 1.3849	* 2.8348 *
11	* 1.7076	* 1.3209	* 1.2693	* 1.3332	* 1.7578	* 1.4445	* 1.7070	* .7560 *
	* 1.4233	* 1.8348	* 1.9214	* 1.8978	* 1.4572	* 1.7545	* 1.4841	* 3.3329 *
12	* 1.3986	* 1.7657	* 1.3955	* 1.7578	* 1.5194	* 1.7833	* 1.0922	*
	* 1.7362	* 1.3870	* 1.7830	* 1.4573	* 1.6905	* 1.4523	* 2.3465	*
13	* 1.7711	* 1.4906	* 1.8204	* 1.4445	* 1.7833	* 1.6563	* .7683	*
	* 1.3797	* 1.6392	* 1.3771	* 1.7546	* 1.4524	* 1.5653	* 3.3655	*
14	* 1.2686	* 1.8007	* 1.8079	* 1.7070	* 1.0917	* .7684	*	
	* 1.9220	* 1.3773	* 1.3849	* 1.4841	* 2.3475	* 3.3652	*	
15	* .7267	* .9319	* .8734	* .7559	* F-SUB-Q			
	* 3.3553	* 2.6435	* 2.8349	* 3.3330	* M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0125	* 1.5464	* 1.2355	* 1.5754	* 1.3088	* 1.6326	* 1.1859	* .6774 *
	* 2.3151	* 1.5216	* 1.8871	* 1.4816	* 1.7838	* 1.4385	* 1.9791	* 3.4719 *
9	* 1.5464	* 1.2120	* 1.5371	* 1.2385	* 1.6308	* 1.3977	* 1.6619	* .8689 *
	* 1.5216	* 1.9349	* 1.5224	* 1.8804	* 1.4425	* 1.6799	* 1.4329	* 2.7306 *
10	* 1.2355	* 1.5369	* 1.0697	* 1.2027	* 1.3198	* 1.6764	* 1.6674	* .8161 *
	* 1.8871	* 1.5225	* 2.1803	* 1.9490	* 1.8072	* 1.4322	* 1.4394	* 2.9207 *
11	* 1.5754	* 1.2389	* 1.2021	* 1.2597	* 1.6326	* 1.3630	* 1.5819	* .7084 *
	* 1.4816	* 1.8798	* 1.9516	* 1.9157	* 1.4957	* 1.7779	* 1.5361	* 3.4197 *
12	* 1.3088	* 1.6308	* 1.3197	* 1.6326	* 1.4345	* 1.6606	* 1.0217	*
	* 1.7838	* 1.4425	* 1.8073	* 1.4958	* 1.6996	* 1.4829	* 2.3988	*
13	* 1.6326	* 1.3975	* 1.6764	* 1.3629	* 1.6606	* 1.5427	* .7230	*
	* 1.4385	* 1.6802	* 1.4323	* 1.7780	* 1.4830	* 1.6056	* 3.4206	*
14	* 1.1859	* 1.6618	* 1.6674	* 1.5819	* 1.0214	* .7231	*	
	* 1.9791	* 1.4331	* 1.4394	* 1.5361	* 2.3997	* 3.4205	*	
15	* .6774	* .8691	* .8160	* .7083	* F-SUB-Q			
	* 3.4719	* 2.7303	* 2.9208	* 3.4199	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 204 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 350 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8656 *	* 1.2784 *	* .9980 *	* 1.3048 *	* 1.0534 *	* 1.3488 *	* .9558 *	* .5664 *
	* 2.6271 *	* 1.7788 *	* 2.2663 *	* 1.7340 *	* 2.1513 *	* 1.6885 *	* 2.3911 *	* 4.0464 *
9	* 1.2784 *	* .9816 *	* 1.2696 *	* .9998 *	* 1.3498 *	* 1.1477 *	* 1.3604 *	* .7164 *
	* 1.7788 *	* 2.3073 *	* 1.7839 *	* 2.2609 *	* 1.6890 *	* 1.9853 *	* 1.6959 *	* 3.2224 *
10	* .9980 *	* 1.2697 *	* .9278 *	* 1.0249 *	* 1.1182 *	* 1.3831 *	* 1.3586 *	* .6810 *
	* 2.2663 *	* 1.7837 *	* 2.4380 *	* 2.2277 *	* 2.0659 *	* 1.6795 *	* 1.7112 *	* 3.4122 *
11	* 1.3048 *	* 1.0000 *	* 1.0245 *	* 1.0365 *	* 1.3589 *	* 1.1256 *	* 1.2859 *	* .5886 *
	* 1.7340 *	* 2.2604 *	* 2.2288 *	* 2.2548 *	* 1.7369 *	* 2.0863 *	* 1.8330 *	* 3.9953 *
12	* 1.0534 *	* 1.3498 *	* 1.1182 *	* 1.3589 *	* 1.2084 *	* 1.3677 *	* .8427 *	
	* 2.1513 *	* 1.6890 *	* 2.0660 *	* 1.7369 *	* 1.9502 *	* 1.7381 *	* 2.8193 *	
13	* 1.3488 *	* 1.1475 *	* 1.3830 *	* 1.1255 *	* 1.3677 *	* 1.2579 *	* .6050 *	
	* 1.6885 *	* 1.9856 *	* 1.6795 *	* 2.0864 *	* 1.7381 *	* 1.9051 *	* 3.9615 *	
14	* .9558 *	* 1.3603 *	* 1.3586 *	* 1.2859 *	* .8425 *	* .6050 *		
	* 2.3911 *	* 1.6960 *	* 1.7113 *	* 1.8330 *	* 2.8202 *	* 3.9616 *		
15	* .5664 *	* .7165 *	* .6809 *	* .5885 *	F-SUB-Q			
	* 4.0464 *	* 3.2222 *	* 3.4126 *	* 3.9956 *	M-SUB-Q			

AT 50% POWER, 350 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6197 *	* .5663 *	* .4817 *	* .5799 *	* .5076 *	* .5976 *	* .4722 *	* .4038 *
	* 3.5648 *	* 3.8849 *	* 4.5597 *	* 3.7897 *	* 4.3576 *	* 3.7012 *	* 4.7101 *	* 5.5467 *
9	* .5663 *	* .4767 *	* .5621 *	* .4893 *	* .5998 *	* .5301 *	* .5668 *	* .3597 *
	* 3.8849 *	* 4.6132 *	* 3.9111 *	* 4.4999 *	* 3.6917 *	* 4.1809 *	* 3.9535 *	* 6.2753 *
10	* .4817 *	* .5623 *	* .4891 *	* .4858 *	* .5219 *	* .6070 *	* .5816 *	* .3487 *
	* 4.5597 *	* 3.9085 *	* 4.5010 *	* 4.5723 *	* 4.3010 *	* 3.6985 *	* 3.8787 *	* 6.4783 *
11	* .5799 *	* .4895 *	* .4857 *	* .5113 *	* .6016 *	* .5237 *	* .5416 *	* .3062 *
	* 3.7897 *	* 4.4987 *	* 4.5734 *	* 4.4661 *	* 3.8101 *	* 4.3486 *	* 4.2179 *	* 7.4790 *
12	* .5076 *	* .5998 *	* .5219 *	* .6016 *	* .5551 *	* .5754 *	* .4128 *	
	* 4.3576 *	* 3.6919 *	* 4.3013 *	* 3.8102 *	* 4.1290 *	* 4.0130 *	* 5.6044 *	
13	* .5976 *	* .5300 *	* .6069 *	* .5236 *	* .5754 *	* .5319 *	* .4341 *	
	* 3.7012 *	* 4.1815 *	* 3.6987 *	* 4.3489 *	* 4.0132 *	* 4.3665 *	* 5.3825 *	
14	* .4722 *	* .5668 *	* .5816 *	* .5415 *	* .4129 *	* .4341 *		
	* 4.7101 *	* 3.9539 *	* 3.8789 *	* 4.2181 *	* 5.6034 *	* 5.3831 *		
15	* .4038 *	* .3597 *	* .3487 *	* .3062 *	F-SUB-Q			
	* 5.5467 *	* 6.2756 *	* 6.4789 *	* 7.4797 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 205 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .5883 *	* .6063 *	* .5784 *	* .7222 *	* .6545 *	* .7178 *	* .4930 *	* .4145 *
	* 3.6760 *	* 4.1228 *	* 4.3572 *	* 3.6253 *	* 3.9747 *	* 3.4913 *	* 4.2820 *	* 4.6199 *
9	* .6063 *	* .5305 *	* .6349 *	* .6176 *	* .7450 *	* .6648 *	* .6772 *	* .4608 *
	* 4.1228 *	* 4.5260 *	* 3.8415 *	* 4.2072 *	* 3.5227 *	* 3.8825 *	* 3.7410 *	* 5.4508 *
10	* .5784 *	* .6351 *	* .4732 *	* .5883 *	* .6574 *	* .7489 *	* .7105 *	* .4551 *
	* 4.3572 *	* 3.8411 *	* 4.4055 *	* 4.3696 *	* 4.0304 *	* 3.5417 *	* 3.7254 *	* 5.7333 *
11	* .7222 *	* .6177 *	* .5883 *	* .5391 *	* .6814 *	* .6349 *	* .6721 *	* .4217 *
	* 3.6253 *	* 4.2071 *	* 4.3713 *	* 4.5314 *	* 3.8111 *	* 4.1154 *	* 3.9043 *	* 6.2064 *
12	* .6545 *	* .7451 *	* .6574 *	* .6814 *	* .4941 *	* .5897 *	* .4962 *	
	* 3.9747 *	* 3.5226 *	* 4.0301 *	* 3.8111 *	* 3.9323 *	* 3.9239 *	* 5.1874 *	
13	* .7178 *	* .6648 *	* .7489 *	* .6349 *	* .5897 *	* .5392 *	* .5266 *	
	* 3.4913 *	* 3.8822 *	* 3.5416 *	* 4.1153 *	* 3.9239 *	* 4.2174 *	* 4.8179 *	
14	* .4930 *	* .6772 *	* .7105 *	* .6721 *	* .4964 *	* .5265 *		
	* 4.2820 *	* 3.7393 *	* 3.7253 *	* 3.9043 *	* 5.1855 *	* 4.8194 *		
15	* .4145 *	* .4609 *	* .4552 *	* .4217 *	F-SUB-Q			
	* 4.6199 *	* 5.4477 *	* 5.7310 *	* 6.2063 *	M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .7089 *	* 1.1848 *	* 1.1157 *	* 1.4161 *	* 1.2657 *	* 1.4148 *	* .9064 *	* .5399 *
	* 2.8715 *	* 2.1576 *	* 2.3087 *	* 1.8886 *	* 2.0975 *	* 1.8105 *	* 2.2547 *	* 3.6878 *
9	* 1.1848 *	* 1.0159 *	* 1.2467 *	* 1.1899 *	* 1.4646 *	* 1.3063 *	* 1.3959 *	* .8228 *
	* 2.1576 *	* 2.4118 *	* 2.0021 *	* 2.2288 *	* 1.8296 *	* 2.0143 *	* 1.8345 *	* 3.0463 *
10	* 1.1157 *	* 1.2469 *	* .8074 *	* 1.1036 *	* 1.2645 *	* 1.4792 *	* 1.4459 *	* .8164 *
	* 2.3087 *	* 2.0023 *	* 2.5583 *	* 2.3432 *	* 2.1668 *	* 1.8548 *	* 1.8824 *	* 3.2610 *
11	* 1.4161 *	* 1.1902 *	* 1.1035 *	* 1.0213 *	* 1.3399 *	* 1.2461 *	* 1.3930 *	* .7529 *
	* 1.8886 *	* 2.2286 *	* 2.3444 *	* 2.4156 *	* 1.9541 *	* 2.1653 *	* 1.9399 *	* 3.5902 *
12	* 1.2657 *	* 1.4646 *	* 1.2646 *	* 1.3399 *	* .9383 *	* 1.2236 *	* .9237 *	
	* 2.0975 *	* 1.8296 *	* 2.1667 *	* 1.9541 *	* 2.1080 *	* 1.9214 *	* 2.8783 *	
13	* 1.4148 *	* 1.3063 *	* 1.4793 *	* 1.2461 *	* 1.2236 *	* 1.1322 *	* .6617 *	
	* 1.8105 *	* 2.0143 *	* 1.8547 *	* 2.1653 *	* 1.9214 *	* 2.0756 *	* 3.8828 *	
14	* .9064 *	* 1.3960 *	* 1.4460 *	* 1.3930 *	* .9236 *	* .6617 *		
	* 2.2547 *	* 1.8339 *	* 1.8821 *	* 1.9399 *	* 2.8785 *	* 3.8830 *		
15	* .5399 *	* .8229 *	* .8165 *	* .7529 *	F-SUB-Q			
	* 3.6878 *	* 3.0449 *	* 3.2600 *	* 3.5902 *	M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 206 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8034	* 1.3525	* 1.2530	* 1.6230	* 1.4248	* 1.6298	* 1.0658	* .6217
	* 2.6519	* 1.9260	* 2.1006	* 1.6783	* 1.8947	* 1.6011	* 2.0358	* 3.3091
9	* 1.3525	* 1.1311	* 1.4294	* 1.3360	* 1.6832	* 1.4703	* 1.6363	* .9425
	* 1.9260	* 2.2118	* 1.7828	* 2.0279	* 1.6181	* 1.8123	* 1.6011	* 2.7188
10	* 1.2530	* 1.4295	* .9290	* 1.2645	* 1.4146	* 1.7118	* 1.6907	* .9355
	* 2.1006	* 1.7832	* 2.3647	* 2.1342	* 1.9762	* 1.6274	* 1.6328	* 2.8670
11	* 1.6230	* 1.3364	* 1.2644	* 1.1405	* 1.5309	* 1.3964	* 1.6280	* .8655
	* 1.6783	* 2.0276	* 2.1349	* 2.1829	* 1.7304	* 1.9707	* 1.6997	* 3.1863
12	* 1.4248	* 1.6832	* 1.4147	* 1.5309	* 1.0789	* 1.4106	* 1.0767	*
	* 1.8947	* 1.6181	* 1.9760	* 1.7304	* 1.9104	* 1.6873	* 2.5215	*
13	* 1.6298	* 1.4703	* 1.7119	* 1.3964	* 1.4106	* 1.3099	* .7444	*
	* 1.6011	* 1.8124	* 1.6273	* 1.9707	* 1.6873	* 1.8048	* 3.4826	*
14	* 1.0658	* 1.6363	* 1.6908	* 1.6280	* 1.0765	* .7444	*	*
	* 2.0358	* 1.6009	* 1.6326	* 1.6997	* 2.5220	* 3.4825	*	*
15	* .6217	* .9426	* .9356	* .8655	* F-SUB-Q			
	* 3.3091	* 2.7179	* 2.8664	* 3.1862	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8336	* 1.4450	* 1.3026	* 1.7410	* 1.4870	* 1.7545	* 1.1078	* .6515
	* 2.6250	* 1.8514	* 2.0723	* 1.6001	* 1.8563	* 1.5189	* 1.9948	* 3.2427
9	* 1.4450	* 1.1709	* 1.5302	* 1.3889	* 1.8096	* 1.5383	* 1.7564	* .9742
	* 1.8514	* 2.1979	* 1.7102	* 1.9957	* 1.5384	* 1.7664	* 1.5185	* 2.6693
10	* 1.3026	* 1.5302	* .9485	* 1.2981	* 1.4740	* 1.8487	* 1.8253	* .9665
	* 2.0723	* 1.7107	* 2.3647	* 2.1271	* 1.9391	* 1.5396	* 1.5443	* 2.8469
11	* 1.7410	* 1.3894	* 1.2980	* 1.1799	* 1.6361	* 1.4541	* 1.7420	* .8815
	* 1.6001	* 1.9953	* 2.1278	* 2.1457	* 1.6495	* 1.9335	* 1.6181	* 3.1863
12	* 1.4870	* 1.8096	* 1.4741	* 1.6361	* 1.1245	* 1.5059	* 1.1124	*
	* 1.8563	* 1.5384	* 1.9389	* 1.6496	* 1.8651	* 1.6114	* 2.4945	*
13	* 1.7545	* 1.5382	* 1.8488	* 1.4541	* 1.5059	* 1.3972	* .7714	*
	* 1.5189	* 1.7665	* 1.5395	* 1.9335	* 1.6114	* 1.7252	* 3.4174	*
14	* 1.1078	* 1.7564	* 1.8254	* 1.7420	* 1.1121	* .7714	*	*
	* 1.9948	* 1.5184	* 1.5442	* 1.6181	* 2.4951	* 3.4173	*	*
15	* .6515	* .9744	* .9665	* .8815	* F-SUB-Q			
	* 3.2427	* 2.6686	* 2.8465	* 3.1862	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 207 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8270	* 1.4480	* 1.2942	* 1.7479	* 1.4776	* 1.7664	* 1.1093	* .6489
	* 2.7608	* 1.9175	* 2.1667	* 1.6525	* 1.9338	* 1.5620	* 2.0780	* 3.3900
9	* 1.4480	* 1.1597	* 1.5344	* 1.3786	* 1.8190	* 1.5291	* 1.7695	* .9708
	* 1.9175	* 2.3072	* 1.7706	* 2.0866	* 1.5824	* 1.8350	* 1.5578	* 2.7759
10	* 1.2942	* 1.5343	* .9391	* 1.2904	* 1.4623	* 1.8621	* 1.8374	* .9622
	* 2.1667	* 1.7712	* 2.4958	* 2.2167	* 2.0167	* 1.5713	* 1.5776	* 2.9443
11	* 1.7479	* 1.3791	* 1.2903	* 1.1662	* 1.6346	* 1.4385	* 1.7447	* .8731
	* 1.6525	* 2.0862	* 2.2174	* 2.2331	* 1.6985	* 2.0148	* 1.6639	* 3.3301
12	* 1.4776	* 1.8191	* 1.4624	* 1.6346	* 1.1174	* 1.4987	* 1.1040	*
	* 1.9338	* 1.5824	* 2.0166	* 1.6985	* 1.9396	* 1.6618	* 2.5925	*
13	* 1.7664	* 1.5291	* 1.8621	* 1.4385	* 1.4987	* 1.3891	* .7584	*
	* 1.5620	* 1.8352	* 1.5713	* 2.0147	* 1.6618	* 1.7758	* 3.5655	*
14	* 1.1093	* 1.7695	* 1.8374	* 1.7447	* 1.1037	* .7585	*	*
	* 2.0779	* 1.5577	* 1.5775	* 1.6638	* 2.5931	* 3.5654	*	*
15	* .6489	* .9709	* .9623	* .8732	* F-SUB-Q			
	* 3.3900	* 2.7754	* 2.9440	* 3.3301	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8173	* 1.4303	* 1.2753	* 1.7255	* 1.4538	* 1.7491	* 1.1046	* .6465
	* 2.9293	* 2.0251	* 2.3116	* 1.7516	* 2.0560	* 1.6499	* 2.2032	* 3.5867
9	* 1.4303	* 1.1422	* 1.5166	* 1.3560	* 1.7967	* 1.5059	* 1.7526	* .9612
	* 2.0251	* 2.4743	* 1.8850	* 2.2200	* 1.6729	* 1.9485	* 1.6452	* 2.9398
10	* 1.2753	* 1.5165	* .9285	* 1.2754	* 1.4341	* 1.8381	* 1.8136	* .9506
	* 2.3116	* 1.8857	* 2.6665	* 2.3463	* 2.1267	* 1.6432	* 1.6517	* 3.0971
11	* 1.7255	* 1.3565	* 1.2753	* 1.1420	* 1.6017	* 1.4043	* 1.7158	* .8626
	* 1.7516	* 2.2195	* 2.3469	* 2.3665	* 1.7978	* 2.1540	* 1.7671	* 3.5170
12	* 1.4538	* 1.7968	* 1.4342	* 1.6017	* 1.0955	* 1.4611	* 1.0822	*
	* 2.0560	* 1.6729	* 2.1266	* 1.7979	* 2.0615	* 1.7641	* 2.7621	*
13	* 1.7491	* 1.5058	* 1.8381	* 1.4043	* 1.4611	* 1.3509	* .7373	*
	* 1.6499	* 1.9487	* 1.6431	* 2.1539	* 1.7641	* 1.8848	* 3.7978	*
14	* 1.1046	* 1.7526	* 1.8136	* 1.7158	* 1.0820	* .7373	*	*
	* 2.2032	* 1.6451	* 1.6516	* 1.7671	* 2.7627	* 3.7976	*	*
15	* .6465	* .9614	* .9506	* .8626	* F-SUB-Q			
	* 3.5867	* 2.9393	* 3.0968	* 3.5169	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 208 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8114 *	* 1.4338 *	* 1.2693 *	* 1.7241 *	* 1.4448 *	* 1.7591 *	* 1.1113 *	* .6601 *
	* 3.1111 *	* 2.1227 *	* 2.4665 *	* 1.8449 *	* 2.1734 *	* 1.7318 *	* 2.3349 *	* 3.8036 *
9	* 1.4338 *	* 1.1395 *	* 1.5241 *	* 1.3450 *	* 1.7955 *	* 1.5002 *	* 1.7575 *	* .9573 *
	* 2.1227 *	* 2.6565 *	* 2.0002 *	* 2.3548 *	* 1.7568 *	* 2.0558 *	* 1.7191 *	* 3.0938 *
10	* 1.2693 *	* 1.5240 *	* .9257 *	* 1.2564 *	* 1.4165 *	* 1.8336 *	* 1.8110 *	* .9405 *
	* 2.4665 *	* 2.0009 *	* 2.8753 *	* 2.5006 *	* 2.2649 *	* 1.7282 *	* 1.7351 *	* 3.2778 *
11	* 1.7241 *	* 1.3455 *	* 1.2563 *	* 1.1281 *	* 1.5840 *	* 1.3794 *	* 1.6966 *	* .8414 *
	* 1.8449 *	* 2.3542 *	* 2.5013 *	* 2.5284 *	* 1.9080 *	* 2.3063 *	* 1.8855 *	* 3.8074 *
12	* 1.4448 *	* 1.7956 *	* 1.4166 *	* 1.5840 *	* 1.0739 *	* 1.4351 *	* 1.0545 *	
	* 2.1734 *	* 1.7568 *	* 2.2649 *	* 1.9080 *	* 2.2003 *	* 1.8720 *	* 2.9629 *	
13	* 1.7591 *	* 1.5001 *	* 1.8336 *	* 1.3794 *	* 1.4351 *	* 1.3236 *	* .7198 *	
	* 1.7318 *	* 2.0560 *	* 1.7281 *	* 2.3063 *	* 1.8720 *	* 2.0015 *	* 4.0459 *	
14	* 1.1113 *	* 1.7576 *	* 1.8111 *	* 1.6967 *	* 1.0543 *	* .7199 *		
	* 2.3349 *	* 1.7190 *	* 1.7351 *	* 1.8854 *	* 2.9636 *	* 4.0456 *		
15	* .6601 *	* .9574 *	* .9405 *	* .8414 *	* F-SUB-Q			
	* 3.8036 *	* 3.0933 *	* 3.2776 *	* 3.8073 *	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8089 *	* 1.4440 *	* 1.2746 *	* 1.7248 *	* 1.4448 *	* 1.7812 *	* 1.1849 *	* .7135 *
	* 3.3440 *	* 2.2744 *	* 2.6580 *	* 1.9855 *	* 2.3452 *	* 1.8592 *	* 2.5030 *	* 4.0933 *
9	* 1.4440 *	* 1.1519 *	* 1.5448 *	* 1.3433 *	* 1.7978 *	* 1.5073 *	* 1.7804 *	* .9691 *
	* 2.2744 *	* 2.8596 *	* 2.1478 *	* 2.5430 *	* 1.8914 *	* 2.2159 *	* 1.8447 *	* 3.3348 *
10	* 1.2746 *	* 1.5446 *	* .9712 *	* 1.2546 *	* 1.4045 *	* 1.8298 *	* 1.8107 *	* .9387 *
	* 2.6580 *	* 2.1485 *	* 3.0977 *	* 2.7077 *	* 2.4531 *	* 1.8626 *	* 1.8685 *	* 3.5385 *
11	* 1.7248 *	* 1.3438 *	* 1.2545 *	* 1.1232 *	* 1.5648 *	* 1.3577 *	* 1.6775 *	* .8274 *
	* 1.9855 *	* 2.5423 *	* 2.7084 *	* 2.6961 *	* 2.0359 *	* 2.4680 *	* 2.0388 *	* 4.1238 *
12	* 1.4448 *	* 1.7978 *	* 1.4046 *	* 1.5648 *	* 1.0574 *	* 1.4052 *	* 1.0323 *	
	* 2.3452 *	* 1.8914 *	* 2.4530 *	* 2.0359 *	* 2.3559 *	* 2.0044 *	* 3.1608 *	
13	* 1.7812 *	* 1.5072 *	* 1.8298 *	* 1.3577 *	* 1.4051 *	* 1.2914 *	* .6992 *	
	* 1.8592 *	* 2.2162 *	* 1.8625 *	* 2.4680 *	* 2.0044 *	* 2.1480 *	* 4.3570 *	
14	* 1.1849 *	* 1.7805 *	* 1.8108 *	* 1.6776 *	* 1.0321 *	* .6993 *		
	* 2.5030 *	* 1.8446 *	* 1.8684 *	* 2.0387 *	* 3.1616 *	* 4.3567 *		
15	* .7135 *	* .9693 *	* .9387 *	* .8274 *	* F-SUB-Q			
	* 4.0933 *	* 3.3341 *	* 3.5382 *	* 4.1236 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 209 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8167	* 1.4692	* 1.2910	* 1.7402	* 1.4567	* 1.8204	* 1.2898	* .7845
	* 3.6381	* 2.4669	* 2.9079	* 2.1650	* 2.5617	* 2.0250	* 2.7320	* 4.4566
9	* 1.4692	* 1.1774	* 1.5861	* 1.3519	* 1.8143	* 1.5291	* 1.8217	* .9955
	* 2.4669	* 3.1276	* 2.3397	* 2.7846	* 2.0557	* 2.4190	* 2.0024	* 3.6411
10	* 1.2910	* 1.5858	* 1.0548	* 1.2623	* 1.4014	* 1.8376	* 1.8232	* .9475
	* 2.9079	* 2.3405	* 3.3895	* 2.9711	* 2.6676	* 2.0106	* 2.0162	* 3.8585
11	* 1.7402	* 1.3523	* 1.2621	* 1.1283	* 1.5572	* 1.3433	* 1.6675	* .8176
	* 2.1650	* 2.7837	* 2.9717	* 2.9254	* 2.2015	* 2.6805	* 2.2212	* 4.5171
12	* 1.4567	* 1.8144	* 1.4015	* 1.5572	* 1.0471	* 1.3850	* 1.0132	*
	* 2.5617	* 2.0556	* 2.6675	* 2.2015	* 2.5548	* 2.1652	* 3.4340	*
13	* 1.8204	* 1.5289	* 1.8377	* 1.3433	* 1.3849	* 1.2680	* .6858	*
	* 2.0250	* 2.4192	* 2.0105	* 2.6805	* 2.1652	* 2.3192	* 4.7050	*
14	* 1.2898	* 1.8217	* 1.8233	* 1.6676	* 1.0130	* .6859	*	*
	* 2.7320	* 2.0022	* 2.0161	* 2.2211	* 3.4349	* 4.7046	*	*
15	* .7845	* .9957	* .9475	* .8176	* F-SUB-Q			
	* 4.4566	* 3.6400	* 3.8578	* 4.5168	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8198	* 1.4681	* 1.2960	* 1.7260	* 1.4517	* 1.8183	* 1.3364	* .8124
	* 3.9901	* 2.6862	* 3.2263	* 2.4034	* 2.8323	* 2.2415	* 3.0105	* 4.9137
9	* 1.4681	* 1.1960	* 1.5935	* 1.3494	* 1.7982	* 1.5284	* 1.8188	* 1.0099
	* 2.6862	* 3.3931	* 2.6131	* 3.0753	* 2.2835	* 2.6722	* 2.2172	* 3.9774
10	* 1.2960	* 1.5931	* 1.1131	* 1.2784	* 1.4022	* 1.8128	* 1.8009	* .9617
	* 3.2263	* 2.6139	* 3.7405	* 3.2421	* 2.9351	* 2.2426	* 2.2462	* 4.1920
11	* 1.7260	* 1.3498	* 1.2781	* 1.1231	* 1.5251	* 1.3206	* 1.6418	* .8221
	* 2.4034	* 3.0744	* 3.2428	* 3.2409	* 2.4558	* 2.9790	* 2.4839	* 4.9329
12	* 1.4517	* 1.7983	* 1.4023	* 1.5251	* 1.0374	* 1.3447	* 1.0020	*
	* 2.8323	* 2.2834	* 2.9348	* 2.4557	* 2.8416	* 2.4149	* 3.7634	*
13	* 1.8183	* 1.5283	* 1.8128	* 1.3206	* 1.3447	* 1.2262	* .6670	*
	* 2.2415	* 2.6724	* 2.2424	* 2.9789	* 2.4148	* 2.5750	* 5.2172	*
14	* 1.3364	* 1.8189	* 1.8010	* 1.6419	* 1.0017	* .6671	*	*
	* 3.0105	* 2.2170	* 2.2459	* 2.4837	* 3.7643	* 5.2168	*	*
15	* .8124	* 1.0100	* .9618	* .8221	* F-SUB-Q			
	* 4.9137	* 3.9758	* 4.1911	* 4.9325	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 210 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8238	* 1.4948	* 1.3063	* 1.7472	* 1.4579	* 1.8442	* 1.3552	* .8259
	* 4.0821	* 2.7278	* 3.3872	* 2.5717	* 3.0711	* 2.4331	* 3.2985	* 5.4048
9	* 1.4948	* 1.2140	* 1.6240	* 1.3544	* 1.8175	* 1.5382	* 1.8441	* 1.0140
	* 2.7278	* 3.4706	* 2.7124	* 3.3149	* 2.4750	* 2.9174	* 2.4371	* 4.4170
10	* 1.3063	* 1.6236	* 1.1167	* 1.2676	* 1.3885	* 1.8267	* 1.8169	* .9532
	* 3.3872	* 2.7131	* 3.8905	* 3.5008	* 3.1757	* 2.4410	* 2.4711	* 4.7083
11	* 1.7472	* 1.3548	* 1.2673	* 1.1249	* 1.5298	* 1.3116	* 1.6388	* .8024
	* 2.5717	* 3.3142	* 3.5017	* 3.3782	* 2.5688	* 3.0971	* 2.6341	* 5.5541
12	* 1.4579	* 1.8176	* 1.3886	* 1.5298	* 1.0273	* 1.3417	* .9835	*
	* 3.0711	* 2.4749	* 3.1756	* 2.5688	* 3.0083	* 2.5477	* 3.9905	*
13	* 1.8442	* 1.5381	* 1.8268	* 1.3117	* 1.3417	* 1.2213	* .6603	*
	* 2.4331	* 2.9177	* 2.4409	* 3.0971	* 2.5477	* 2.7408	* 5.5342	*
14	* 1.3552	* 1.8442	* 1.8170	* 1.6389	* .9832	* .6603	*	*
	* 3.2985	* 2.4369	* 2.4709	* 2.6339	* 3.9916	* 5.5337	*	*
15	* .8259	* 1.0141	* .9532	* .8024	* F-SUB-Q			
	* 5.4048	* 4.4156	* 4.7074	* 5.5540	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8222	* 1.4966	* 1.3036	* 1.7412	* 1.4485	* 1.8368	* 1.3508	* .8229
	* 4.2200	* 2.8117	* 3.3900	* 2.5333	* 3.0334	* 2.3971	* 3.2509	* 5.3351
9	* 1.4966	* 1.2141	* 1.6243	* 1.3476	* 1.8081	* 1.5289	* 1.8352	* 1.0092
	* 2.8117	* 3.5845	* 2.7283	* 3.2706	* 2.4415	* 2.8801	* 2.4156	* 4.3788
10	* 1.3036	* 1.6239	* 1.1182	* 1.2615	* 1.3784	* 1.8134	* 1.8040	* .9477
	* 3.3900	* 2.7290	* 3.9652	* 3.5183	* 3.2265	* 2.4625	* 2.4728	* 4.6797
11	* 1.7412	* 1.3479	* 1.2612	* 1.1178	* 1.5160	* 1.2964	* 1.6237	* .7944
	* 2.5333	* 3.2699	* 3.5191	* 3.4836	* 2.6511	* 3.1979	* 2.7147	* 5.6540
12	* 1.4485	* 1.8082	* 1.3785	* 1.5160	* 1.0183	* 1.3254	* .9721	*
	* 3.0334	* 2.4414	* 3.2264	* 2.6510	* 3.1101	* 2.6372	* 4.1214	*
13	* 1.8368	* 1.5288	* 1.8135	* 1.2964	* 1.3254	* 1.2052	* .6503	*
	* 2.3971	* 2.8804	* 2.4624	* 3.1979	* 2.6372	* 2.8388	* 5.7420	*
14	* 1.3508	* 1.8353	* 1.8041	* 1.6238	* .9718	* .6504	*	*
	* 3.2509	* 2.4155	* 2.4726	* 2.7146	* 4.1226	* 5.7415	*	*
15	* .8229	* 1.0094	* .9478	* .7944	* F-SUB-Q			
	* 5.3351	* 4.3782	* 4.6795	* 5.6539	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 211 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8220	* 1.4782	* 1.2893	* 1.7114	* 1.4251	* 1.8028	* 1.3310	* .8123
	* 4.4049	* 2.9423	* 3.4046	* 2.5583	* 3.0588	* 2.4221	* 3.2726	* 5.3632
9	* 1.4782	* 1.2010	* 1.6004	* 1.3296	* 1.7744	* 1.5036	* 1.8003	* .9976
	* 2.9423	* 3.6741	* 2.7503	* 3.2907	* 2.4680	* 2.9051	* 2.4421	* 4.3954
10	* 1.2893	* 1.6000	* 1.1194	* 1.2582	* 1.3688	* 1.7775	* 1.7681	* .9436
	* 3.4045	* 2.7510	* 3.9403	* 3.5020	* 3.2240	* 2.4918	* 2.5024	* 4.6636
11	* 1.7114	* 1.3299	* 1.2579	* 1.1033	* 1.4873	* 1.2776	* 1.5971	* .7938
	* 2.5583	* 3.2899	* 3.5029	* 3.6399	* 2.7827	* 3.3490	* 2.8065	* 5.6164
12	* 1.4251	* 1.7744	* 1.3688	* 1.4873	* 1.0147	* 1.2992	* .9646	*
	* 3.0588	* 2.4679	* 3.2238	* 2.7826	* 3.2561	* 2.7722	* 4.2719	*
13	* 1.8028	* 1.5035	* 1.7776	* 1.2776	* 1.2992	* 1.1827	* .6397	*
	* 2.4221	* 2.9054	* 2.4916	* 3.3489	* 2.7721	* 2.9753	* 6.0107	*
14	* 1.3310	* 1.8003	* 1.7682	* 1.5972	* .9643	* .6398	*	*
	* 3.2726	* 2.4420	* 2.5023	* 2.8064	* 4.2730	* 6.0102	*	*
15	* .8123	* .9978	* .9437	* .7938	* F-SUB-Q			
	* 5.3632	* 4.3947	* 4.6633	* 5.6163	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8268	* 1.4884	* 1.2825	* 1.7139	* 1.4146	* 1.8031	* 1.3211	* .8062
	* 4.3815	* 2.9150	* 3.4277	* 2.5635	* 3.0903	* 2.4280	* 3.3054	* 5.4177
9	* 1.4884	* 1.1976	* 1.6062	* 1.3199	* 1.7746	* 1.4939	* 1.8020	* .9901
	* 2.9150	* 3.6850	* 2.7471	* 3.3242	* 2.4747	* 2.9315	* 2.4455	* 4.4399
10	* 1.2825	* 1.6058	* 1.1020	* 1.2355	* 1.3450	* 1.7783	* 1.7693	* .9262
	* 3.4277	* 2.7478	* 4.0004	* 3.5664	* 3.2903	* 2.4969	* 2.5065	* 4.7633
11	* 1.7139	* 1.3202	* 1.2340	* 1.0986	* 1.4913	* 1.2644	* 1.5908	* .7746
	* 2.5635	* 3.3233	* 3.5706	* 3.6644	* 2.7949	* 3.3818	* 2.8252	* 5.7712
12	* 1.4146	* 1.7747	* 1.3451	* 1.4913	* 1.0192	* 1.3053	* .9511	*
	* 3.0903	* 2.4746	* 3.2901	* 2.7948	* 3.2839	* 2.7806	* 4.3396	*
13	* 1.8031	* 1.4938	* 1.7784	* 1.2644	* 1.3053	* 1.1933	* .6396	*
	* 2.4280	* 2.9318	* 2.4967	* 3.3817	* 2.7806	* 2.9867	* 6.0030	*
14	* 1.3211	* 1.8020	* 1.7694	* 1.5909	* .9508	* .6396	*	*
	* 3.3054	* 2.4454	* 2.5064	* 2.8250	* 4.3409	* 6.0025	*	*
15	* .8062	* .9903	* .9263	* .7746	* F-SUB-Q			
	* 5.4177	* 4.4392	* 4.7631	* 5.7711	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 212 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8263	* 1.4863	* 1.2725	* 1.7032	* 1.3993	* 1.7893	* 1.3069	* .7950
	* 3.9800	* 2.6675	* 3.2998	* 2.4802	* 3.0090	* 2.3663	* 3.2249	* 5.2823
9	* 1.4863	* 1.1899	* 1.5992	* 1.3072	* 1.7615	* 1.4783	* 1.7893	* .9791
	* 2.6675	* 3.4102	* 2.6391	* 3.2155	* 2.4067	* 2.8593	* 2.3867	* 4.3253
10	* 1.2725	* 1.5988	* 1.0907	* 1.2248	* 1.3293	* 1.7661	* 1.7573	* .9135
	* 3.2998	* 2.6397	* 3.8447	* 3.4300	* 3.2035	* 2.4341	* 2.4455	* 4.6508
11	* 1.7032	* 1.3075	* 1.2234	* 1.0914	* 1.4846	* 1.2538	* 1.5799	* .7642
	* 2.4802	* 3.2146	* 3.4335	* 3.3410	* 2.5612	* 3.1125	* 2.6500	* 5.5735
12	* 1.3993	* 1.7616	* 1.3293	* 1.4846	* 1.0189	* 1.3025	* .9435	*
	* 3.0090	* 2.4066	* 3.2034	* 2.5611	* 2.9929	* 2.5361	* 3.9646	*
13	* 1.7893	* 1.4781	* 1.7663	* 1.2539	* 1.3025	* 1.1949	* .6362	*
	* 2.3663	* 2.8596	* 2.4339	* 3.1124	* 2.5361	* 2.7112	* 5.4204	*
14	* 1.3069	* 1.7893	* 1.7574	* 1.5801	* .9433	* .6362	*	*
	* 3.2249	* 2.3866	* 2.4453	* 2.6498	* 3.9658	* 5.4199	*	*
15	* .7950	* .9793	* .9135	* .7642	* F-SUB-Q			
	* 5.2823	* 4.3245	* 4.6506	* 5.5733	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8267	* 1.4815	* 1.2647	* 1.6911	* 1.3857	* 1.7737	* 1.2941	* .7882
	* 3.5180	* 2.3526	* 2.9391	* 2.2282	* 2.7235	* 2.1509	* 2.9283	* 4.7611
9	* 1.4815	* 1.1834	* 1.5907	* 1.2972	* 1.7470	* 1.4640	* 1.7739	* .9712
	* 2.3526	* 3.0104	* 2.3495	* 2.8815	* 2.1775	* 2.5928	* 2.1678	* 3.8976
10	* 1.2647	* 1.5903	* 1.0879	* 1.2201	* 1.3213	* 1.7521	* 1.7427	* .9089
	* 2.9391	* 2.3500	* 3.3800	* 3.0374	* 2.8490	* 2.1974	* 2.2129	* 4.1686
11	* 1.6911	* 1.2975	* 1.2186	* 1.0864	* 1.4769	* 1.2453	* 1.5706	* .7607
	* 2.2282	* 2.8807	* 3.0405	* 2.9620	* 2.2726	* 2.7642	* 2.3481	* 4.9278
12	* 1.3857	* 1.7471	* 1.3214	* 1.4769	* 1.0180	* 1.2986	* .9422	*
	* 2.7235	* 2.1775	* 2.8488	* 2.2725	* 2.6559	* 2.2524	* 3.5133	*
13	* 1.7737	* 1.4639	* 1.7523	* 1.2453	* 1.2986	* 1.1938	* .6356	*
	* 2.1509	* 2.5931	* 2.1972	* 2.7641	* 2.2524	* 2.4074	* 4.8208	*
14	* 1.2941	* 1.7739	* 1.7429	* 1.5707	* .9419	* .6356	*	*
	* 2.9283	* 2.1678	* 2.2127	* 2.3480	* 3.5143	* 4.8204	*	*
15	* .7882	* .9713	* .9090	* .7607	* F-SUB-Q			
	* 4.7611	* 3.8969	* 4.1684	* 4.9276	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 213 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8289	* 1.4740	* 1.2602	* 1.6761	* 1.3747	* 1.7548	* 1.2837	* .7824
	* 3.1185	* 2.0897	* 2.5778	* 1.9641	* 2.3997	* 1.8993	* 2.5821	* 4.2034
9	* 1.4740	* 1.1793	* 1.5797	* 1.2905	* 1.7298	* 1.4518	* 1.7552	* .9693
	* 2.0897	* 2.6672	* 2.0668	* 2.5312	* 1.9208	* 2.2849	* 1.9140	* 3.4192
10	* 1.2602	* 1.5793	* 1.0982	* 1.2227	* 1.3254	* 1.7362	* 1.7259	* .9136
	* 2.5778	* 2.0672	* 2.9471	* 2.6506	* 2.5025	* 1.9368	* 1.9509	* 3.6303
11	* 1.6761	* 1.2909	* 1.2224	* 1.0854	* 1.4692	* 1.2441	* 1.5654	* .7706
	* 1.9641	* 2.5305	* 2.6538	* 2.6370	* 2.0343	* 2.4635	* 2.0858	* 4.2973
12	* 1.3747	* 1.7298	* 1.3255	* 1.4693	* 1.0238	* 1.2955	* .9506	
	* 2.3997	* 1.9207	* 2.5024	* 2.0342	* 2.3724	* 2.0206	* 3.1099	
13	* 1.7548	* 1.4517	* 1.7364	* 1.2441	* 1.2955	* 1.1938	* .6384	
	* 1.8993	* 2.2851	* 1.9367	* 2.4635	* 2.0206	* 2.1537	* 4.3171	
14	* 1.2837	* 1.7553	* 1.7261	* 1.5655	* .9503	* .6385		
	* 2.5821	* 1.9139	* 1.9507	* 2.0856	* 3.1108	* 4.3167		
15	* .7824	* .9695	* .9136	* .7706	* F-SUB-Q			
	* 4.2034	* 3.4185	* 3.6301	* 4.2972	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8381	* 1.5072	* 1.2717	* 1.7040	* 1.3837	* 1.7807	* 1.2906	* .7870
	* 2.7620	* 1.8273	* 2.2692	* 1.7166	* 2.1193	* 1.6634	* 2.2850	* 3.7243
9	* 1.5072	* 1.1941	* 1.6101	* 1.2997	* 1.7569	* 1.4633	* 1.7841	* .9726
	* 1.8273	* 2.3502	* 1.8015	* 2.2345	* 1.6803	* 2.0149	* 1.6733	* 3.0343
10	* 1.2717	* 1.6098	* 1.0941	* 1.2290	* 1.3232	* 1.7676	* 1.7567	* .9072
	* 2.2692	* 1.8019	* 2.6286	* 2.3437	* 2.2189	* 1.6890	* 1.7019	* 3.2545
11	* 1.7040	* 1.3001	* 1.2279	* 1.1036	* 1.5064	* 1.2614	* 1.5908	* .7626
	* 1.7166	* 2.2339	* 2.3455	* 2.3431	* 1.7879	* 2.1850	* 1.8333	* 3.8689
12	* 1.3837	* 1.7570	* 1.3232	* 1.5064	* 1.0400	* 1.3363	* .9593	
	* 2.1193	* 1.6802	* 2.2188	* 1.7878	* 2.0932	* 1.7759	* 2.7963	
13	* 1.7807	* 1.4632	* 1.7678	* 1.2614	* 1.3363	* 1.2390	* .6564	
	* 1.6634	* 2.0151	* 1.6889	* 2.1849	* 1.7758	* 1.9005	* 3.8300	
14	* 1.2906	* 1.7841	* 1.7569	* 1.5910	* .9590	* .6564	*	
	* 2.2850	* 1.6733	* 1.7018	* 1.8331	* 2.7972	* 3.8296	*	
15	* .7870	* .9728	* .9073	* .7627	* F-SUB-Q			
	* 3.7243	* 3.0336	* 3.2543	* 3.8688	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 214 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .8611 *	* 1.5397 *	* 1.2872 *	* 1.7216 *	* 1.3933 *	* 1.7949 *	* 1.2979 *	* .7914 *
	* 2.4473 *	* 1.6294 *	* 2.0315 *	* 1.5390 *	* 1.9076 *	* 1.4945 *	* 2.0606 *	* 3.3643 *
9	* 1.5397 *	* 1.2133 *	* 1.6329 *	* 1.3118 *	* 1.7736 *	* 1.4741 *	* 1.8007 *	* .9803 *
	* 1.6294 *	* 2.1030 *	* 1.6086 *	* 2.0066 *	* 1.5072 *	* 1.8123 *	* 1.5014 *	* 2.7327 *
10	* 1.2872 *	* 1.6325 *	* 1.1100 *	* 1.2460 *	* 1.3397 *	* 1.7897 *	* 1.7770 *	* .9144 *
	* 2.0315 *	* 1.6089 *	* 2.3466 *	* 2.0956 *	* 1.9849 *	* 1.5095 *	* 1.5231 *	* 2.9306 *
11	* 1.7216 *	* 1.3122 *	* 1.2450 *	* 1.1334 *	* 1.5490 *	* 1.2912 *	* 1.6187 *	* .7721 *
	* 1.5390 *	* 2.0060 *	* 2.0970 *	* 2.0868 *	* 1.5950 *	* 1.9500 *	* 1.6448 *	* 3.4637 *
12	* 1.3933 *	* 1.7736 *	* 1.3397 *	* 1.5491 *	* 1.0846 *	* 1.3857 *	* .9870 *	
	* 1.9076 *	* 1.5071 *	* 1.9848 *	* 1.5949 *	* 1.8669 *	* 1.5868 *	* 2.4971 *	
13	* 1.7949 *	* 1.4740 *	* 1.7899 *	* 1.2913 *	* 1.3857 *	* 1.2987 *	* .6818 *	
	* 1.4945 *	* 1.8124 *	* 1.5094 *	* 1.9500 *	* 1.5868 *	* 1.7021 *	* 3.4377 *	
14	* 1.2979 *	* 1.8008 *	* 1.7771 *	* 1.6188 *	* .9866 *	* .6818 *		
	* 2.0606 *	* 1.5013 *	* 1.5230 *	* 1.6447 *	* 2.4980 *	* 3.4373 *		
15	* .7914 *	* .9805 *	* .9144 *	* .7721 *	* F-SUB-Q			
	* 3.3643 *	* 2.7321 *	* 2.9304 *	* 3.4636 *	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9221 *	* 1.5657 *	* 1.2994 *	* 1.7166 *	* 1.3962 *	* 1.7849 *	* 1.2985 *	* .7900 *
	* 2.2597 *	* 1.5037 *	* 1.8607 *	* 1.4251 *	* 1.7590 *	* 1.3873 *	* 1.9037 *	* 3.1211 *
9	* 1.5657 *	* 1.2328 *	* 1.6364 *	* 1.3202 *	* 1.7671 *	* 1.4765 *	* 1.7922 *	* .9867 *
	* 1.5037 *	* 1.9220 *	* 1.4823 *	* 1.8426 *	* 1.3964 *	* 1.6711 *	* 1.3925 *	* 2.5120 *
10	* 1.2994 *	* 1.6361 *	* 1.1430 *	* 1.2681 *	* 1.3655 *	* 1.7892 *	* 1.7735 *	* .9317 *
	* 1.8607 *	* 1.4826 *	* 2.1038 *	* 1.9042 *	* 1.8052 *	* 1.3932 *	* 1.4081 *	* 2.6613 *
11	* 1.7166 *	* 1.3206 *	* 1.2667 *	* 1.1726 *	* 1.5902 *	* 1.3251 *	* 1.6387 *	* .7959 *
	* 1.4251 *	* 1.8420 *	* 1.9060 *	* 1.9175 *	* 1.4726 *	* 1.7988 *	* 1.5036 *	* 3.1073 *
12	* 1.3962 *	* 1.7672 *	* 1.3656 *	* 1.5903 *	* 1.2014 *	* 1.4674 *	* 1.0313 *	
	* 1.7590 *	* 1.3964 *	* 1.8051 *	* 1.4725 *	* 1.7121 *	* 1.4651 *	* 2.2740 *	
13	* 1.7849 *	* 1.4764 *	* 1.7894 *	* 1.3252 *	* 1.4674 *	* 1.3741 *	* .7105 *	
	* 1.3873 *	* 1.6713 *	* 1.3931 *	* 1.7987 *	* 1.4650 *	* 1.5644 *	* 3.1712 *	
14	* 1.2985 *	* 1.7923 *	* 1.7737 *	* 1.6388 *	* 1.0310 *	* .7106 *		
	* 1.9037 *	* 1.3925 *	* 1.4080 *	* 1.5035 *	* 2.2747 *	* 3.1709 *		
15	* .7900 *	* .9869 *	* .9317 *	* .7960 *	* F-SUB-Q			
	* 3.1211 *	* 2.5115 *	* 2.6612 *	* 3.1072 *	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 215 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0053	* 1.6185	* 1.3126	* 1.7303	* 1.4016	* 1.7951	* 1.3003	* .7895 *
	* 2.0925	* 1.3818	* 1.7323	* 1.3290	* 1.6476	* 1.2960	* 1.7888	* 2.9442 *
9	* 1.6185	* 1.2607	* 1.6592	* 1.3272	* 1.7807	* 1.4856	* 1.8060	* .9856 *
	* 1.3818	* 1.7758	* 1.3745	* 1.7245	* 1.3021	* 1.5617	* 1.2985	* 2.3692 *
10	* 1.3126	* 1.6589	* 1.1446	* 1.2776	* 1.3726	* 1.8090	* 1.7912	* .9227 *
	* 1.7323	* 1.3748	* 1.9816	* 1.7797	* 1.6855	* 1.2944	* 1.3099	* 2.5316 *
11	* 1.7303	* 1.3277	* 1.2769	* 1.2409	* 1.6570	* 1.3679	* 1.6595	* .7887 *
	* 1.3290	* 1.7239	* 1.7806	* 1.7785	* 1.3626	* 1.6585	* 1.4019	* 2.9607 *
12	* 1.4016	* 1.7807	* 1.3727	* 1.6571	* 1.3401	* 1.6020	* 1.0555	* .7440 *
	* 1.6476	* 1.3021	* 1.6854	* 1.3626	* 1.5995	* 1.3674	* 2.1418	* .9227 *
13	* 1.7951	* 1.4854	* 1.8091	* 1.3680	* 1.6020	* 1.4818	* 1.7440	* .7440 *
	* 1.2960	* 1.5619	* 1.2943	* 1.6585	* 1.3674	* 1.4709	* 2.9870	* .7440 *
14	* 1.3003	* 1.8060	* 1.7914	* 1.6596	* 1.0552	* .7441	* .7441	* .7441 *
	* 1.7888	* 1.2984	* 1.3098	* 1.4018	* 2.1425	* 2.9868	* 2.9868	* 2.9868 *
15	* .7895	* .9858	* .9227	* .7887	* F-SUB-Q			
	* 2.9442	* 2.3687	* 2.5315	* 2.9607	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0312	* 1.5673	* 1.2688	* 1.6427	* 1.3462	* 1.7026	* 1.2472	* .7544 *
	* 2.0561	* 1.3787	* 1.7138	* 1.3370	* 1.6391	* 1.3046	* 1.7834	* 2.9535 *
9	* 1.5673	* 1.2333	* 1.5844	* 1.2783	* 1.6928	* 1.4318	* 1.7179	* .9428 *
	* 1.3787	* 1.7526	* 1.3758	* 1.7115	* 1.3079	* 1.5479	* 1.3038	* 2.3723 *
10	* 1.2688	* 1.5842	* 1.1151	* 1.2431	* 1.3356	* 1.7223	* 1.7056	* .8838 *
	* 1.7138	* 1.3760	* 1.9456	* 1.7524	* 1.6544	* 1.2981	* 1.3136	* 2.5321 *
11	* 1.6427	* 1.2788	* 1.2418	* 1.2419	* 1.6168	* 1.3488	* 1.5918	* .7610 *
	* 1.3370	* 1.7109	* 1.7542	* 1.7412	* 1.3539	* 1.6281	* 1.4045	* 2.9416 *
12	* 1.3462	* 1.6929	* 1.3356	* 1.6168	* 1.3772	* 1.6047	* 1.0317	* .7366 *
	* 1.6391	* 1.3078	* 1.6543	* 1.3539	* 1.5605	* 1.3490	* 2.1258	* .7366 *
13	* 1.7026	* 1.4316	* 1.7224	* 1.3488	* 1.6047	* 1.4804	* .7365	* .7365 *
	* 1.3046	* 1.5481	* 1.2981	* 1.6281	* 1.3490	* 1.4577	* 2.9444	* .7365 *
14	* 1.2472	* 1.7179	* 1.7057	* 1.5919	* 1.0314	* .7366	* .7366	* .7366 *
	* 1.7834	* 1.3038	* 1.3136	* 1.4044	* 2.1265	* 2.9442	* 2.9442	* 2.9442 *
15	* .7544	* .9430	* .8838	* .7611	* F-SUB-Q			
	* 2.9535	* 2.3719	* 2.5320	* 2.9416	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 216 of 311

TABLE 4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 460 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .9282	* 1.3532	* 1.0734	* 1.4012	* 1.1336	* 1.4482	* 1.0457	* .6515
	* 2.2507	* 1.5510	* 1.9591	* 1.5147	* 1.8819	* 1.4816	* 2.0585	* 3.3211
9	* 1.3532	* 1.0529	* 1.3576	* 1.0800	* 1.4429	* 1.2283	* 1.4552	* .8038
	* 1.5510	* 1.9896	* 1.5529	* 1.9597	* 1.4823	* 1.7444	* 1.4862	* 2.6990
10	* 1.0734	* 1.3575	* 1.0047	* 1.1026	* 1.1824	* 1.4636	* 1.4392	* .7592
	* 1.9591	* 1.5530	* 2.0932	* 1.9149	* 1.8078	* 1.4756	* 1.5046	* 2.8577
11	* 1.4012	* 1.0803	* 1.1023	* 1.0816	* 1.4007	* 1.1741	* 1.3549	* .6540
	* 1.5147	* 1.9592	* 1.9168	* 1.9594	* 1.5245	* 1.8253	* 1.5986	* 3.3223
12	* 1.1336	* 1.4430	* 1.1824	* 1.4008	* 1.2350	* 1.3926	* .8929	*
	* 1.8819	* 1.4823	* 1.8078	* 1.5245	* 1.7133	* 1.5268	* 2.4028	*
13	* 1.4482	* 1.2282	* 1.4636	* 1.1741	* 1.3926	* 1.2846	* .6466	*
	* 1.4816	* 1.7446	* 1.4755	* 1.8253	* 1.5268	* 1.6559	* 3.2968	*
14	* 1.0457	* 1.4552	* 1.4393	* 1.3549	* .8927	* .6466	*	*
	* 2.0585	* 1.4862	* 1.5046	* 1.5986	* 2.4035	* 3.2968	*	*
15	* .6515	* .8039	* .7592	* .6540	* F-SUB-Q			
	* 3.3211	* 2.6987	* 2.8578	* 3.3223	* M-SUB-Q			

AT 50% POWER, 460 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* .6995	* .6498	* .5580	* .6688	* .5866	* .6880	* .5515	* .4902
	* 2.9166	* 3.1382	* 3.6577	* 3.0796	* 3.5366	* 3.0246	* 3.7960	* 4.3095
9	* .6498	* .5513	* .6486	* .5657	* .6874	* .6116	* .6561	* .4330
	* 3.1382	* 3.6981	* 3.1554	* 3.6465	* 3.0192	* 3.4035	* 3.1983	* 4.8823
10	* .5580	* .6486	* .5697	* .5618	* .5952	* .6901	* .6668	* .4190
	* 3.6577	* 3.1539	* 3.5927	* 3.6759	* 3.4926	* 3.0225	* 3.1497	* 5.0458
11	* .6688	* .5659	* .5618	* .5710	* .6708	* .5900	* .6212	* .3662
	* 3.0796	* 3.6454	* 3.6765	* 3.6359	* 3.1048	* 3.5355	* 3.3841	* 5.7830
12	* .5866	* .6874	* .5952	* .6708	* .6162	* .6389	* .4709	*
	* 3.5366	* 3.0192	* 3.4926	* 3.1048	* 3.3673	* 3.2589	* 4.4594	*
13	* .6880	* .6116	* .6901	* .5900	* .6389	* .5934	* .4941	*
	* 3.0246	* 3.4038	* 3.0224	* 3.5355	* 3.2589	* 3.5082	* 4.2386	*
14	* .5515	* .6561	* .6668	* .6213	* .4710	* .4941	*	*
	* 3.7960	* 3.1985	* 3.1496	* 3.3840	* 4.4589	* 4.2390	*	*
15	* .4902	* .4330	* .4190	* .3662	* F-SUB-Q			
	* 4.3095	* 4.8823	* 5.0460	* 5.7831	* M-SUB-Q			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 265 of 311

TABLE 6

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.6250	* 2.9773	* 3.6395	* 3.1160	* 3.7638	* 3.2559	* 4.2264	* 5.1450
	* 2.9416	* 3.4391	* 4.0686	* 3.5972	* 4.2101	* 3.7459	* 4.6963	* 5.6612
	* 3.2997	* 3.7918	* 4.5013	* 3.9293	* 4.5487	* 4.0185	* 5.0504	* 5.9130
	* 3.2559	* 3.7241	* 4.3547	* 3.8245	* 4.3410	* 3.8274	* 4.7645	* 5.3433
	* 3.1033	* 3.5187	* 4.0089	* 3.3937	* 3.8121	* 3.3714	* 4.1509	* 4.5071
	* 2.8289	* 3.2067	* 3.6508	* 3.1042	* 3.4695	* 3.0753	* 3.7170	* 3.9213
9	* 2.9773	* 3.5743	* 3.0712	* 3.7389	* 3.1545	* 3.7448	* 3.6116	* 5.9795
	* 3.4391	* 3.9950	* 3.5442	* 4.1844	* 3.6489	* 4.1738	* 4.1513	* 6.5882
	* 3.7918	* 4.3852	* 3.8925	* 4.6209	* 3.9530	* 4.5159	* 4.4040	* 6.9104
	* 3.7241	* 4.2456	* 3.8117	* 4.4500	* 3.8180	* 4.3028	* 4.2108	* 6.4383
	* 3.5187	* 3.9943	* 3.5141	* 3.9349	* 3.3720	* 3.7627	* 3.6639	* 5.4551
	* 3.2067	* 3.6470	* 3.2087	* 3.5769	* 3.0797	* 3.4115	* 3.3030	* 4.7270
10	* 3.6395	* 3.0673	* 3.6792	* 3.8250	* 3.7243	* 3.1934	* 3.4860	* 6.3572
	* 4.0686	* 3.5401	* 4.1296	* 4.2704	* 4.1496	* 3.6905	* 4.0183	* 6.9918
	* 4.5013	* 3.8883	* 4.6239	* 4.6340	* 4.4666	* 3.9691	* 4.2876	* 7.2998
	* 4.3547	* 3.8081	* 4.4964	* 4.4340	* 4.3035	* 3.8436	* 4.1200	* 6.8036
	* 4.0089	* 3.5135	* 4.1406	* 4.0251	* 3.9245	* 3.4986	* 3.6831	* 5.7338
	* 3.6508	* 3.2082	* 3.6906	* 3.6194	* 3.5476	* 3.1769	* 3.3254	* 4.9633
11	* 3.1161	* 3.7379	* 3.8276	* 3.6791	* 3.0838	* 3.6857	* 3.7707	* 7.0425
	* 3.5972	* 4.1822	* 4.2732	* 4.1357	* 3.5808	* 4.1343	* 4.3214	* 7.7578
	* 3.9293	* 4.6210	* 4.6366	* 4.5070	* 3.8550	* 4.4570	* 4.5609	* 8.0798
	* 3.8245	* 4.4497	* 4.4360	* 4.3737	* 3.7216	* 4.2663	* 4.3386	* 7.5331
	* 3.3937	* 3.9345	* 4.0267	* 4.0594	* 3.4482	* 3.9252	* 3.9888	* 6.5945
	* 3.1042	* 3.5763	* 3.6204	* 3.6116	* 3.0857	* 3.4954	* 3.5528	* 5.6526
12	* 3.7638	* 3.1551	* 3.7249	* 3.0840	* 3.4738	* 3.3030	* 4.7968	*
	* 4.2101	* 3.6495	* 4.1503	* 3.5810	* 3.8696	* 3.8281	* 5.3408	*
	* 4.5487	* 3.9533	* 4.4670	* 3.8552	* 4.1305	* 4.0810	* 5.6881	*
	* 4.3410	* 3.8180	* 4.3037	* 3.7217	* 3.9344	* 3.8996	* 5.4167	*
	* 3.8121	* 3.3719	* 3.9245	* 3.4482	* 3.5911	* 3.5807	* 4.9443	*
	* 3.4695	* 3.0796	* 3.5475	* 3.0857	* 3.1623	* 3.1820	* 4.3503	*
13	* 3.2559	* 3.7451	* 3.1937	* 3.6859	* 3.3031	* 3.6321	* 4.4097	*
	* 3.7459	* 4.1742	* 3.6907	* 4.1345	* 3.8282	* 4.1849	* 4.9050	*
	* 4.0185	* 4.5160	* 3.9691	* 4.4572	* 4.0810	* 4.4323	* 5.1885	*
	* 3.8274	* 4.3026	* 3.8436	* 4.2664	* 3.8997	* 4.2021	* 4.8976	*
	* 3.3714	* 3.7625	* 3.4984	* 3.9252	* 3.5808	* 3.8374	* 4.4176	*
	* 3.0753	* 3.4114	* 3.1767	* 3.4954	* 3.1820	* 3.3852	* 3.8255	*
14	* 4.2264	* 3.6099	* 3.4854	* 3.7707	* 4.7942	* 4.4111	*	*
	* 4.6963	* 4.1495	* 4.0177	* 4.3214	* 5.3380	* 4.9066	*	*
	* 5.0504	* 4.4020	* 4.2868	* 4.5607	* 5.6854	* 5.1901	*	*
	* 4.7645	* 4.2092	* 4.1194	* 4.3385	* 5.4149	* 4.8991	*	*
	* 4.1509	* 3.6624	* 3.6824	* 3.9886	* 4.9422	* 4.4189	*	*
	* 3.7170	* 3.3018	* 3.3248	* 3.5527	* 4.3487	* 3.8267	*	*
15	* 5.1450	* 5.9767	* 6.3547	* 7.0420	* 4 EFPD	118 % POWER		
	* 5.6612	* 6.5854	* 6.9893	* 7.7573	* 50 EFPD	118 % POWER		
	* 5.9130	* 6.9073	* 7.2970	* 8.0791	* 150 EFPD	118 % POWER		
	* 5.3433	* 6.4337	* 6.8012	* 7.5325	* 250 EFPD	118 % POWER		
	* 4.5070	* 5.4510	* 5.7316	* 6.5937	* 350 EFPD	118 % POWER		
	* 3.9213	* 4.7241	* 4.9617	* 5.6520	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 266 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0940	* 1.4330	* 1.9301	* 1.5155	* 1.9887	* 1.5719	* 2.2296	* 3.8985
	* 2.2631	* 1.6007	* 2.0695	* 1.6922	* 2.1354	* 1.7591	* 2.4305	* 4.1976
	* 2.4520	* 1.7824	* 2.2096	* 1.8618	* 2.2496	* 1.9017	* 2.5587	* 4.3415
	* 2.4455	* 1.8374	* 2.2109	* 1.8957	* 2.1842	* 1.8972	* 2.4282	* 4.0364
	* 2.3645	* 1.8373	* 2.1355	* 1.7738	* 2.0259	* 1.7572	* 2.1933	* 3.5180
	* 2.2341	* 1.7994	* 2.0721	* 1.7191	* 1.9655	* 1.6957	* 2.1000	* 3.1848
9	* 1.4330	* 1.9074	* 1.4573	* 1.9768	* 1.5276	* 1.9090	* 1.5816	* 3.0614
	* 1.6007	* 2.0456	* 1.6342	* 2.1282	* 1.7147	* 2.0662	* 1.7861	* 3.3092
	* 1.7824	* 2.1874	* 1.8222	* 2.2667	* 1.8709	* 2.1829	* 1.9209	* 3.4598
	* 1.8374	* 2.1767	* 1.8775	* 2.2427	* 1.8885	* 2.1480	* 1.9222	* 3.3122
	* 1.8373	* 2.1643	* 1.8284	* 2.0957	* 1.7621	* 1.9747	* 1.7903	* 2.9287
	* 1.7994	* 2.1077	* 1.7756	* 2.0309	* 1.7019	* 1.9102	* 1.7220	* 2.6946
10	* 1.9301	* 1.4573	* 1.9981	* 1.8775	* 1.8509	* 1.5621	* 1.5857	* 3.1678
	* 2.0695	* 1.6340	* 2.1845	* 2.0604	* 2.0227	* 1.7549	* 1.7912	* 3.4298
	* 2.2096	* 1.8220	* 2.3930	* 2.2480	* 2.1766	* 1.8931	* 1.9332	* 3.5893
	* 2.2109	* 1.8771	* 2.3954	* 2.2571	* 2.1672	* 1.8893	* 1.9331	* 3.4620
	* 2.1355	* 1.8284	* 2.2524	* 2.1631	* 2.0988	* 1.8142	* 1.8398	* 3.0817
	* 2.0721	* 1.7757	* 2.1201	* 2.0840	* 2.0263	* 1.7446	* 1.7694	* 2.8358
11	* 1.5155	* 1.9777	* 1.8792	* 1.9509	* 1.5062	* 1.8822	* 1.6469	* 3.5369
	* 1.6922	* 2.1291	* 2.0627	* 2.1409	* 1.7028	* 2.0511	* 1.8626	* 3.8319
	* 1.8618	* 2.2674	* 2.2497	* 2.2841	* 1.8433	* 2.1734	* 1.9905	* 4.0062
	* 1.8957	* 2.2425	* 2.2585	* 2.2413	* 1.8369	* 2.1259	* 1.9769	* 3.8527
	* 1.7738	* 2.0954	* 2.1642	* 2.1808	* 1.7835	* 2.0409	* 1.9226	* 3.5693
	* 1.7191	* 2.0306	* 2.0858	* 2.1016	* 1.7205	* 1.9700	* 1.8507	* 3.2535
12	* 1.9887	* 1.5279	* 1.8512	* 1.5063	* 1.7115	* 1.4570	* 2.4619	*
	* 2.1354	* 1.7150	* 2.0230	* 1.7029	* 1.8776	* 1.6604	* 2.6916	*
	* 2.2496	* 1.8711	* 2.1768	* 1.8433	* 2.0143	* 1.7969	* 2.8648	*
	* 2.1842	* 1.8885	* 2.1673	* 1.8370	* 1.9958	* 1.7980	* 2.8104	*
	* 2.0259	* 1.7620	* 2.0988	* 1.7835	* 1.9372	* 1.7533	* 2.6612	*
	* 1.9655	* 1.7019	* 2.0263	* 1.7205	* 1.8694	* 1.6934	* 2.5007	*
13	* 1.5719	* 1.9093	* 1.5622	* 1.8823	* 1.4571	* 1.5949	* 3.4025	*
	* 1.7591	* 2.0664	* 1.7551	* 2.0512	* 1.6605	* 1.8168	* 3.7037	*
	* 1.9017	* 2.1831	* 1.8932	* 2.1735	* 1.7970	* 1.9496	* 3.8791	*
	* 1.8972	* 2.1482	* 1.8893	* 2.1259	* 1.7981	* 1.9330	* 3.7371	*
	* 1.7572	* 1.9747	* 1.8141	* 2.0409	* 1.7534	* 1.8787	* 3.4897	*
	* 1.6957	* 1.9102	* 1.7446	* 1.9700	* 1.6934	* 1.8023	* 3.1916	*
14	* 2.2296	* 1.5811	* 1.5855	* 1.6469	* 2.4622	* 3.4027	*	*
	* 2.4305	* 1.7855	* 1.7910	* 1.8626	* 2.6920	* 3.7039	*	*
	* 2.5587	* 1.9203	* 1.9329	* 1.9904	* 2.8652	* 3.8793	*	*
	* 2.4282	* 1.9217	* 1.9329	* 1.9769	* 2.8107	* 3.7372	*	*
	* 2.1933	* 1.7898	* 1.8395	* 1.9226	* 2.6614	* 3.4898	*	*
	* 2.1000	* 1.7216	* 1.7692	* 1.8507	* 2.5008	* 3.1917	*	*
15	* 3.8985	* 3.0600	* 3.1669	* 3.5368	* 4 EFPD	118 % POWER		
	* 4.1976	* 3.3078	* 3.4288	* 3.8317	* 50 EFPD	118 % POWER		
	* 4.3415	* 3.4582	* 3.5882	* 4.0059	* 150 EFPD	118 % POWER		
	* 4.0364	* 3.3108	* 3.4610	* 3.8525	* 250 EFPD	118 % POWER		
	* 3.5180	* 2.9274	* 3.0808	* 3.5689	* 350 EFPD	118 % POWER		
	* 3.1848	* 2.6935	* 2.8350	* 3.2532	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 267 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9405	* 1.4479	* 1.7142	* 1.4765	* 1.7716	* 1.5219	* 2.0252	* 3.4525 *
	* 2.0166	* 1.5323	* 1.7726	* 1.5712	* 1.8347	* 1.6231	* 2.1026	* 3.6548 *
	* 2.1014	* 1.6042	* 1.8837	* 1.6482	* 1.8919	* 1.6652	* 2.1357	* 3.6920 *
	* 2.0888	* 1.6080	* 1.9295	* 1.6580	* 1.8967	* 1.6476	* 2.0862	* 3.4344 *
	* 2.0159	* 1.6096	* 1.8905	* 1.5456	* 1.7848	* 1.5240	* 1.9357	* 3.0312 *
	* 1.9190	* 1.6171	* 1.8852	* 1.5240	* 1.7765	* 1.4947	* 1.8957	* 2.7911 *
9	* 1.4479	* 1.7067	* 1.4542	* 1.7416	* 1.4790	* 1.7162	* 1.5187	* 2.7750 *
	* 1.5323	* 1.7660	* 1.5451	* 1.8161	* 1.5961	* 1.7964	* 1.6284	* 2.9051 *
	* 1.6042	* 1.8677	* 1.6328	* 1.9238	* 1.6546	* 1.8511	* 1.6636	* 2.9487 *
	* 1.6080	* 1.9161	* 1.6335	* 1.9550	* 1.6482	* 1.8444	* 1.6425	* 2.8156 *
	* 1.6096	* 1.9373	* 1.5934	* 1.8565	* 1.5308	* 1.7296	* 1.5348	* 2.5143 *
	* 1.6171	* 1.9484	* 1.5777	* 1.8477	* 1.5028	* 1.7177	* 1.5023	* 2.3491 *
10	* 1.7142	* 1.4540	* 1.8126	* 1.6191	* 1.6420	* 1.5020	* 1.5520	* 2.8449 *
	* 1.7726	* 1.5448	* 1.9292	* 1.7535	* 1.7674	* 1.6243	* 1.6715	* 2.9636 *
	* 1.8837	* 1.6327	* 2.0437	* 1.9207	* 1.8920	* 1.6842	* 1.7011	* 2.9834 *
	* 1.9295	* 1.6337	* 2.0371	* 1.9704	* 1.8919	* 1.6695	* 1.6622	* 2.8467 *
	* 1.8905	* 1.5937	* 1.9159	* 1.9307	* 1.8621	* 1.5808	* 1.5722	* 2.5412 *
	* 1.8852	* 1.5779	* 1.8145	* 1.9086	* 1.8403	* 1.5321	* 1.5323	* 2.3549 *
11	* 1.4765	* 1.7429	* 1.6228	* 1.7525	* 1.4332	* 1.7033	* 1.4697	* 3.1153 *
	* 1.5712	* 1.8174	* 1.7573	* 1.8567	* 1.5630	* 1.7953	* 1.5998	* 3.2687 *
	* 1.6482	* 1.9241	* 1.9241	* 1.9562	* 1.6292	* 1.8427	* 1.6553	* 3.3142 *
	* 1.6580	* 1.9549	* 1.9731	* 1.9557	* 1.6111	* 1.8212	* 1.6450	* 3.1826 *
	* 1.5456	* 1.8562	* 1.9330	* 1.9302	* 1.5624	* 1.7963	* 1.6251	* 2.9697 *
	* 1.5240	* 1.8473	* 1.9102	* 1.9175	* 1.5321	* 1.7898	* 1.6206	* 2.7374 *
12	* 1.7716	* 1.4796	* 1.6427	* 1.4332	* 1.5454	* 1.4386	* 2.1834 *	
	* 1.8347	* 1.5968	* 1.7682	* 1.5630	* 1.6483	* 1.5564	* 2.3127 *	
	* 1.8919	* 1.6547	* 1.8923	* 1.6292	* 1.7343	* 1.6008	* 2.3974 *	
	* 1.8967	* 1.6483	* 1.8920	* 1.6111	* 1.7322	* 1.5581	* 2.3648 *	
	* 1.7848	* 1.5308	* 1.8621	* 1.5624	* 1.7192	* 1.5138	* 2.3084 *	
	* 1.7765	* 1.5027	* 1.8403	* 1.5321	* 1.7129	* 1.4980	* 2.2504 *	
13	* 1.5219	* 1.7165	* 1.5023	* 1.7034	* 1.4387	* 1.4147	* 3.0532 *	
	* 1.6231	* 1.7967	* 1.6247	* 1.7954	* 1.5565	* 1.5526	* 3.2194 *	
	* 1.6652	* 1.8512	* 1.6844	* 1.8428	* 1.6008	* 1.6179	* 3.2681 *	
	* 1.6476	* 1.8446	* 1.6696	* 1.8213	* 1.5581	* 1.6121	* 3.1442 *	
	* 1.5240	* 1.7297	* 1.5808	* 1.7963	* 1.5138	* 1.5919	* 2.9775 *	
	* 1.4947	* 1.7178	* 1.5321	* 1.7898	* 1.4980	* 1.5805	* 2.7947 *	
14	* 2.0252	* 1.5184	* 1.5520	* 1.4697	* 2.1838	* 3.0531 *		
	* 2.1026	* 1.6282	* 1.6714	* 1.5998	* 2.3132	* 3.2192 *		
	* 2.1357	* 1.6632	* 1.7010	* 1.6553	* 2.3978	* 3.2680 *		
	* 2.0862	* 1.6423	* 1.6620	* 1.6450	* 2.3652	* 3.1440 *		
	* 1.9357	* 1.5345	* 1.5720	* 1.6251	* 2.3088	* 2.9774 *		
	* 1.8957	* 1.5021	* 1.5322	* 1.6206	* 2.2507	* 2.7945 *		
15	* 3.4525	* 2.7741	* 2.8443	* 3.1153	* 4 EFPD	118 % POWER		
	* 3.6548	* 2.9042	* 2.9630	* 3.2687	* 50 EFPD	118 % POWER		
	* 3.6920	* 2.9477	* 2.9827	* 3.3141	* 150 EFPD	118 % POWER		
	* 3.4344	* 2.8149	* 2.8461	* 3.1825	* 250 EFPD	118 % POWER		
	* 3.0312	* 2.5136	* 2.5406	* 2.9695	* 350 EFPD	118 % POWER		
	* 2.7911	* 2.3486	* 2.3544	* 2.7373	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 268 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8966	* 1.3882	* 1.6247	* 1.4103	* 1.6700	* 1.4456	* 1.9030	* 3.2934 *
	* 1.9119	* 1.4186	* 1.6711	* 1.4524	* 1.7000	* 1.4956	* 1.9564	* 3.4144 *
	* 1.9376	* 1.4568	* 1.7618	* 1.4966	* 1.7616	* 1.4980	* 1.9838	* 3.3782 *
	* 1.9020	* 1.4634	* 1.8159	* 1.4934	* 1.7624	* 1.4782	* 1.9439	* 3.1641 *
	* 1.8531	* 1.4906	* 1.7959	* 1.4141	* 1.6824	* 1.3859	* 1.8286	* 2.8355 *
	* 1.7910	* 1.5378	* 1.8186	* 1.4269	* 1.7027	* 1.3917	* 1.8228	* 2.6447 *
9	* 1.3882	* 1.6228	* 1.3907	* 1.6278	* 1.4090	* 1.6441	* 1.4454	* 2.6961 *
	* 1.4186	* 1.6651	* 1.4281	* 1.7032	* 1.4732	* 1.6815	* 1.4953	* 2.7490 *
	* 1.4568	* 1.7565	* 1.4794	* 1.8007	* 1.4943	* 1.7010	* 1.4898	* 2.7056 *
	* 1.4634	* 1.8126	* 1.4853	* 1.8319	* 1.4810	* 1.6950	* 1.4741	* 2.5798 *
	* 1.4906	* 1.8586	* 1.4656	* 1.7618	* 1.3942	* 1.6193	* 1.3912	* 2.3317 *
	* 1.5378	* 1.8951	* 1.4838	* 1.7809	* 1.4013	* 1.6379	* 1.3949	* 2.1926 *
10	* 1.6247	* 1.3911	* 1.7259	* 1.5307	* 1.5701	* 1.4365	* 1.4851	* 2.7682 *
	* 1.6711	* 1.4284	* 1.8242	* 1.6409	* 1.6662	* 1.5027	* 1.5497	* 2.7922 *
	* 1.7618	* 1.4799	* 1.8859	* 1.7929	* 1.7620	* 1.5212	* 1.5277	* 2.7154 *
	* 1.8159	* 1.4856	* 1.8634	* 1.8615	* 1.7653	* 1.4970	* 1.4839	* 2.5791 *
	* 1.7959	* 1.4660	* 1.7618	* 1.8392	* 1.7538	* 1.4258	* 1.4185	* 2.3244 *
	* 1.8186	* 1.4841	* 1.6939	* 1.8519	* 1.7657	* 1.4202	* 1.4165	* 2.1819 *
11	* 1.4103	* 1.6311	* 1.5347	* 1.6583	* 1.3667	* 1.6329	* 1.3807	* 3.0107 *
	* 1.4524	* 1.7040	* 1.6448	* 1.7444	* 1.4422	* 1.6739	* 1.4539	* 3.0714 *
	* 1.4966	* 1.8011	* 1.7964	* 1.8246	* 1.4682	* 1.6938	* 1.4786	* 3.0343 *
	* 1.4934	* 1.8317	* 1.8644	* 1.8284	* 1.4568	* 1.6879	* 1.4813	* 2.9087 *
	* 1.4141	* 1.7615	* 1.8414	* 1.8298	* 1.4212	* 1.6920	* 1.4877	* 2.7378 *
	* 1.4269	* 1.7805	* 1.8535	* 1.8550	* 1.4395	* 1.7230	* 1.5166	* 2.5612 *
12	* 1.6700	* 1.4097	* 1.5709	* 1.3667	* 1.4844	* 1.3707	* 2.1147	*
	* 1.7000	* 1.4739	* 1.6670	* 1.4422	* 1.5467	* 1.4292	* 2.1927	*
	* 1.7616	* 1.4944	* 1.7623	* 1.4682	* 1.5983	* 1.4348	* 2.2385	*
	* 1.7624	* 1.4812	* 1.7655	* 1.4568	* 1.6064	* 1.3950	* 2.2220	*
	* 1.6824	* 1.3943	* 1.7539	* 1.4212	* 1.6107	* 1.3817	* 2.1943	*
	* 1.7027	* 1.4012	* 1.7657	* 1.4395	* 1.6436	* 1.4065	* 2.1838	*
13	* 1.4456	* 1.6446	* 1.4368	* 1.6331	* 1.3708	* 1.3230	* 2.8935	*
	* 1.4956	* 1.6818	* 1.5031	* 1.6741	* 1.4293	* 1.4073	* 2.9793	*
	* 1.4980	* 1.7013	* 1.5214	* 1.6939	* 1.4349	* 1.4404	* 2.9706	*
	* 1.4782	* 1.6952	* 1.4971	* 1.6880	* 1.3951	* 1.4482	* 2.8535	*
	* 1.3859	* 1.6195	* 1.4257	* 1.6920	* 1.3818	* 1.4580	* 2.7249	*
	* 1.3917	* 1.6380	* 1.4202	* 1.7230	* 1.4065	* 1.4836	* 2.5941	*
14	* 1.9030	* 1.4454	* 1.4853	* 1.3808	* 2.1156	* 2.8934	*	
	* 1.9564	* 1.4952	* 1.5498	* 1.4540	* 2.1936	* 2.9793	*	
	* 1.9838	* 1.4896	* 1.5278	* 1.4787	* 2.2392	* 2.9705	*	
	* 1.9439	* 1.4740	* 1.4839	* 1.4814	* 2.2226	* 2.8534	*	
	* 1.8286	* 1.3911	* 1.4184	* 1.4877	* 2.1948	* 2.7247	*	
	* 1.8228	* 1.3948	* 1.4165	* 1.5166	* 2.1843	* 2.5940	*	
15	* 3.2934	* 2.6958	* 2.7679	* 3.0109	* 4 EFPD	118 % POWER		
	* 3.4144	* 2.7486	* 2.7918	* 3.0715	* 50 EFPD	118 % POWER		
	* 3.3782	* 2.7051	* 2.7150	* 3.0343	* 150 EFPD	118 % POWER		
	* 3.1641	* 2.5794	* 2.5787	* 2.9087	* 250 EFPD	118 % POWER		
	* 2.8355	* 2.3313	* 2.3240	* 2.7377	* 350 EFPD	118 % POWER		
	* 2.6447	* 2.1925	* 2.1816	* 2.5611	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 269 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9446	* 1.3951	* 1.6472	* 1.4075	* 1.6571	* 1.4392	* 1.9124	* 3.3436 *
	* 1.9205	* 1.3992	* 1.6705	* 1.4285	* 1.6862	* 1.4581	* 1.9389	* 3.4042 *
	* 1.9019	* 1.4183	* 1.7438	* 1.4480	* 1.7266	* 1.4441	* 1.9427	* 3.3185 *
	* 1.8563	* 1.4395	* 1.8090	* 1.4428	* 1.7263	* 1.4215	* 1.9100	* 3.1250 *
	* 1.8257	* 1.4855	* 1.8011	* 1.3947	* 1.6775	* 1.3579	* 1.8243	* 2.8286 *
	* 1.7954	* 1.5533	* 1.8429	* 1.4266	* 1.7169	* 1.3849	* 1.8377	* 2.6515 *
9	* 1.3951	* 1.6529	* 1.3900	* 1.6417	* 1.4060	* 1.6420	* 1.4355	* 2.7161 *
	* 1.3992	* 1.6716	* 1.4074	* 1.7005	* 1.4421	* 1.6507	* 1.4550	* 2.7174 *
	* 1.4183	* 1.7457	* 1.4385	* 1.7738	* 1.4428	* 1.6576	* 1.4262	* 2.6342 *
	* 1.4395	* 1.8103	* 1.4588	* 1.8014	* 1.4218	* 1.6516	* 1.4086	* 2.5121 *
	* 1.4855	* 1.8752	* 1.4536	* 1.7655	* 1.3690	* 1.6081	* 1.3598	* 2.2971 *
	* 1.5533	* 1.9287	* 1.4892	* 1.8036	* 1.3960	* 1.6461	* 1.3856	* 2.1797 *
10	* 1.6472	* 1.3904	* 1.7409	* 1.5389	* 1.5857	* 1.4384	* 1.4815	* 2.7569 *
	* 1.6705	* 1.4077	* 1.8208	* 1.6386	* 1.6591	* 1.4735	* 1.5102	* 2.7317 *
	* 1.7438	* 1.4391	* 1.8495	* 1.7794	* 1.7340	* 1.4693	* 1.4624	* 2.6067 *
	* 1.8090	* 1.4593	* 1.8293	* 1.8598	* 1.7448	* 1.4448	* 1.4255	* 2.4674 *
	* 1.8011	* 1.4541	* 1.7470	* 1.8558	* 1.7489	* 1.3868	* 1.3818	* 2.2651 *
	* 1.8429	* 1.4895	* 1.7006	* 1.8855	* 1.7815	* 1.4082	* 1.4047	* 2.1494 *
11	* 1.4075	* 1.6450	* 1.5432	* 1.6611	* 1.3649	* 1.6370	* 1.3732	* 3.0141 *
	* 1.4285	* 1.7013	* 1.6427	* 1.7282	* 1.4093	* 1.6449	* 1.4141	* 3.0145 *
	* 1.4480	* 1.7738	* 1.7831	* 1.7892	* 1.4155	* 1.6556	* 1.4239	* 2.9353 *
	* 1.4428	* 1.8012	* 1.8614	* 1.8058	* 1.4115	* 1.6621	* 1.4384	* 2.8245 *
	* 1.3947	* 1.7652	* 1.8580	* 1.8289	* 1.3939	* 1.6878	* 1.4624	* 2.6777 *
	* 1.4266	* 1.8032	* 1.8871	* 1.8793	* 1.4415	* 1.7437	* 1.5112	* 2.5334 *
12	* 1.6571	* 1.4067	* 1.5867	* 1.3649	* 1.4890	* 1.3683	* 2.1240 *	
	* 1.6862	* 1.4424	* 1.6600	* 1.4094	* 1.5246	* 1.3927	* 2.1629 *	
	* 1.7266	* 1.4429	* 1.7344	* 1.4156	* 1.5590	* 1.3771	* 2.1871 *	
	* 1.7263	* 1.4219	* 1.7450	* 1.4116	* 1.5770	* 1.3490	* 2.1836 *	
	* 1.6775	* 1.3691	* 1.7490	* 1.3939	* 1.6021	* 1.3586	* 2.1831 *	
	* 1.7169	* 1.3960	* 1.7815	* 1.4415	* 1.6595	* 1.4091	* 2.2016 *	
13	* 1.4392	* 1.6426	* 1.4389	* 1.6372	* 1.3684	* 1.3081	* 2.8975 *	
	* 1.4581	* 1.6511	* 1.4738	* 1.6451	* 1.3928	* 1.3603	* 2.9197 *	
	* 1.4441	* 1.6579	* 1.4695	* 1.6558	* 1.3771	* 1.3810	* 2.8694 *	
	* 1.4215	* 1.6519	* 1.4449	* 1.6622	* 1.3490	* 1.4054	* 2.7784 *	
	* 1.3579	* 1.6083	* 1.3868	* 1.6879	* 1.3586	* 1.4349	* 2.6828 *	
	* 1.3849	* 1.6463	* 1.4082	* 1.7437	* 1.4091	* 1.4827	* 2.5876 *	
14	* 1.9124	* 1.4356	* 1.4817	* 1.3733	* 2.1251	* 2.8975 *		
	* 1.9389	* 1.4550	* 1.5104	* 1.4143	* 2.1641	* 2.9196 *		
	* 1.9427	* 1.4262	* 1.4625	* 1.4240	* 2.1879	* 2.8693 *		
	* 1.9100	* 1.4085	* 1.4256	* 1.4385	* 2.1843	* 2.7783 *		
	* 1.8243	* 1.3597	* 1.3818	* 1.4624	* 2.1837	* 2.6826 *		
	* 1.8377	* 1.3856	* 1.4046	* 1.5112	* 2.2021	* 2.5874 *		
15	* 3.3436	* 2.7159	* 2.7567	* 3.0144	* 4 EFPD	118 % POWER		
	* 3.4042	* 2.7172	* 2.7315	* 3.0148	* 50 EFPD	118 % POWER		
	* 3.3185	* 2.6339	* 2.6064	* 2.9354	* 150 EFPD	118 % POWER		
	* 3.1250	* 2.5118	* 2.4670	* 2.8246	* 250 EFPD	118 % POWER		
	* 2.8286	* 2.2971	* 2.2647	* 2.6777	* 350 EFPD	118 % POWER		
	* 2.6515	* 2.1797	* 2.1491	* 2.5334	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 270 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0121	* 1.4262	* 1.6924	* 1.4397	* 1.7002	* 1.4712	* 1.9667	* 3.4635
	* 1.9686	* 1.4186	* 1.7010	* 1.4436	* 1.7127	* 1.4682	* 1.9675	* 3.4699
	* 1.9277	* 1.4261	* 1.7638	* 1.4551	* 1.7414	* 1.4452	* 1.9570	* 3.3547
	* 1.8812	* 1.4556	* 1.8303	* 1.4472	* 1.7408	* 1.4201	* 1.9254	* 3.1586
	* 1.8549	* 1.5096	* 1.8548	* 1.4234	* 1.7176	* 1.3781	* 1.8667	* 2.8914
	* 1.8339	* 1.5837	* 1.9075	* 1.4657	* 1.7693	* 1.4172	* 1.8919	* 2.7317
9	* 1.4262	* 1.7025	* 1.4217	* 1.6906	* 1.4341	* 1.6810	* 1.4618	* 2.7930
	* 1.4186	* 1.7096	* 1.4243	* 1.7317	* 1.4539	* 1.6639	* 1.4577	* 2.7531
	* 1.4261	* 1.7723	* 1.4455	* 1.7963	* 1.4428	* 1.6634	* 1.4169	* 2.6457
	* 1.4556	* 1.8410	* 1.4657	* 1.8220	* 1.4184	* 1.6588	* 1.3989	* 2.5174
	* 1.5096	* 1.9123	* 1.4898	* 1.8157	* 1.3909	* 1.6421	* 1.3764	* 2.3381
	* 1.5837	* 1.9889	* 1.5346	* 1.8651	* 1.4300	* 1.6925	* 1.4149	* 2.2340
10	* 1.6924	* 1.4221	* 1.7887	* 1.5793	* 1.6213	* 1.4668	* 1.5035	* 2.8074
	* 1.7010	* 1.4246	* 1.8441	* 1.6689	* 1.6866	* 1.4813	* 1.5094	* 2.7390
	* 1.7638	* 1.4462	* 1.8709	* 1.8089	* 1.7432	* 1.4660	* 1.4476	* 2.5922
	* 1.8303	* 1.4662	* 1.8470	* 1.8834	* 1.7618	* 1.4266	* 1.4076	* 2.4476
	* 1.8548	* 1.4903	* 1.7949	* 1.9114	* 1.7912	* 1.4013	* 1.3959	* 2.2869
	* 1.9075	* 1.5350	* 1.7561	* 1.9526	* 1.8370	* 1.4366	* 1.4333	* 2.1868
11	* 1.4397	* 1.6942	* 1.5839	* 1.6972	* 1.3952	* 1.6744	* 1.3946	* 3.0627
	* 1.4436	* 1.7326	* 1.6733	* 1.7542	* 1.4216	* 1.6618	* 1.4192	* 3.0296
	* 1.4551	* 1.7963	* 1.8127	* 1.8012	* 1.4160	* 1.6635	* 1.4170	* 2.9142
	* 1.4472	* 1.8218	* 1.8849	* 1.8307	* 1.4176	* 1.6847	* 1.4394	* 2.8092
	* 1.4234	* 1.8154	* 1.9121	* 1.8696	* 1.4173	* 1.7274	* 1.4775	* 2.7032
	* 1.4657	* 1.8647	* 1.9532	* 1.9331	* 1.4788	* 1.7967	* 1.5427	* 2.5674
12	* 1.7002	* 1.4350	* 1.6224	* 1.3952	* 1.5239	* 1.4002	* 2.1696	*
	* 1.7127	* 1.4542	* 1.6876	* 1.4216	* 1.5411	* 1.4008	* 2.1813	*
	* 1.7414	* 1.4431	* 1.7435	* 1.4161	* 1.5674	* 1.3713	* 2.1911	*
	* 1.7408	* 1.4185	* 1.7620	* 1.4176	* 1.5970	* 1.3579	* 2.2039	*
	* 1.7176	* 1.3910	* 1.7913	* 1.4174	* 1.6388	* 1.3842	* 2.2228	*
	* 1.7693	* 1.4300	* 1.8370	* 1.4788	* 1.7098	* 1.4490	* 2.2542	*
13	* 1.4712	* 1.6817	* 1.4674	* 1.6747	* 1.4004	* 1.3303	* 2.9738	*
	* 1.4682	* 1.6643	* 1.4818	* 1.6621	* 1.4009	* 1.3609	* 2.9534	*
	* 1.4452	* 1.6638	* 1.4663	* 1.6637	* 1.3714	* 1.3771	* 2.8832	*
	* 1.4201	* 1.6591	* 1.4267	* 1.6848	* 1.3580	* 1.4170	* 2.8170	*
	* 1.3781	* 1.6423	* 1.4014	* 1.7274	* 1.3842	* 1.4615	* 2.7453	*
	* 1.4172	* 1.6927	* 1.4366	* 1.7967	* 1.4490	* 1.5233	* 2.6680	*
14	* 1.9667	* 1.4620	* 1.5037	* 1.3948	* 2.1706	* 2.9739	*	*
	* 1.9675	* 1.4578	* 1.5096	* 1.4195	* 2.1823	* 2.9534	*	*
	* 1.9570	* 1.4170	* 1.4477	* 1.4172	* 2.1919	* 2.8831	*	*
	* 1.9254	* 1.3989	* 1.4077	* 1.4394	* 2.2046	* 2.8169	*	*
	* 1.8667	* 1.3764	* 1.3959	* 1.4775	* 2.2234	* 2.7451	*	*
	* 1.8919	* 1.4149	* 1.4332	* 1.5427	* 2.2548	* 2.6679	*	*
15	* 3.4635	* 2.7930	* 2.8073	* 3.0632	* 4 EFPD	118 % POWER		
	* 3.4699	* 2.7531	* 2.7389	* 3.0301	* 50 EFPD	118 % POWER		
	* 3.3547	* 2.6455	* 2.5920	* 2.9145	* 150 EFPD	118 % POWER		
	* 3.1586	* 2.5175	* 2.4473	* 2.8093	* 250 EFPD	118 % POWER		
	* 2.8914	* 2.3382	* 2.2866	* 2.7032	* 350 EFPD	118 % POWER		
	* 2.7317	* 2.2341	* 2.1865	* 2.5674	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 271 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0921	* 1.4680	* 1.7533	* 1.4808	* 1.7579	* 1.5105	* 2.0316	* 3.5796 *
	* 2.0282	* 1.4475	* 1.7486	* 1.4725	* 1.7569	* 1.4899	* 2.0145	* 3.5568 *
	* 1.9763	* 1.4513	* 1.8126	* 1.4746	* 1.7706	* 1.4570	* 1.9848	* 3.4004 *
	* 1.9176	* 1.4758	* 1.8741	* 1.4683	* 1.7792	* 1.4336	* 1.9644	* 3.2219 *
	* 1.8958	* 1.5304	* 1.9302	* 1.4644	* 1.7780	* 1.4109	* 1.9306	* 2.9863 *
	* 1.8697	* 1.5993	* 1.9889	* 1.5137	* 1.8375	* 1.4582	* 1.9628	* 2.8306 *
9	* 1.4680	* 1.7685	* 1.4629	* 1.7520	* 1.4696	* 1.7285	* 1.4956	* 2.8813 *
	* 1.4475	* 1.7618	* 1.4534	* 1.7819	* 1.4780	* 1.6927	* 1.4722	* 2.8111 *
	* 1.4513	* 1.8254	* 1.4720	* 1.8379	* 1.4579	* 1.6855	* 1.4255	* 2.6794 *
	* 1.4758	* 1.8884	* 1.4854	* 1.8676	* 1.4320	* 1.6886	* 1.4058	* 2.5539 *
	* 1.5304	* 1.9528	* 1.5381	* 1.8869	* 1.4251	* 1.6946	* 1.4051	* 2.4035 *
	* 1.5993	* 2.0228	* 1.5888	* 1.9429	* 1.4736	* 1.7534	* 1.4519	* 2.3043 *
10	* 1.7533	* 1.4634	* 1.8566	* 1.6317	* 1.6688	* 1.5002	* 1.5339	* 2.9102 *
	* 1.7486	* 1.4538	* 1.9025	* 1.7155	* 1.7237	* 1.5008	* 1.5225	* 2.8091 *
	* 1.8126	* 1.4727	* 1.9221	* 1.8621	* 1.7739	* 1.4759	* 1.4542	* 2.6376 *
	* 1.8741	* 1.4859	* 1.8885	* 1.9258	* 1.7866	* 1.4254	* 1.4082	* 2.4903 *
	* 1.9302	* 1.5383	* 1.8463	* 1.9812	* 1.8398	* 1.4275	* 1.4231	* 2.3601 *
	* 1.9889	* 1.5891	* 1.8205	* 2.0367	* 1.9069	* 1.4736	* 1.4698	* 2.2687 *
11	* 1.4808	* 1.7541	* 1.6365	* 1.7487	* 1.4226	* 1.7081	* 1.4190	* 3.1613 *
	* 1.4725	* 1.7827	* 1.7201	* 1.7859	* 1.4366	* 1.6826	* 1.4273	* 3.0959 *
	* 1.4746	* 1.8379	* 1.8660	* 1.8317	* 1.4240	* 1.6830	* 1.4240	* 2.9743 *
	* 1.4683	* 1.8673	* 1.9273	* 1.8739	* 1.4326	* 1.7204	* 1.4437	* 2.8501 *
	* 1.4644	* 1.8866	* 1.9821	* 1.9205	* 1.4451	* 1.7760	* 1.4926	* 2.7781 *
	* 1.5137	* 1.9424	* 2.0383	* 1.9840	* 1.5144	* 1.8526	* 1.5646	* 2.6755 *
12	* 1.7579	* 1.4706	* 1.6700	* 1.4227	* 1.5533	* 1.4239	* 2.2312 *	
	* 1.7569	* 1.4783	* 1.7246	* 1.4366	* 1.5625	* 1.4118	* 2.2293 *	
	* 1.7706	* 1.4582	* 1.7743	* 1.4241	* 1.5841	* 1.3732	* 2.2293 *	
	* 1.7792	* 1.4321	* 1.7868	* 1.4327	* 1.6267	* 1.3723	* 2.2613 *	
	* 1.7780	* 1.4251	* 1.8399	* 1.4451	* 1.6818	* 1.4103	* 2.2962 *	
	* 1.8375	* 1.4736	* 1.9069	* 1.5143	* 1.7597	* 1.4823	* 2.3334 *	
13	* 1.5105	* 1.7291	* 1.5007	* 1.7084	* 1.4241	* 1.3504	* 3.0333 *	
	* 1.4899	* 1.6932	* 1.5014	* 1.6829	* 1.4119	* 1.3698	* 2.9958 *	
	* 1.4570	* 1.6859	* 1.4761	* 1.6832	* 1.3733	* 1.3824	* 2.9167 *	
	* 1.4336	* 1.6889	* 1.4255	* 1.7205	* 1.3723	* 1.4359	* 2.8688 *	
	* 1.4109	* 1.6948	* 1.4275	* 1.7761	* 1.4103	* 1.4936	* 2.8139 *	
	* 1.4582	* 1.7536	* 1.4736	* 1.8526	* 1.4823	* 1.5604	* 2.7385 *	
14	* 2.0316	* 1.4958	* 1.5342	* 1.4192	* 2.2327	* 3.0334 *		
	* 2.0145	* 1.4724	* 1.5228	* 1.4276	* 2.2308	* 2.9958 *		
	* 1.9848	* 1.4256	* 1.4544	* 1.4242	* 2.2301	* 2.9167 *		
	* 1.9644	* 1.4059	* 1.4082	* 1.4438	* 2.2620	* 2.8687 *		
	* 1.9306	* 1.4051	* 1.4231	* 1.4926	* 2.2968	* 2.8138 *		
	* 1.9628	* 1.4518	* 1.4698	* 1.5646	* 2.3340	* 2.7384 *		
15	* 3.5796	* 2.8814	* 2.9102	* 3.1619	* 4 EFPD	118 % POWER		
	* 3.5568	* 2.8112	* 2.8091	* 3.0964	* 50 EFPD	118 % POWER		
	* 3.4004	* 2.6794	* 2.6375	* 2.9746	* 150 EFPD	118 % POWER		
	* 3.2219	* 2.5541	* 2.4900	* 2.8503	* 250 EFPD	118 % POWER		
	* 2.9863	* 2.4036	* 2.3598	* 2.7781	* 350 EFPD	118 % POWER		
	* 2.8306	* 2.3044	* 2.2684	* 2.6754	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 272 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2303	* 1.5400	* 1.8405	* 1.5454	* 1.8332	* 1.5679	* 2.1124	* 3.7556
	* 2.1433	* 1.5156	* 1.8363	* 1.5386	* 1.8379	* 1.5473	* 2.1003	* 3.7340
	* 2.0728	* 1.5087	* 1.8868	* 1.5245	* 1.8334	* 1.5011	* 2.0521	* 3.5374
	* 2.0111	* 1.5330	* 1.9599	* 1.5269	* 1.8508	* 1.4802	* 2.0391	* 3.3575
	* 1.9547	* 1.5745	* 2.0053	* 1.5355	* 1.8710	* 1.4744	* 2.0277	* 3.1392
	* 1.9225	* 1.6462	* 2.0586	* 1.5868	* 1.9338	* 1.5262	* 2.0613	* 2.9742
9	* 1.5400	* 1.8636	* 1.5297	* 1.8347	* 1.5324	* 1.7951	* 1.5505	* 3.0044
	* 1.5156	* 1.8553	* 1.5204	* 1.8699	* 1.5374	* 1.7596	* 1.5220	* 2.9364
	* 1.5087	* 1.9069	* 1.5242	* 1.9093	* 1.5000	* 1.7385	* 1.4579	* 2.7697
	* 1.5330	* 1.9796	* 1.5469	* 1.9545	* 1.4835	* 1.7544	* 1.4498	* 2.6466
	* 1.5745	* 2.0232	* 1.5876	* 1.9883	* 1.4885	* 1.7786	* 1.4598	* 2.5167
	* 1.6462	* 2.0930	* 1.6406	* 2.0354	* 1.5438	* 1.8413	* 1.5141	* 2.4131
10	* 1.8405	* 1.5310	* 1.9545	* 1.7099	* 1.7506	* 1.5676	* 1.5978	* 3.0320
	* 1.8363	* 1.5208	* 1.9973	* 1.7997	* 1.7996	* 1.5567	* 1.5728	* 2.9254
	* 1.8868	* 1.5249	* 2.0007	* 1.9387	* 1.8434	* 1.5149	* 1.4898	* 2.7148
	* 1.9599	* 1.5475	* 1.9757	* 2.0134	* 1.8509	* 1.4646	* 1.4478	* 2.5829
	* 2.0053	* 1.5879	* 1.9174	* 2.0551	* 1.9065	* 1.4679	* 1.4670	* 2.4635
	* 2.0586	* 1.6409	* 1.8781	* 2.1017	* 1.9671	* 1.5354	* 1.5318	* 2.3760
11	* 1.5454	* 1.8371	* 1.7152	* 1.8305	* 1.4848	* 1.7827	* 1.4752	* 3.3138
	* 1.5386	* 1.8708	* 1.8048	* 1.8604	* 1.4904	* 1.7468	* 1.4726	* 3.2242
	* 1.5245	* 1.9092	* 1.9429	* 1.9103	* 1.4772	* 1.7491	* 1.4711	* 3.0771
	* 1.5269	* 1.9542	* 2.0151	* 1.9303	* 1.4689	* 1.7717	* 1.4839	* 2.9514
	* 1.5355	* 1.9879	* 2.0561	* 1.9776	* 1.4886	* 1.8348	* 1.5406	* 2.8719
	* 1.5868	* 2.0349	* 2.1034	* 2.0329	* 1.5518	* 1.9019	* 1.6103	* 2.7628
12	* 1.8332	* 1.5334	* 1.7519	* 1.4849	* 1.6221	* 1.4851	* 2.3322	*
	* 1.8379	* 1.5379	* 1.8006	* 1.4905	* 1.6227	* 1.4589	* 2.3162	*
	* 1.8334	* 1.5003	* 1.8438	* 1.4773	* 1.6479	* 1.4180	* 2.3178	*
	* 1.8508	* 1.4837	* 1.8512	* 1.4690	* 1.6782	* 1.4112	* 2.3280	*
	* 1.8710	* 1.4886	* 1.9066	* 1.4886	* 1.7416	* 1.4566	* 2.3706	*
	* 1.9338	* 1.5437	* 1.9671	* 1.5518	* 1.8083	* 1.5284	* 2.3908	*
13	* 1.5679	* 1.7956	* 1.5681	* 1.7831	* 1.4853	* 1.4015	* 3.1625	*
	* 1.5473	* 1.7601	* 1.5572	* 1.7471	* 1.4590	* 1.4104	* 3.1039	*
	* 1.5011	* 1.7389	* 1.5151	* 1.7493	* 1.4181	* 1.4275	* 3.0255	*
	* 1.4802	* 1.7547	* 1.4647	* 1.7718	* 1.4113	* 1.4820	* 2.9619	*
	* 1.4744	* 1.7788	* 1.4680	* 1.8349	* 1.4566	* 1.5475	* 2.9130	*
	* 1.5262	* 1.8415	* 1.5353	* 1.9019	* 1.5284	* 1.6122	* 2.8082	*
14	* 2.1124	* 1.5508	* 1.5981	* 1.4756	* 2.3339	* 3.1626	*	*
	* 2.1003	* 1.5223	* 1.5732	* 1.4729	* 2.3177	* 3.1040	*	*
	* 2.0521	* 1.4581	* 1.4901	* 1.4713	* 2.3188	* 3.0256	*	*
	* 2.0391	* 1.4499	* 1.4479	* 1.4840	* 2.3289	* 2.9618	*	*
	* 2.0277	* 1.4598	* 1.4670	* 1.5406	* 2.3713	* 2.9129	*	*
	* 2.0613	* 1.5141	* 1.5317	* 1.6102	* 2.3914	* 2.8081	*	*
15	* 3.7556	* 3.0046	* 3.0321	* 3.3146	* 4 EFPD	118 % POWER		
	* 3.7340	* 2.9366	* 2.9255	* 3.2249	* 50 EFPD	118 % POWER		
	* 3.5374	* 2.7698	* 2.7147	* 3.0775	* 150 EFPD	118 % POWER		
	* 3.3575	* 2.6468	* 2.5827	* 2.9516	* 250 EFPD	118 % POWER		
	* 3.1392	* 2.5169	* 2.4632	* 2.8719	* 350 EFPD	118 % POWER		
	* 2.9742	* 2.4132	* 2.3757	* 2.7627	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 273 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.3711	* 1.6184	* 1.9414	* 1.6208	* 1.9285	* 1.6382	* 2.2170	* 3.9471
	* 2.2987	* 1.6055	* 1.9506	* 1.6197	* 1.9398	* 1.6207	* 2.2069	* 3.9124
	* 2.2023	* 1.5856	* 1.9935	* 1.5987	* 1.9268	* 1.5687	* 2.1528	* 3.7084
	* 2.1504	* 1.6215	* 2.0801	* 1.5997	* 1.9490	* 1.5457	* 2.1444	* 3.5265
	* 2.0674	* 1.6494	* 2.1120	* 1.6166	* 1.9832	* 1.5516	* 2.1505	* 3.3265
	* 2.0271	* 1.7157	* 2.1497	* 1.6542	* 2.0317	* 1.6027	* 2.1767	* 3.1245
9	* 1.6184	* 1.9699	* 1.6052	* 1.9309	* 1.6009	* 1.8780	* 1.6158	* 3.1497
	* 1.6055	* 1.9769	* 1.6070	* 1.9808	* 1.6125	* 1.8479	* 1.5914	* 3.0825
	* 1.5856	* 2.0185	* 1.6003	* 2.0134	* 1.5665	* 1.8205	* 1.5142	* 2.8989
	* 1.6215	* 2.1067	* 1.6351	* 2.0627	* 1.5502	* 1.8413	* 1.5113	* 2.7703
	* 1.6494	* 2.1336	* 1.6627	* 2.1057	* 1.5624	* 1.8770	* 1.5260	* 2.6492
	* 1.7157	* 2.1901	* 1.7050	* 2.1321	* 1.6126	* 1.9344	* 1.5873	* 2.5301
10	* 1.9414	* 1.6076	* 2.0596	* 1.7964	* 1.8341	* 1.6372	* 1.6648	* 3.1874
	* 1.9506	* 1.6074	* 2.1242	* 1.9077	* 1.9031	* 1.6351	* 1.6455	* 3.0831
	* 1.9935	* 1.6011	* 2.1133	* 2.0451	* 1.9284	* 1.5717	* 1.5436	* 2.8461
	* 2.0801	* 1.6357	* 2.0953	* 2.1356	* 1.9514	* 1.5294	* 1.5123	* 2.7152
	* 2.1120	* 1.6630	* 2.0194	* 2.1622	* 1.9963	* 1.5278	* 1.5276	* 2.6008
	* 2.1497	* 1.7054	* 1.9596	* 2.1921	* 2.0446	* 1.5858	* 1.5906	* 2.4930
11	* 1.6208	* 1.9334	* 1.8020	* 1.9252	* 1.5617	* 1.8747	* 1.5388	* 3.4728
	* 1.6197	* 1.9817	* 1.9130	* 1.9680	* 1.5702	* 1.8418	* 1.5395	* 3.4069
	* 1.5987	* 2.0134	* 2.0496	* 2.0017	* 1.5471	* 1.8317	* 1.5243	* 3.2222
	* 1.5997	* 2.0624	* 2.1373	* 2.0343	* 1.5348	* 1.8617	* 1.5527	* 3.1199
	* 1.6166	* 2.1052	* 2.1632	* 2.0699	* 1.5569	* 1.9257	* 1.6066	* 3.0124
	* 1.6542	* 2.1315	* 2.1939	* 2.1257	* 1.6136	* 1.9846	* 1.6643	* 2.8758
12	* 1.9285	* 1.6020	* 1.8355	* 1.5618	* 1.7148	* 1.5648	* 2.4600	*
	* 1.9398	* 1.6131	* 1.9042	* 1.5705	* 1.7175	* 1.5331	* 2.4474	*
	* 1.9268	* 1.5668	* 1.9289	* 1.5472	* 1.7341	* 1.4810	* 2.4332	*
	* 1.9490	* 1.5504	* 1.9516	* 1.5349	* 1.7671	* 1.4724	* 2.4501	*
	* 1.9832	* 1.5625	* 1.9963	* 1.5569	* 1.8285	* 1.5236	* 2.4912	*
	* 2.0317	* 1.6125	* 2.0445	* 1.6136	* 1.8905	* 1.5864	* 2.4973	*
13	* 1.6382	* 1.8786	* 1.6379	* 1.8751	* 1.5650	* 1.4750	* 3.3320	*
	* 1.6207	* 1.8485	* 1.6356	* 1.8422	* 1.5332	* 1.4765	* 3.2664	*
	* 1.5687	* 1.8210	* 1.5720	* 1.8320	* 1.4811	* 1.4949	* 3.1744	*
	* 1.5457	* 1.8417	* 1.5295	* 1.8619	* 1.4724	* 1.5446	* 3.0983	*
	* 1.5516	* 1.8773	* 1.5278	* 1.9257	* 1.5236	* 1.6172	* 3.0354	*
	* 1.6027	* 1.9346	* 1.5857	* 1.9846	* 1.5863	* 1.6731	* 2.9170	*
14	* 2.2170	* 1.6162	* 1.6652	* 1.5391	* 2.4618	* 3.3321	*	*
	* 2.2069	* 1.5918	* 1.6459	* 1.5399	* 2.4491	* 3.2665	*	*
	* 2.1528	* 1.5144	* 1.5439	* 1.5246	* 2.4348	* 3.1745	*	*
	* 2.1444	* 1.5114	* 1.5124	* 1.5528	* 2.4510	* 3.0982	*	*
	* 2.1505	* 1.5260	* 1.5276	* 1.6066	* 2.4920	* 3.0353	*	*
	* 2.1767	* 1.5872	* 1.5905	* 1.6642	* 2.4980	* 2.9169	*	*
15	* 3.9471	* 3.1500	* 3.1876	* 3.4737	* 4 EFPD	118 % POWER		
	* 3.9124	* 3.0829	* 3.0833	* 3.4077	* 50 EFPD	118 % POWER		
	* 3.7084	* 2.8991	* 2.8461	* 3.2227	* 150 EFPD	118 % POWER		
	* 3.5265	* 2.7705	* 2.7149	* 3.1201	* 250 EFPD	118 % POWER		
	* 3.3265	* 2.6494	* 2.6005	* 3.0124	* 350 EFPD	118 % POWER		
	* 3.1245	* 2.5301	* 2.4925	* 2.8757	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 274 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.5596	* 1.7601	* 2.1030	* 1.7572	* 2.0813	* 1.7692	* 2.3779	* 4.2649 *
	* 2.4844	* 1.7406	* 2.1055	* 1.7464	* 2.0843	* 1.7416	* 2.3570	* 4.2110 *
	* 2.4028	* 1.7313	* 2.1671	* 1.7347	* 2.0811	* 1.6967	* 2.3154	* 4.0097 *
	* 2.3503	* 1.7646	* 2.2488	* 1.7340	* 2.1043	* 1.6702	* 2.3087	* 3.8244 *
	* 2.2617	* 1.7893	* 2.2818	* 1.7554	* 2.1468	* 1.6816	* 2.3214	* 3.6139 *
	* 2.1844	* 1.8291	* 2.2987	* 1.7728	* 2.1741	* 1.7156	* 2.3230	* 3.3525 *
9	* 1.7601	* 2.1331	* 1.7430	* 2.0856	* 1.7294	* 2.0214	* 1.7355	* 3.3841 *
	* 1.7406	* 2.1383	* 1.7398	* 2.1332	* 1.7311	* 1.9796	* 1.7018	* 3.2940 *
	* 1.7313	* 2.1984	* 1.7436	* 2.1817	* 1.6927	* 1.9620	* 1.6297	* 3.1144 *
	* 1.7646	* 2.2771	* 1.7735	* 2.2303	* 1.6749	* 1.9838	* 1.6257	* 2.9796 *
	* 1.7893	* 2.3085	* 1.8011	* 2.2718	* 1.6923	* 2.0273	* 1.6454	* 2.8562 *
	* 1.8291	* 2.3336	* 1.8260	* 2.2802	* 1.7256	* 2.0659	* 1.6918	* 2.7028 *
10	* 2.1030	* 1.7461	* 2.2148	* 1.9404	* 1.9738	* 1.7645	* 1.7856	* 3.3933 *
	* 2.1055	* 1.7403	* 2.2806	* 2.0542	* 2.0455	* 1.7567	* 1.7609	* 3.2655 *
	* 2.1671	* 1.7444	* 2.2908	* 2.2187	* 2.0797	* 1.6881	* 1.6598	* 3.0366 *
	* 2.2488	* 1.7741	* 2.2454	* 2.2955	* 2.1120	* 1.6451	* 1.6250	* 2.8895 *
	* 2.2818	* 1.8014	* 2.1686	* 2.3247	* 2.1484	* 1.6439	* 1.6438	* 2.7707 *
	* 2.2987	* 1.8263	* 2.0802	* 2.3340	* 2.1759	* 1.6881	* 1.6935	* 2.6269 *
11	* 1.7572	* 2.0883	* 1.9464	* 2.0667	* 1.6825	* 2.0121	* 1.6490	* 3.6951 *
	* 1.7464	* 2.1333	* 2.0599	* 2.1171	* 1.6999	* 1.9840	* 1.6552	* 3.6110 *
	* 1.7347	* 2.1816	* 2.2213	* 2.1561	* 1.6696	* 1.9699	* 1.6398	* 3.4267 *
	* 1.7340	* 2.2299	* 2.2966	* 2.2044	* 1.6666	* 2.0159	* 1.6767	* 3.3082 *
	* 1.7554	* 2.2713	* 2.3254	* 2.2248	* 1.6776	* 2.0689	* 1.7169	* 3.1893 *
	* 1.7728	* 2.2797	* 2.3343	* 2.2613	* 1.7258	* 2.1073	* 1.7578	* 3.0065 *
12	* 2.0813	* 1.7307	* 1.9754	* 1.6826	* 1.8414	* 1.6832	* 2.6054 *	
	* 2.0843	* 1.7317	* 2.0467	* 1.7002	* 1.8561	* 1.6614	* 2.6018 *	
	* 2.0811	* 1.6930	* 2.0803	* 1.6697	* 1.8687	* 1.5942	* 2.5845 *	
	* 2.1043	* 1.6750	* 2.1123	* 1.6667	* 1.9174	* 1.5969	* 2.6192 *	
	* 2.1468	* 1.6924	* 2.1484	* 1.6776	* 1.9681	* 1.6452	* 2.6403 *	
	* 2.1741	* 1.7255	* 2.1759	* 1.7258	* 2.0243	* 1.7004	* 2.6200 *	
13	* 1.7692	* 2.0221	* 1.7651	* 2.0126	* 1.6834	* 1.5797	* 3.6007 *	
	* 1.7416	* 1.9802	* 1.7574	* 1.9844	* 1.6615	* 1.5990	* 3.5540 *	
	* 1.6967	* 1.9625	* 1.6884	* 1.9703	* 1.5944	* 1.6073	* 3.4302 *	
	* 1.6702	* 1.9842	* 1.6453	* 2.0161	* 1.5970	* 1.6733	* 3.3744 *	
	* 1.6816	* 2.0276	* 1.6439	* 2.0689	* 1.6452	* 1.7451	* 3.2783 *	
	* 1.7156	* 2.0661	* 1.6880	* 2.1073	* 1.7004	* 1.7874	* 3.1393 *	
14	* 2.3779	* 1.7359	* 1.7861	* 1.6494	* 2.6070	* 3.6009 *		
	* 2.3570	* 1.7022	* 1.7614	* 1.6557	* 2.6033	* 3.5542 *		
	* 2.3154	* 1.6300	* 1.6601	* 1.6402	* 2.5857	* 3.4305 *		
	* 2.3087	* 1.6258	* 1.6251	* 1.6768	* 2.6202	* 3.3743 *		
	* 2.3214	* 1.6454	* 1.6438	* 1.7169	* 2.6411	* 3.2782 *		
	* 2.3230	* 1.6917	* 1.6934	* 1.7577	* 2.6207	* 3.1392 *		
15	* 4.2649	* 3.3846	* 3.3936	* 3.6960	* 4 EFPD	118 % POWER		
	* 4.2110	* 3.2944	* 3.2658	* 3.6119	* 50 EFPD	118 % POWER		
	* 4.0097	* 3.1147	* 3.0366	* 3.4273	* 150 EFPD	118 % POWER		
	* 3.8244	* 2.9799	* 2.8892	* 3.3083	* 250 EFPD	118 % POWER		
	* 3.6139	* 2.8564	* 2.7703	* 3.1893	* 350 EFPD	118 % POWER		
	* 3.3525	* 2.7026	* 2.6264	* 3.0064	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 275 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.6954	* 1.8339	* 2.2049	* 1.8361	* 2.1982	* 1.8535	* 2.5108	* 4.4632
	* 2.6061	* 1.8153	* 2.2106	* 1.8311	* 2.1976	* 1.8193	* 2.4808	* 4.4113
	* 2.5383	* 1.8282	* 2.2971	* 1.8374	* 2.2144	* 1.7908	* 2.4590	* 4.2416
	* 2.5081	* 1.8725	* 2.4018	* 1.8526	* 2.2677	* 1.7782	* 2.4833	* 4.0877
	* 2.4333	* 1.9144	* 2.4514	* 1.8718	* 2.3206	* 1.7981	* 2.5046	* 3.8802
	* 2.3272	* 1.9452	* 2.4662	* 1.8856	* 2.3298	* 1.8223	* 2.4851	* 3.5699
9	* 1.8339	* 2.2428	* 1.8204	* 2.2090	* 1.8219	* 2.1268	* 1.8192	* 3.5663
	* 1.8153	* 2.2461	* 1.8153	* 2.2467	* 1.8117	* 2.0781	* 1.7745	* 3.4606
	* 1.8282	* 2.3312	* 1.8407	* 2.3246	* 1.7899	* 2.0821	* 1.7164	* 3.3021
	* 1.8725	* 2.4377	* 1.8835	* 2.3994	* 1.7844	* 2.1298	* 1.7238	* 3.1846
	* 1.9144	* 2.4895	* 1.9213	* 2.4375	* 1.8097	* 2.1837	* 1.7507	* 3.0616
	* 1.9452	* 2.5030	* 1.9444	* 2.4447	* 1.8329	* 2.2071	* 1.7874	* 2.8691
10	* 2.2049	* 1.8212	* 2.3525	* 2.0559	* 2.0992	* 1.8578	* 1.8836	* 3.6133
	* 2.2106	* 1.8157	* 2.4017	* 2.1681	* 2.1705	* 1.8418	* 1.8421	* 3.4638
	* 2.2971	* 1.8415	* 2.4226	* 2.3543	* 2.2260	* 1.7868	* 1.7489	* 3.2426
	* 2.4018	* 1.8841	* 2.4086	* 2.4664	* 2.2618	* 1.7406	* 1.7194	* 3.1156
	* 2.4514	* 1.9217	* 2.3460	* 2.5083	* 2.3103	* 1.7475	* 1.7453	* 2.9956
	* 2.4662	* 1.9448	* 2.2487	* 2.5091	* 2.3206	* 1.7857	* 1.7881	* 2.8186
11	* 1.8361	* 2.2121	* 2.0617	* 2.2056	* 1.7808	* 2.1341	* 1.7388	* 3.9493
	* 1.8311	* 2.2475	* 2.1736	* 2.2543	* 1.7897	* 2.1024	* 1.7364	* 3.8470
	* 1.8374	* 2.3244	* 2.3589	* 2.3196	* 1.7798	* 2.1101	* 1.7393	* 3.6889
	* 1.8526	* 2.3989	* 2.4702	* 2.3698	* 1.7755	* 2.1647	* 1.7789	* 3.5760
	* 1.8718	* 2.4368	* 2.5094	* 2.3969	* 1.7884	* 2.2223	* 1.8321	* 3.4587
	* 1.8856	* 2.4440	* 2.5113	* 2.4084	* 1.8195	* 2.2407	* 1.8656	* 3.2458
12	* 2.1982	* 1.8232	* 2.1009	* 1.7808	* 1.9562	* 1.7757	* 2.7965	
	* 2.1976	* 1.8123	* 2.1721	* 1.7900	* 1.9670	* 1.7460	* 2.7872	
	* 2.2144	* 1.7903	* 2.2266	* 1.7799	* 2.0027	* 1.6907	* 2.7934	
	* 2.2677	* 1.7846	* 2.2621	* 1.7756	* 2.0614	* 1.7047	* 2.8364	
	* 2.3206	* 1.8097	* 2.3104	* 1.7884	* 2.1138	* 1.7472	* 2.8601	
	* 2.3298	* 1.8328	* 2.3206	* 1.8194	* 2.1445	* 1.7872	* 2.8048	
13	* 1.8535	* 2.1275	* 1.8586	* 2.1346	* 1.7760	* 1.6646	* 3.7913	
	* 1.8193	* 2.0788	* 1.8426	* 2.1029	* 1.7462	* 1.6761	* 3.7332	
	* 1.7908	* 2.0827	* 1.7871	* 2.1104	* 1.6909	* 1.7046	* 3.6484	
	* 1.7782	* 2.1302	* 1.7408	* 2.1649	* 1.7048	* 1.7898	* 3.6038	
	* 1.7981	* 2.1840	* 1.7475	* 2.2223	* 1.7472	* 1.8543	* 3.4900	
	* 1.8223	* 2.2072	* 1.7856	* 2.2407	* 1.7871	* 1.8850	* 3.2922	
14	* 2.5108	* 1.8196	* 1.8841	* 1.7393	* 2.7987	* 3.7915		
	* 2.4808	* 1.7750	* 1.8427	* 1.7369	* 2.7893	* 3.7333		
	* 2.4590	* 1.7167	* 1.7493	* 1.7397	* 2.7949	* 3.6490		
	* 2.4833	* 1.7240	* 1.7195	* 1.7790	* 2.8375	* 3.6037		
	* 2.5046	* 1.7507	* 1.7453	* 1.8321	* 2.8610	* 3.4899		
	* 2.4851	* 1.7873	* 1.7880	* 1.8655	* 2.8056	* 3.2920		
15	* 4.4632	* 3.5668	* 3.6136	* 3.9503	* 4 EFPD	118 % POWER		
	* 4.4113	* 3.4611	* 3.4641	* 3.8481	* 50 EFPD	118 % POWER		
	* 4.2416	* 3.3025	* 3.2427	* 3.6897	* 150 EFPD	118 % POWER		
	* 4.0877	* 3.1850	* 3.1153	* 3.5762	* 250 EFPD	118 % POWER		
	* 3.8802	* 3.0618	* 2.9953	* 3.4587	* 350 EFPD	118 % POWER		
	* 3.5699	* 2.8690	* 2.8180	* 3.2456	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 276 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7581	* 1.8754	* 2.2541	* 1.8838	* 2.2584	* 1.9174	* 2.6389	* 4.6922
	* 2.6233	* 1.8289	* 2.2275	* 1.8506	* 2.2297	* 1.8578	* 2.5721	* 4.6322
	* 2.5787	* 1.8603	* 2.3378	* 1.8708	* 2.2708	* 1.8412	* 2.5610	* 4.4740
	* 2.6630	* 1.9758	* 2.5340	* 1.9536	* 2.4078	* 1.9060	* 2.6774	* 4.3900
	* 2.6466	* 2.0718	* 2.6624	* 2.0252	* 2.5163	* 1.9602	* 2.7288	* 4.1866
	* 2.5521	* 2.1234	* 2.6940	* 2.0559	* 2.5467	* 1.9838	* 2.7079	* 3.8850
9	* 1.8754	* 2.2942	* 1.8646	* 2.2676	* 1.8807	* 2.2105	* 1.9205	* 3.7632
	* 1.8289	* 2.2641	* 1.8320	* 2.2768	* 1.8483	* 2.1325	* 1.8482	* 3.6443
	* 1.8603	* 2.3735	* 1.8736	* 2.3712	* 1.8448	* 2.1505	* 1.7999	* 3.4877
	* 1.9758	* 2.5786	* 1.9866	* 2.5323	* 1.9065	* 2.2801	* 1.8734	* 3.4537
	* 2.0718	* 2.7045	* 2.0795	* 2.6453	* 1.9655	* 2.3778	* 1.9108	* 3.3258
	* 2.1234	* 2.7406	* 2.1177	* 2.6729	* 1.9958	* 2.4070	* 1.9370	* 3.1145
10	* 2.2541	* 1.8653	* 2.4134	* 2.1039	* 2.1680	* 1.9332	* 1.9965	* 3.8096
	* 2.2275	* 1.8324	* 2.4327	* 2.2031	* 2.2164	* 1.8956	* 1.9205	* 3.6501
	* 2.3378	* 1.8745	* 2.4734	* 2.4224	* 2.3031	* 1.8745	* 1.8373	* 3.4277
	* 2.5340	* 1.9873	* 2.5583	* 2.6286	* 2.4338	* 1.8922	* 1.8684	* 3.3832
	* 2.6623	* 2.0799	* 2.5479	* 2.7208	* 2.5029	* 1.9044	* 1.9013	* 3.2528
	* 2.6940	* 2.1181	* 2.4575	* 2.7384	* 2.5316	* 1.9337	* 1.9351	* 3.0559
11	* 1.8838	* 2.2706	* 2.1105	* 2.2679	* 1.8747	* 2.2615	* 1.8516	* 4.1791
	* 1.8506	* 2.2778	* 2.2093	* 2.3243	* 1.8724	* 2.2116	* 1.8303	* 4.0774
	* 1.8708	* 2.3710	* 2.4270	* 2.4144	* 1.8824	* 2.2366	* 1.8395	* 3.9252
	* 1.9536	* 2.5318	* 2.6311	* 2.5555	* 1.9279	* 2.3577	* 1.9331	* 3.8799
	* 2.0252	* 2.6445	* 2.7219	* 2.6014	* 1.9415	* 2.4136	* 1.9970	* 3.7354
	* 2.0559	* 2.6720	* 2.7408	* 2.6227	* 1.9743	* 2.4391	* 2.0217	* 3.5128
12	* 2.2584	* 1.8822	* 2.1701	* 1.8748	* 2.0739	* 1.8951	* 2.9909	*
	* 2.2297	* 1.8487	* 2.2182	* 1.8725	* 2.0657	* 1.8489	* 2.9553	*
	* 2.2708	* 1.8453	* 2.3039	* 1.8826	* 2.1221	* 1.8127	* 2.9820	*
	* 2.4078	* 1.9067	* 2.4342	* 1.9280	* 2.2445	* 1.8474	* 3.0811	*
	* 2.5163	* 1.9655	* 2.5030	* 1.9415	* 2.2998	* 1.9022	* 3.0991	*
	* 2.5467	* 1.9957	* 2.5316	* 1.9743	* 2.3308	* 1.9347	* 3.0372	*
13	* 1.9174	* 2.2113	* 1.9342	* 2.2624	* 1.8954	* 1.7828	* 4.0662	*
	* 1.8578	* 2.1333	* 1.8965	* 2.2122	* 1.8492	* 1.7888	* 3.9917	*
	* 1.8412	* 2.1511	* 1.8750	* 2.2370	* 1.8129	* 1.8402	* 3.9397	*
	* 1.9060	* 2.2805	* 1.8924	* 2.3579	* 1.8475	* 1.9368	* 3.9086	*
	* 1.9602	* 2.3781	* 1.9044	* 2.4137	* 1.9022	* 2.0140	* 3.7885	*
	* 1.9838	* 2.4072	* 1.9336	* 2.4391	* 1.9347	* 2.0365	* 3.5594	*
14	* 2.6389	* 1.9211	* 1.9972	* 1.8521	* 2.9933	* 4.0664	*	*
	* 2.5721	* 1.8488	* 1.9211	* 1.8309	* 2.9577	* 3.9919	*	*
	* 2.5610	* 1.8003	* 1.8378	* 1.8399	* 2.9836	* 3.9401	*	*
	* 2.6774	* 1.8736	* 1.8686	* 1.9332	* 3.0824	* 3.9085	*	*
	* 2.7288	* 1.9108	* 1.9013	* 1.9970	* 3.1002	* 3.7883	*	*
	* 2.7079	* 1.9369	* 1.9349	* 2.0216	* 3.0381	* 3.5592	*	*
15	* 4.6922	* 3.7637	* 3.8099	* 4.1801	* 4 EFPD	118 % POWER		
	* 4.6322	* 3.6450	* 3.6505	* 4.0787	* 50 EFPD	118 % POWER		
	* 4.4740	* 3.4886	* 3.4280	* 3.9261	* 150 EFPD	118 % POWER		
	* 4.3900	* 3.4541	* 3.3829	* 3.8801	* 250 EFPD	118 % POWER		
	* 4.1866	* 3.3261	* 3.2524	* 3.7354	* 350 EFPD	118 % POWER		
	* 3.8850	* 3.1146	* 3.0554	* 3.5126	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 277 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7730	* 1.8790	* 2.2496	* 1.8847	* 2.2663	* 1.9394	* 2.6626	* 4.7952
	* 2.6364	* 1.8266	* 2.2170	* 1.8478	* 2.2339	* 1.8746	* 2.5830	* 4.6508
	* 2.5935	* 1.8618	* 2.3300	* 1.8862	* 2.2928	* 1.8613	* 2.5784	* 4.5119
	* 2.6465	* 1.9765	* 2.5152	* 1.9603	* 2.4074	* 1.9081	* 2.6725	* 4.4582
	* 2.6479	* 2.0757	* 2.6409	* 2.0253	* 2.5100	* 1.9716	* 2.7486	* 4.3004
	* 2.5640	* 2.1377	* 2.6916	* 2.0929	* 2.5910	* 2.0514	* 2.7915	* 4.0503
9	* 1.8790	* 2.2931	* 1.8665	* 2.2660	* 1.8950	* 2.2356	* 1.9397	* 3.8361
	* 1.8266	* 2.2574	* 1.8287	* 2.2667	* 1.8618	* 2.1470	* 1.8606	* 3.6672
	* 1.8618	* 2.3685	* 1.8788	* 2.3768	* 1.8656	* 2.1701	* 1.8158	* 3.5153
	* 1.9765	* 2.5565	* 1.9910	* 2.5331	* 1.9099	* 2.2780	* 1.8824	* 3.4758
	* 2.0757	* 2.6897	* 2.0818	* 2.6325	* 1.9755	* 2.3827	* 1.9560	* 3.3999
	* 2.1377	* 2.7300	* 2.1383	* 2.6914	* 2.0568	* 2.4709	* 2.0386	* 3.2625
10	* 2.2496	* 1.8674	* 2.3953	* 2.1128	* 2.1890	* 1.9588	* 2.0170	* 3.8523
	* 2.2170	* 1.8292	* 2.4136	* 2.1972	* 2.2280	* 1.9127	* 1.9325	* 3.6473
	* 2.3300	* 1.8796	* 2.4601	* 2.4159	* 2.3282	* 1.8908	* 1.8535	* 3.4360
	* 2.5152	* 1.9916	* 2.5120	* 2.6042	* 2.4355	* 1.8981	* 1.8849	* 3.3785
	* 2.6409	* 2.0821	* 2.5221	* 2.7163	* 2.5356	* 1.9478	* 1.9562	* 3.3014
	* 2.6916	* 2.1382	* 2.4382	* 2.7442	* 2.6139	* 2.0357	* 2.0446	* 3.1762
11	* 1.8847	* 2.2673	* 2.1187	* 2.2816	* 1.8981	* 2.2875	* 1.8744	* 4.2501
	* 1.8478	* 2.2675	* 2.2027	* 2.3378	* 1.8885	* 2.2249	* 1.8429	* 4.0758
	* 1.8862	* 2.3766	* 2.4205	* 2.4377	* 1.9040	* 2.2583	* 1.8560	* 3.9253
	* 1.9603	* 2.5325	* 2.6066	* 2.5664	* 1.9595	* 2.3755	* 1.9537	* 3.8959
	* 2.0253	* 2.6320	* 2.7172	* 2.6634	* 2.0170	* 2.4759	* 2.0473	* 3.8161
	* 2.0929	* 2.6908	* 2.7476	* 2.7296	* 2.1042	* 2.5594	* 2.1293	* 3.6554
12	* 2.2663	* 1.8965	* 2.1909	* 1.8982	* 2.0934	* 1.9187	* 3.0019	*
	* 2.2339	* 1.8622	* 2.2296	* 1.8886	* 2.0782	* 1.8646	* 2.9452	*
	* 2.2928	* 1.8661	* 2.3290	* 1.9041	* 2.1429	* 1.8324	* 2.9853	*
	* 2.4074	* 1.9101	* 2.4359	* 1.9596	* 2.2766	* 1.9053	* 3.1177	*
	* 2.5100	* 1.9755	* 2.5358	* 2.0170	* 2.3905	* 1.9972	* 3.1922	*
	* 2.5910	* 2.0567	* 2.6138	* 2.1041	* 2.4835	* 2.0935	* 3.2038	*
13	* 1.9394	* 2.2364	* 1.9599	* 2.2884	* 1.9191	* 1.8257	* 4.1916	*
	* 1.8746	* 2.1477	* 1.9136	* 2.2255	* 1.8649	* 1.8128	* 4.0678	*
	* 1.8613	* 2.1708	* 1.8913	* 2.2587	* 1.8326	* 1.8696	* 4.0092	*
	* 1.9081	* 2.2785	* 1.8983	* 2.3758	* 1.9054	* 2.0189	* 4.0630	*
	* 1.9716	* 2.3830	* 1.9478	* 2.4760	* 1.9972	* 2.1284	* 4.0164	*
	* 2.0514	* 2.4711	* 2.0356	* 2.5594	* 2.0935	* 2.2094	* 3.8563	*
14	* 2.6626	* 1.9403	* 2.0178	* 1.8750	* 3.0041	* 4.1919	*	*
	* 2.5830	* 1.8613	* 1.9333	* 1.8436	* 2.9473	* 4.0681	*	*
	* 2.5784	* 1.8163	* 1.8540	* 1.8564	* 2.9870	* 4.0094	*	*
	* 2.6725	* 1.8826	* 1.8851	* 1.9539	* 3.1190	* 4.0630	*	*
	* 2.7486	* 1.9561	* 1.9562	* 2.0473	* 3.1934	* 4.0163	*	*
	* 2.7915	* 2.0385	* 2.0445	* 2.1292	* 3.2048	* 3.8562	*	*
15	* 4.7952	* 3.8370	* 3.8529	* 4.2515	* 4 EFPD	118 % POWER		
	* 4.6508	* 3.6679	* 3.6477	* 4.0772	* 50 EFPD	118 % POWER		
	* 4.5119	* 3.5159	* 3.4363	* 3.9262	* 150 EFPD	118 % POWER		
	* 4.4582	* 3.4764	* 3.3783	* 3.8963	* 250 EFPD	118 % POWER		
	* 4.3004	* 3.4003	* 3.3010	* 3.8161	* 350 EFPD	118 % POWER		
	* 4.0503	* 3.2628	* 3.1757	* 3.6553	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 278 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.7293	* 1.8315	* 2.2044	* 1.8313	* 2.2125	* 1.8777	* 2.6008	* 4.6470
	* 2.5799	* 1.7737	* 2.1656	* 1.7886	* 2.1727	* 1.8100	* 2.5203	* 4.4896
	* 2.5381	* 1.8112	* 2.2785	* 1.8267	* 2.2369	* 1.8091	* 2.5231	* 4.3697
	* 2.5705	* 1.9072	* 2.4454	* 1.8960	* 2.3549	* 1.8574	* 2.6205	* 4.3132
	* 2.5376	* 1.9947	* 2.5529	* 1.9604	* 2.4460	* 1.9046	* 2.6752	* 4.1655
	* 2.4395	* 2.0488	* 2.5895	* 2.0046	* 2.4961	* 1.9629	* 2.6857	* 3.8781
9	* 1.8315	* 2.2524	* 1.8157	* 2.2174	* 1.8404	* 2.1800	* 1.8929	* 3.7268
	* 1.7737	* 2.2092	* 1.7727	* 2.2097	* 1.7977	* 2.0900	* 1.8019	* 3.5522
	* 1.8112	* 2.3209	* 1.8229	* 2.3187	* 1.8149	* 2.1204	* 1.7669	* 3.4231
	* 1.9072	* 2.4903	* 1.9180	* 2.4582	* 1.8621	* 2.2343	* 1.8314	* 3.3928
	* 1.9947	* 2.5932	* 2.0044	* 2.5594	* 1.9110	* 2.3184	* 1.8883	* 3.2970
	* 2.0488	* 2.6244	* 2.0492	* 2.5974	* 1.9689	* 2.3784	* 1.9467	* 3.1228
10	* 2.2044	* 1.8165	* 2.3628	* 2.0671	* 2.1437	* 1.9073	* 1.9733	* 3.7901
	* 2.1656	* 1.7731	* 2.3679	* 2.1428	* 2.1741	* 1.8574	* 1.8783	* 3.5704
	* 2.2785	* 1.8237	* 2.4131	* 2.3616	* 2.2831	* 1.8465	* 1.8064	* 3.3767
	* 2.4454	* 1.9186	* 2.4612	* 2.5385	* 2.3941	* 1.8488	* 1.8348	* 3.3350
	* 2.5529	* 2.0048	* 2.4453	* 2.6317	* 2.4765	* 1.8821	* 1.8889	* 3.2374
	* 2.5895	* 2.0490	* 2.3559	* 2.6471	* 2.5187	* 1.9455	* 1.9525	* 3.0797
11	* 1.8313	* 2.2186	* 2.0728	* 2.2356	* 1.8593	* 2.2558	* 1.8435	* 4.1922
	* 1.7886	* 2.2106	* 2.1482	* 2.2921	* 1.8495	* 2.1984	* 1.8027	* 4.0061
	* 1.8267	* 2.3184	* 2.3661	* 2.3985	* 1.8786	* 2.2408	* 1.8225	* 3.8886
	* 1.8960	* 2.4575	* 2.5406	* 2.5150	* 1.9152	* 2.3440	* 1.9157	* 3.8733
	* 1.9604	* 2.5586	* 2.6336	* 2.6035	* 1.9537	* 2.4156	* 1.9879	* 3.7656
	* 2.0046	* 2.5965	* 2.6491	* 2.6341	* 2.0151	* 2.4654	* 2.0452	* 3.5671
12	* 2.2125	* 1.8418	* 2.1457	* 1.8594	* 2.0674	* 1.8866	* 3.0001	*
	* 2.1727	* 1.7981	* 2.1756	* 1.8496	* 2.0523	* 1.8319	* 2.9227	*
	* 2.2369	* 1.8153	* 2.2838	* 1.8787	* 2.1256	* 1.8046	* 2.9831	*
	* 2.3549	* 1.8623	* 2.3944	* 1.9153	* 2.2420	* 1.8617	* 3.1021	*
	* 2.4460	* 1.9110	* 2.4766	* 1.9537	* 2.3311	* 1.9342	* 3.1446	*
	* 2.4961	* 1.9688	* 2.5186	* 2.0151	* 2.3926	* 2.0037	* 3.1156	*
13	* 1.8777	* 2.1808	* 1.9083	* 2.2567	* 1.8869	* 1.7979	* 4.1006	*
	* 1.8100	* 2.0909	* 1.8582	* 2.1991	* 1.8323	* 1.7774	* 3.9476	*
	* 1.8091	* 2.1211	* 1.8470	* 2.2413	* 1.8048	* 1.8420	* 3.9523	*
	* 1.8574	* 2.2348	* 1.8490	* 2.3443	* 1.8618	* 1.9740	* 3.9798	*
	* 1.9046	* 2.3187	* 1.8821	* 2.4157	* 1.9342	* 2.0659	* 3.8947	*
	* 1.9629	* 2.3786	* 1.9453	* 2.4653	* 2.0037	* 2.1202	* 3.6897	*
14	* 2.6008	* 1.8935	* 1.9740	* 1.8442	* 3.0027	* 4.1009	*	*
	* 2.5203	* 1.8026	* 1.8790	* 1.8034	* 2.9252	* 3.9479	*	*
	* 2.5231	* 1.7673	* 1.8068	* 1.8230	* 2.9848	* 3.9524	*	*
	* 2.6205	* 1.8316	* 1.8349	* 1.9158	* 3.1035	* 3.9798	*	*
	* 2.6752	* 1.8884	* 1.8889	* 1.9878	* 3.1458	* 3.8945	*	*
	* 2.6857	* 1.9466	* 1.9524	* 2.0450	* 3.1166	* 3.6896	*	*
15	* 4.6470	* 3.7277	* 3.7908	* 4.1937	* 4 EFPD	118 % POWER		
	* 4.4896	* 3.5529	* 3.5709	* 4.0076	* 50 EFPD	118 % POWER		
	* 4.3697	* 3.4241	* 3.3770	* 3.8895	* 150 EFPD	118 % POWER		
	* 4.3132	* 3.3934	* 3.3348	* 3.8736	* 250 EFPD	118 % POWER		
	* 4.1655	* 3.2973	* 3.2371	* 3.7656	* 350 EFPD	118 % POWER		
	* 3.8781	* 3.1231	* 3.0792	* 3.5670	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 279 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.5969	* 1.7353	* 2.0932	* 1.7365	* 2.1051	* 1.7813	* 2.4648	* 4.4153
	* 2.4355	* 1.6690	* 2.0425	* 1.6848	* 2.0535	* 1.6996	* 2.3657	* 4.2448
	* 2.3911	* 1.7018	* 2.1456	* 1.7209	* 2.1093	* 1.6969	* 2.3721	* 4.1274
	* 2.4312	* 1.8032	* 2.3161	* 1.7997	* 2.2411	* 1.7600	* 2.4875	* 4.0938
	* 2.4220	* 1.9008	* 2.4347	* 1.8738	* 2.3536	* 1.8350	* 2.5790	* 3.9777
	* 2.3285	* 1.9486	* 2.4694	* 1.9157	* 2.3975	* 1.8872	* 2.5883	* 3.7095
9	* 1.7353	* 2.1403	* 1.7212	* 2.1082	* 1.7459	* 2.0614	* 1.7821	* 3.5389
	* 1.6690	* 2.0846	* 1.6688	* 2.0871	* 1.6937	* 1.9613	* 1.6849	* 3.3328
	* 1.7018	* 2.1865	* 1.7144	* 2.1889	* 1.7023	* 1.9939	* 1.6564	* 3.2068
	* 1.8032	* 2.3588	* 1.8155	* 2.3359	* 1.7621	* 2.1202	* 1.7382	* 3.2082
	* 1.9008	* 2.4751	* 1.9089	* 2.4448	* 1.8391	* 2.2359	* 1.8189	* 3.1650
	* 1.9486	* 2.5054	* 1.9493	* 2.4793	* 1.8919	* 2.2903	* 1.8695	* 2.9970
10	* 2.0932	* 1.7220	* 2.2477	* 1.9640	* 2.0342	* 1.7999	* 1.8546	* 3.6035
	* 2.0425	* 1.6692	* 2.2364	* 2.0226	* 2.0482	* 1.7346	* 1.7512	* 3.3514
	* 2.1456	* 1.7151	* 2.2740	* 2.2268	* 2.1455	* 1.7290	* 1.6900	* 3.1684
	* 2.3161	* 1.8160	* 2.3308	* 2.4062	* 2.2711	* 1.7524	* 1.7404	* 3.1593
	* 2.4347	* 1.9092	* 2.3312	* 2.5104	* 2.3820	* 1.8122	* 1.8179	* 3.1173
	* 2.4694	* 1.9492	* 2.2477	* 2.5267	* 2.4238	* 1.8706	* 1.8762	* 2.9666
11	* 1.7365	* 2.1093	* 1.9694	* 2.1201	* 1.7599	* 2.1244	* 1.7302	* 3.9612
	* 1.6848	* 2.0879	* 2.0276	* 2.1461	* 1.7245	* 2.0424	* 1.6734	* 3.7449
	* 1.7209	* 2.1887	* 2.2311	* 2.2554	* 1.7574	* 2.0949	* 1.6999	* 3.6365
	* 1.7997	* 2.3352	* 2.4076	* 2.3986	* 1.8220	* 2.2227	* 1.8129	* 3.6652
	* 1.8738	* 2.4440	* 2.5119	* 2.4995	* 1.8875	* 2.3320	* 1.9157	* 3.6138
	* 1.9157	* 2.4785	* 2.5284	* 2.5311	* 1.9444	* 2.3842	* 1.9699	* 3.4333
12	* 2.1051	* 1.7472	* 2.0362	* 1.7600	* 1.9589	* 1.7756	* 2.8171	*
	* 2.0535	* 1.6941	* 2.0498	* 1.7245	* 1.9154	* 1.6984	* 2.7245	*
	* 2.1093	* 1.7027	* 2.1462	* 1.7575	* 1.9965	* 1.6866	* 2.7885	*
	* 2.2411	* 1.7622	* 2.2714	* 1.8222	* 2.1408	* 1.7792	* 2.9454	*
	* 2.3536	* 1.8391	* 2.3821	* 1.8875	* 2.2594	* 1.8743	* 3.0373	*
	* 2.3975	* 1.8918	* 2.4237	* 1.9443	* 2.3150	* 1.9352	* 3.0169	*
13	* 1.7813	* 2.0622	* 1.8009	* 2.1253	* 1.7759	* 1.6924	* 3.8363	*
	* 1.6996	* 1.9622	* 1.7354	* 2.0430	* 1.6987	* 1.6475	* 3.6667	*
	* 1.6969	* 1.9945	* 1.7294	* 2.0953	* 1.6868	* 1.7220	* 3.6639	*
	* 1.7600	* 2.1206	* 1.7526	* 2.2229	* 1.7793	* 1.8860	* 3.7625	*
	* 1.8350	* 2.2361	* 1.8122	* 2.3321	* 1.8744	* 2.0027	* 3.7415	*
	* 1.8872	* 2.2905	* 1.8704	* 2.3841	* 1.9351	* 2.0488	* 3.5492	*
14	* 2.4648	* 1.7827	* 1.8553	* 1.7308	* 2.8196	* 3.8366	*	*
	* 2.3657	* 1.6855	* 1.7519	* 1.6740	* 2.7269	* 3.6670	*	*
	* 2.3721	* 1.6568	* 1.6904	* 1.7003	* 2.7905	* 3.6641	*	*
	* 2.4875	* 1.7384	* 1.7406	* 1.8131	* 2.9467	* 3.7625	*	*
	* 2.5790	* 1.8189	* 1.8178	* 1.9157	* 3.0385	* 3.7413	*	*
	* 2.5883	* 1.8694	* 1.8760	* 1.9697	* 3.0179	* 3.5490	*	*
15	* 4.4153	* 3.5398	* 3.6041	* 3.9628	* 4 EFPD	118 % POWER		
	* 4.2448	* 3.3337	* 3.3521	* 3.7464	* 50 EFPD	118 % POWER		
	* 4.1274	* 3.2078	* 3.1686	* 3.6374	* 150 EFPD	118 % POWER		
	* 4.0938	* 3.2087	* 3.1591	* 3.6655	* 250 EFPD	118 % POWER		
	* 3.9777	* 3.1653	* 3.1169	* 3.6138	* 350 EFPD	118 % POWER		
	* 3.7095	* 2.9973	* 2.9662	* 3.4331	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 280 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.4698	* 1.6404	* 1.9801	* 1.6410	* 1.9896	* 1.6801	* 2.3297	* 4.1975
	* 2.3185	* 1.5787	* 1.9344	* 1.5936	* 1.9435	* 1.6051	* 2.2388	* 4.0369
	* 2.2660	* 1.6004	* 2.0236	* 1.6195	* 1.9863	* 1.5939	* 2.2335	* 3.9055
	* 2.2937	* 1.6875	* 2.1750	* 1.6861	* 2.1014	* 1.6444	* 2.3318	* 3.8616
	* 2.2840	* 1.7817	* 2.2889	* 1.7585	* 2.2118	* 1.7164	* 2.4197	* 3.7532
	* 2.2158	* 1.8479	* 2.3450	* 1.8201	* 2.2827	* 1.7935	* 2.4617	* 3.5307
9	* 1.6404	* 2.0268	* 1.6266	* 1.9939	* 1.6478	* 1.9430	* 1.6768	* 3.3481
	* 1.5787	* 1.9762	* 1.5786	* 1.9767	* 1.5997	* 1.8514	* 1.5870	* 3.1553
	* 1.6004	* 2.0637	* 1.6132	* 2.0657	* 1.5973	* 1.8736	* 1.5499	* 3.0190
	* 1.6875	* 2.2166	* 1.7004	* 2.1958	* 1.6465	* 1.9845	* 1.6201	* 3.0071
	* 1.7817	* 2.3279	* 1.7907	* 2.3012	* 1.7201	* 2.0955	* 1.6998	* 2.9673
	* 1.8479	* 2.3795	* 1.8494	* 2.3585	* 1.7981	* 2.1793	* 1.7768	* 2.8480
10	* 1.9801	* 1.6273	* 2.1225	* 1.8521	* 1.9167	* 1.6957	* 1.7453	* 3.4052
	* 1.9344	* 1.5790	* 2.1167	* 1.9128	* 1.9351	* 1.6363	* 1.6490	* 3.1686
	* 2.0236	* 1.6140	* 2.1516	* 2.1010	* 2.0185	* 1.6175	* 1.5811	* 2.9768
	* 2.1750	* 1.7009	* 2.1960	* 2.2599	* 2.1259	* 1.6318	* 1.6200	* 2.9530
	* 2.2889	* 1.7910	* 2.1969	* 2.3585	* 2.2320	* 1.6919	* 1.6976	* 2.9113
	* 2.3450	* 1.8493	* 2.1362	* 2.3948	* 2.3046	* 1.7768	* 1.7825	* 2.8059
11	* 1.6410	* 1.9950	* 1.8572	* 1.9977	* 1.6506	* 1.9955	* 1.6210	* 3.7359
	* 1.5936	* 1.9774	* 1.9176	* 2.0195	* 1.6200	* 1.9201	* 1.5700	* 3.5363
	* 1.6195	* 2.0654	* 2.1050	* 2.1141	* 1.6416	* 1.9600	* 1.5888	* 3.4163
	* 1.6861	* 2.1952	* 2.2613	* 2.2386	* 1.6937	* 2.0735	* 1.6871	* 3.4178
	* 1.7585	* 2.3004	* 2.3600	* 2.3406	* 1.7592	* 2.1784	* 1.7854	* 3.3759
	* 1.8201	* 2.3576	* 2.3964	* 2.3976	* 1.8408	* 2.2580	* 1.8649	* 3.2457
12	* 1.9896	* 1.6490	* 1.9185	* 1.6507	* 1.8353	* 1.6644	* 2.6436	*
	* 1.9435	* 1.6001	* 1.9366	* 1.6201	* 1.7975	* 1.5935	* 2.5599	*
	* 1.9863	* 1.5977	* 2.0192	* 1.6417	* 1.8659	* 1.5720	* 2.6040	*
	* 2.1014	* 1.6466	* 2.1262	* 1.6938	* 1.9924	* 1.6506	* 2.7389	*
	* 2.2118	* 1.7201	* 2.2320	* 1.7592	* 2.1064	* 1.7436	* 2.8267	*
	* 2.2827	* 1.7980	* 2.3045	* 1.8407	* 2.1907	* 1.8296	* 2.8394	*
13	* 1.6801	* 1.9438	* 1.6967	* 1.9964	* 1.6647	* 1.5809	* 3.6136	*
	* 1.6051	* 1.8522	* 1.6371	* 1.9207	* 1.5938	* 1.5408	* 3.4580	*
	* 1.5939	* 1.8742	* 1.6179	* 1.9603	* 1.5722	* 1.6030	* 3.4374	*
	* 1.6444	* 1.9850	* 1.6320	* 2.0738	* 1.6506	* 1.7497	* 3.5093	*
	* 1.7164	* 2.0958	* 1.6918	* 2.1785	* 1.7436	* 1.8602	* 3.4923	*
	* 1.7935	* 2.1795	* 1.7767	* 2.2579	* 1.8295	* 1.9324	* 3.3511	*
14	* 2.3297	* 1.6774	* 1.7460	* 1.6216	* 2.6461	* 3.6139	*	*
	* 2.2388	* 1.5877	* 1.6497	* 1.5707	* 2.5622	* 3.4583	*	*
	* 2.2335	* 1.5503	* 1.5816	* 1.5892	* 2.6055	* 3.4375	*	*
	* 2.3318	* 1.6203	* 1.6202	* 1.6872	* 2.7401	* 3.5093	*	*
	* 2.4197	* 1.6998	* 1.6975	* 1.7854	* 2.8277	* 3.4921	*	*
	* 2.4617	* 1.7767	* 1.7824	* 1.8647	* 2.8403	* 3.3509	*	*
15	* 4.1975	* 3.3491	* 3.4060	* 3.7375	* 4 EFPD	118 % POWER		
	* 4.0369	* 3.1563	* 3.1694	* 3.5377	* 50 EFPD	118 % POWER		
	* 3.9055	* 3.0200	* 2.9771	* 3.4171	* 150 EFPD	118 % POWER		
	* 3.8616	* 3.0076	* 2.9528	* 3.4181	* 250 EFPD	118 % POWER		
	* 3.7532	* 2.9676	* 2.9109	* 3.3758	* 350 EFPD	118 % POWER		
	* 3.5307	* 2.8483	* 2.8054	* 3.2456	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 281 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.3738 *	* 1.5716 *	* 1.8918 *	* 1.5724 *	* 1.9016 *	* 1.6088 *	* 2.2259 *	* 4.0486 *
	* 2.2408 *	* 1.5176 *	* 1.8548 *	* 1.5326 *	* 1.8646 *	* 1.5434 *	* 2.1478 *	* 3.9039 *
	* 2.1797 *	* 1.5302 *	* 1.9320 *	* 1.5482 *	* 1.8965 *	* 1.5227 *	* 2.1311 *	* 3.7535 *
	* 2.1909 *	* 1.6007 *	* 2.0622 *	* 1.6014 *	* 1.9899 *	* 1.5581 *	* 2.2066 *	* 3.6897 *
	* 2.1765 *	* 1.6874 *	* 2.1681 *	* 1.6664 *	* 2.0912 *	* 1.6226 *	* 2.2859 *	* 3.5761 *
	* 2.1245 *	* 1.7622 *	* 2.2365 *	* 1.7364 *	* 2.1765 *	* 1.7068 *	* 2.3401 *	* 3.3797 *
9	* 1.5716 *	* 1.9381 *	* 1.5578 *	* 1.9053 *	* 1.5770 *	* 1.8552 *	* 1.5981 *	* 3.1990 *
	* 1.5176 *	* 1.8971 *	* 1.5172 *	* 1.8973 *	* 1.5383 *	* 1.7739 *	* 1.5207 *	* 3.0267 *
	* 1.5302 *	* 1.9716 *	* 1.5431 *	* 1.9738 *	* 1.5245 *	* 1.7861 *	* 1.4752 *	* 2.8817 *
	* 1.6007 *	* 2.1025 *	* 1.6144 *	* 2.0838 *	* 1.5604 *	* 1.8770 *	* 1.5309 *	* 2.8503 *
	* 1.6874 *	* 2.2056 *	* 1.6976 *	* 2.1806 *	* 1.6260 *	* 1.9792 *	* 1.6035 *	* 2.8055 *
	* 1.7622 *	* 2.2699 *	* 1.7644 *	* 2.2491 *	* 1.7121 *	* 2.0728 *	* 1.6878 *	* 2.7120 *
10	* 1.8918 *	* 1.5585 *	* 2.0168 *	* 1.7651 *	* 1.8253 *	* 1.6198 *	* 1.6622 *	* 3.2305 *
	* 1.8548 *	* 1.5176 *	* 2.0240 *	* 1.8323 *	* 1.8534 *	* 1.5698 *	* 1.5787 *	* 3.0193 *
	* 1.9320 *	* 1.5437 *	* 2.0477 *	* 2.0068 *	* 1.9241 *	* 1.5362 *	* 1.5042 *	* 2.8241 *
	* 2.0622 *	* 1.6148 *	* 2.0682 *	* 2.1390 *	* 2.0111 *	* 1.5414 *	* 1.5290 *	* 2.7789 *
	* 2.1681 *	* 1.6979 *	* 2.0675 *	* 2.2269 *	* 2.1084 *	* 1.5939 *	* 1.5993 *	* 2.7319 *
	* 2.2365 *	* 1.7643 *	* 2.0216 *	* 2.2725 *	* 2.1956 *	* 1.6858 *	* 1.6913 *	* 2.6460 *
11	* 1.5724 *	* 1.9063 *	* 1.7700 *	* 1.9035 *	* 1.5689 *	* 1.8975 *	* 1.5402 *	* 3.5414 *
	* 1.5326 *	* 1.8979 *	* 1.8369 *	* 1.9268 *	* 1.5465 *	* 1.8304 *	* 1.5001 *	* 3.3659 *
	* 1.5482 *	* 1.9735 *	* 2.0106 *	* 2.0084 *	* 1.5560 *	* 1.8577 *	* 1.5094 *	* 3.2262 *
	* 1.6014 *	* 2.0832 *	* 2.1407 *	* 2.1096 *	* 1.5965 *	* 1.9546 *	* 1.5882 *	* 3.2019 *
	* 1.6664 *	* 2.1800 *	* 2.2286 *	* 2.2024 *	* 1.6543 *	* 2.0508 *	* 1.6772 *	* 3.1523 *
	* 1.7364 *	* 2.2484 *	* 2.2746 *	* 2.2744 *	* 1.7453 *	* 2.1401 *	* 1.7620 *	* 3.0397 *
12	* 1.9016 *	* 1.5783 *	* 1.8270 *	* 1.5690 *	* 1.7369 *	* 1.5814 *	* 2.4934 *	
	* 1.8646 *	* 1.5387 *	* 1.8549 *	* 1.5466 *	* 1.7096 *	* 1.5203 *	* 2.4226 *	
	* 1.8965 *	* 1.5249 *	* 1.9247 *	* 1.5561 *	* 1.7648 *	* 1.4887 *	* 2.4521 *	
	* 1.9899 *	* 1.5605 *	* 2.0113 *	* 1.5966 *	* 1.8730 *	* 1.5518 *	* 2.5591 *	
	* 2.0912 *	* 1.6259 *	* 2.1085 *	* 1.6543 *	* 1.9783 *	* 1.6376 *	* 2.6357 *	
	* 2.1765 *	* 1.7120 *	* 2.1955 *	* 1.7452 *	* 2.0700 *	* 1.7296 *	* 2.6611 *	
13	* 1.6088 *	* 1.8560 *	* 1.6207 *	* 1.8984 *	* 1.5817 *	* 1.4947 *	* 3.4610 *	
	* 1.5434 *	* 1.7747 *	* 1.5706 *	* 1.8310 *	* 1.5206 *	* 1.4651 *	* 3.3255 *	
	* 1.5227 *	* 1.7866 *	* 1.5366 *	* 1.8581 *	* 1.4889 *	* 1.5146 *	* 3.2815 *	
	* 1.5581 *	* 1.8774 *	* 1.5416 *	* 1.9548 *	* 1.5519 *	* 1.6409 *	* 3.3269 *	
	* 1.6226 *	* 1.9795 *	* 1.5938 *	* 2.0509 *	* 1.6376 *	* 1.7426 *	* 3.3038 *	
	* 1.7068 *	* 2.0730 *	* 1.6856 *	* 2.1401 *	* 1.7296 *	* 1.8202 *	* 3.1860 *	
14	* 2.2259 *	* 1.5988 *	* 1.6629 *	* 1.5408 *	* 2.4955 *	* 3.4613 *		
	* 2.1478 *	* 1.5214 *	* 1.5794 *	* 1.5008 *	* 2.4246 *	* 3.3258 *		
	* 2.1311 *	* 1.4756 *	* 1.5046 *	* 1.5098 *	* 2.4536 *	* 3.2817 *		
	* 2.2066 *	* 1.5311 *	* 1.5292 *	* 1.5883 *	* 2.5603 *	* 3.3268 *		
	* 2.2859 *	* 1.6035 *	* 1.5992 *	* 1.6771 *	* 2.6367 *	* 3.3036 *		
	* 2.3401 *	* 1.6877 *	* 1.6912 *	* 1.7619 *	* 2.6620 *	* 3.1858 *		
15	* 4.0486 *	* 3.2000 *	* 3.2313 *	* 3.5429 *	4 EFPD	118 % POWER		
	* 3.9039 *	* 3.0277 *	* 3.0201 *	* 3.3673 *	50 EFPD	118 % POWER		
	* 3.7535 *	* 2.8823 *	* 2.8244 *	* 3.2270 *	150 EFPD	118 % POWER		
	* 3.6897 *	* 2.8508 *	* 2.7787 *	* 3.2021 *	250 EFPD	118 % POWER		
	* 3.5761 *	* 2.8057 *	* 2.7315 *	* 3.1522 *	350 EFPD	118 % POWER		
	* 3.3797 *	* 2.7122 *	* 2.6455 *	* 3.0395 *	460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 282 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2374	* 1.4745	* 1.7898	* 1.4765	* 1.7995	* 1.5088	* 2.1094	* 3.8258
	* 2.1265	* 1.4347	* 1.7689	* 1.4505	* 1.7790	* 1.4601	* 2.0529	* 3.7203
	* 2.0573	* 1.4355	* 1.8350	* 1.4609	* 1.8048	* 1.4361	* 2.0297	* 3.5711
	* 2.0426	* 1.4831	* 1.9364	* 1.4911	* 1.8751	* 1.4511	* 2.0803	* 3.4706
	* 2.0297	* 1.5649	* 2.0351	* 1.5508	* 1.9642	* 1.5077	* 2.1475	* 3.3539
	* 1.9987	* 1.6557	* 2.1205	* 1.6325	* 2.0628	* 1.5995	* 2.2127	* 3.1894
9	* 1.4745	* 1.8356	* 1.4618	* 1.8036	* 1.4791	* 1.7461	* 1.4972	* 3.0295
	* 1.4347	* 1.8100	* 1.4347	* 1.8104	* 1.4544	* 1.6879	* 1.4344	* 2.8913
	* 1.4355	* 1.8731	* 1.4509	* 1.8790	* 1.4370	* 1.6943	* 1.3844	* 2.7396
	* 1.4831	* 1.9747	* 1.4997	* 1.9637	* 1.4537	* 1.7635	* 1.4215	* 2.6793
	* 1.5649	* 2.0712	* 1.5772	* 2.0522	* 1.5113	* 1.8543	* 1.4856	* 2.6275
	* 1.6557	* 2.1530	* 1.6588	* 2.1353	* 1.6051	* 1.9565	* 1.5763	* 2.5482
10	* 1.7898	* 1.4625	* 1.9215	* 1.6621	* 1.7166	* 1.5165	* 1.5546	* 3.0940
	* 1.7689	* 1.4350	* 1.9424	* 1.7420	* 1.7640	* 1.4827	* 1.4896	* 2.9145
	* 1.8350	* 1.4516	* 1.9629	* 1.9070	* 1.8259	* 1.4425	* 1.4097	* 2.7110
	* 1.9364	* 1.5001	* 1.9685	* 2.0202	* 1.8883	* 1.4288	* 1.4170	* 2.6413
	* 2.0351	* 1.5774	* 1.9644	* 2.1052	* 1.9755	* 1.4757	* 1.4796	* 2.5902
	* 2.1205	* 1.6587	* 1.9368	* 2.1694	* 2.0725	* 1.5744	* 1.5782	* 2.5190
11	* 1.4765	* 1.8046	* 1.6669	* 1.7898	* 1.4586	* 1.7754	* 1.4359	* 3.3799
	* 1.4505	* 1.8111	* 1.7465	* 1.8295	* 1.4531	* 1.7328	* 1.4093	* 3.2414
	* 1.4609	* 1.8787	* 1.9107	* 1.8988	* 1.4528	* 1.7493	* 1.4152	* 3.1024
	* 1.4911	* 1.9630	* 2.0213	* 1.9663	* 1.4650	* 1.8215	* 1.4733	* 3.0561
	* 1.5508	* 2.0515	* 2.1063	* 2.0579	* 1.5254	* 1.9149	* 1.5588	* 2.9974
	* 1.6325	* 2.1344	* 2.1705	* 2.1469	* 1.6262	* 2.0123	* 1.6525	* 2.9112
12	* 1.7995	* 1.4803	* 1.7180	* 1.4587	* 1.6161	* 1.4675	* 2.3706	*
	* 1.7790	* 1.4548	* 1.7655	* 1.4531	* 1.6081	* 1.4233	* 2.3277	*
	* 1.8048	* 1.4374	* 1.8265	* 1.4529	* 1.6527	* 1.3860	* 2.3417	*
	* 1.8751	* 1.4538	* 1.8885	* 1.4651	* 1.7244	* 1.4197	* 2.4074	*
	* 1.9642	* 1.5112	* 1.9754	* 1.5253	* 1.8308	* 1.5077	* 2.4891	*
	* 2.0628	* 1.6050	* 2.0724	* 1.6261	* 1.9351	* 1.6071	* 2.5288	*
13	* 1.5088	* 1.7468	* 1.5174	* 1.7761	* 1.4678	* 1.3856	* 3.2241	*
	* 1.4601	* 1.6887	* 1.4835	* 1.7334	* 1.4235	* 1.3700	* 3.1311	*
	* 1.4361	* 1.6949	* 1.4429	* 1.7497	* 1.3862	* 1.4082	* 3.0798	*
	* 1.4511	* 1.7639	* 1.4290	* 1.8217	* 1.4197	* 1.5007	* 3.0721	*
	* 1.5077	* 1.8545	* 1.4756	* 1.9149	* 1.5077	* 1.6070	* 3.0617	*
	* 1.5995	* 1.9567	* 1.5743	* 2.0122	* 1.6070	* 1.6958	* 2.9662	*
14	* 2.1094	* 1.4978	* 1.5552	* 1.4365	* 2.3729	* 3.2244	*	*
	* 2.0529	* 1.4350	* 1.4903	* 1.4099	* 2.3300	* 3.1314	*	*
	* 2.0297	* 1.3848	* 1.4101	* 1.4156	* 2.3434	* 3.0799	*	*
	* 2.0803	* 1.4217	* 1.4171	* 1.4735	* 2.4086	* 3.0721	*	*
	* 2.1475	* 1.4856	* 1.4795	* 1.5587	* 2.4900	* 3.0614	*	*
	* 2.2127	* 1.5762	* 1.5781	* 1.6523	* 2.5297	* 2.9661	*	*
15	* 3.8258	* 3.0304	* 3.0947	* 3.3814	* 4 EFPD	118 % POWER		
	* 3.7203	* 2.8922	* 2.9153	* 3.2429	* 50 EFPD	118 % POWER		
	* 3.5711	* 2.7404	* 2.7112	* 3.1031	* 150 EFPD	118 % POWER		
	* 3.4706	* 2.6797	* 2.6410	* 3.0563	* 250 EFPD	118 % POWER		
	* 3.3539	* 2.6277	* 2.5897	* 2.9972	* 350 EFPD	118 % POWER		
	* 3.1894	* 2.5484	* 2.5185	* 2.9110	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 283 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.1354	* 1.4026	* 1.7055	* 1.4072	* 1.7194	* 1.4433	* 2.0287	* 3.6939 *
	* 2.0706	* 1.3922	* 1.7201	* 1.4100	* 1.7309	* 1.4203	* 2.0008	* 3.6348 *
	* 1.9911	* 1.3817	* 1.7701	* 1.4082	* 1.7472	* 1.3918	* 1.9741	* 3.4837 *
	* 1.9369	* 1.3965	* 1.8306	* 1.4068	* 1.7787	* 1.3743	* 1.9805	* 3.3238 *
	* 1.8991	* 1.4555	* 1.9024	* 1.4451	* 1.8425	* 1.4088	* 2.0197	* 3.1790 *
	* 1.8694	* 1.5453	* 1.9868	* 1.5278	* 1.9353	* 1.4959	* 2.0820	* 3.0280 *
9	* 1.4026	* 1.7492	* 1.3915	* 1.7200	* 1.4093	* 1.6752	* 1.4328	* 2.9165 *
	* 1.3922	* 1.7604	* 1.3930	* 1.7621	* 1.4129	* 1.6407	* 1.3916	* 2.8204 *
	* 1.3817	* 1.8077	* 1.3970	* 1.8157	* 1.3930	* 1.6444	* 1.3388	* 2.6699 *
	* 1.3965	* 1.8674	* 1.4132	* 1.8582	* 1.3753	* 1.6730	* 1.3423	* 2.5573 *
	* 1.4555	* 1.9362	* 1.4688	* 1.9208	* 1.4108	* 1.7376	* 1.3871	* 2.4796 *
	* 1.5453	* 2.0165	* 1.5503	* 2.0064	* 1.4998	* 1.8348	* 1.4747	* 2.4086 *
10	* 1.7055	* 1.3921	* 1.8320	* 1.5791	* 1.6356	* 1.4518	* 1.4864	* 2.9857 *
	* 1.7201	* 1.3933	* 1.8920	* 1.6891	* 1.7107	* 1.4396	* 1.4455	* 2.8500 *
	* 1.7701	* 1.3976	* 1.9008	* 1.8370	* 1.7683	* 1.3931	* 1.3630	* 2.6460 *
	* 1.8306	* 1.4136	* 1.8703	* 1.9114	* 1.7894	* 1.3489	* 1.3359	* 2.5219 *
	* 1.9024	* 1.4690	* 1.8443	* 1.9699	* 1.8463	* 1.3744	* 1.3790	* 2.4445 *
	* 1.9868	* 1.5502	* 1.8213	* 2.0366	* 1.9392	* 1.4697	* 1.4748	* 2.3795 *
11	* 1.4072	* 1.7218	* 1.5837	* 1.6997	* 1.3880	* 1.6929	* 1.3687	* 3.2566 *
	* 1.4100	* 1.7627	* 1.6935	* 1.7710	* 1.4024	* 1.6748	* 1.3624	* 3.1646 *
	* 1.4082	* 1.8154	* 1.8407	* 1.8319	* 1.3971	* 1.6866	* 1.3642	* 3.0236 *
	* 1.4068	* 1.8576	* 1.9126	* 1.8607	* 1.3813	* 1.7207	* 1.3896	* 2.9117 *
	* 1.4451	* 1.9201	* 1.9708	* 1.9174	* 1.4135	* 1.7844	* 1.4515	* 2.8258 *
	* 1.5278	* 2.0056	* 2.0374	* 2.0035	* 1.5103	* 1.8801	* 1.5436	* 2.7503 *
12	* 1.7194	* 1.4104	* 1.6369	* 1.3881	* 1.5333	* 1.3959	* 2.2683	* 2.9857 *
	* 1.7309	* 1.4132	* 1.7120	* 1.4025	* 1.5487	* 1.3730	* 2.2569	* 2.8500 *
	* 1.7472	* 1.3933	* 1.7689	* 1.3972	* 1.5870	* 1.3320	* 2.2640	* 2.6460 *
	* 1.7787	* 1.3754	* 1.7896	* 1.3814	* 1.6233	* 1.3348	* 2.2792	* 2.5219 *
	* 1.8425	* 1.4108	* 1.8463	* 1.4134	* 1.6964	* 1.3954	* 2.3221	* 2.4445 *
	* 1.9353	* 1.4997	* 1.9392	* 1.5102	* 1.7960	* 1.4929	* 2.3678	* 2.3795 *
13	* 1.4433	* 1.6759	* 1.4526	* 1.6935	* 1.3962	* 1.3152	* 3.0907	* 3.2566 *
	* 1.4203	* 1.6415	* 1.4404	* 1.6754	* 1.3732	* 1.3203	* 3.0423	* 3.1646 *
	* 1.3918	* 1.6450	* 1.3935	* 1.6869	* 1.3322	* 1.3505	* 2.9848	* 3.0236 *
	* 1.3743	* 1.6734	* 1.3491	* 1.7208	* 1.3349	* 1.4102	* 2.9183	* 2.9117 *
	* 1.4088	* 1.7378	* 1.3744	* 1.7844	* 1.3954	* 1.4876	* 2.8646	* 2.8258 *
	* 1.4959	* 1.8350	* 1.4695	* 1.8800	* 1.4928	* 1.5756	* 2.7883	* 2.7503 *
14	* 2.0287	* 1.4334	* 1.4870	* 1.3693	* 2.2706	* 3.0910	* 3.0426	* 3.0907 *
	* 2.0008	* 1.3923	* 1.4462	* 1.3630	* 2.2591	* 3.0426	* 2.9849	* 3.0423 *
	* 1.9741	* 1.3392	* 1.3634	* 1.3646	* 2.2657	* 2.9849	* 2.9183	* 2.9183 *
	* 1.9805	* 1.3425	* 1.3361	* 1.3897	* 2.2803	* 2.9183	* 2.8644	* 2.8644 *
	* 2.0197	* 1.3871	* 1.3789	* 1.4514	* 2.3230	* 2.8644	* 2.7881	* 2.7881 *
	* 2.0820	* 1.4746	* 1.4747	* 1.5434	* 2.3687	* 2.7881	* 2.7881	* 2.7881 *
15	* 3.6939	* 2.9174	* 2.9864	* 3.2580	* 4 EFPD	118 % POWER		
	* 3.6348	* 2.8214	* 2.8507	* 3.1660	* 50 EFPD	118 % POWER		
	* 3.4837	* 2.6706	* 2.6461	* 3.0243	* 150 EFPD	118 % POWER		
	* 3.3238	* 2.5578	* 2.5217	* 2.9119	* 250 EFPD	118 % POWER		
	* 3.1790	* 2.4798	* 2.4441	* 2.8257	* 350 EFPD	118 % POWER		
	* 3.0280	* 2.4088	* 2.3790	* 2.7501	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 284 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0910	* 1.3741	* 1.6568	* 1.3797	* 1.6703	* 1.4103	* 1.9784	* 3.6537 *
	* 2.0881	* 1.3965	* 1.7102	* 1.4149	* 1.7220	* 1.4277	* 1.9949	* 3.6657 *
	* 2.0077	* 1.3839	* 1.7565	* 1.4073	* 1.7335	* 1.3907	* 1.9702	* 3.5030 *
	* 1.9112	* 1.3642	* 1.7756	* 1.3769	* 1.7254	* 1.3495	* 1.9280	* 3.2790 *
	* 1.8394	* 1.3953	* 1.8151	* 1.3874	* 1.7575	* 1.3524	* 1.9269	* 3.0796 *
	* 1.7982	* 1.4686	* 1.8835	* 1.4509	* 1.8306	* 1.4192	* 1.9685	* 2.9035 *
9	* 1.3741	* 1.6983	* 1.3636	* 1.6689	* 1.3783	* 1.6342	* 1.4074	* 2.8608 *
	* 1.3965	* 1.7514	* 1.3971	* 1.7525	* 1.4175	* 1.6379	* 1.3978	* 2.8244 *
	* 1.3839	* 1.7935	* 1.3987	* 1.8015	* 1.3902	* 1.6358	* 1.3442	* 2.6796 *
	* 1.3642	* 1.8106	* 1.3807	* 1.8031	* 1.3492	* 1.6280	* 1.3148	* 2.5143 *
	* 1.3953	* 1.8467	* 1.4091	* 1.8321	* 1.3535	* 1.6566	* 1.3281	* 2.3870 *
	* 1.4686	* 1.9107	* 1.4741	* 1.8999	* 1.4229	* 1.7346	* 1.3977	* 2.2957 *
10	* 1.6568	* 1.3642	* 1.7674	* 1.5312	* 1.5839	* 1.4165	* 1.4585	* 2.9022 *
	* 1.7102	* 1.3974	* 1.8757	* 1.6744	* 1.6946	* 1.4456	* 1.4522	* 2.8333 *
	* 1.7565	* 1.3993	* 1.8798	* 1.8172	* 1.7528	* 1.3968	* 1.3716	* 2.6417 *
	* 1.7756	* 1.3811	* 1.8034	* 1.8475	* 1.7396	* 1.3248	* 1.3095	* 2.4554 *
	* 1.8151	* 1.4093	* 1.7481	* 1.8693	* 1.7593	* 1.3164	* 1.3197	* 2.3271 *
	* 1.8835	* 1.4740	* 1.7166	* 1.9162	* 1.8307	* 1.3910	* 1.3961	* 2.2399 *
11	* 1.3797	* 1.6711	* 1.5356	* 1.6534	* 1.3595	* 1.6539	* 1.3410	* 3.1743 *
	* 1.4149	* 1.7530	* 1.6788	* 1.7561	* 1.4014	* 1.6623	* 1.3657	* 3.1418 *
	* 1.4073	* 1.8011	* 1.8209	* 1.8109	* 1.3965	* 1.6760	* 1.3660	* 3.0037 *
	* 1.3769	* 1.8025	* 1.8491	* 1.8048	* 1.3540	* 1.6702	* 1.3557	* 2.8214 *
	* 1.3874	* 1.8316	* 1.8706	* 1.8239	* 1.3515	* 1.6985	* 1.3832	* 2.6825 *
	* 1.4509	* 1.8993	* 1.9176	* 1.8872	* 1.4263	* 1.7726	* 1.4536	* 2.5733 *
12	* 1.6703	* 1.3793	* 1.5851	* 1.3595	* 1.4909	* 1.3685	* 2.1902	* 3.0709 *
	* 1.7220	* 1.4178	* 1.6958	* 1.4015	* 1.5353	* 1.3734	* 2.2183	* 3.0766 *
	* 1.7335	* 1.3906	* 1.7533	* 1.3966	* 1.5745	* 1.3346	* 2.2276	* 3.0158 *
	* 1.7254	* 1.3494	* 1.7399	* 1.3541	* 1.5756	* 1.3039	* 2.1921	* 2.8813 *
	* 1.7575	* 1.3535	* 1.7593	* 1.3515	* 1.6116	* 1.3313	* 2.1854	* 2.7731 *
	* 1.8306	* 1.4228	* 1.8306	* 1.4262	* 1.6888	* 1.4089	* 2.2048	* 2.6713 *
13	* 1.4103	* 1.6349	* 1.4172	* 1.6544	* 1.3687	* 1.2867	* 3.0709	* 3.0766 *
	* 1.4277	* 1.6385	* 1.4463	* 1.6629	* 1.3736	* 1.3207	* 3.0766	* 3.0158 *
	* 1.3907	* 1.6364	* 1.3972	* 1.6764	* 1.3348	* 1.3491	* 3.0158	* 2.8813 *
	* 1.3495	* 1.6284	* 1.3249	* 1.6704	* 1.3039	* 1.3754	* 2.8813	* 2.7731 *
	* 1.3524	* 1.6568	* 1.3163	* 1.6985	* 1.3312	* 1.4160	* 2.7731	* 2.6713 *
	* 1.4192	* 1.7348	* 1.3909	* 1.7726	* 1.4088	* 1.4823	* 2.6713	
14	* 1.9784	* 1.4080	* 1.4592	* 1.3416	* 2.1922	* 3.0712		
	* 1.9949	* 1.3985	* 1.4529	* 1.3663	* 2.2202	* 3.0769		
	* 1.9702	* 1.3446	* 1.3721	* 1.3664	* 2.2290	* 3.0158		
	* 1.9280	* 1.3150	* 1.3096	* 1.3558	* 2.1932	* 2.8812		
	* 1.9269	* 1.3281	* 1.3196	* 1.3831	* 2.1862	* 2.7729		
	* 1.9685	* 1.3976	* 1.3960	* 1.4534	* 2.2056	* 2.6711		
15	* 3.6537	* 2.8617	* 2.9029	* 3.1758	* 4 EFPD	118 % POWER		
	* 3.6657	* 2.8253	* 2.8341	* 3.1432	* 50 EFPD	118 % POWER		
	* 3.5030	* 2.6796	* 2.6415	* 3.0043	* 150 EFPD	118 % POWER		
	* 3.2790	* 2.5148	* 2.4552	* 2.8215	* 250 EFPD	118 % POWER		
	* 3.0796	* 2.3873	* 2.3266	* 2.6823	* 350 EFPD	118 % POWER		
	* 2.9035	* 2.2959	* 2.2394	* 2.5731	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 285 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0180	* 1.3259	* 1.5987	* 1.3346	* 1.6127	* 1.3611	* 1.9151	* 3.5516
	* 2.0893	* 1.3911	* 1.7013	* 1.4117	* 1.7124	* 1.4223	* 1.9933	* 3.6711
	* 2.0309	* 1.3914	* 1.7617	* 1.4134	* 1.7379	* 1.3958	* 1.9805	* 3.5383
	* 1.8989	* 1.3394	* 1.7449	* 1.3556	* 1.6960	* 1.3310	* 1.9045	* 3.2546
	* 1.7942	* 1.3388	* 1.7494	* 1.3347	* 1.6959	* 1.3014	* 1.8623	* 3.0100
	* 1.7320	* 1.3909	* 1.7936	* 1.3743	* 1.7410	* 1.3423	* 1.8745	* 2.7939
9	* 1.3259	* 1.6369	* 1.3187	* 1.6126	* 1.3320	* 1.5764	* 1.3602	* 2.7856
	* 1.3911	* 1.7413	* 1.3924	* 1.7443	* 1.4123	* 1.6337	* 1.3948	* 2.8368
	* 1.3914	* 1.7983	* 1.4055	* 1.8067	* 1.3945	* 1.6379	* 1.3542	* 2.7197
	* 1.3394	* 1.7789	* 1.3550	* 1.7728	* 1.3265	* 1.5984	* 1.2950	* 2.5131
	* 1.3388	* 1.7795	* 1.3523	* 1.7675	* 1.3032	* 1.5950	* 1.2755	* 2.3344
	* 1.3909	* 1.8194	* 1.3964	* 1.8107	* 1.3458	* 1.6454	* 1.3194	* 2.2107
10	* 1.5987	* 1.3192	* 1.7297	* 1.4781	* 1.5245	* 1.3646	* 1.4147	* 2.8741
	* 1.7013	* 1.3926	* 1.8941	* 1.6603	* 1.6775	* 1.4400	* 1.4517	* 2.8940
	* 1.7617	* 1.4060	* 1.9209	* 1.8107	* 1.7505	* 1.4117	* 1.3859	* 2.7257
	* 1.7449	* 1.3553	* 1.8173	* 1.8127	* 1.7044	* 1.3098	* 1.2914	* 2.4857
	* 1.7494	* 1.3525	* 1.7235	* 1.8084	* 1.6913	* 1.2662	* 1.2672	* 2.3033
	* 1.7936	* 1.3963	* 1.6710	* 1.8337	* 1.7336	* 1.3130	* 1.3174	* 2.1799
11	* 1.3346	* 1.6144	* 1.4823	* 1.6049	* 1.3115	* 1.5995	* 1.2991	* 3.1517
	* 1.4117	* 1.7448	* 1.6646	* 1.7426	* 1.3946	* 1.6508	* 1.3617	* 3.2127
	* 1.4134	* 1.8063	* 1.8145	* 1.8114	* 1.4041	* 1.6818	* 1.3760	* 3.1088
	* 1.3556	* 1.7722	* 1.8156	* 1.7710	* 1.3353	* 1.6410	* 1.3382	* 2.8655
	* 1.3347	* 1.7668	* 1.8090	* 1.7563	* 1.2976	* 1.6330	* 1.3336	* 2.6649
	* 1.3743	* 1.8100	* 1.8342	* 1.7910	* 1.3442	* 1.6782	* 1.3807	* 2.5200
12	* 1.6127	* 1.3330	* 1.5257	* 1.3115	* 1.4360	* 1.3208	* 2.1509	*
	* 1.7124	* 1.4126	* 1.6788	* 1.3946	* 1.5205	* 1.3661	* 2.2387	*
	* 1.7379	* 1.3948	* 1.7510	* 1.4042	* 1.5762	* 1.3430	* 2.2683	*
	* 1.6960	* 1.3267	* 1.7047	* 1.3354	* 1.5470	* 1.2810	* 2.1864	*
	* 1.6959	* 1.3032	* 1.6908	* 1.2975	* 1.5458	* 1.2749	* 2.1306	*
	* 1.7410	* 1.3458	* 1.7336	* 1.3442	* 1.5978	* 1.3259	* 2.1180	*
13	* 1.3611	* 1.5770	* 1.3653	* 1.6000	* 1.3211	* 1.2470	* 2.9984	*
	* 1.4223	* 1.6344	* 1.4408	* 1.6514	* 1.3663	* 1.3165	* 3.0855	*
	* 1.3958	* 1.6384	* 1.4121	* 1.6822	* 1.3432	* 1.3547	* 3.0607	*
	* 1.3310	* 1.5988	* 1.3100	* 1.6411	* 1.2811	* 1.3503	* 2.8698	*
	* 1.3014	* 1.5952	* 1.2661	* 1.6329	* 1.2749	* 1.3609	* 2.6968	*
	* 1.3423	* 1.6456	* 1.3129	* 1.6781	* 1.3259	* 1.4028	* 2.5589	*
14	* 1.9151	* 1.3607	* 1.4153	* 1.2996	* 2.1530	* 2.9987	*	
	* 1.9933	* 1.3954	* 1.4524	* 1.3623	* 2.2408	* 3.0858	*	
	* 1.9805	* 1.3546	* 1.3863	* 1.3764	* 2.2698	* 3.0599	*	
	* 1.9045	* 1.2952	* 1.2915	* 1.3383	* 2.1875	* 2.8698	*	
	* 1.8623	* 1.2755	* 1.2671	* 1.3335	* 2.1314	* 2.6966	*	
	* 1.8745	* 1.3193	* 1.3172	* 1.3806	* 2.1188	* 2.5587	*	
15	* 3.5516	* 2.7865	* 2.8748	* 3.1531	* 4 EFPD	118 %	POWER	
	* 3.6711	* 2.8377	* 2.8948	* 3.2142	* 50 EFPD	118 %	POWER	
	* 3.5383	* 2.7195	* 2.7255	* 3.1093	* 150 EFPD	118 %	POWER	
	* 3.2546	* 2.5136	* 2.4856	* 2.8657	* 250 EFPD	118 %	POWER	
	* 3.0100	* 2.3346	* 2.3029	* 2.6648	* 350 EFPD	118 %	POWER	
	* 2.7939	* 2.2109	* 2.1795	* 2.5199	* 460 EFPD	118 %	POWER	

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 286 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0098	* 1.3284	* 1.6061	* 1.3404	* 1.6287	* 1.3634	* 1.9174	* 3.6390
	* 2.1766	* 1.4610	* 1.7656	* 1.4846	* 1.7770	* 1.4918	* 2.0766	* 3.8886
	* 2.1974	* 1.4976	* 1.8706	* 1.5192	* 1.8443	* 1.4993	* 2.1061	* 3.8190
	* 2.0345	* 1.4168	* 1.8216	* 1.4379	* 1.7714	* 1.4121	* 1.9922	* 3.4597
	* 1.8857	* 1.3769	* 1.7827	* 1.3783	* 1.7297	* 1.3476	* 1.9064	* 3.1461
	* 1.7782	* 1.3943	* 1.7881	* 1.3838	* 1.7390	* 1.3488	* 1.8732	* 2.8746
9	* 1.3284	* 1.6282	* 1.3264	* 1.6201	* 1.3386	* 1.5770	* 1.3632	* 2.8222
	* 1.4610	* 1.8030	* 1.4646	* 1.8142	* 1.4804	* 1.7056	* 1.4667	* 2.9882
	* 1.4976	* 1.9062	* 1.5134	* 1.9176	* 1.4944	* 1.7320	* 1.4615	* 2.9286
	* 1.4168	* 1.8551	* 1.4331	* 1.8512	* 1.4049	* 1.6644	* 1.3789	* 2.6768
	* 1.3769	* 1.8127	* 1.3906	* 1.8023	* 1.3480	* 1.6264	* 1.3186	* 2.4563
	* 1.3943	* 1.8133	* 1.4028	* 1.8056	* 1.3513	* 1.6367	* 1.3224	* 2.2771
10	* 1.6061	* 1.3264	* 1.7667	* 1.5055	* 1.5315	* 1.3629	* 1.4072	* 2.9346
	* 1.7656	* 1.4647	* 1.9899	* 1.7389	* 1.7378	* 1.5036	* 1.5120	* 3.0795
	* 1.8706	* 1.5138	* 2.0734	* 1.9119	* 1.8352	* 1.5204	* 1.4958	* 2.9760
	* 1.8216	* 1.4333	* 1.9394	* 1.8780	* 1.7654	* 1.4003	* 1.3776	* 2.6931
	* 1.7827	* 1.3907	* 1.8063	* 1.8279	* 1.7143	* 1.3122	* 1.3111	* 2.4453
	* 1.7881	* 1.4026	* 1.7066	* 1.8153	* 1.7167	* 1.3177	* 1.3208	* 2.2614
11	* 1.3404	* 1.6214	* 1.5095	* 1.6262	* 1.3122	* 1.6022	* 1.3194	* 3.2509
	* 1.4846	* 1.8146	* 1.7431	* 1.8021	* 1.4592	* 1.7213	* 1.4429	* 3.4401
	* 1.5192	* 1.9173	* 1.9157	* 1.9076	* 1.5012	* 1.7818	* 1.4858	* 3.3999
	* 1.4379	* 1.8506	* 1.8810	* 1.8393	* 1.4218	* 1.7115	* 1.4219	* 3.1062
	* 1.3783	* 1.8016	* 1.8301	* 1.7868	* 1.3394	* 1.6601	* 1.3772	* 2.8262
	* 1.3838	* 1.8049	* 1.8169	* 1.7796	* 1.3445	* 1.6644	* 1.3860	* 2.6090
12	* 1.6287	* 1.3394	* 1.5326	* 1.3122	* 1.4256	* 1.3221	* 2.1769	*
	* 1.7770	* 1.4810	* 1.7388	* 1.4593	* 1.5701	* 1.4322	* 2.3452	*
	* 1.8443	* 1.4948	* 1.8358	* 1.5013	* 1.6608	* 1.4508	* 2.4297	*
	* 1.7714	* 1.4051	* 1.7656	* 1.4219	* 1.6158	* 1.3591	* 2.3076	*
	* 1.7297	* 1.3480	* 1.7142	* 1.3394	* 1.5717	* 1.3131	* 2.1911	*
	* 1.7390	* 1.3513	* 1.7166	* 1.3444	* 1.5858	* 1.3237	* 2.1249	*
13	* 1.3634	* 1.5777	* 1.3636	* 1.6028	* 1.3223	* 1.2623	* 3.0772	*
	* 1.4918	* 1.7063	* 1.5043	* 1.7219	* 1.4324	* 1.3923	* 3.2886	*
	* 1.4993	* 1.7326	* 1.5208	* 1.7822	* 1.4510	* 1.4639	* 3.3458	*
	* 1.4121	* 1.6649	* 1.4005	* 1.7116	* 1.3591	* 1.4316	* 3.0931	*
	* 1.3476	* 1.6266	* 1.3122	* 1.6601	* 1.3131	* 1.4023	* 2.8411	*
	* 1.3488	* 1.6369	* 1.3177	* 1.6643	* 1.3237	* 1.4072	* 2.6333	*
14	* 1.9174	* 1.3637	* 1.4078	* 1.3199	* 2.1788	* 3.0775	*	*
	* 2.0766	* 1.4674	* 1.5127	* 1.4435	* 2.3473	* 3.2889	*	*
	* 2.1061	* 1.4619	* 1.4962	* 1.4862	* 2.4314	* 3.3458	*	*
	* 1.9922	* 1.3792	* 1.3778	* 1.4220	* 2.3087	* 3.0931	*	*
	* 1.9064	* 1.3186	* 1.3110	* 1.3771	* 2.1919	* 2.8410	*	*
	* 1.8732	* 1.3224	* 1.3207	* 1.3859	* 2.1256	* 2.6331	*	*
15	* 3.6390	* 2.8232	* 2.9355	* 3.2524	* 4 EFPD	118 % POWER		
	* 3.8886	* 2.9892	* 3.0804	* 3.4417	* 50 EFPD	118 % POWER		
	* 3.8190	* 2.9290	* 2.9761	* 3.4007	* 150 EFPD	118 % POWER		
	* 3.4597	* 2.6770	* 2.6930	* 3.1065	* 250 EFPD	118 % POWER		
	* 3.1461	* 2.4562	* 2.4450	* 2.8261	* 350 EFPD	118 % POWER		
	* 2.8746	* 2.2773	* 2.2610	* 2.6089	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 287 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2035 *	* 1.3324 *	* 1.8469 *	* 1.3760 *	* 1.8665 *	* 1.4076 *	* 2.1592 *	* 4.1572 *
	* 2.5109 *	* 1.5626 *	* 2.1373 *	* 1.6161 *	* 2.1482 *	* 1.6322 *	* 2.4495 *	* 4.5997 *
	* 2.6468 *	* 1.7082 *	* 2.3231 *	* 1.7417 *	* 2.2879 *	* 1.7226 *	* 2.5744 *	* 4.6517 *
	* 2.4712 *	* 1.6588 *	* 2.2300 *	* 1.6667 *	* 2.1701 *	* 1.6377 *	* 2.4250 *	* 4.1801 *
	* 2.2687 *	* 1.5882 *	* 2.1040 *	* 1.5818 *	* 2.0446 *	* 1.5545 *	* 2.2678 *	* 3.7101 *
	* 2.0882 *	* 1.5503 *	* 2.0229 *	* 1.5391 *	* 1.9754 *	* 1.5097 *	* 2.1411 *	* 3.3027 *
9	* 1.3324 *	* 1.8806 *	* 1.3325 *	* 1.8941 *	* 1.3702 *	* 1.7355 *	* 1.4110 *	* 3.1835 *
	* 1.5626 *	* 2.1756 *	* 1.5747 *	* 2.2037 *	* 1.5985 *	* 1.9808 *	* 1.6274 *	* 3.5272 *
	* 1.7082 *	* 2.3633 *	* 1.7312 *	* 2.3808 *	* 1.7058 *	* 2.0954 *	* 1.7155 *	* 3.5875 *
	* 1.6588 *	* 2.2652 *	* 1.6801 *	* 2.2651 *	* 1.6278 *	* 1.9876 *	* 1.6291 *	* 3.2543 *
	* 1.5882 *	* 2.1350 *	* 1.6046 *	* 2.1276 *	* 1.5483 *	* 1.8863 *	* 1.5404 *	* 2.9342 *
	* 1.5503 *	* 2.0491 *	* 1.5595 *	* 2.0428 *	* 1.5103 *	* 1.8275 *	* 1.4867 *	* 2.6556 *
10	* 1.8469 *	* 1.3327 *	* 1.9647 *	* 1.7298 *	* 1.7216 *	* 1.4140 *	* 1.4244 *	* 3.3007 *
	* 2.1373 *	* 1.5749 *	* 2.2942 *	* 2.0516 *	* 2.0049 *	* 1.6360 *	* 1.6336 *	* 3.6464 *
	* 2.3231 *	* 1.7313 *	* 2.4804 *	* 2.2722 *	* 2.1435 *	* 1.7140 *	* 1.7181 *	* 3.6877 *
	* 2.2300 *	* 1.6800 *	* 2.3308 *	* 2.1739 *	* 2.0373 *	* 1.6179 *	* 1.6335 *	* 3.3458 *
	* 2.1040 *	* 1.6043 *	* 2.1537 *	* 2.0517 *	* 1.9316 *	* 1.5234 *	* 1.5426 *	* 3.0174 *
	* 2.0229 *	* 1.5591 *	* 1.9810 *	* 1.9617 *	* 1.8654 *	* 1.4785 *	* 1.4957 *	* 2.7104 *
11	* 1.3760 *	* 1.8947 *	* 1.7336 *	* 1.8232 *	* 1.3742 *	* 1.7527 *	* 1.4731 *	* 3.7727 *
	* 1.6161 *	* 2.2041 *	* 2.0558 *	* 2.1263 *	* 1.6037 *	* 2.0003 *	* 1.7061 *	* 4.1843 *
	* 1.7417 *	* 2.3805 *	* 2.2762 *	* 2.3118 *	* 1.7125 *	* 2.1418 *	* 1.8199 *	* 4.2596 *
	* 1.6667 *	* 2.2647 *	* 2.1752 *	* 2.1972 *	* 1.6321 *	* 2.0395 *	* 1.7271 *	* 3.8761 *
	* 1.5818 *	* 2.1269 *	* 2.0528 *	* 2.0724 *	* 1.5450 *	* 1.9293 *	* 1.6271 *	* 3.4925 *
	* 1.5391 *	* 2.0422 *	* 1.9635 *	* 1.9888 *	* 1.4987 *	* 1.8524 *	* 1.5582 *	* 3.1297 *
12	* 1.8665 *	* 1.3708 *	* 1.7226 *	* 1.3744 *	* 1.5673 *	* 1.3278 *	* 2.4308 *	
	* 2.1482 *	* 1.5992 *	* 2.0059 *	* 1.6040 *	* 1.8085 *	* 1.5324 *	* 2.7423 *	
	* 2.2879 *	* 1.7062 *	* 2.1442 *	* 1.7127 *	* 1.9533 *	* 1.6662 *	* 2.9156 *	
	* 2.1701 *	* 1.6279 *	* 2.0375 *	* 1.6321 *	* 1.8717 *	* 1.6081 *	* 2.7459 *	
	* 2.0446 *	* 1.5483 *	* 1.9315 *	* 1.5450 *	* 1.7863 *	* 1.5281 *	* 2.5530 *	
	* 1.9754 *	* 1.5103 *	* 1.8654 *	* 1.4986 *	* 1.7302 *	* 1.4835 *	* 2.3879 *	
13	* 1.4076 *	* 1.7363 *	* 1.4146 *	* 1.7533 *	* 1.3281 *	* 1.4248 *	* 3.5233 *	
	* 1.6322 *	* 1.9816 *	* 1.6366 *	* 2.0009 *	* 1.5327 *	* 1.6623 *	* 3.9244 *	
	* 1.7226 *	* 2.0960 *	* 1.7144 *	* 2.1422 *	* 1.6664 *	* 1.8091 *	* 4.1141 *	
	* 1.6377 *	* 1.9880 *	* 1.6181 *	* 2.0398 *	* 1.6082 *	* 1.7407 *	* 3.7993 *	
	* 1.5545 *	* 1.8866 *	* 1.5233 *	* 1.9292 *	* 1.5281 *	* 1.6487 *	* 3.4344 *	
	* 1.5097 *	* 1.8277 *	* 1.4784 *	* 1.8524 *	* 1.4835 *	* 1.5787 *	* 3.1025 *	
14	* 2.1592 *	* 1.4116 *	* 1.4250 *	* 1.4738 *	* 2.4325 *	* 3.5238 *		
	* 2.4495 *	* 1.6281 *	* 1.6343 *	* 1.7068 *	* 2.7443 *	* 3.9250 *		
	* 2.5744 *	* 1.7159 *	* 1.7185 *	* 1.8203 *	* 2.9173 *	* 4.1144 *		
	* 2.4250 *	* 1.6293 *	* 1.6337 *	* 1.7272 *	* 2.7471 *	* 3.7994 *		
	* 2.2678 *	* 1.5405 *	* 1.5426 *	* 1.6270 *	* 2.5538 *	* 3.4344 *		
	* 2.1411 *	* 1.4866 *	* 1.4957 *	* 1.5582 *	* 2.3886 *	* 3.1025 *		
15	* 4.1572 *	* 3.1844 *	* 3.3021 *	* 3.7745 *	* 4 EFPD 118 % POWER			
	* 4.5997 *	* 3.5281 *	* 3.6479 *	* 4.1861 *	* 50 EFPD 118 % POWER			
	* 4.6517 *	* 3.5882 *	* 3.6886 *	* 4.2607 *	* 150 EFPD 118 % POWER			
	* 4.1801 *	* 3.2547 *	* 3.3462 *	* 3.8766 *	* 250 EFPD 118 % POWER			
	* 3.7101 *	* 2.9342 *	* 3.0172 *	* 3.4925 *	* 350 EFPD 118 % POWER			
	* 3.3027 *	* 2.6556 *	* 2.7102 *	* 3.1296 *	* 460 EFPD 118 % POWER			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 288 of 311

TABLE 6 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.8806	* 3.0220	* 3.7006	* 3.0598	* 3.7553	* 3.1434	* 4.3123	* 5.8148
	* 3.4235	* 3.6984	* 4.4028	* 3.7439	* 4.4326	* 3.7811	* 4.9790	* 6.5680
	* 3.7648	* 4.0107	* 4.8327	* 4.0285	* 4.7579	* 3.9885	* 5.2542	* 6.7144
	* 3.5107	* 3.7076	* 4.4801	* 3.6886	* 4.3596	* 3.6295	* 4.7549	* 5.8886
	* 3.1668	* 3.3289	* 3.9986	* 3.2999	* 3.8962	* 3.2477	* 4.2057	* 5.0138
	* 2.8739	* 3.0109	* 3.5845	* 2.9877	* 3.5081	* 2.9447	* 3.7390	* 4.2527
9	* 3.0220	* 3.7336	* 3.0536	* 3.7757	* 3.0573	* 3.6491	* 3.4815	* 6.5251
	* 3.6984	* 4.4413	* 3.7489	* 4.4898	* 3.7107	* 4.2710	* 4.1379	* 7.3693
	* 4.0107	* 4.8754	* 4.0685	* 4.8785	* 3.9461	* 4.5719	* 4.3002	* 7.5528
	* 3.7076	* 4.5191	* 3.7519	* 4.4832	* 3.6029	* 4.1791	* 3.8763	* 6.6577
	* 3.3289	* 4.0375	* 3.3614	* 4.0056	* 3.2303	* 3.7294	* 3.4360	* 5.7015
	* 3.0109	* 3.6182	* 3.0321	* 3.6103	* 2.9347	* 3.3581	* 3.0772	* 4.8490
10	* 3.7006	* 3.0523	* 3.7738	* 3.8480	* 3.6845	* 3.0986	* 3.3709	* 6.7642
	* 4.4028	* 3.7473	* 4.5137	* 4.5752	* 4.3295	* 3.7346	* 4.0088	* 7.6304
	* 4.8326	* 4.0667	* 4.9893	* 4.9597	* 4.6510	* 3.9424	* 4.1736	* 7.8012
	* 4.4801	* 3.7504	* 4.5937	* 4.5202	* 4.2528	* 3.5879	* 3.7727	* 6.8573
	* 3.9986	* 3.3582	* 4.0623	* 4.0014	* 3.7850	* 3.2135	* 3.3590	* 5.8685
	* 3.5845	* 3.0310	* 3.5904	* 3.5706	* 3.4012	* 2.9153	* 3.0215	* 4.9969
11	* 3.0598	* 3.7754	* 3.8508	* 3.6259	* 3.0149	* 3.6701	* 3.6772	* 7.7074
	* 3.7439	* 4.4891	* 4.5781	* 4.3111	* 3.6828	* 4.3126	* 4.3695	* 8.7030
	* 4.0285	* 4.8774	* 4.9621	* 4.6937	* 3.9409	* 4.6358	* 4.5374	* 8.9094
	* 3.6886	* 4.4819	* 4.5217	* 4.3214	* 3.6108	* 4.2404	* 4.0750	* 7.8297
	* 3.2999	* 4.0043	* 4.0021	* 3.8697	* 3.2419	* 3.7914	* 3.5966	* 6.6806
	* 2.9877	* 3.6091	* 3.5711	* 3.4885	* 2.9368	* 3.4024	* 3.1962	* 5.6488
12	* 3.7553	* 3.0585	* 3.6861	* 3.0153	* 3.4267	* 3.2257	* 4.9389	*
	* 4.4326	* 3.7121	* 4.3312	* 3.6832	* 4.0402	* 3.8944	* 5.7088	*
	* 3.7439	* 3.9468	* 4.6522	* 3.9413	* 4.3495	* 4.1366	* 6.0435	*
	* 4.3596	* 3.6032	* 4.2534	* 3.6110	* 3.9813	* 3.7874	* 5.4689	*
	* 3.8962	* 3.2303	* 3.7849	* 3.2416	* 3.5596	* 3.3898	* 4.8044	*
	* 3.5081	* 2.9347	* 3.4012	* 2.9367	* 3.2109	* 3.0483	* 4.1982	*
13	* 3.1434	* 3.6503	* 3.1000	* 3.6709	* 3.2263	* 3.5559	* 4.9251	*
	* 3.7811	* 4.2722	* 3.7361	* 4.3134	* 3.8951	* 4.2696	* 5.6616	*
	* 3.9885	* 4.5729	* 3.9434	* 4.6369	* 4.1370	* 4.5188	* 5.9740	*
	* 3.6295	* 4.1798	* 3.5884	* 4.2410	* 3.7876	* 4.1164	* 5.3788	*
	* 3.2477	* 3.7298	* 3.2134	* 3.7913	* 3.3895	* 3.6585	* 4.6805	*
	* 2.9447	* 3.3585	* 2.9153	* 3.4023	* 3.0483	* 3.2478	* 4.0255	*
14	* 4.3123	* 3.4831	* 3.3724	* 3.6788	* 4.9378	* 4.9263	*	*
	* 4.9790	* 4.1396	* 4.0104	* 4.3711	* 5.7074	* 5.6629	*	*
	* 5.2542	* 4.3015	* 4.1746	* 4.5385	* 6.0418	* 5.9750	*	*
	* 4.7549	* 3.8770	* 3.7732	* 4.0754	* 5.4674	* 5.3796	*	*
	* 4.2057	* 3.4361	* 3.3589	* 3.5964	* 4.8031	* 4.6809	*	*
	* 3.7390	* 3.0773	* 3.0214	* 3.1961	* 4.1979	* 4.0258	*	*
15	* 5.8148	* 6.5273	* 6.7672	* 7.7110	* 4 EFPD	118 % POWER		
	* 6.5680	* 7.3715	* 7.6336	* 8.7068	* 50 EFPD	118 % POWER		
	* 6.7144	* 7.5529	* 7.8021	* 8.9107	* 150 EFPD	118 % POWER		
	* 5.8886	* 6.6580	* 6.8583	* 7.8309	* 250 EFPD	118 % POWER		
	* 5.0138	* 5.7016	* 5.8687	* 6.6805	* 350 EFPD	118 % POWER		
	* 4.2527	* 4.8490	* 4.9970	* 5.6489	* 460 EFPD	118 % POWER		

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 301 of 311

TABLE 8

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9824	* 1.3879	* 1.2423	* 1.3809	* 1.2296	* 1.3429	* 1.0444	* .5752
	* 1.5508	* 1.1701	* 1.2834	* 1.1500	* 1.2673	* 1.1657	* 1.4465	* 2.4989
9	* 1.3879	* 1.2247	* 1.3953	* 1.2335	* 1.3733	* 1.2463	* 1.3279	* .7125
	* 1.1701	* 1.3115	* 1.1489	* 1.2752	* 1.1560	* 1.2498	* 1.1659	* 2.0419
10	* 1.2423	* 1.3950	* 1.1293	* 1.3060	* 1.2768	* 1.3330	* 1.2760	* .6604
	* 1.2834	* 1.1506	* 1.3762	* 1.2199	* 1.2576	* 1.2269	* 1.2685	* 2.2229
11	* 1.3809	* 1.2326	* 1.3024	* 1.2133	* 1.3720	* 1.2210	* 1.3587	* .5964
	* 1.1500	* 1.2760	* 1.2232	* 1.3201	* 1.1681	* 1.3042	* 1.1750	* 2.5144
12	* 1.2296	* 1.3723	* 1.2757	* 1.3720	* 1.3095	* 1.3534	* .9232	*
	* 1.2673	* 1.1563	* 1.2585	* 1.1682	* 1.1976	* 1.1757	* 1.6877	*
13	* 1.3429	* 1.2458	* 1.3324	* 1.2205	* 1.3532	* 1.3881	* .6434	*
	* 1.1657	* 1.2501	* 1.2274	* 1.3044	* 1.1759	* 1.1317	* 2.3586	*
14	* 1.0444	* 1.3276	* 1.2756	* 1.3583	* .9226	* .6433	*	*
	* 1.4465	* 1.1660	* 1.2688	* 1.1752	* 1.6885	* 2.3587	*	*
15	* .5752	* .7125	* .6602	* .5962	* F-DEL-H			
	* 2.4989	* 2.0417	* 2.2229	* 2.5149	* M-DEL-H			

AT 100% POWER, 50 EFPD

	H	G	F	E	D	C	B	A
8	* .9885	* 1.4014	* 1.2266	* 1.3833	* 1.2148	* 1.3615	* 1.0419	* .5714
	* 1.5870	* 1.1826	* 1.3358	* 1.1713	* 1.3171	* 1.1765	* 1.4747	* 2.5741
9	* 1.4014	* 1.2099	* 1.3988	* 1.2005	* 1.3742	* 1.2533	* 1.3579	* .7159
	* 1.1826	* 1.3280	* 1.1773	* 1.3227	* 1.1725	* 1.2743	* 1.1693	* 2.0803
10	* 1.2266	* 1.3985	* 1.0683	* 1.2263	* 1.2235	* 1.3387	* 1.3122	* .6678
	* 1.3358	* 1.1777	* 1.4695	* 1.3135	* 1.3369	* 1.2377	* 1.2453	* 2.2499
11	* 1.3833	* 1.2000	* 1.2231	* 1.1700	* 1.3620	* 1.2181	* 1.3651	* .5963
	* 1.1713	* 1.3229	* 1.3168	* 1.3814	* 1.2074	* 1.3416	* 1.1944	* 2.5941
12	* 1.2148	* 1.3739	* 1.2226	* 1.3620	* 1.2948	* 1.3718	* .9136	*
	* 1.3171	* 1.1727	* 1.3378	* 1.2075	* 1.2536	* 1.1909	* 1.7366	*
13	* 1.3615	* 1.2529	* 1.3381	* 1.2178	* 1.3716	* 1.3886	* .6374	*
	* 1.1765	* 1.2746	* 1.2381	* 1.3419	* 1.1910	* 1.1632	* 2.4272	*
14	* 1.0419	* 1.3575	* 1.3118	* 1.3647	* .9130	* .6373	*	*
	* 1.4747	* 1.1695	* 1.2456	* 1.1947	* 1.7375	* 2.4273	*	*
15	* .5714	* .7158	* .6677	* .5961	* F-DEL-H			
	* 2.5741	* 2.0801	* 2.2501	* 2.5946	* M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 302 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* .9604	* 1.3950	* 1.1705	* 1.3692	* 1.1859	* 1.3788	* 1.0413	* .5810
	* 1.6286	* 1.1847	* 1.3745	* 1.1709	* 1.3169	* 1.1568	* 1.4756	* 2.5438
9	* 1.3950	* 1.1552	* 1.3812	* 1.1473	* 1.3818	* 1.2443	* 1.3957	* .7311
	* 1.1847	* 1.3822	* 1.1826	* 1.3698	* 1.1604	* 1.2785	* 1.1388	* 2.0770
10	* 1.1705	* 1.3806	* 1.0041	* 1.1265	* 1.1756	* 1.3519	* 1.3673	* .6880
	* 1.3745	* 1.1831	* 1.5573	* 1.4182	* 1.3801	* 1.2136	* 1.1928	* 2.2231
11	* 1.3692	* 1.1474	* 1.1242	* 1.1263	* 1.3601	* 1.2044	* 1.3677	* .6044
	* 1.1709	* 1.3697	* 1.4211	* 1.4253	* 1.1982	* 1.3500	* 1.1919	* 2.5779
12	* 1.1859	* 1.3814	* 1.1753	* 1.3600	* 1.2647	* 1.4038	* .9010	*
	* 1.3169	* 1.1607	* 1.3804	* 1.1983	* 1.2758	* 1.1561	* 1.7568	*
13	* 1.3788	* 1.2439	* 1.3516	* 1.2042	* 1.4036	* 1.3623	* .6336	*
	* 1.1568	* 1.2787	* 1.2138	* 1.3501	* 1.1562	* 1.1803	* 2.4748	*
14	* 1.0413	* 1.3954	* 1.3670	* 1.3674	* .9006	* .6336	*	*
	* 1.4756	* 1.1389	* 1.1929	* 1.1921	* 1.7574	* 2.4748	*	*
15	* .5810	* .7312	* .6879	* .6043	* F-DEL-H			
	* 2.5438	* 2.0768	* 2.2232	* 2.5782	* M-DEL-H			

AT 100% POWER, 250 EFPD

	H	G	F	E	D	C	B	A
8	* .9385	* 1.3790	* 1.1277	* 1.3766	* 1.1675	* 1.3971	* 1.0397	* .5997
	* 1.6612	* 1.1633	* 1.3963	* 1.1509	* 1.3156	* 1.1410	* 1.4556	* 2.4676
9	* 1.3790	* 1.1134	* 1.3661	* 1.1196	* 1.4038	* 1.2271	* 1.4050	* .7473
	* 1.1633	* 1.4276	* 1.1606	* 1.3798	* 1.1439	* 1.2767	* 1.1314	* 2.0019
10	* 1.1277	* 1.3657	* .9756	* 1.0842	* 1.1616	* 1.4011	* 1.4035	* .7056
	* 1.3963	* 1.1611	* 1.6003	* 1.4442	* 1.3702	* 1.1580	* 1.1467	* 2.1370
11	* 1.3766	* 1.1198	* 1.0824	* 1.1105	* 1.3840	* 1.1919	* 1.3592	* .6174
	* 1.1509	* 1.3796	* 1.4465	* 1.4197	* 1.1623	* 1.3233	* 1.1881	* 2.4751
12	* 1.1675	* 1.4036	* 1.1614	* 1.3839	* 1.2449	* 1.4197	* .8965	*
	* 1.3156	* 1.1441	* 1.3703	* 1.1624	* 1.2530	* 1.1243	* 1.7352	*
13	* 1.3971	* 1.2269	* 1.4009	* 1.1918	* 1.4197	* 1.3330	* .6408	*
	* 1.1410	* 1.2769	* 1.1581	* 1.3233	* 1.1243	* 1.1878	* 2.4051	*
14	* 1.0397	* 1.4049	* 1.4034	* 1.3592	* .8961	* .6408	*	*
	* 1.4556	* 1.1315	* 1.1468	* 1.1882	* 1.7357	* 2.4051	*	*
15	* .5997	* .7474	* .7056	* .6174	* F-DEL-H			
	* 2.4676	* 2.0016	* 2.1369	* 2.4752	* M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 303 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 350 EFPD

	H	G	F	E	D	C	B	A
8	* .9313	* 1.3545	* 1.1012	* 1.3723	* 1.1472	* 1.3977	* 1.0373	* .6245
	* 1.6508	* 1.1828	* 1.4278	* 1.1359	* 1.3357	* 1.1052	* 1.4570	* 2.3364
9	* 1.3545	* 1.0883	* 1.3450	* 1.1003	* 1.4011	* 1.2061	* 1.4012	* .7661
	* 1.1828	* 1.4614	* 1.1782	* 1.4044	* 1.1102	* 1.2766	* 1.1003	* 1.9243
10	* 1.1012	* 1.3448	* .9659	* 1.0669	* 1.1476	* 1.4186	* 1.4031	* .7249
	* 1.4278	* 1.1786	* 1.5957	* 1.4688	* 1.3751	* 1.1297	* 1.1149	* 2.0503
11	* 1.3723	* 1.1006	* 1.0657	* 1.1005	* 1.3978	* 1.1793	* 1.3434	* .6359
	* 1.1359	* 1.4041	* 1.4697	* 1.4301	* 1.1285	* 1.3342	* 1.1799	* 2.3685
12	* 1.1472	* 1.4011	* 1.1475	* 1.3978	* 1.2255	* 1.4104	* .9000	*
	* 1.3357	* 1.1102	* 1.3751	* 1.1285	* 1.2656	* 1.1096	* 1.7257	*
13	* 1.3977	* 1.2059	* 1.4186	* 1.1793	* 1.4104	* 1.3138	* .6573	*
	* 1.1052	* 1.2768	* 1.1297	* 1.3343	* 1.1096	* 1.1828	* 2.3073	*
14	* 1.0373	* 1.4012	* 1.4031	* 1.3434	* .8998	* .6574	*	*
	* 1.4570	* 1.1003	* 1.1148	* 1.1799	* 1.7261	* 2.3072	*	*
15	* .6245	* .7662	* .7249	* .6359	* F-DEL-H			
	* 2.3364	* 1.9239	* 2.0501	* 2.3685	* M-DEL-H			

AT 100% POWER, 460 EFPD

	H	G	F	E	D	C	B	A
8	* .9356	* 1.3357	* 1.0850	* 1.3578	* 1.1244	* 1.3825	* 1.0345	* .6566
	* 1.6387	* 1.1856	* 1.4357	* 1.1509	* 1.3455	* 1.1176	* 1.4419	* 2.2273
9	* 1.3357	* 1.0744	* 1.3313	* 1.0838	* 1.3838	* 1.1796	* 1.3819	* .7900
	* 1.1856	* 1.4575	* 1.1923	* 1.4093	* 1.1246	* 1.2886	* 1.1161	* 1.8650
10	* 1.0850	* 1.3314	* .9664	* 1.0609	* 1.1294	* 1.4013	* 1.3809	* .7488
	* 1.4357	* 1.1921	* 1.6019	* 1.4621	* 1.3821	* 1.1259	* 1.1317	* 1.9830
11	* 1.3578	* 1.0841	* 1.0600	* 1.0878	* 1.3811	* 1.1599	* 1.3227	* .6607
	* 1.1509	* 1.4089	* 1.4634	* 1.4242	* 1.1425	* 1.3354	* 1.2017	* 2.2775
12	* 1.1244	* 1.3838	* 1.1294	* 1.3812	* 1.2007	* 1.3895	* .9104	*
	* 1.3455	* 1.1246	* 1.3821	* 1.1425	* 1.2687	* 1.1116	* 1.6802	*
13	* 1.3825	* 1.1795	* 1.4013	* 1.1599	* 1.3895	* 1.2987	* .6840	*
	* 1.1176	* 1.2887	* 1.1259	* 1.3354	* 1.1116	* 1.1822	* 2.2104	*
14	* 1.0345	* 1.3820	* 1.3810	* 1.3228	* .9102	* .6840	*	*
	* 1.4419	* 1.1160	* 1.1317	* 1.2017	* 1.6806	* 2.2103	*	*
15	* .6566	* .7901	* .7488	* .6607	* F-DEL-H			
	* 2.2273	* 1.8646	* 1.9828	* 2.2774	* M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 304 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9397	* 1.3873	* 1.2485	* 1.3976	* 1.2501	* 1.3708	* 1.0625	* .5783
	* 1.9908	* 1.4678	* 1.5467	* 1.3803	* 1.5166	* 1.4052	* 1.7330	* 3.0748
9	* 1.3873	* 1.2211	* 1.4075	* 1.2470	* 1.3945	* 1.2718	* 1.3578	* .7185
	* 1.4678	* 1.6054	* 1.3881	* 1.5278	* 1.3849	* 1.4892	* 1.3963	* 2.5036
10	* 1.2485	* 1.4069	* 1.1371	* 1.3200	* 1.2905	* 1.3518	* 1.2981	* .6640
	* 1.5467	* 1.3902	* 1.6844	* 1.4716	* 1.5171	* 1.4527	* 1.4877	* 2.7161
11	* 1.3976	* 1.2460	* 1.3160	* 1.2151	* 1.3592	* 1.2160	* 1.3715	* .5949
	* 1.3803	* 1.5283	* 1.4758	* 1.6502	* 1.4649	* 1.6173	* 1.4703	* 3.0996
12	* 1.2501	* 1.3934	* 1.2893	* 1.3584	* 1.2357	* 1.3097	* .9114	*
	* 1.5166	* 1.3851	* 1.5182	* 1.4649	* 1.4799	* 1.4714	* 2.1143	*
13	* 1.3708	* 1.2713	* 1.3511	* 1.2155	* 1.3094	* 1.3574	* .6227	*
	* 1.4052	* 1.4895	* 1.4532	* 1.6177	* 1.4716	* 1.4164	* 3.0038	*
14	* 1.0625	* 1.3574	* 1.2976	* 1.3710	* .9108	* .6226	*	*
	* 1.7330	* 1.3964	* 1.4881	* 1.4707	* 2.1153	* 3.0039	*	*
15	* .5783	* .7184	* .6638	* .5947	F-DEL-H			
	* 3.0748	* 2.5034	* 2.7163	* 3.1002	M-DEL-H			

AT 75% POWER, 50 EFPD

	H	G	F	E	D	C	B	A
8	* .9393	* 1.3991	* 1.2262	* 1.3997	* 1.2334	* 1.3906	* 1.0605	* .5748
	* 2.0154	* 1.4785	* 1.6004	* 1.3843	* 1.5466	* 1.3866	* 1.7720	* 3.1048
9	* 1.3991	* 1.2032	* 1.4072	* 1.2110	* 1.4004	* 1.2793	* 1.3908	* .7229
	* 1.4785	* 1.6681	* 1.4151	* 1.5848	* 1.3841	* 1.4981	* 1.3810	* 2.5098
10	* 1.2262	* 1.4067	* 1.0712	* 1.2328	* 1.2341	* 1.3584	* 1.3372	* .6728
	* 1.6004	* 1.4156	* 1.7810	* 1.5937	* 1.5998	* 1.4532	* 1.4619	* 2.7135
11	* 1.3997	* 1.2104	* 1.2294	* 1.1477	* 1.3286	* 1.2089	* 1.3798	* .5959
	* 1.3843	* 1.5851	* 1.5979	* 1.7316	* 1.4791	* 1.6421	* 1.4655	* 3.1300
12	* 1.2334	* 1.4000	* 1.2331	* 1.3281	* 1.2155	* 1.3310	* .9031	*
	* 1.5466	* 1.3844	* 1.6009	* 1.4791	* 1.5318	* 1.4531	* 2.1781	*
13	* 1.3906	* 1.2789	* 1.3578	* 1.2084	* 1.3307	* 1.3616	* .6180	*
	* 1.3866	* 1.4985	* 1.4537	* 1.6424	* 1.4532	* 1.4180	* 3.0968	*
14	* 1.0605	* 1.3904	* 1.3367	* 1.3793	* .9025	* .6180	*	*
	* 1.7720	* 1.3812	* 1.4622	* 1.4659	* 2.1793	* 3.0970	*	*
15	* .5748	* .7228	* .6726	* .5957	F-DEL-H			
	* 3.1048	* 2.5096	* 2.7136	* 3.1306	M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 305 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* .9061	* 1.3817	* 1.1663	* 1.3945	* 1.2099	* 1.4137	* 1.0645	* .5871
	* 2.1132	* 1.4859	* 1.6687	* 1.3856	* 1.5671	* 1.3716	* 1.7711	* 3.0775
9	* 1.3817	* 1.1434	* 1.3899	* 1.1601	* 1.4149	* 1.2740	* 1.4362	* .7422
	* 1.4859	* 1.7516	* 1.4237	* 1.6448	* 1.3713	* 1.5023	* 1.3520	* 2.4989
10	* 1.1663	* 1.3893	* 1.0018	* 1.1267	* 1.1883	* 1.3820	* 1.4030	* .6970
	* 1.6687	* 1.4245	* 1.9112	* 1.7310	* 1.6479	* 1.4359	* 1.4096	* 2.6801
11	* 1.3945	* 1.1601	* 1.1243	* 1.0974	* 1.3321	* 1.1957	* 1.3871	* .6061
	* 1.3856	* 1.6448	* 1.7345	* 1.7946	* 1.4713	* 1.6574	* 1.4502	* 3.1348
12	* 1.2099	* 1.4145	* 1.1879	* 1.3318	* 1.1793	* 1.3627	* .8890	*
	* 1.5671	* 1.3716	* 1.6484	* 1.4714	* 1.5661	* 1.4347	* 2.2054	*
13	* 1.4137	* 1.2737	* 1.3817	* 1.1954	* 1.3625	* 1.3274	* .6118	*
	* 1.3716	* 1.5027	* 1.4362	* 1.6577	* 1.4348	* 1.4438	* 3.1205	*
14	* 1.0645	* 1.4359	* 1.4027	* 1.3868	* .8885	* .6118	*	*
	* 1.7711	* 1.3521	* 1.4098	* 1.4505	* 2.2061	* 3.1207	*	*
15	* .5871	* .7422	* .6969	* .6059	F-DEL-H			
	* 3.0775	* 2.4986	* 2.6802	* 3.1352	M-DEL-H			

AT 75% POWER, 250 EFPD

	H	G	F	E	D	C	B	A
8	* .8792	* 1.3620	* 1.1297	* 1.4086	* 1.1973	* 1.4461	* 1.0691	* .6097
	* 2.1284	* 1.4967	* 1.7089	* 1.3757	* 1.5852	* 1.3316	* 1.7686	* 2.9846
9	* 1.3620	* 1.0994	* 1.3759	* 1.1354	* 1.4455	* 1.2625	* 1.4548	* .7631
	* 1.4967	* 1.7920	* 1.4357	* 1.6647	* 1.3400	* 1.5142	* 1.3230	* 2.4121
10	* 1.1297	* 1.3755	* .9738	* 1.0847	* 1.1764	* 1.4426	* 1.4478	* .7189
	* 1.7089	* 1.4363	* 1.9712	* 1.7665	* 1.6617	* 1.3678	* 1.3504	* 2.5780
11	* 1.4086	* 1.1355	* 1.0839	* 1.0748	* 1.3618	* 1.1831	* 1.3808	* .6211
	* 1.3757	* 1.6645	* 1.7674	* 1.8127	* 1.4429	* 1.6724	* 1.4462	* 3.0068
12	* 1.1973	* 1.4453	* 1.1762	* 1.3616	* 1.1552	* 1.3647	* .8810	*
	* 1.5852	* 1.3402	* 1.6620	* 1.4430	* 1.5827	* 1.3927	* 2.2087	*
13	* 1.4461	* 1.2622	* 1.4424	* 1.1830	* 1.3646	* 1.2817	* .6141	*
	* 1.3316	* 1.5145	* 1.3679	* 1.6725	* 1.3928	* 1.4715	* 3.0385	*
14	* 1.0691	* 1.4547	* 1.4477	* 1.3806	* .8806	* .6141	*	*
	* 1.7686	* 1.3230	* 1.3504	* 1.4463	* 2.2093	* 3.0384	*	*
15	* .6097	* .7631	* .7189	* .6210	F-DEL-H			
	* 2.9846	* 2.4117	* 2.5778	* 3.0069	M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 306 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 350 EFPD

	H	G	F	E	D	C	B	A
8	* .8655	* 1.3349	* 1.1091	* 1.4110	* 1.1835	* 1.4555	* 1.0738	* .6394
	* 2.1431	* 1.5007	* 1.7356	* 1.3716	* 1.5910	* 1.3241	* 1.7452	* 2.8759
9	* 1.3349	* 1.0741	* 1.3583	* 1.1208	* 1.4509	* 1.2478	* 1.4591	* .7873
	* 1.5007	* 1.8338	* 1.4355	* 1.6920	* 1.3362	* 1.5173	* 1.3201	* 2.3499
10	* 1.1091	* 1.3578	* .9661	* 1.0721	* 1.1651	* 1.4669	* 1.4540	* .7430
	* 1.7356	* 1.4359	* 1.9958	* 1.7874	* 1.6543	* 1.3387	* 1.3396	* 2.4910
11	* 1.4110	* 1.1210	* 1.0717	* 1.0573	* 1.3746	* 1.1674	* 1.3663	* .6419
	* 1.3716	* 1.6916	* 1.7881	* 1.7940	* 1.4221	* 1.6612	* 1.4543	* 2.9039
12	* 1.1835	* 1.4508	* 1.1650	* 1.3746	* 1.1280	* 1.3397	* .8805	*
	* 1.5910	* 1.3363	* 1.6543	* 1.4221	* 1.5752	* 1.3943	* 2.1620	*
13	* 1.4555	* 1.2477	* 1.4669	* 1.1674	* 1.3397	* 1.2432	* .6248	*
	* 1.3241	* 1.5175	* 1.3388	* 1.6612	* 1.3943	* 1.4895	* 2.9553	*
14	* 1.0738	* 1.4591	* 1.4541	* 1.3663	* .8803	* .6248	*	*
	* 1.7452	* 1.3200	* 1.3396	* 1.4543	* 2.1625	* 2.9552	*	*
15	* .6394	* .7875	* .7431	* .6419	F-DEL-H			
	* 2.8759	* 2.3495	* 2.4907	* 2.9039	M-DEL-H			

AT 75% POWER, 460 EFPD

	H	G	F	E	D	C	B	A
8	* .8600	* 1.3212	* 1.0984	* 1.4055	* 1.1688	* 1.4498	* 1.0802	* .6785
	* 2.2402	* 1.5478	* 1.7657	* 1.3734	* 1.6188	* 1.3193	* 1.7488	* 2.7467
9	* 1.3212	* 1.0614	* 1.3529	* 1.1113	* 1.4427	* 1.2293	* 1.4486	* .8184
	* 1.5478	* 1.8636	* 1.4469	* 1.7187	* 1.3319	* 1.5435	* 1.3196	* 2.2838
10	* 1.0984	* 1.3526	* .9706	* 1.0682	* 1.1492	* 1.4559	* 1.4387	* .7730
	* 1.7657	* 1.4472	* 1.9983	* 1.8094	* 1.6780	* 1.3307	* 1.3385	* 2.4151
11	* 1.4055	* 1.1116	* 1.0672	* 1.0349	* 1.3541	* 1.1446	* 1.3470	* .6695
	* 1.3734	* 1.7183	* 1.8099	* 1.8421	* 1.4587	* 1.7023	* 1.4495	* 2.7968
12	* 1.1688	* 1.4427	* 1.1492	* 1.3541	* 1.0898	* 1.2990	* .8856	*
	* 1.6188	* 1.3319	* 1.6780	* 1.4587	* 1.6899	* 1.4411	* 2.1675	*
13	* 1.4498	* 1.2292	* 1.4560	* 1.1446	* 1.2990	* 1.2096	* .6435	*
	* 1.3193	* 1.5436	* 1.3306	* 1.7023	* 1.4411	* 1.5432	* 2.9119	*
14	* 1.0802	* 1.4487	* 1.4388	* 1.3470	* .8854	* .6435	*	*
	* 1.7488	* 1.3195	* 1.3384	* 1.4495	* 2.1680	* 2.9118	*	*
15	* .6785	* .8186	* .7731	* .6695	F-DEL-H			
	* 2.7467	* 2.2833	* 2.4149	* 2.7967	M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 307 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* .9080	* 1.3884	* 1.2596	* 1.4207	* 1.2723	* 1.4015	* 1.0826	* .5831
	* 1.9362	* 1.5488	* 1.6617	* 1.4859	* 1.6270	* 1.5049	* 1.8677	* 3.3350
9	* 1.3884	* 1.2236	* 1.4239	* 1.2617	* 1.4190	* 1.2996	* 1.3899	* .7259
	* 1.5488	* 1.7302	* 1.4960	* 1.6357	* 1.4919	* 1.5983	* 1.5061	* 2.7178
10	* 1.2596	* 1.4215	* 1.1460	* 1.3335	* 1.3040	* 1.3716	* 1.3216	* .6691
	* 1.6617	* 1.4984	* 1.7916	* 1.5794	* 1.6334	* 1.5418	* 1.6221	* 2.9180
11	* 1.4207	* 1.2606	* 1.3293	* 1.2147	* 1.3570	* 1.2082	* 1.3814	* .5941
	* 1.4859	* 1.6364	* 1.5842	* 1.7826	* 1.5652	* 1.7397	* 1.5802	* 3.4060
12	* 1.2723	* 1.4185	* 1.3027	* 1.3561	* 1.1892	* 1.2656	* .8975	*
	* 1.6269	* 1.4921	* 1.6348	* 1.5662	* 1.4366	* 1.5749	* 2.2718	*
13	* 1.4015	* 1.2991	* 1.3708	* 1.2077	* 1.2653	* 1.3155	* .6015	*
	* 1.5049	* 1.5986	* 1.5423	* 1.7400	* 1.5751	* 1.4960	* 3.2324	*
14	* 1.0826	* 1.3894	* 1.3211	* 1.3808	* .8969	* .6014	*	*
	* 1.8677	* 1.5062	* 1.6224	* 1.5806	* 2.2728	* 3.2325	*	*
15	* .5831	* .7259	* .6689	* .5939	* F-DEL-H			
	* 3.3350	* 2.7174	* 2.9179	* 3.4067	* M-DEL-H			

AT 50% POWER, 50 EFPD

	H	G	F	E	D	C	B	A
8	* .9084	* 1.3979	* 1.2311	* 1.4236	* 1.2523	* 1.4208	* 1.0798	* .5792
	* 2.2047	* 1.6078	* 1.7147	* 1.5056	* 1.6584	* 1.5221	* 1.8992	* 3.4148
9	* 1.3979	* 1.1981	* 1.4174	* 1.2227	* 1.4274	* 1.3058	* 1.4244	* .7307
	* 1.6078	* 1.7898	* 1.5281	* 1.6968	* 1.5091	* 1.6114	* 1.5148	* 2.7547
10	* 1.2311	* 1.4168	* 1.0745	* 1.2385	* 1.2441	* 1.3799	* 1.3633	* .6785
	* 1.7147	* 1.5287	* 1.9242	* 1.7088	* 1.7258	* 1.6189	* 1.6257	* 2.9912
11	* 1.4236	* 1.2224	* 1.2349	* 1.1314	* 1.3273	* 1.2025	* 1.3922	* .5960
	* 1.5056	* 1.6973	* 1.7136	* 1.8513	* 1.6238	* 1.7532	* 1.6079	* 3.4884
12	* 1.2523	* 1.4270	* 1.2431	* 1.3267	* 1.1733	* 1.2923	* .8916	*
	* 1.6584	* 1.5094	* 1.7271	* 1.6241	* 1.6317	* 1.5835	* 2.3208	*
13	* 1.4208	* 1.3053	* 1.3793	* 1.2020	* 1.2920	* 1.3272	* .5993	*
	* 1.5221	* 1.6118	* 1.6195	* 1.7535	* 1.5836	* 1.5272	* 3.2981	*
14	* 1.0798	* 1.4239	* 1.3628	* 1.3916	* .8910	* .5993	*	*
	* 1.8992	* 1.5149	* 1.6261	* 1.6083	* 2.3218	* 3.2982	*	*
15	* .5792	* .7306	* .6783	* .5958	* F-DEL-H			
	* 3.4148	* 2.7544	* 2.9912	* 3.4890	* M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 308 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* .8660	* 1.3698	* 1.1760	* 1.4270	* 1.2410	* 1.4570	* 1.0943	* .5977
	* 2.2934	* 1.6464	* 1.7865	* 1.5004	* 1.6701	* 1.4708	* 1.8847	* 3.3535
9	* 1.3698	* 1.1361	* 1.4032	* 1.1783	* 1.4547	* 1.3104	* 1.4832	* .7576
	* 1.6464	* 1.8801	* 1.5502	* 1.7563	* 1.4793	* 1.6183	* 1.4485	* 2.6886
10	* 1.1760	* 1.4023	* 1.0042	* 1.1302	* 1.2039	* 1.4168	* 1.4430	* .7097
	* 1.7865	* 1.5512	* 2.0666	* 1.8573	* 1.7707	* 1.5459	* 1.5156	* 2.8917
11	* 1.4270	* 1.1783	* 1.1276	* 1.0605	* 1.3283	* 1.1855	* 1.4056	* .6095
	* 1.5004	* 1.7564	* 1.8615	* 1.9185	* 1.5962	* 1.7870	* 1.5678	* 3.3718
12	* 1.2410	* 1.4543	* 1.2035	* 1.3279	* 1.1163	* 1.3034	* .8720	*
	* 1.6701	* 1.4797	* 1.7712	* 1.5963	* 1.6834	* 1.5210	* 2.3791	*
13	* 1.4570	* 1.3101	* 1.4164	* 1.1852	* 1.3032	* 1.2704	* .5861	*
	* 1.4708	* 1.6187	* 1.5461	* 1.7873	* 1.5211	* 1.5385	* 3.3086	*
14	* 1.0943	* 1.4829	* 1.4427	* 1.4053	* .8715	* .5861	*	*
	* 1.8847	* 1.4486	* 1.5158	* 1.5680	* 2.3798	* 3.3086	*	*
15	* .5977	* .7577	* .7096	* .6094	F-DEL-H			
	* 3.3535	* 2.6881	* 2.8916	* 3.3721	M-DEL-H			

AT 50% POWER, 250 EFPD

	H	G	F	E	D	C	B	A
8	* .8173	* 1.3416	* 1.1479	* 1.4643	* 1.2501	* 1.5208	* 1.0824	* .6224
	* 2.1852	* 1.6031	* 1.8407	* 1.4693	* 1.6758	* 1.4256	* 1.8636	* 3.2299
9	* 1.3416	* 1.0884	* 1.3947	* 1.1687	* 1.5129	* 1.3199	* 1.5270	* .7904
	* 1.6031	* 1.9513	* 1.5400	* 1.7895	* 1.4354	* 1.6027	* 1.4155	* 2.6019
10	* 1.1479	* 1.3940	* .9686	* 1.1040	* 1.2052	* 1.5039	* 1.5132	* .7442
	* 1.8407	* 1.5408	* 2.1296	* 1.9080	* 1.7501	* 1.4480	* 1.4405	* 2.7843
11	* 1.4643	* 1.1689	* 1.1034	* 1.0182	* 1.3392	* 1.1735	* 1.4124	* .6339
	* 1.4693	* 1.7893	* 1.9090	* 1.9317	* 1.5546	* 1.7646	* 1.4973	* 3.1338
12	* 1.2501	* 1.5127	* 1.2050	* 1.3390	* 1.0488	* 1.2663	* .8582	*
	* 1.6758	* 1.4356	* 1.7502	* 1.5547	* 1.5989	* 1.4848	* 2.3375	*
13	* 1.5208	* 1.3196	* 1.5037	* 1.1733	* 1.2662	* 1.1857	* .5775	*
	* 1.4256	* 1.6029	* 1.4481	* 1.7647	* 1.4848	* 1.5644	* 3.2567	*
14	* 1.0824	* 1.5269	* 1.5130	* 1.4123	* .8579	* .5775	*	*
	* 1.8636	* 1.4155	* 1.4405	* 1.4974	* 2.3381	* 3.2567	*	*
15	* .6224	* .7905	* .7442	* .6338	F-DEL-H			
	* 3.2299	* 2.6013	* 2.7840	* 3.1338	M-DEL-H			

Catawba 2 Cycle 12 Core Operating Limits Report

CNEI-0400-25
Appendix A, Rev. 19
Page 309 of 311

TABLE 8 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 350 EFPD

	H	G	F	E	D	C	B	A
8	* .7903	* 1.3117	* 1.1251	* 1.4735	* 1.2409	* 1.5329	* 1.0740	* .6400
	* 1.9586	* 1.5006	* 1.8735	* 1.4432	* 1.6900	* 1.3913	* 1.8503	* 3.0922
9	* 1.3117	* 1.0546	* 1.3733	* 1.1581	* 1.5283	* 1.3081	* 1.5354	* .8145
	* 1.5006	* 1.9459	* 1.5050	* 1.8165	* 1.4042	* 1.6096	* 1.3860	* 2.5167
10	* 1.1251	* 1.3729	* .9421	* 1.0941	* 1.2019	* 1.5425	* 1.5323	* .7724
	* 1.8735	* 1.5054	* 2.1624	* 1.9307	* 1.7453	* 1.3865	* 1.3988	* 2.6836
11	* 1.4735	* 1.1584	* 1.0937	* 1.0047	* 1.3595	* 1.1688	* 1.4133	* .6633
	* 1.4432	* 1.8162	* 1.9315	* 1.9364	* 1.4617	* 1.7688	* 1.4685	* 3.0009
12	* 1.2409	* 1.5282	* 1.2019	* 1.3594	* 1.0136	* 1.2439	* .8667	*
	* 1.6900	* 1.4043	* 1.7452	* 1.4618	* 1.4995	* 1.4582	* 2.3156	*
13	* 1.5329	* 1.3079	* 1.5425	* 1.1688	* 1.2439	* 1.1541	* .5934	*
	* 1.3913	* 1.6098	* 1.3865	* 1.7688	* 1.4582	* 1.5559	* 3.1763	*
14	* 1.0740	* 1.5354	* 1.5323	* 1.4133	* .8665	* .5934	*	*
	* 1.8503	* 1.3859	* 1.3987	* 1.4685	* 2.3161	* 3.1762	*	*
15	* .6400	* .8146	* .7724	* .6633	* F-DEL-H			
	* 3.0922	* 2.5161	* 2.6832	* 3.0008	* M-DEL-H			

AT 50% POWER, 460 EFPD

	H	G	F	E	D	C	B	A
8	* .7635	* 1.2874	* 1.1145	* 1.4787	* 1.2338	* 1.5302	* 1.0603	* .6606
	* 1.7984	* 1.4041	* 1.7782	* 1.3739	* 1.7065	* 1.3406	* 1.8504	* 2.9520
9	* 1.2874	* 1.0318	* 1.3647	* 1.1560	* 1.5317	* 1.2939	* 1.5277	* .8456
	* 1.4041	* 1.8288	* 1.4232	* 1.7749	* 1.3456	* 1.6129	* 1.3460	* 2.4376
10	* 1.1145	* 1.3645	* .9197	* 1.0921	* 1.1996	* 1.5485	* 1.5326	* .8088
	* 1.7782	* 1.4234	* 2.0005	* 1.8210	* 1.7044	* 1.3393	* 1.3571	* 2.5941
11	* 1.4787	* 1.1564	* 1.0919	* .9932	* 1.3495	* 1.1606	* 1.4155	* .7047
	* 1.3739	* 1.7744	* 1.8213	* 1.8873	* 1.3733	* 1.6965	* 1.4486	* 2.8688
12	* 1.2338	* 1.5318	* 1.1997	* 1.3495	* .9620	* 1.2094	* .8856	*
	* 1.7065	* 1.3455	* 1.7043	* 1.3732	* 1.4032	* 1.4356	* 2.2239	*
13	* 1.5302	* 1.2938	* 1.5486	* 1.1607	* 1.2093	* 1.1282	* .6206	*
	* 1.3406	* 1.6131	* 1.3392	* 1.6965	* 1.4356	* 1.5656	* 3.0713	*
14	* 1.0603	* 1.5278	* 1.5327	* 1.4156	* .8854	* .6207	*	*
	* 1.8504	* 1.3460	* 1.3570	* 1.4485	* 2.2246	* 3.0712	*	*
15	* .6606	* .8457	* .8088	* .7047	* F-DEL-H			
	* 2.9520	* 2.4371	* 2.5937	* 2.8687	* M-DEL-H			