



H. B. Barron
Vice President

Duke Energy Corporation

McGuire Nuclear Station
12700 Hagers Ferry Road
Huntersville, NC 28078-9340
(704) 875-4800 OFFICE
(704) 875-4809 FAX

October 23, 2001

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Duke Energy Corporation
McGuire Nuclear Station Units 1 and 2
Docket Nos. 50-369 and 50-370
Technical Specification Bases Change

Attached is a revision to the McGuire Technical Specification
Bases Manual Section 3.6.2 (Containment Air Locks).

This revision modifies the Tech Spec Bases by inserting additional information concerning the bulkhead associated with an air lock door. This information clarifies that for the purposes of Required Actions A.1, A.2, and A.3, the bulkhead is considered to be part of the door. It is appropriate to treat the associated bulkhead as part of the door because a leak path through the bulkhead (of the air lock) is no different than a leak path past the door seals. For example, an air lock door may be declared inoperable if the equalizing valve becomes inoperable or is replaced. This information will add conservatism to the Bases when assessing air lock door operability.

This revision also removes erroneous information from the Tech Spec Bases. The last sentence of the second paragraph in the Background section is not correct. It states: "To effect a leak tight seal, the air lock design uses pressure seated doors (i.e., an increase in containment internal pressure results in increased sealing force on each door)." The inflatable air lock door seals at McGuire seal circumferentially around the door filling the gap between the O.D. of the door and the I.D. of the door opening. Each door is equipped with stop blocks to resist containment pressure forces and prevent the door from being pushed open but an increase in containment pressure in no way increases the sealing capability of the door or seals. This erroneous sentence was added as part of the Westinghouse Standardized Tech Spec conversion process in 1997. This generic sentence should have been removed during the ITS conversion review process.

This change was implemented in accordance with the provisions of 10 CFR 50.59. Attachment 1 contains the revised Bases List of Effective Pages. Attachment 2 contains revised Bases 3.6.2.

A 001
Rec'd 01/18/02

U. S. Nuclear Regulatory Commission
October 23, 2001
Page 2

Please contact Lee Hentz at (704) 875-4947 if you have any questions.

Very truly yours,



H. B. Barron

Attachments

Xc w/attachments:

L. A. Reyes
U. S. Nuclear Regulatory Commission
Regional Administrator, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

R. E. Martin
NRC Senior Project Manager
U. S. Nuclear Regulatory Commission
Mail Stop O-8G9
Washington, DC 20555-0001

S. M. Shaeffer
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
McGuire Nuclear Station

U. S. Nuclear Regulatory Commission
October 23, 2001
Page 3

Bc w/attachments:

L. Burba (EC050)
ELL (EC050)
K. Crane
McGuire Master File 1.3.2.12

ATTACHMENT 1

**REVISED TECHNICAL SPECIFICATION BASES
LIST OF EFFECTIVE SECTIONS**

McGuire Nuclear Station Technical Specifications
List of Effective Pages and Bases List of Effective Sections

Page Number	Amendment	Revision Date
i	184/166	9/30/98
ii	184/166	9/30/98
iii	184/166	9/30/98
iv	184/166	9/30/98
1.1-1	184/166	9/30/98
1.1-2	184/166	9/30/98
1.1-3	184/166	9/30/98
1.1-4	194/175	9/18/00
1.1-5	194/175	9/18/00
1.1-6	194/175	9/18/00
1.1-7	194/175	9/18/00
1.2-1	184/166	9/30/98
1.2-2	184/166	9/30/98
1.2-3	184/166	9/30/98
1.3-1	184/166	9/30/98
1.3-2	184/166	9/30/98
1.3-3	184/166	9/30/98
1.3-4	184/166	9/30/98
1.3-5	184/166	9/30/98
1.3-6	184/166	9/30/98
1.3-7	184/166	9/30/98
1.3-8	184/166	9/30/98
1.3-9	184/166	9/30/98
1.3-10	184/166	9/30/98
1.3-11	184/166	9/30/98
1.3-12	184/166	9/30/98
1.3-13	184/166	9/30/98
1.4-1	184/166	9/30/98
1.4-2	184/166	9/30/98
1.4-3	184/166	9/30/98
1.4-4	184/166	9/30/98

Page Number	Amendment	Revision Date
2.0-1	184/166	9/30/98
2.0-2	191/172	3/20/00
3.0-1	184/166	9/30/98
3.0-2	184/166	9/30/98
3.0-3	184/166	9/30/98
3.0-4	184/166	9/30/98
3.0-5	184/166	9/30/98
3.1.1-1	184/166	9/30/98
3.1.2-1	184/166	9/30/98
3.1.2-2	184/166	9/30/98
3.1.3-1	184/166	9/30/98
3.1.3-2	184/166	9/30/98
3.1.3-3	184/166	9/30/98
3.1.4-1	184/166	9/30/98
3.1.4-2	184/166	9/30/98
3.1.4-3	184/166	9/30/98
3.1.4-4	186/167	9/8/99
3.1.5-1	184/166	9/30/98
3.1.5-2	184/166	9/30/98
3.1.6-1	184/166	9/30/98
3.1.6-2	184/166	9/30/98
3.1.6-3	184/166	9/30/98
3.1.7-1	184/166	9/30/98
3.1.7-2	184/166	9/30/98
3.1.8-1	184/166	9/30/98
3.1.8-2	184/166	9/30/98
3.2.1-1	184/166	9/30/98
3.2.1-2	184/166	9/30/98
3.2.1-3	184/166	9/30/98
3.2.1-4	188/169	9/22/99
3.2.1-5	188/169	9/22/99
3.2.2-1	184/166	9/30/98
3.2.2-2	184/166	9/30/98

Page Number	Amendment	Revision Date
3.2.2-3	184/166	9/30/98
3.2.2-4	188/169	9/22/99
3.2.3-1	184/166	9/30/98
3.2.4-1	184/166	9/30/98
3.2.4-2	184/166	9/30/98
3.2.4-3	184/166	9/30/98
3.2.4-4	184/166	9/30/98
3.3.1-1	184/166	9/30/98
3.3.1-2	184/166	9/30/98
3.3.1-3	184/166	9/30/98
3.3.1-4	184/166	9/30/98
3.3.1-5	184/166	9/30/98
3.3.1-6	184/166	9/30/98
3.3.1-7	184/166	9/30/98
3.3.1-8	184/166	9/30/98
3.3.1-9	184/166	9/30/98
3.3.1-10	184/166	9/30/98
3.3.1-11	184/166	9/30/98
3.3.1-12	184/166	9/30/98
3.3.1-13	184/166	9/30/98
3.3.1-14	194/175	9/18/00
3.3.1-15	194/175	9/18/00
3.3.1-16	194/175	9/18/00
3.3.1-17	194/175	9/18/00
3.3.1-18	194/175	9/18/00
3.3.1-19	194/175	9/18/00
3.3.1-20	184/166	9/30/98
3.3.2-1	184/166	9/30/98
3.3.2-2	184/166	9/30/98
3.3.2-3	184/166	9/30/98
3.3.2-4	184/166	9/30/98
3.3.2-5	184/166	9/30/98
3.3.2-6	184/166	9/30/98

Page Number	Amendment	Revision Date
3.3.2-7	184/166	9/30/98
3.3.2-8	184/166	9/30/98
3.3.2-9	184/166	9/30/98
3.3.2-10	194/175	9/18/00
3.3.2-11	194/175	9/18/00
3.3.2-12	194/175	9/18/00
3.3.2-13	194/175	9/18/00
3.3.2-14	194/175	9/18/00
3.3.2-15	184/166	9/30/98
3.3.3-1	184/166	9/30/98
3.3.3-2	184/166	9/30/98
3.3.3-3	184/166	9/30/98
3.3.3-4	184/166	9/30/98
3.3.4-1	184/166	9/30/98
3.3.4-2	184/166	9/30/98
3.3.4-3	184/166	9/30/98
3.3.5-1	184/166	9/30/98
3.3.5-2	194/175	9/18/00
3.3.6-1	184/166	9/30/98
3.3.6-2	184/166	9/30/98
3.3.6-3	194/175	9/18/00
3.4.1-1	191/172	3/20/00
3.4.1-2	191/175	3/20/00
3.4.1-3	184/166	9/30/98
3.4.1-4	191/172	3/20/00
3.4.2-1	184/166	9/30/98
3.4.3-1	184/166	9/30/98
3.4.3-2	184/166	9/30/98
3.4.3-3	184/166	9/30/98
3.4.3-4	184/166	9/30/98
3.4.3-5	184/166	9/30/98
3.4.3-6	184/166	9/30/98
3.4.4-1	184/166	9/30/98

Page Number	Amendment	Revision Date
3.4.5-1	184/166	9/30/98
3.4.5-2	184/166	9/30/98
3.4.5-3	184/166	9/30/98
3.4.6-1	184/166	9/30/98
3.4.6-2	184/166	9/30/98
3.4.7-1	184/166	9/30/98
3.4.7-2	184/166	9/30/98
3.4.8-1	184/166	9/30/98
3.4.8-2	184/166	9/30/98
3.4.9-1	184/166	9/30/98
3.4.9-2	184/166	9/30/98
3.4.10-1	184/166	9/30/98
3.4.10-2	184/166	9/30/98
3.4.11-1	184/166	9/30/98
3.4.11-2	184/166	9/30/98
3.4.11-3	184/166	9/30/98
3.4.11-4	184/166	9/30/98
3.4.12-1	184/166	9/30/98
3.4.12-2	184/166	9/30/98
3.4.12-3	184/166	9/30/98
3.4.12-4	184/166	9/30/98
3.4.12-5	184/166	9/30/98
3.4.12-6	184/166	9/30/98
3.4.13-1	184/166	9/30/98
3.4.13-2	184/166	9/30/98
3.4.14-1	184/166	9/30/98
3.4.14-2	184/166	9/30/98
3.4.14-3	184/166	9/30/98
3.4.14-4	184/166	9/30/98
3.4.15-1	184/166	9/30/98
3.4.15-2	184/166	9/30/98
3.4.15-3	184/166	9/30/98
3.4.16-1	184/166	9/30/98

Page Number	Amendment	Revision Date
3.4.16-2	184/166	9/30/98
3.4.16-3	184/166	9/30/98
3.4.16-4	184/166	9/30/98
3.4.17-1	184/166	9/30/98
3.5.1-1	184/166	9/30/98
3.5.1-2	184/166	9/30/98
3.5.2-1	184/166	9/30/98
3.5.2-2	184/166	9/30/98
3.5.2-3	184/166	9/30/98
3.5.3-1	184/166	9/30/98
3.5.3-2	184/166	9/30/98
3.5.4-1	184/166	9/30/98
3.5.4-2	184/166	9/30/98
3.5.5-1	184/166	9/30/98
3.5.5-2	184/166	9/30/98
3.6.1-1	184/166	9/30/98
3.6.1-2	184/166	9/30/98
3.6.2-1	184/166	9/30/98
3.6.2-2	184/166	9/30/98
3.6.2-3	184/166	9/30/98
3.6.2-4	184/166	9/30/98
3.6.2-5	184/166	9/30/98
3.6.3-1	184/166	9/30/98
3.6.3-2	184/166	9/30/98
3.6.3-3	184/166	9/30/98
3.6.3-4	184/166	9/30/98
3.6.3-5	184/166	9/30/98
3.6.3-6	184/166	9/30/98
3.6.3-7	184/166	9/30/98
3.6.4-1	184/166	9/30/98
3.6.5-1	184/166	9/30/98
3.6.5-2	184/166	9/30/98
3.6.6-1	184/166	9/30/98

Page Number	Amendment	Revision Date
3.6.6-2	184/166	9/30/98
3.6.7-1	184/166	9/30/98
3.6.7-2	184/166	9/30/98
3.6.8-1	184/166	9/30/98
3.6.8-2	184/166	9/30/98
3.6.9-1	184/166	9/30/98
3.6.9-2	184/166	9/30/98
3.6.10-1	184/166	9/30/98
3.6.10-2	184/166	9/30/98
3.6.11-1	184/166	9/30/98
3.6.11-2	184/166	9/30/98
3.6.12-1	184/166	9/30/98
3.6.12-2	184/166	9/30/98
3.6.12-3	184/166	9/30/98
3.6.13-1	184/166	9/30/98
3.6.13-2	184/166	9/30/98
3.6.13-3	184/166	9/30/98
3.6.14-1	184/166	9/30/98
3.6.14-2	184/166	9/30/98
3.6.14-3	184/166	9/30/98
3.6.15-1	184/166	9/30/98
3.6.15-2	184/166	9/30/98
3.6.16-1	184/166	9/30/98
3.6.16-2	184/166	9/30/98
3.7.1-1	184/166	9/30/98
3.7.1-2	184/166	9/30/98
3.7.1-3	184/166	9/30/98
3.7.2-1	184/166	9/30/98
3.7.2-2	184/166	9/30/98
3.7.3-1	184/166	9/30/98
3.7.3-2	184/166	9/30/98
3.7.4-1	184/166	9/30/98
3.7.4-2	184/166	9/30/98

Page Number	Amendment	Revision Date
3.7.5-1	184/166	9/30/98
3.7.5-2	184/166	9/30/98
3.7.5-3	184/166	9/30/98
3.7.5-4	184/166	9/30/98
3.7.6-1	184/166	9/30/98
3.7.6-2	184/166	9/30/98
3.7.7-1	184/166	9/30/98
3.7.7-2	184/166	9/30/98
3.7.8-1	184/166	9/30/98
3.7.8-2	184/166	9/30/98
3.7.9-1	187/168	9/22/99
3.7.9-2	187/168	9/22/99
3.7.9-3	184/166	9/30/98
3.7.10-1	184/166	9/30/98
3.7.10-2	184/166	9/30/98
3.7.11-1	184/166	9/30/98
3.7.11-2	184/166	9/30/98
3.7.12-1	184/166	9/30/98
3.7.12-2	184/166	9/30/98
3.7.13-1	184/166	9/30/98
3.7.14-1	184/166	9/30/98
3.7.15-1	197/178	11/27/00
3.7.15-2	197/178	11/27/00
3.7.15-3	197/178	11/27/00
3.7.15-4	197/178	11/27/00
3.7.15-5	197/178	11/27/00
3.7.15-6	197/178	11/27/00
3.7.15-7	197/178	11/27/00
3.7.15-8	197/178	11/27/00
3.7.15-9	197/178	11/27/00
3.7.15-10	197/178	11/27/00
3.7.15-11	197/178	11/27/00
3.7.15-12	197/178	11/27/00

Page Number	Amendment	Revision Date
3.7.15-13	197/178	11/27/00
3.7.15-14	197/178	11/27/00
3.7.15-15	197/178	11/27/00
3.7.15-16	197/178	11/27/00
3.7.15-17	197/178	11/27/00
3.7.15-18	197/178	11/27/00
3.7.15-19	197/178	11/27/00
3.7.15-20	197/178	11/27/00
3.7.15-21	197/178	11/27/00
3.7.16-1	184/166	9/30/98
3.8.1-1	184/166	9/30/98
3.8.1-2	184/166	9/30/98
3.8.1-3	184/166	9/30/98
3.8.1-4	184/166	9/30/98
3.8.1-5	184/166	9/30/98
3.8.1-6	184/166	9/30/98
3.8.1-7	184/166	9/30/98
3.8.1-8	192/173	3/15/00
3.8.1-9	184/166	9/30/98
3.8.1-10	184/166	9/30/98
3.8.1-11	192/173	3/15/00
3.8.1-12	184/166	9/30/98
3.8.1-13	184/166	9/30/98
3.8.1-14	184/166	9/30/98
3.8.1-15	184/166	9/30/98
3.8.2-1	184/166	9/30/98
3.8.2-2	184/166	9/30/98
3.8.2-3	184/166	9/30/98
3.8.3-1	184/166	9/30/98
3.8.3-2	184/166	9/30/98
3.8.3-3	184/166	9/30/98
3.8.4-1	184/166	9/30/98
3.8.4-2	184/166	9/30/98

Page Number	Amendment	Revision Date
3.8.4-3	184/166	9/30/98
3.8.5-1	184/166	9/30/98
3.8.5-2	184/166	9/30/98
3.8.6-1	184/166	9/30/98
3.8.6-2	184/166	9/30/98
3.8.6-3	184/166	9/30/98
3.8.6-4	184/166	9/30/98
3.8.7-1	184/166	9/30/98
3.8.8-1	184/166	9/30/98
3.8.8-2	184/166	9/30/98
3.8.9-1	184/166	9/30/98
3.8.9-2	184/166	9/30/98
3.8.10-1	184/166	9/30/98
3.8.10-2	184/166	9/30/98
3.9.1-1	184/166	9/30/98
3.9.2-1	184/166	9/30/98
3.9.3-1	184/166	9/30/98
3.9.3-2	184/166	9/30/98
3.9.4-1	184/166	9/30/98
3.9.4-2	184/166	9/30/98
3.9.5-1	184/166	9/30/98
3.9.5-2	184/166	9/30/98
3.9.6-1	184/166	9/30/98
3.9.6-2	184/166	9/30/98
3.9.7-1	184/166	9/30/98
4.0.1	197/178	11/27/00
4.0.2	197/178	11/27/00
5.1-1	184/166	9/30/98
5.2-1	184/166	9/30/98
5.2-2	184/166	9/30/98
5.2-3	184/166	9/30/98
5.3-1	184/166	9/30/98
5.4-1	184/166	9/30/98

Page Number	Amendment	Revision Date
5.5-1	184/166	9/30/98
5.5-2	184/166	9/30/98
5.5-3	184/166	9/30/98
5.5-4	184/166	9/30/98
5.5-5	190/171	12/21/99
5.5-6	184/166	9/30/98
5.5-7	184/166	9/30/98
5.5-8	184/166	9/30/98
5.5-9	184/166	9/30/98
5.5-10	184/166	9/30/98
5.5-11	184/166	9/30/98
5.5-12	184/166	9/30/98
5.5-13	184/166	9/30/98
5.5-14	196/177	11/2/00
5.5-15	184/166	9/30/98
5.5-16	184/166	9/30/98
5.5-17	184/166	9/30/98
5.5-18	184/166	9/30/98
5.6-1	184/166	9/30/98
5.6-2	184/166	9/30/98
5.6-3	188/169	9/22/99
5.6-4	195/176	9/22/00
5.6-5	184/166	9/30/98
5.7-1	184/166	9/30/98
5.7-2	184/166	9/30/98

BASES

(Revised per section)

i	Revision 0	9/30/98
ii	Revision 0	9/30/98
iii	Revision 0	9/30/98
B 2.1.1	Revision 0	9/30/98
B 2.1.2	Revision 0	9/30/98

Page Number	Amendment	Revision Date
B 3.0	Revision 0	9/30/98
B 3.1.1	Revision 0	9/30/98
B 3.1.2	Revision 10	9/22/00
B 3.1.3	Revision 10	9/22/00
B 3.1.4	Revision 0	9/30/98
B 3.1.5	Revision 0	9/30/98
B 3.1.6	Revision 0	9/30/98
B 3.1.7	Revision 15	01/04/01
B 3.1.8	Revision 0	9/30/98
B 3.2.1	Revision 10	9/22/00
B 3.2.2	Revision 10	9/22/00
B 3.2.3	Revision 0	9/30/98
B 3.2.4	Revision 10	9/22/00
B 3.3.1	Revision 11	9/18/00
B 3.3.2	Revision 11	9/18/00
B 3.3.3	Revision 0	9/30/98
B 3.3.4	Revision 0	9/30/98
B 3.3.5	Revision 11	9/18/00
B 3.3.6	Revision 0	9/30/98
B 3.4.1	Revision 8	3/20/00
B 3.4.2	Revision 0	9/30/98
B 3.4.3	Revision 0	9/30/98
B 3.4.4	Revision 0	9/30/98
B 3.4.5	Revision 0	9/30/98
B 3.4.6	Revision 0	9/30/98
B 3.4.7	Revision 0	9/30/98
B 3.4.8	Revision 0	9/30/98
B 3.4.9	Revision 0	9/30/98
B 3.4.10	Revision 0	9/30/98
B 3.4.11	Revision 0	9/30/98
B 3.4.12	Revision 12	8/23/00
B 3.4.13	Revision 0	9/30/98
B 3.4.14	Revision 0	9/30/98

Page Number	Amendment	Revision Date
B 3.4.15	Revision 0	9/30/98
B 3.4.16	Revision 0	9/30/98
B 3.4.17	Revision 0	9/30/98
B 3.5.1	Revision 10	9/22/00
B 3.5.2	Revision 10	9/22/00
B 3.5.3	Revision 0	9/30/98
B 3.5.4	Revision 0	9/30/98
B 3.5.5	Revision 0	9/30/98
B 3.6.1	Revision 0	9/30/98
B 3.6.2	Revision 17	10/08/01
B 3.6.3	Revision 0	9/30/98
B 3.6.4	Revision 0	9/30/98
B 3.6.5	Revision 0	9/30/98
B 3.6.6	Revision 0	9/30/98
B 3.6.7	Revision 0	9/30/98
B 3.6.8	Revision 0	9/30/98
B 3.6.9	Revision 0	9/30/98
B 3.6.10	Revision 0	9/30/98
B 3.6.11	Revision 0	9/30/98
B 3.6.12	Revision 0	9/30/98
B 3.6.13	Revision 0	9/30/98
B 3.6.14	Revision 0	9/30/98
B 3.6.15	Revision 0	9/30/98
B 3.6.16	Revision 0	9/30/98
B 3.7.1	Revision 0	9/30/98
B 3.7.2	Revision 0	9/30/98
B 3.7.3	Revision 0	9/30/98
B 3.7.4	Revision 0	9/30/98
B 3.7.5	Revision 0	9/30/98
B 3.7.6	Revision 0	9/30/98
B 3.7.7	Revision 0	9/30/98
B 3.7.8	Revision 0	9/30/98
B 3.7.9	Revision 0	9/30/98

Page Number	Amendment	Revision Date
B 3.7.10	Revision 0	9/30/98
B 3.7.11	Revision 0	9/30/98
B 3.7.12	Revision 6	10/6/99
B 3.7.13	Revision 0	9/30/98
B 3.7.14	Revision 14	11/27/00
B 3.7.15	Revision 14	11/27/00
B 3.7.16	Revision 0	9/30/98
B 3.8.1	Revision 13	1/18/01
B 3.8.2	Revision 0	9/30/98
B 3.8.3	Revision 0	9/30/98
B 3.8.4	Revision 0	9/30/98
B 3.8.5	Revision 0	9/30/98
B 3.8.6	Revision 0	9/30/98
B 3.8.7	Revision 0	9/30/98
B 3.8.8	Revision 0	9/30/98
B 3.8.9	Revision 0	9/30/98
B 3.8.10	Revision 0	9/30/98
B 3.9.1	Revision 0	9/30/98
B 3.9.2	Revision 0	9/30/98
B 3.9.3	Revision 0	9/30/98
B 3.9.4	Revision 0	9/30/98
B 3.9.5	Revision 0	9/30/98
B 3.9.6	Revision 0	9/30/98
B 3.9.7	Revision 0	9/30/98

ATTACHMENT 2

REVISED TECHNICAL SPECIFICATION BASES 3.6.2

B 3.6 CONTAINMENT SYSTEMS

B 3.6.2 Containment Air Locks

BASES

BACKGROUND

Containment air locks form part of the containment pressure boundary and provide a means for personnel access during all MODES of operation.

Each air lock is nominally a right circular cylinder, 10 ft in diameter, with a door at each end. The doors are interlocked to prevent simultaneous opening. During periods when containment is not required to be OPERABLE, the door interlock mechanism may be disabled, allowing both doors of an air lock to remain open for extended periods when frequent containment entry is necessary. Each air lock door has been designed and tested to certify its ability to withstand a pressure in excess of the maximum expected pressure following a Design Basis Accident (DBA) in containment. As such, closure of a single door supports containment OPERABILITY. Each of the doors contains double inflatable seals and local leakage rate testing capability to ensure pressure integrity.

Each personnel air lock is provided with limit switches on both doors that provide control room indication of door position. Additionally, control room indication is provided to alert the operator whenever an air lock door interlock mechanism is defeated.

The containment air locks form part of the containment pressure boundary. As such, air lock integrity and leak tightness is essential for maintaining the containment leakage rate within limit in the event of a DBA. Not maintaining air lock integrity or leak tightness may result in a leakage rate in excess of that assumed in the unit safety analyses.

APPLICABLE SAFETY ANALYSES

The DBAs that result in a release of radioactive material within containment are a loss of coolant accident and a rod ejection accident (Ref. 2). In the analysis of each of these accidents, it is assumed that containment is OPERABLE such that release of fission products to the environment is controlled by the rate of containment leakage. The containment was designed with an allowable leakage rate of 0.3% of containment air weight per day (Ref. 2). This leakage rate is

BASES

APPLICABLE SAFETY ANALYSES (continued)

defined in 10 CFR 50, Appendix J (Ref. 1), as $L_a = 0.30\%$ of containment air weight per day, the maximum allowable containment leakage rate at the calculated peak containment internal pressure $P_a = 14.8$ psig following a DBA. This allowable leakage rate forms the basis for the acceptance criteria imposed on the SRs associated with the air locks.

The containment air locks satisfy Criterion 3 of 10 CFR 50.36 (Ref. 3).

LCO

Each containment air lock forms part of the containment pressure boundary. As part of the containment pressure boundary, the air lock safety function is related to control of the containment leakage rate resulting from a DBA. Thus, each air lock's structural integrity and leak tightness are essential to the successful mitigation of such an event.

Each air lock is required to be OPERABLE. For the air lock to be considered OPERABLE, the air lock interlock mechanism must be OPERABLE, the air lock must be in compliance with the Type B air lock leakage test, and both air lock doors must be OPERABLE. The interlock allows only one air lock door of an air lock to be opened at one time. This provision ensures that a gross breach of containment does not exist when containment is required to be OPERABLE. Closure of a single door in each air lock is sufficient to provide a leak tight barrier following postulated events. Nevertheless, both doors are kept closed when the air lock is not being used for normal entry into or exit from containment.

APPLICABILITY

In MODES 1, 2, 3, and 4, a DBA could cause a release of radioactive material to containment. In MODES 5 and 6, the probability and consequences of these events are reduced due to the pressure and temperature limitations of these MODES. Therefore, the containment air locks are not required in MODE 5 to prevent leakage of radioactive material from containment. The requirements for the containment air locks during MODE 6 are addressed in LCO 3.9.4, "Containment Penetrations."

ACTIONS

The ACTIONS are modified by a Note that allows entry and exit to perform repairs on the affected air lock component. If the outer door is inoperable, then it may be easily accessed for most repairs. It is preferred that the air lock be accessed from inside primary containment by entering through the other OPERABLE air lock. However, if this is not practicable, or if repairs on either door must be performed from the barrel

BASES

ACTIONS (continued)

side of the door then it is permissible to enter the air lock through the OPERABLE door, which means there is a short time during which the containment boundary is not intact (during access through the OPERABLE door). The ability to open the OPERABLE door, even if it means the containment boundary is temporarily not intact, is acceptable due to the low probability of an event that could pressurize the containment during the short time in which the OPERABLE door is expected to be open. After each entry and exit, the OPERABLE door must be immediately closed. If ALARA conditions permit, entry and exit should be via an OPERABLE air lock.

A second Note has been added to provide clarification that, for this LCO, separate Condition entry is allowed for each air lock. This is acceptable, since the Required Actions for each Condition provide appropriate compensatory actions for each inoperable air lock. Complying with the Required Actions may allow for continued operation, and a subsequent inoperable air lock is governed by subsequent Condition entry and application of associated Required Actions.

In the event the air lock leakage results in exceeding the overall containment leakage rate, Note 3 directs entry into the applicable Conditions and Required Actions of LCO 3.6.1, "Containment."

A.1, A.2, and A.3

With one air lock door in one or more containment air locks inoperable, the OPERABLE door must be verified closed (Required Action A.1) in each affected containment air lock. This ensures that a leak tight containment barrier is maintained by the use of an OPERABLE air lock door. This action must be completed within 1 hour. This specified time period is consistent with the ACTIONS of LCO 3.6.1, which requires containment be restored to OPERABLE status within 1 hour.

Note that for the purpose of Required Action A.1, A.2, and A.3, the bulkhead associated with an air lock door is considered to be part of the door. For example, an air lock door may be declared inoperable if the equalizing valve becomes inoperable or if it is replaced. It is appropriate to treat the associated bulkhead as part of the door because a leak path through the bulkhead is no different than a leak path past the door seals. The remaining OPERABLE door/bulkhead provides the necessary barrier between the containment atmosphere and the environs.

BASES

ACTIONS (continued)

In addition, the affected air lock penetration must be isolated by locking closed the OPERABLE air lock door within the 24 hour Completion Time. The 24 hour Completion Time is reasonable for locking the OPERABLE air lock door, considering the OPERABLE door of the affected air lock is being maintained closed.

Required Action A.3 verifies that an air lock with an inoperable door has been isolated by the use of a locked and closed OPERABLE air lock door. This ensures that an acceptable containment leakage boundary is maintained. The Completion Time of once per 31 days is based on engineering judgment and is considered adequate in view of the low likelihood of a locked door being mispositioned and other administrative controls. Required Action A.3 is modified by a Note that applies to air lock doors located in high radiation areas and allows these doors to be verified locked closed by use of administrative means. Allowing verification by administrative means is considered acceptable, since access to these areas is typically restricted. Therefore, the probability of misalignment of the door, once it has been verified to be in the proper position, is small.

The Required Actions have been modified by two Notes. Note 1 ensures that only the Required Actions and associated Completion Times of Condition C are required if both doors in the same air lock are inoperable. With both doors in the same air lock inoperable, an OPERABLE door is not available to be closed. Required Actions C.1 and C.2 are the appropriate remedial actions. The exception of Note 1 does not affect tracking the Completion Time from the initial entry into Condition A; only the requirement to comply with the Required Actions. Note 2 allows use of the air lock for entry and exit for 7 days under administrative controls if both air locks have an inoperable door. This 7 day restriction begins when the second air lock is discovered inoperable. Containment entry may be required on a periodic basis to perform Technical Specifications (TS) Surveillances and Required Actions, as well as other activities on equipment inside containment that are required by TS or activities on equipment that support TS-required equipment. This Note is not intended to preclude performing other activities (i.e., non-TS-required activities) if the containment is entered, using the inoperable air lock, to perform an allowed activity listed above. This allowance is acceptable due to the low probability of an event that could pressurize the containment during the short time that the OPERABLE door is expected to be open.

BASES

ACTIONS (continued)

B.1, B.2, and B.3

With an air lock interlock mechanism inoperable in one or more air locks, the Required Actions and associated Completion Times are consistent with those specified in Condition A.

The Required Actions have been modified by two Notes. Note 1 ensures that only the Required Actions and associated Completion Times of Condition C are required if both doors in the same air lock are inoperable. With both doors in the same air lock inoperable, an OPERABLE door is not available to be closed. Required Actions C.1 and C.2 are the appropriate remedial actions. Note 2 allows entry into and exit from containment under the control of a dedicated individual stationed at the air lock to ensure that only one door is opened at a time (i.e., the individual performs the function of the interlock).

Required Action B.3 is modified by a Note that applies to air lock doors located in high radiation areas and allows these doors to be verified locked closed by use of administrative means. Allowing verification by administrative means is considered acceptable, since access to these areas is typically restricted. Therefore, the probability of misalignment of the door, once it has been verified to be in the proper position, is small.

With one or more air locks inoperable for reasons other than those described in Condition A or B, Required Action C.1 requires action to be initiated immediately to evaluate previous combined leakage rates using current air lock test results. An evaluation is acceptable, since it is overly conservative to immediately declare the containment inoperable if both doors in an air lock have failed a seal test or if the overall air lock leakage is not within limits. In many instances (e.g., only one seal per door has failed), containment remains OPERABLE, yet only 1 hour (per LCO 3.6.1) would be provided to restore the air lock door to OPERABLE status prior to requiring a plant shutdown. In addition, even with both doors failing the seal test, the overall containment leakage rate can still be within limits.

Required Action C.2 requires that one door in the affected containment air lock must be verified to be closed within the 1 hour Completion Time. This specified time period is consistent with the ACTIONS of LCO 3.6.1, which requires that containment be restored to OPERABLE status within 1 hour.

Additionally, the affected air lock(s) must be restored to OPERABLE status within the 24 hour Completion Time. The specified time period is considered reasonable for restoring an inoperable air lock to OPERABLE)

BASES

ACTIONS (continued)

status, assuming that at least one door is maintained closed in each affected air lock.

D.1 and D.2

If the inoperable containment air lock cannot be restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 6 hours and to MODE 5 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

SURVEILLANCE REQUIREMENTS

SR 3.6.2.1

Maintaining containment air locks OPERABLE requires compliance with the leakage rate test requirements of 10 CFR 50, Appendix J, Option A (Ref. 1), as modified by approved exemptions. This SR reflects the leakage rate testing requirements with regard to air lock leakage (Type B leakage tests). The acceptance criteria were established during initial air lock and containment OPERABILITY testing. The periodic testing requirements verify that the air lock leakage does not exceed the allowed fraction of the overall containment leakage rate. The Frequency is required by Appendix J, Option A (Ref. 1), as modified by approved exemptions. Thus, SR 3.0.2 (which allows Frequency extensions) does not apply.

The frequency required by 10 CFR 50 Appendix J, Option A, includes leak testing each door seal within 72 hours of closing or every 72 hours when entries are being made more frequently. The seal annulus leakage must be $< 0.01 L_a$ as determined by precision flow measurements when measured for at least 30 seconds with the pressure between the seals $\geq P_a$. Overall airlock leakage tests are conducted at P_a every 6 months. The overall air lock leakage rate must also be verified prior to establishing containment OPERABILITY. If the periodic 6-month test required Appendix J, Option A, is current, the seal leakage test may be substituted for the full pressure test provided no maintenance has been performed on an air lock. Whenever maintenance has been performed on an air lock, the requirements of paragraph III.D.2(b)(ii) of Appendix J, Option A must still be met. This is an exemption from 10 CFR 50, Appendix J, Option A.

BASES

SURVEILLANCE REQUIREMENTS (continued)

The SR has been modified by two Notes. Note 1 states that an inoperable air lock door does not invalidate the previous successful performance of the overall air lock leakage test. This is considered reasonable since either air lock door is capable of providing a fission product barrier in the event of a DBA. Note 2 has been added to this SR requiring the results to be evaluated against the acceptance criteria of SR 3.6.1.2. This ensures that air lock leakage is properly accounted for in determining the combined Type B and C containment leakage rate.

SR 3.6.2.2

Door seals must be tested every 6 months to verify the integrity of the inflatable door seal. The measured leakage rate must be less than 15 standard cubic centimeters per minute (sccm) per door seal when the seal is inflated to approximately 85 psig. This ensures that the seals will remain inflated for at least 7 days should the instrument air supply to the seals be lost. The Frequency of testing is consistent with the overall airlock leakage tests required every 6 months by 10 CFR 50, Appendix J, Option A (Ref. 1).

SR 3.6.2.3

The air lock interlock is designed to prevent simultaneous opening of both doors in a single air lock. Since both the inner and outer doors of an air lock are designed to withstand the maximum expected post accident containment pressure, closure of either door will support containment OPERABILITY. Thus, the door interlock feature supports containment OPERABILITY while the air lock is being used for personnel transit in and out of the containment. Periodic testing of this interlock demonstrates that the interlock will function as designed and that simultaneous opening of the inner and outer doors will not inadvertently occur. Due to the purely mechanical nature of this interlock, and given that the interlock mechanism is not normally challenged when the containment air lock door is used for entry and exit (procedures require strict adherence to single door opening), this test is only required to be performed every 18 months. The 18 month Frequency is based on the need to perform this surveillance under the conditions that apply during a plant outage, and the potential for loss of containment OPERABILITY if the surveillance were performed with the reactor at power. The 18 month Frequency for the interlock is justified based on generic operating experience. The Frequency is based on engineering judgment and is considered adequate given that the interlock is not challenged during the use of the interlock.

BASES

REFERENCES

1. 10 CFR 50, Appendix J.
2. UFSAR, Section 6.2.
3. 10 CFR 50.36, Technical Specifications, (c)(2)(ii).