

3/4.9 REFUELING OPERATIONS

BASES

3/4.9.1 REACTOR MODE SWITCH

Locking the OPERABLE reactor mode switch in the Shutdown or Refuel position, as specified, ensures that the restrictions on control rod withdrawal and refueling platform movement during the refueling operations are properly activated. These conditions reinforce the refueling procedures and reduce the probability of inadvertent criticality, damage to reactor internals or fuel assemblies, and exposure of personnel to excessive radiation.

3/4.9.2 INSTRUMENTATION

The OPERABILITY of at least two source range monitors ensures that redundant monitoring capability is available to detect changes in the reactivity condition of the core. The flux need not be monitored for the first sixteen bundles loaded before a SPIRAL RELOAD or for the last sixteen bundles unloaded during a SPIRAL UNLOAD. In the case of the SPIRAL RELOAD, the sixteen bundles loaded may be different from the bundles scheduled to occupy the bundle locations for the next cycle provided; (i) the cold reactivity of any unscheduled bundle temporarily loaded is individually less than the cold reactivity of the respective bundle scheduled for the subject location, (ii) the uncontrolled k-infinity of the lattice is less than 1.31, and (iii) the bundles are arranged in four two-by-two arrays surrounding an SRM with each array having a minimum of 12 inches between it and an adjacent array.

3/4.9.3 CONTROL ROD POSITION

The requirement that all control rods be inserted during other CORE ALTERATIONS minimizes the possibility that fuel will be loaded into a cell without a control rod, although one rod may be withdrawn under control of the reactor mode switch refuel position one-rod-out-interlock.

3/4.9.4 DELETED

3/4.9.5 DELETED

REFUELING OPERATIONS

BASES

3/4.9.6 DELETED

3/4.9.7 DELETED

3/4.9.8 and 3/4.9.9 WATER LEVEL - REACTOR VESSEL and WATER LEVEL - SPENT FUEL STORAGE POOL

The restrictions on minimum water level ensure that sufficient water depth is available to remove 99% of the assumed 10% iodine gas activity released from the rupture of an irradiated fuel assembly. This minimum water depth is consistent with the assumptions of the accident analysis.

3/4.9.10 CONTROL ROD REMOVAL

These specifications ensure that maintenance or repair of control rods or control rod drives will be performed under conditions that limit the probability of inadvertent criticality. The requirements for simultaneous removal of more than one control rod are more stringent since the SHUTDOWN MARGIN specification provides for the core to remain subcritical with only one control rod fully withdrawn.

3/4.9.11 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION

The requirement that at least one residual heat removal loop be OPERABLE or that an alternate method capable of decay heat removal be demonstrated and that an alternate method of coolant mixing be in operation ensures that (1) sufficient cooling capacity is available to remove decay heat and maintain the water in the reactor pressure vessel below 140°F as required during REFUELING, and (2) sufficient coolant circulation would be available through the reactor core to assure accurate temperature indication and to distribute and prevent stratification of the poison in the event it becomes necessary to actuate the standby liquid control system.

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
Motor Operated Valve Thermal Overload Protection (Not Bypassed).....	3/4 8-38
Table 3.8.4.3-1 Motor Operated Valves-Thermal Overload Protection (Not Bypassed).....	3/4 8-39
Reactor Protection System Electric Power Monitoring.....	3/4 8-40
Class 1E Isolation Breaker Overcurrent Protection Devices (Breaker Tripped by LOCA Signal).....	3/4 8-41
Table 3.8.4.5-1 Class 1E Isolation Breaker Overcurrent Protective Devices (Breaker Tripped by a LOCA Signal).....	3/4 8-42
Power Range Neutron Monitoring System Electric Power Monitoring.....	3/4 8-44
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1 REACTOR MODE SWITCH.....	3/4 9-1
3/4.9.2 INSTRUMENTATION.....	3/4 9-3
3/4.9.3 CONTROL ROD POSITION.....	3/4 9-5
3/4.9.4 DELETED.....	3/4 9-6
3/4.9.5 DELETED.....	3/4 9-7
3/4.9.6 DELETED.....	3/4 9-8
3/4.9.7 DELETED.....	3/4 9-10
3/4.9.8 WATER LEVEL - REACTOR VESSEL.....	3/4 9-11
3/4.9.9 WATER LEVEL - SPENT FUEL STORAGE POOL.....	3/4 9-12
3/4.9.10 CONTROL ROD REMOVAL	
Single Control Rod Removal.....	3/4 9-13
Multiple Control Rod Removal.....	3/4 9-15

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 SERVICE WATER SYSTEMS.....	B 3/4 7-1
3/4.7.2 CONTROL ROOM EMERGENCY FILTRATION SYSTEM.....	B 3/4 7-1
3/4.7.3 FLOOD PROTECTION.....	B 3/4 7-1
3/4.7.4 REACTOR CORE ISOLATION COOLING SYSTEM.....	B 3/4 7-1a
3/4.7.5 SNUBBERS.....	B 3/4 7-2
3/4.7.6 SEALED SOURCE CONTAMINATION.....	B 3/4 7-4
3/4.7.7 MAIN TURBINE BYPASS SYSTEM.....	B 3/4 7-4
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1, 3/4.8.2 and 3/4.8.3 A.C. SOURCES, D.C. SOURCES and ONSITE POWER DISTRIBUTION SYSTEMS.....	B 3/4 8-1
3/4.8.4 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES.....	B 3/4 8-3
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1 REACTOR MODE SWITCH.....	B 3/4 9-1
3/4.9.2 INSTRUMENTATION.....	B 3/4 9-1
3/4.9.3 CONTROL ROD POSITION.....	B 3/4 9-1
3/4.9.4 DELETED.....	B 3/4 9-1
3/4.9.5 DELETED.....	B 3/4 9-1
3/4.9.6 DELETED.....	B 3/4 9-2
3/4.9.7 DELETED.....	B 3/4 9-2
3/4.9.8 and 3/4.9.9 WATER LEVEL - REACTOR VESSEL and WATER LEVEL - SPENT FUEL STORAGE POOL.....	B 3/4 9-2
3/4.9.10 CONTROL ROD REMOVAL.....	B 3/4 9-2
3/4.9.11 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION....	B 3/4 9-2

REFUELING OPERATIONS

3/4.9.4 DELETED

REFUELING OPERATIONS

3/4.9.5 DELETED

REFUELING OPERATIONS

3/4.9.6 DELETED

REFUELING OPERATIONS

3/4.9.7 DELETED