

February 8, 2002

Mr. Michael Kansler
Senior Vice President and
Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 - REQUEST FOR
ADDITIONAL INFORMATION RE: PROPOSED TECHNICAL SPECIFICATION
AMENDMENT FOR LABORATORY TESTING OF NUCLEAR-GRADE
CHARCOAL (TAC NO. MB3329)

Dear Mr. Kansler:

In a letter dated November 29, 1999, Entergy Nuclear Operations, Inc. (ENO) submitted a proposed change to the Technical Specifications (TSs) for the Indian Point Nuclear Generating Unit No. 3 (IP3). Specifically, ENO requested a change to TS 5.5.10, "Ventilation Filter Testing Program," to adopt the criteria of the American Society for Testing and Materials (ASTM) Standard D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," in accordance with the guidance of Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Carbon." In a letter dated September 20, 2000, the U.S. Nuclear Regulatory Commission (NRC) staff requested additional information regarding the proposed changes. Based on the concerns raised in the request for additional information (RAI), ENO withdrew its November 29, 1999, application and submitted a revised request for amendment on October 23, 2001.

The NRC staff has reviewed the information in the October 23, 2001, application. On December 11, 2001, the staff held a telephone conference call with representatives of your staff to obtain additional clarification regarding the application. On the basis of the information discussed during the conference call, the NRC staff determined that ENO needs to provide additional information as detailed in the enclosed RAI. On February 4, 2002, the ENO staff indicated that a response would be provided within 60 days.

Sincerely,

/RAI/

Patrick D. Milano, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure: RAI

cc w/encl: See next page

Indian Point Nuclear Generating Unit No. 3

cc:

Mr. Jerry Yelverton
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

Mr. Robert J. Barrett
Vice President - Operations
Entergy Nuclear Operations, Inc.
Indian Point Nuclear Generating Unit 3
295 Broadway, Suite 3
P. O. Box 308
Buchanan, NY 10511-0308

Mr. Dan Pace
Vice President Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Knubel
Vice President Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Joseph DeRoy
General Manager Operations
Entergy Nuclear Operations, Inc.
Indian Point Nuclear Generating Unit 3
295 Broadway, Suite 3
P. O. Box 308
Buchanan, NY 10511-0308

Mr. John Kelly
Director - Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene Fiason
Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Harry P. Salmon, Jr.
Director of Oversight

Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Comiotes
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Indian Point Nuclear Generating Unit 3
295 Broadway, Suite 3
P.O. Box 308
Buchanan, NY 10511-0308

Mr. John Donnelly
Licensing Manager
Entergy Nuclear Operations, Inc.
Indian Point Nuclear Generating Unit 3
295 Broadway, Suite 3
P.O. Box 308
Buchanan, NY 10511-0308

Mr. John McCann
Manager, Licensing and Regulatory Affairs
Entergy Nuclear Operations, Inc.
Indian Point Nuclear Generating Unit 2
295 Broadway, Suite 1
P. O. Box 249
Buchanan, NY 10511-0249

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
295 Broadway, Suite 3
P.O. Box 337
Buchanan, NY 10511-0337

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. John M. Fulton
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601
Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue

Indian Point Nuclear Generating Unit No. 3

cc:

Mail Stop: L-ENT-15E
New Orleans, LA 70113

Mr. William M. Flynn, President
New York State Energy, Research, and
Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mr. J. Spath, Program Director
New York State Energy, Research, and
Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mr. Paul Eddy
Electric Division
New York State Department
of Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Ray Albanese
Executive Chair
Four County Nuclear Safety Committee
Westchester County Fire Training Center
4 Dana Road
Valhalla, NY 10592

Mr. Ronald Schwartz
SRC Consultant
64 Walnut Drive
Spring Lake Heights, NJ 07762

Mr. Ronald J. Toole
SRC Consultant
Toole Insight
605 West Horner Street
Ebensburg, PA 15931

Mr. Charles W. Hehl
SRC Consultant
Charles Hehl, Inc.
1486 Matthew Lane
Pottstown, PA 19465

Mr. Ronald Schwartz
SRC Consultant
64 Walnut Drive
Spring Lake Heights, NJ 07762

Mr. Ronald J. Toole
SRC Consultant
Toole Insight
605 West Horner Street
Ebensburg, PA 15931

Mr. Charles W. Hehl
SRC Consultant
Charles Hehl, Inc.
1486 Matthew Lane
Pottstown, PA 19465

Mr. Alex Matthiessen
Executive Director
Riverkeeper, Inc.
25 Wing & Wing
Garrison, NY 10524

Mr. Paul Leventhal
The Nuclear Control Institute
1000 Connecticut Avenue NW
Suite 410
Washington, DC, 20036

Indian Point Nuclear Generating Unit No. 3

cc:

Mr. Karl Copeland
Pace Environmental Litigation Clinic
78 No. Broadway
White Plains, NY 10603

February 8, 2002

Mr. Michael R. Kansler
Senior Vice President and
Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 - REQUEST FOR
ADDITIONAL INFORMATION RE: PROPOSED TECHNICAL SPECIFICATION
AMENDMENT FOR LABORATORY TESTING OF NUCLEAR-GRADE
CHARCOAL (TAC NO. MB3329)

Dear Mr. Kansler:

In a letter dated November 29, 1999, Entergy Nuclear Operations, Inc. (ENO) submitted a proposed change to the Technical Specifications (TSs) for the Indian Point Nuclear Generating Unit No. 3 (IP3). Specifically, ENO requested a change to TS 5.5.10, "Ventilation Filter Testing Program," to adopt the criteria of the American Society for Testing and Materials (ASTM) Standard D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," in accordance with the guidance of Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Carbon." In a letter dated September 20, 2000, the U.S. Nuclear Regulatory Commission (NRC) staff requested additional information regarding the proposed changes. Based on the concerns raised in the request for additional information (RAI), ENO withdrew its November 29, 1999, application and submitted a revised request for amendment on October 23, 2001.

The NRC staff has reviewed the information in the October 23, 2001, application. On December 11, 2001, the staff held a telephone conference call with representatives of your staff to obtain additional clarification regarding the application. On the basis of the information discussed during the conference call, the NRC staff determined that ENO needs to provide additional information as detailed in the enclosed RAI. On February 4, 2002, the ENO staff indicated that a response would be provided within 60 days.

Sincerely,

/RA/

Patrick D. Milano, Sr. Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDI-1 R/F J. Munday S. Little P. Milano OGC
ACRS B. Platchek, RI

Accession Number: ML020250149

OFFICE	PDI-1\PM	PDI-1\LA	DSSA\SPLB\SC	DSSA\SPLB	PDI-1\ASC
NAME	PMilano	SLittle	HWalker	JHRaval	PTam for JMunday
DATE	2/6/02	2/6/02	2/6/2002	2/6/2002	2/8/02

OFFICIAL RECORD COPY

INDIAN POINT NUCLEAR GENERATING UNIT NO. 3

REQUEST FOR ADDITIONAL INFORMATION

PROPOSED TECHNICAL SPECIFICATION AMENDMENT FOR LABORATORY TESTING OF
NUCLEAR-GRADE CHARCOAL FOR NRC GENERIC LETTER 99-02

By letter dated November 29, 1999, Entergy Nuclear Operations, Inc. (ENO) submitted a Technical Specification (TS) amendment request in accordance with the guidance of Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-Grade Activated Charcoal," dated June 3, 1999. In a letter dated September 20, 2000, the NRC staff submitted a request for additional information (RAI) regarding Entergy's request. By letter dated October 23, 2001, Entergy submitted a revised TS amendment request to revise Section 5.5.10 of Appendix A to the Indian Point 3 (IP3) TS and withdrew the amendment request dated November 29, 1999. The following RAI is based on our review of Entergy's submittal dated October 23, 2001, and a followup telephone conference between the NRC staff and Entergy:

The following questions refer to Containment Fan Cooler Units (CFCU) and the Control Room Air Filtration System (CRAFS), unless otherwise noted:

1. TS 5.5.10, "Ventilation Filter Testing Program," for the CFCUs requires that a laboratory test of a sample of the charcoal adsorber shows methyl iodide removal efficiency of 85% when tested in accordance with American Society for Testing and Materials (ASTM) D3803-89, at a temperature of 86 °F and a relative humidity of 95%. On page 5 of 10 of Attachment II to the October 23, 2001, submittal, ENO states that, "The TS efficiency of 85% (equivalent to 15% penetration) provides a factor of safety (penetration assumed in analysis divided by penetration acceptance criteria) of 2 without considering the 1% allowable bypass." The staff finds that, in reality, the total penetration is 16% (15% penetration as laboratory tested and 1% bypass) for the CFCUs which will result in a safety factor of 1.875. The NRC staff guidance in GL 99-02 specifies a safety factor of 2. Clarify the discrepancy.
2. On page 4 of 10 of Attachment II to the October 23 submittal, ENO stated that "The Indian Point 3 CRVS [control room ventilation system] has two filters (Reference 6) with each having a 1" bed depth that was designed with a residence time of 0.075 seconds at 1,000 cfm. This equates to a face velocity of 66.7 ft/min... (Reference 3)". However, (a) Item 2 on page 2 of 3, (b) tabulated items for the CRVS in Attachments I and III on Page 5.0-24, and (c) Item 3.b in Attachment II on page 1 of 10 identified a face velocity of 50 ft/min for 1-inch deep charcoal beds for the CRVS filters. Clarify the discrepancy with respect to the design face velocity and the face velocity used during laboratory testing of a sample of charcoal adsorber, and provide an explanation and justification as to how this condition meets the guidance of GL 99-02.
3. On page 4 of 10, Paragraphs 3, 4, and 5, of Attachment II, to your submittal dated October 23, 2001, you stated that "The current TS for CRAFS requires that impregnated

Enclosure

charcoal shall have a methyl iodide removal efficiency $\geq 90\%$ at $\pm 20\%$ of the accident design flow rate... The proposed TS increases the methyl iodide removal efficiency to $\geq 91\%$... The 1% increase in the required efficiency is to reflect the allowable value of 1% for bypass leakage... The TS efficiency of 91% provides a factor of safety of 1 and 1% allowable for bypass. Dose analyses assumed a methyl iodide removal efficiency of 90% for the charcoal filter.” The total penetration is 9% including 1% bypass which results in a safety factor of 1.11.

Provide a discussion explaining how this situation meets the guidance of GL 99-02. On the basis of the above, it is not clear whether adequate protection will be afforded to the operators in the event of a design-basis accident.