

January 24, 2002

MEMORANDUM TO: Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

FROM: Ashok C. Thadani, Director **/RA/ by Roy Zimmerman**
Office of Nuclear Regulatory Research

SUBJECT: GENERIC ISSUE 192: SECONDARY CONTAINMENT DRAWDOWN
TIME

The Office of Nuclear Regulatory Research (RES) has reviewed the information on the proposed generic issue submitted in your December 3, 2001, memorandum. The issue addresses the concern for the adequacy of the calculations, testing, and acceptance criteria associated with the creation of a vacuum in the reactor building of a BWR, following an engineered safeguards actuation signal. RES has concluded that adequate information has been provided for a technical screening of the issue to begin, in accordance with the guidelines outlined in Management Directive 6.4, "Generic Issues Program." Accordingly, the issue has been assigned the number 192 for tracking purposes.

The RES screening may require estimating: (1) the safety benefit of the issue, and (2) the cost of developing and implementing a solution. RES will need to consult with the NRR contact, R. Lobel, on an ongoing basis in the collection and explanation of the information generated so far on the subject. It is expected that our screening will be completed by the end of June 2002. All questions on the status of the GSI should be directed to Ronald C. Emrit, 415-6447.

cc: B. Sheron, NRR
G. Holahan
J. Hannon
R. Lobel

January 24, 2002

MEMORANDUM TO: Samuel J. Collins, Director
Office of Nuclear Reactor Regulation

FROM: Ashok C. Thadani, Director /S/ Roy Zimmerman
Office of Nuclear Regulatory Research

SUBJECT: GENERIC ISSUE 192: SECONDARY CONTAINMENT DRAWDOWN
TIME

The Office of Nuclear Regulatory Research (RES) has reviewed the information on the proposed generic issue submitted in your December 3, 2001, memorandum. The issue addresses the concern for the adequacy of the calculations, testing, and acceptance criteria associated with the creation of a vacuum in the reactor building of a BWR, following an engineered safeguards actuation signal. RES has concluded that adequate information has been provided for a technical screening of the issue to begin, in accordance with the guidelines outlined in Management Directive 6.4, "Generic Issues Program." Accordingly, the issue has been assigned the number 192 for tracking purposes.

The RES screening may require estimating: (1) the safety benefit of the issue, and (2) the cost of developing and implementing a solution. RES will need to consult with the NRR contact, R. Lobel, on an ongoing basis in the collection and explanation of the information generated so far on the subject. It is expected that our screening will be completed by the end of June 2002. All questions on the status of the GSI should be directed to Ronald C. Emrit, 415-6447.

cc: B. Sheron, NRR
G. Holahan
J. Hannon
R. Lobel

Distribution:
REAHFB R/F
DSARE R/F
SNesmith
RES-2001268
PNorian

C:\Program Files\Adobe\Acrobat 4.0\PDF Output\GSI192.wpd

*See previous concurrence

OAR in ADAMS? (Y or N) Y ADAMS ACCESSION NO.: MI 020250413 TEMPLATE NO. RES-006

Publicly Available? (Y or N) Y DATE OF RELEASE TO PUBLIC 01/29/2 SENSITIVE? NO

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure

"N" = No copy

OFFICE	REAHFB	C	REAHFB	C	C:REAHFB	C	D:DSARE	C	DD:RES		D:RES	
NAME	REmrit:ecm		HVandermolen		Jflack by JIbarra		FEltawila		RZimmerman		AThadani	
DATE	01/16/02*		01/18/02*		01/22/02*		01/22/02*		01/24/02*		01/24/02*	

OFFICIAL RECORD COPY - RES File Code 2D3