


INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED
AREA WAS FOR COLORIZING THE
LINE CLASS CODES (REF. DCN 4)

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED
AREA WAS FOR COLORIZING THE
LINE CLASS CODES (REF. DCN 4)



- BSIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

NOTES:

- DELETED
- FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE 15102-029C-4
- FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING W-001.
- UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED
AREA WAS FOR COLORIZING THE
LINE CLASS CODES (REF. DCN 4)

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED
AREA WAS FOR COLORIZING THE
LINE CLASS CODES (REF. DCN 4)

1	INC. DCN 15102-029C-3 PER DCR 99-0042 AND DCN 15102-029C-4 PER DCR 00-1766	SDW			
2	INC. DCN 15102-029C-2 PER DCR 97-1047		INITIALS ON FILE		
3	INC. DCN 15102-029C-1 FOR DCR 91-0011		INITIALS ON FILE		
4	ISSUED FOR SECOND 10 YEAR ISI PROGRAM		LPM	TWS	MGP ECC
REV.	DATE	REVISION	BY	CHKD.	APPD.
SCALE N.T.S.	DESIGNED	DRWN	CB	DATE	
DAVIS-BESSE NUCLEAR POWER STATION					
UNIT NO. 1					
THE TOLSON DESIGN COMPANY					
INSERVICE INSPECTION DIAGRAM					
CONTAINMENT AND PENETRATION ROOMS					
SHEET 2					
DRWING NO.	REV.				
15102-029C	3				

D-15

I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE MANNER AND BY THE PERSONS OR PERSONS AS THE TITLE SET FORTH BELOW AND THAT THE IMAGE IS A TRUE AND ACCURATE REPRESENTATION OF THE SUBJECT MATTER.

DATE: 5/2/99 OPERATOR: D. W. W. 30X