



- IS1M2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

- NOTES:**
- DELETED
  - FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE IS1D2-001.
  - FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
  - UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 1/4" AND DRAIN CONNECTIONS ARE 1/2". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
  - AN 1/4" THICK BLANK PLATE HAS BEEN INSERTED BETWEEN THESE FLANGES PER MOD 98-0050-00.

D-29

6	INC DCM IS1D2-036C-6 PER FPR 95-0267-901	'INITIALS ON FILE'
7	INC DCM IS1D2-036C-7 PER MOD 95-2486	'INITIALS ON FILE'
8	INC DCM IS1D2-036C-8 PER MOD 00-1766	SBW
9	INC DCM IS1D2-036C-9 PER MOD 98-0050 SUP. 00	'INITIALS ON FILE'
10	INC DCM IS1D2-036C-10 B 11 PER MOD 97-0009 SUP. 01	'INITIALS ON FILE'
11	INC DCM IS1D2-036C-11 PER MOD 97-0009	'INITIALS ON FILE'
12	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	DJR TMB MCP ECC

NO.	DATE	REVISIONS	BY	CHK'D	EXP.	SUP.	APP.	REV.
1								

DESIGNED BY: M.T.S. CHECKED BY: CB DATE: 10-10-90

**DAVIS-BESSE NUCLEAR POWER STATION  
UNIT NO. 1**

INSERVICE INSPECTION DIAGRAM  
COMPONENT COOLING WATER  
SYSTEM

DRAWING NO. **IS1D2-036C** REV. **10**