






- | | |
|---|---|
|  | REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS. |
|  | RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES. |
|  | REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL. |
|  | ASME SECTION XI CLASS CHANGE |
|  | ISI PROGRAM BOUNDARY |

NOTES:

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE IS102-001.
3. FOR PIPING SYMBOLS AND P B I D INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE $\frac{3}{4}$ " AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.


D-30

6	1/4	INC. DCH IS102-0040-6 PER DOR 001-1685	SBW	✓	✓	✓
4	1/4	INC. DCH IS102-0040-5 PER DOR 001-766				"INITIALS ON FILE"
3	1/4	INC. DCH IS102-0040-4 PER MOD 97-0008 SUP. 01				"INITIALS ON FILE"
2	1/4	INC. DCH IS102-0040-3 FOR RS-0031				"INITIALS ON FILE"
2	1/4	INC. DCH IS102-0040-2 FOR DCR 94-0048				"INITIALS ON FILE"
1	1/4	INC. DCH IS102-0040-1 FOR DCR 91-0001				"INITIALS ON FILE"
0	1/4	ISSUED FOR SECOND TO ONE (S) PROGRAM	CB	EFB	TWB	WOP
NO.	DATE	REVISIONS	BY	CHK'D	EXAM.	DATE

SCALE N.T.S.	DESIGNED	DRAWN CB	DATE
--------------	----------	----------	------

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1

INSERVICE INSPECTION DIAGRAM
REACTOR COOLANT SYSTEM DETAILS

	DRAWING NO.	REV.
	1SID2-040A	6