

Date Entered: Dec 13, 2001

TO: USNRC/WASHINGTON
JMCKNIGHT

Copy Number: 145

TRANSMITTAL NUMBER: 206891

PROCEDURE NUMBER: EI-6.10

TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE
GAUSSIAN (MANUAL METHOD)

TRANSMITTAL: LISTED BELOW ARE NEW/REVISED PROCEDURES WHICH MUST BE
IMMEDIATELY INSERTED INTO OR DISCARDED FROM YOUR PROCEDURE
MANUAL.

Action Required

Section or Description

REMOVE AND DESTROY

EI-6.10, R/5, ENTIRE PROCEDURE

REPLACE WITH

EI-6.10, R/5, ENTIRE PROCEDURE

EDITORIAL / APPLICABILITY

SIGN, DATE, AND RETURN THE ACKNOWLEDGEMENT FORM WITHIN 10 DAYS TO THE PALISADES
PLANT DOCUMENT CONTROL.

SIGNATURE OR INITIALS

DATE

A045

EMERGENCY IMPLEMENTING PROCEDURE

**TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE GAUSSIAN
(MANUAL METHOD)**

Date _____

Date _____

Date _____

**TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE GAUSSIAN
(MANUAL METHOD)**

Table of Contents

1.0	<u>PERSONNEL RESPONSIBILITY</u>	1
2.0	<u>PURPOSE</u>	1
3.0	<u>REFERENCES</u>	1
3.1	SOURCE DOCUMENTS	1
3.2	REFERENCE DOCUMENTS	1
4.0	<u>DEFINITIONS</u>	2
4.1	CDE	2
4.2	CEDE	2
4.3	DDE	2
4.4	TEDE	2
4.5	RELEASE OF RADIOACTIVE MATERIAL	2
5.0	<u>INITIAL CONDITIONS AND/OR REQUIREMENTS</u>	2
6.0	<u>PROCEDURE</u>	3
7.0	<u>ATTACHMENTS AND RECORDS</u>	3
7.1	ATTACHMENTS	3
7.2	RECORDS	3
8.0	<u>SPECIAL REVIEWS</u>	3

ATTACHMENTS

Attachment 1, "Manual Dose Work Sheet" —

**TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE GAUSSIAN
(MANUAL METHOD)**

USER ALERT
INFORMATION USE PROCEDURE

The activities covered by this procedure may be performed from memory.

1.0 PERSONNEL RESPONSIBILITY

The Health Physics Group Leader is responsible for the implementation of this procedure. In the absence of a Health Physics Group Leader, the Site Emergency Director or EOF Director shall delegate this responsibility.

2.0 PURPOSE

This procedure implements the same equations and assumptions as used in the automated dose calculations. All calculations are performed manually through the use of precalculated dose factors for whole body dose rates and thyroid dose rates.

Results from this procedure can be used to check the dose calculations performed in the automated dose assessment program "Offsite."

3.0 REFERENCES

3.1 SOURCE DOCUMENTS

- 3.1.1 NUREG 0654 Section I, "Accident Assessment"
- 3.1.2 EPA-400 Manual, "Protective Action Guideline and Protective Actions for Nuclear Incidents"

3.2 REFERENCE DOCUMENTS

- 3.2.1 Emergency Implementing Procedure EI-6.0, "Offsite Dose Calculation and Recommendations for Protective Actions"
- 3.2.2 Emergency Implementing Procedure EI-1, "Emergency Classification and Actions"
- 3.2.3 Palisades Administrative Procedure 10.46, "Plant Records"

**TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE GAUSSIAN
(MANUAL METHOD)**

4.0 DEFINITIONS

4.1 CDE

Committed Dose Equivalent: 50-year integrated dose to organs or tissues due to an intake at time zero.

4.2 CEDE

Committed Effective Dose Equivalent: The dose committed to an individual over the next 50 years due to intake of radioactive material, weighted (by organ) to represent a risk equivalent to that of whole body exposure.

4.3 DDE

Deep Dose Equivalent: Dose equivalent due to external radiation at 1 cm tissue depth.

4.4 TEDE

Total Effective Dose Equivalent: Sum of deep dose equivalent due to external radiation exposure and committed effective dose equivalent due to internal exposure. When no other designator is applied to dose in units of rem, TEDE is implied.

4.5 RELEASE OF RADIOACTIVE MATERIAL

Any discharge of radioactive effluent to the environment that is the result of or associated with the emergency event.

5.0 INITIAL CONDITIONS AND/OR REQUIREMENTS

This procedure shall be implemented per Emergency Implementing Procedure EI-6.0, "Offsite Dose Calculation and Recommendations for Protective Actions," when there is a potential for, or an actual significant release of radioactive materials from the Plant site (as specified by Emergency Implementing Procedure EI-1, "Emergency Classification and Actions"), and the automated dose assessment program "Offsite" is not available.

**TITLE: OFFSITE DOSE CALCULATION - STRAIGHT LINE GAUSSIAN
(MANUAL METHOD)**

6.0 PROCEDURE

USER ALERT

INFORMATION USE PROCEDURE

The activities covered by this procedure may be performed from memory.

- 6.1 From the attached work sheets, select the one corresponding to the current Pasquill stability category (A - G).
- 6.2 Record the required input information in Items 1 through 6, for any applicable page of each stability class.
- 6.3 Complete dose calculations per instructions on the work sheet.
- 6.4 All completed attachments should be forwarded to the Health Physics Support Group Leader or designate for review. |e

7.0 ATTACHMENTS AND RECORDS

7.1 ATTACHMENTS

Attachment 1, "Manual Dose Work Sheet"

7.2 RECORDS

Records generated by this procedure (ie, Attachment 1) shall be filed in accordance with Palisades Administrative Procedure 10.46, "Plant Records."

8.0 SPECIAL REVIEWS

None — |e

MANUAL DOSE WORK SHEET
GROUND LEVEL RELEASE

Stability A

- | | | |
|------------------------------------|----------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | <u>A</u> | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody DDE Dose Factor	9.780E+00	3.434E-01	1.723E-01	9.275E-02	(G)

Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
--	-------	-------	-------	-------	-----

Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)
--------------------------------	-------	-------	-------	-------	-----

Thyroid CDE Factor	1.837E+04	4.760E+02	1.875E+02	9.037E+01	(J)
--------------------	-----------	-----------	-----------	-----------	-----

Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
---	-------	-------	-------	-------	-----

Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)
-----------------------------	-------	-------	-------	-------	-----

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
-----------------------------------	-------	-------	-------	-------	-----

TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)
---------------------------	-------	-------	-------	-------	-----

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET
GROUND LEVEL RELEASE

Stability B

- | | | |
|------------------------------------|----------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | <u>B</u> | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	3.199E+01	2.979E+00	6.071E-01	1.616E-01	(G)
Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)

Thyroid CDE Factor	8.185E+04	4.827E+03	6.987E+02	1.575E+02	(J)
Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET GROUND LEVEL RELEASE

Stability C

- | | | |
|------------------------------------|---------------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | _____ C _____ | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	5.496E+01	7.591E+00	1.976E+00	6.343E-01	(G)
Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)

Thyroid CDE Factor	1.792E+05	1.403E+04	2.410E+03	6.180E+02	(J)
Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET **GROUND LEVEL RELEASE**

	Stability D	
1. Noble Gas Release Rate (Ci/sec)	_____	(A)
2. Iodine Release Rate (Ci/sec)	_____	(B)
3. Wind Speed (mph)	_____	(C)
4. Stability Class (A-G)	D	(D)
5. Release Duration (hours)	_____	(E) (Default = 2 hrs)
6. Average Energy (Mev)	_____	(F) (Default = 0.7)

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	9.378E+01	2.070E+01	7.572E+00	3.578E+00	(G)

Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
--	-------	-------	-------	-------	-----

Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)
--------------------------------	-------	-------	-------	-------	-----

Thyroid CDE Factor	4.298E+05	5.087E+04	1.184E+04	3.875E+03	(J)
--------------------	-----------	-----------	-----------	-----------	-----

Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
---	-------	-------	-------	-------	-----

Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)
-----------------------------	-------	-------	-------	-------	-----

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
-----------------------------------	-------	-------	-------	-------	-----

TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)
---------------------------	-------	-------	-------	-------	-----

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET
GROUND LEVEL RELEASE

Stability E

- | | | |
|------------------------------------|-------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | E | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	1.328E+02	3.498E+01	1.429E+01	7.427E+00	(G)
Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)

Thyroid CDE Factor	7.506E+05	1.060E+05	2.755E+04	9.916E+03	(J)
Thyroid CDE Date (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET
GROUND LEVEL RELEASE

Stability F

- | | | |
|------------------------------------|---------------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | _____ F _____ | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	1.775E+02	6.136E+01	2.769E+01	1.537E+01	(G)
Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)

Thyroid CDE Factor	1.251E+06	2.287E+05	6.508E+04	2.484E+04	(J)
Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____

MANUAL DOSE WORK SHEET GROUND LEVEL RELEASE

Stability G

- | | | |
|------------------------------------|-------|-----------------------|
| 1. Noble Gas Release Rate (Ci/sec) | _____ | (A) |
| 2. Iodine Release Rate (Ci/sec) | _____ | (B) |
| 3. Wind Speed (mph) | _____ | (C) |
| 4. Stability Class (A-G) | G | (D) |
| 5. Release Duration (hours) | _____ | (E) (Default = 2 hrs) |
| 6. Average Energy (Mev) | _____ | (F) (Default = 0.7) |

Downwind Distances (Miles)

	0.5 Mi	2 Mi	5 Mi	10 Mi	
Wholebody (DDE) Dose Factor	1.810E+02	9.741E+01	4.940E+01	2.871E+01	(G)

Wholebody Dose Rate (mrem/hr) (A x G x F)/C	_____	_____	_____	_____	(H)
--	-------	-------	-------	-------	-----

Wholebody Dose (mrem) H x E	_____	_____	_____	_____	(I)
--------------------------------	-------	-------	-------	-------	-----

Thyroid CDE Factor	1.833E+06	5.007E+05	1.557E+05	6.094E+04	(J)
--------------------	-----------	-----------	-----------	-----------	-----

Thyroid CDE Rate (mrem/hr) (B x J)/C	_____	_____	_____	_____	(K)
---	-------	-------	-------	-------	-----

Thyroid CDE (mrem) K x E	_____	_____	_____	_____	(L)
-----------------------------	-------	-------	-------	-------	-----

TEDE Rate (mrem/hr) H + (K/30)	-----	-----	-----	-----	(M)
-----------------------------------	-------	-------	-------	-------	-----

TEDE (mrem) I + (L/30)	-----	-----	-----	-----	(N)
---------------------------	-------	-------	-------	-------	-----

Above doses based on actual/potential (circle one) releases.

Date: _____ Time: _____ Completed By: _____