



PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.

UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.

ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT, ARE INCLUDED IN LR SCOPE.

IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS.

THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG

NOTES:  
1. DPT-1039 CONTROLS SPEED OF FW-10 TO MAINTAIN PUMP DISCHARGE PRESSURE APPROX. 135\* GREATER THAN STEAM INLET. SEE DWG. 11405-M-252, ZONE D-5 AND EM-1039 FOR MORE DETAILS.

FORT CALHOUN STATION		
EAFCD00-032 OF 1201		
FLOW DIAGRAM		
STEAM GENERATOR		
FEEDWATER AND BLOWDOWN		
P & ID		
DWG.	11405-M-253, SH. 4	
REV.	28333	APVD
FILE	56510	1/11/2000
		REV 28

FOR INFORMATION ONLY

NOTE: THIS PRINT IS TO BE USED FOR THE FCS LICENSE RENEWAL PROJECT ONLY. IT MAY NOT REFLECT THE MOST CURRENT REVISION OF THIS DRAWING.

65