



- PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
- UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.
- ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT, ARE INCLUDED IN LR SCOPE.
- IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS.
- THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

| FORT CALHOON STATION    |       |          |     |
|-------------------------|-------|----------|-----|
| EA-FC-00-095 DF 12/01   |       |          |     |
| FIRE PROTECTION         |       |          |     |
| FLOW DIAGRAM            |       |          |     |
| P & ID                  |       |          |     |
| DWG. 11405-M-266, SH.1A |       |          |     |
| REV. SH.                | 33450 | APVD     | REV |
| FILE                    | 41831 | DKH      | 16  |
|                         |       | 12/21/98 |     |