- PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
- UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.
- ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT, ARE INCLUDED IN LR SCOPE.
- IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS.
- THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

ROOM 6 · CORRIDOR 4 · ROOM 30 · ROOM 29 · ROOM 22 · ROOM 5 · ROOM 7 · ROOM 61 · ROOM 23 · ROOM 60 · ROOM 12 · ROOM 14 · ROOM 15A · ROOM 11 · ROOM 59 · ROOM 69 · ROOM 81 · ROOM 13

AUXILIARY BLDG. SUMP TANK ITEM No. WD-25 NOTE "3"

NOTES:
1. ALL ⅜" LINES ARE STAINLESS STEEL TUBING CLASS 2505
2. ALL LINES ½" AND LARGER ARE PIPING CLASS 151R UNLESS NOTED
3. SEE NOTE "B" ON 11405-M-7

FORT CALHOUN STATION		
EA-FC-00-129 DF 12/01		
FLOW DIAGRAM WASTE DISPOSAL SYSTEM P & ID		
DWG. 11405-M-7, SH.2		
REV.SH. 21548	APVD 2/25/99	REV 19
FILE 42761		

FOR INFORMATION ONLY

NOTE: THIS PRINT IS TO BE USED FOR THE FCS LICENSE RENEWAL PROJECT ONLY. IT MAY NOT REFLECT THE MOST CURRENT REVISION OF THIS DRAWING.