

From: Brian Holian
To: Jack Strosnider
Date: Mon, Jul 31, 2000 5:38 PM
Subject: Enforcement panel ...Tues at 1

Thanks for participating...

The Region will summarize the inspection findings and coordination with NRR, add a little on ConEd's disagreement, present the proposed violations, and summarize with a risk (SDP) discussion that colors this as a "Red" finding.

Just a note...we had 2-3 versions, or groupings, of the proposed violations.
In general...we are Leading with an App B, Criterion XVI approach.

The 2 page summary that went out with the most recent package lists a violation of Crit. 16 and 9, with the 4 items (listed below) as examples of both...
We are open to the "packaging" of the violations....and may just cite the first 3 examples as Crit 16...leaving the 4th item as Crit 9.

The items again are, ConEd did not:

- 1) evaluate the extent of the condition following identification of a new tube degradation mechanism
- 2) adjust the program to compensate for high noise signals
- 3) establish a mechanism to monitor for and have an acceptance criteria for significant upper support plate flow slot closure (hour-glassing)
- 4) ensure the use of properly qualified eddy current technique for small radius U-bend inspections

CC: Bill Bateman, Daniel Holody, David Lew, David Nelson, Stephanie Coffin, Wayne Schmidt

4/29