

From: "AS.HUNJAN" <hunjan@igcar.ernet.in>
To: "CAG@nrc.gov" <CAG@nrc.gov>
Date: 1/28/02 10:47PM
Subject: Regulatory Guide 1.143

RECEIVED

2002 JAN 31 AM 11:12

Rules and Directives

Dear Sir/Madame,

I have received RG 1.143 Revision 2 released in November 2001. I thank NRC and its staff for sending this copy to me. I have gone through the RG and have some suggestions, which are given below.

(i) Page 4 lists some of the systems to which this RG does not apply. It includes fuel pool water cleanup system. This system may have Resins in ion exchange columns, which may have to be included.

(ii) In table 2, for RW IIa class of waste, loading due to small aircraft crash is included. This loading is said to be plant specific. After Sept 11 incident, I feel, this should be reviewed.

With regards,

Sincerely
A.S. Hunjan,
Scientific Officer (H),
Room # 421, HBB,
Indira Gandhi Centre for Atomic Research,
PO. Kalpakkam, 603102, India.

12/4/01

66 FR 63078

(1)

Template = ADM-013

E-RIDS = ADM-03
Call = A. BeraneK (AFB)
H. Graves (HLG1)