

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.6.2 Perform a functional test of each required vacuum breaker.</p>	<p>31 days</p> <p><u>AND</u></p> <p>Within 12 hours after discharge of steam to the suppression chamber from S/RV operation</p> <p><u>AND</u></p> <p>Within 12 hours following an operation that causes any of the vacuum breakers to open</p>
<p>SR 3.6.1.6.3 Verify the opening setpoint of each required vacuum breaker is <math>\geq 0.25</math> and <math>\leq .75</math> psid.</p>	<p>24 months</p>

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.6.2 Perform a functional test of each required vacuum breaker.</p>	<p>31 days</p> <p><u>AND</u></p> <p>Within 12 hours after discharge of steam to the suppression chamber from S/RV operation</p> <p><u>AND</u></p> <p>Within 12 hours following an operation that causes any of the vacuum breakers to open</p>
<p>SR 3.6.1.6.3 Verify the opening setpoint of each required vacuum breaker is <math>\geq 0.25</math> and <math>\leq .75</math> psid.</p>	<p>24 months</p>