

**From:** Patrick Milano *NRR*  
**To:** Pete Eselgroth  
**Date:** Mon, Jun 19, 2000 12:51 PM  
**Subject:** Tech Staff Review of CMOA

Pete,

In response to your request for the status of NRR's effort on the IP-2 steam generator review:

1. The staff has been requesting information and clarifications from the licensee during the periodic telephone calls. In particular, the staff is looking for some revised stress analysis of the U-bends and the burst model. We are setting up a telecon with the licensee for 4:00 pm today to discussion the status of the submission and to discuss other technical issues.
2. Recognizing that the review is still ongoing and all of the required information has not yet been received, a current "best guess" for completion is between July 7 and 14.
3. At this time, EMCB would like D. Lew to look at the licensee's supplemental training effort to improve the ability of analysts to identify flaws in the sludge pile region after several flaws were missed in this area. Also, one of the tubes did not pass the 3dP in-situ burst test because of a sludge pile flaw.

Hope this helps to answer your questions.

Pat

**CC:** Leanne Harrison, Marsha Gamberoni

*m/*  
*[Signature]*

*File 70*