



Donna Jacobs
Plant Manager

DEC 7 2001

WO 01-0061

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Subject: Docket No. 50-482: November, 2001, Monthly Operating Report

Gentlemen:

Attached to this letter is the November, 2001, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports." This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have questions regarding this report, please contact me at (620) 364-4246, or Mr. Tony Harris at (620) 364-4038.

Very truly yours,

A handwritten signature in black ink, appearing to read "Donna Jacobs", is written over a horizontal line. To the right of the signature, the text "S.E. HARRIS" is written in a smaller, handwritten font.

Donna Jacobs

DJ/pb

Attachment

cc: J. N. Donohew (NRC), w/a
W. D. Johnson (NRC), w/a
E. W. Merschoff (NRC), w/a
Senior Resident Inspector (NRC), w/a

IE24

OPERATING DATA REPORT

Report Number: 201

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: December 4, 2001
COMPLETED BY: K. W. Hall
TELEPHONE: 620-364-4272

REPORT MONTH: November, 2001

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1170

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	720.0	8,016.0	121,620.7
4.	Number of Hours Generator On-Line:	720.0	7,987.8	120,506.2
5.	Unit Reserve Shutdown Hours:	0.0	0.0	339.8
6.	Net Electrical Energy Generated (MWH)	857,462	9,459,064	136,149,409

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: December 4, 2001
COMPLETED BY: K. W. Hall
TELEPHONE: 620-364-4272

No.	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

SUMMARY: The unit operated at approximately 100% power November 1, 2001, through November 30, 2001.

(1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)
B: MAINTENANCE OR TEST
C: REFUELING
D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION
F: ADMINISTRATIVE
G: OPERATIONAL ERROR (EXPLAIN)
H: OTHER (EXPLAIN)

(2) METHOD: 1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUATION
5. OTHER

Wolf Creek Generating Station
Monthly Operating Report
November, 2001
Page 2 of 2