RC-3C

NOTES:

1. ONE OF SIX STATOR TEMPERATURE ELEMENTS CHOSEN DURING PUMP TEST WILL BE CONNECTED TO THE ERF COMPUTER.
2. LOCAL PRESSURE TAPS ARE SUPPLIED IN THE PUMP SUCTION AND DISCHARGE FOR PUMP CALIBRATION.
3. FOR SYMBOLS, ABBREVIATIONS AND REFERENCE DRAWINGS, SEE DRAWING 11405-MECH-1.
4. ALL SEAL VENT VALVES TO BE LOCATED AT AN ELEVATION NO LOWER THAN THE CONNECTION TO THE SEAL CARTRIDGE.
5. ALL VALVES SHOWN WITHOUT AN ⊛ ARE SUPPLIED BY GHD & R.
6. INTERCONNECTING DRAWING NUMBER M-40 REFERS TO GHD & R DRAWING 11405-M-40 SHTS. 1, 2, & 3.
7. FOR INSTRUMENTATION DETAILS, SEE GHD & R 11405-EM DRAWING SERIES.
8. OIL LIFT AND BACKSTOP LUBRICATION SYSTEM IS SCHEMATIC ONLY, AND DOES NOT REFLECT ACTUAL PIPING.
9. PIPING NOT NUMBERED IS SUPPLIED WITH THE PUMP/MOTOR PACKAGE.

- PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
- UNLESS OTHERWISE INDICATED, VENTS, DRAINS, AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.
- ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT, ARE INCLUDED IN LR SCOPE.
- IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS.
- THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

FORT CALHOUN STATION

EA-FC-00-126 DF 1201

REACTOR COOLANT PUMP RC-3C P & ID

DWG. D-23866-210-111, SH. 3			
REV.SH. 23086	APVD JWS 5/22/98	REV 19	
FILE 45592			

FOR INFORMATION ONLY

NOTE: THIS PRINT IS TO BE USED FOR THE FCS LICENSE RENEWAL PROJECT ONLY. IT MAY NOT REFLECT THE MOST CURRENT REVISION OF THIS DRAWING.