

February 12, 2002

Mr. David L. Wilson
Vice President of Nuclear Energy
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION OF TYPOGRAPHICAL ERROR
IN AMENDMENT NO. 178

Dear Mr. Swailes:

This is in response to the letter of December 14, 2001 (NLS2001110), from David L. Wilson, Vice President of Nuclear Energy, which identified an error on a Technical Specification (TS) page in Amendment No. 178, which was issued July 31, 1998. The error is that an incorrect surveillance requirement (SR) was listed for Function 6.a on page 3.3-53 of TS Table 3.3.6.1-1. This was discussed by phone with your staff on February 6, 2002.

The reference to SR 3.3.6.1.5 in Table 3.3.6.1-1 for Function 6.a is incorrect and should be SR 3.3.6.1.6. SR 3.3.6.1.5 concerns calibration of radiation detectors which duplicates SR 3.3.6.1.4 listed for Function 6.a on page 3.3-53. The correct surveillance SR 3.3.6.1.6 requires a logic system functional test. The NRC staff has verified that the error was not submitted as part of the conversion to the Improved Technical Specifications that were issued in Amendment No. 178, and SR 3.3.6.1.6 was submitted for Function 6.a in the licensee's letters for the amendment. Therefore, issuing incorrect TS page 3.3-53 in Amendment No. 178 was an inadvertent error. Based on this, the staff is issuing the enclosed corrected page for page 3.3-53 of the TSs.

Sincerely,

/RA by Robert A. Gramm for/

Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Corrected TS Page

cc w/encl: See next page

February 12, 2002

Mr. David L. Wilson
Vice President of Nuclear Energy
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - CORRECTION OF TYPOGRAPHICAL ERROR
IN AMENDMENT NO. 178

Dear Mr. Swailes:

This is in response to the letter of December 14, 2001 (NLS2001110), from David L. Wilson, Vice President of Nuclear Energy, which identified an error on a Technical Specification (TS) page in Amendment No. 178, which was issued July 31, 1998. The error is that an incorrect surveillance requirement (SR) was listed for Function 6.a on page 3.3-53 of TS Table 3.3.6.1-1. This was discussed by phone with your staff on February 6, 2002.

The reference to SR 3.3.6.1.5 in Table 3.3.6.1-1 for Function 6.a is incorrect and should be SR 3.3.6.1.6. SR 3.3.6.1.5 concerns calibration of radiation detectors which duplicates SR 3.3.6.1.4 listed for Function 6.a on page 3.3-53. The correct surveillance SR 3.3.6.1.6 requires a logic system functional test. The NRC staff has verified that the error was not submitted as part of the conversion to the Improved Technical Specifications that were issued in Amendment No. 178, and SR 3.3.6.1.6 was submitted for Function 6.a in the licensee's letters for the amendment. Therefore, issuing incorrect TS page 3.3-53 in Amendment No. 178 was an inadvertent error. Based on this, the staff is issuing the enclosed corrected page for page 3.3-53 of the TSs.

Sincerely,

/RA by Robert A. Gramm for/

Jack N. Donohew, Senior Project Manager, Section 2
Project Directorate IV & Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Corrected TS Page

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-1 r/f

RidsNrrDlpmLpdiv (S.Richards)

RidsNrrDlpmLpdiv (R.Gramm)

RidsNrrDripRorp (R.Dennig)

RidsNrrPMJDonohew

RidsNrrPMMThadani

RidsNrrLAMMcAllister

RidsAcrsAcnwMailCenter

RidsOgcRp

RidsRgn4MailCenter (KKennedy)

GHill (2)

ADAMS ACCESSION NUMBER: ML020380347

*See previous concurrence

OFFICE	PDIV-2/PM	PDIV-1/LA	PDIV-1/SC
NAME	JDonohew:as*	MMcAllister*	RGramm*
DATE	02/08/02	02/08/02	02/12/02

OFFICIAL RECORD COPY

Cooper Nuclear Station

cc:

Mr. G. R. Horn
Sr. Vice President of Nuclear and
Enterprise Effectiveness
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. John R. McPhail, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

D. F. Kunsemiller, Risk and
Regulatory Affairs Manager
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

Dr. William D. Leech
Manager-Nuclear
MidAmerican Energy
907 Walnut Street
P. O. Box 657
Des Moines, IA 50303-0657

Mr. Ron Stoddard
Lincoln Electric System
1040 O Street
P. O. Box 80869
Lincoln, NE 68501-0869

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Cheryl K. Rogers, Program Manager
Nebraska Health & Human Services System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P. O. Box 95007
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Jerry Uhlmann, Director
State Emergency Management Agency
P. O. Box 116
Jefferson City, MO 65101

Chief, Radiation Control Program, RCP
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366