

February 13, 2002

Carl Terry, BWRVIP Chairman
Niagara Mohawk Power Company
Post Office Box 63
Lycoming, NY 13093

SUBJECT: REVISION TO BWRVIP-07 TABLE 1

Dear Mr. Terry:

By letter dated January 17, 2001, the BWR Vessel and Internals Project (BWRVIP) requested that the staff consider a revision to Table 1, "Core Shroud Reinspection Intervals for Category C Plants," from the Electric Power Research Institute's (EPRI) Report TR-105747, "BWR Vessel and Internals Project, Guidelines for Reinspection of BWR Core Shrouds (BWRVIP-07)." Specifically, it was requested that this Table's applicability be expanded to include Category B plants.

The staff has reviewed the advisability of this request, and concurs that the Table 1 reinspection guidance can be expanded to include both Category B and C plants.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

/ra/

William H. Bateman, Chief
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

cc: See next page

February 13, 2002

Carl Terry, BWRVIP Chairman
Niagara Mohawk Power Company
Post Office Box 63
Lycoming, NY 13093

SUBJECT: REVISION TO BWRVIP-07 TABLE 1

Dear Mr. Terry:

By letter dated January 17, 2001, the BWR Vessel and Internals Project (BWRVIP) requested that the staff consider a revision to Table 1, "Core Shroud Reinspection Intervals for Category C Plants," from the Electric Power Research Institute's (EPRI) Report TR-105747, "BWR Vessel and Internals Project, Guidelines for Reinspection of BWR Core Shrouds (BWRVIP-07)." Specifically, it was requested that this Table's applicability be expanded to include Category B plants.

The staff has reviewed the advisability of this request, and concurs that the Table 1 reinspection guidance can be expanded to include both Category B and C plants.

Please contact C. E. (Gene) Carpenter, Jr., of my staff at (301) 415-2169 if you have any further questions regarding this subject.

Sincerely,

William H. Bateman, Chief
Materials and Chemical Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:

EMCB R/F SDuraiswamy MEMayfield WLanning, R1 JGrobe, R3
 JLarkins NCChokshi CCasto, R24 AHowell, R

DOCUMENT NAME: C:\Program Files\Adobe\Acrobat 4.0\PDF Output\BWRVIP07 Table 1 Rev 3 Erra~.wpd

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY EMCB:DE

EMCB:DE	E	EMCB:DE	E	EMCB:DE	E	EMCB:DE	E
CECarpenter:cec		WHKoo:whk		ALHiser:alh		WHBateman:whb	
02/05/2002		02/05/2002		02/06/2002		02/13/2002	

OFFICIAL RECORD COPY

cc:

George Vanderheyden, Executive Chair
BWRVIP Assessment Committee
Exelon Corp.
200 Exelon Way (KSA 3-N)
Kennett Square, PA 19348

Bill Eaton, Executive Chair,
BWRVIP Inspection Focus Group
Grand Gulf Gen. Mgr., Plant Operations
Entergy Operations, Inc.
PO BOX 756, Waterloo Rd
Port Gibson, MS 39150-0756

H. Lewis Sumner, Executive Chair
BWRVIP Mitigation Committee
Vice President, Hatch Project
Southern Nuclear Operating Co.
M/S BIN B051, PO BOX 1295
40 Inverness Center Parkway
Birmingham, AL 35242-4809

George T. Jones, Executive Chair
BWRVIP Repair Focus Group
Vice President, Nuclear Engrg. & Support
PP&L, Inc.
M/S GENA61
2 N 9th St
Allentown, PA 18101-1139

Robert Carter, EPRI BWRVIP
Assessment Manager
Greg Selby, EPRI BWRVIP
Inspection Manager
EPRI NDE Center
P. O. Box 217097
1300 W. T. Harris Blvd.
Charlotte, NC 28221

Robin Dyle, Technical Chairman
BWRVIP Assessment Committee
Southern Nuclear Operating Co.
40 Inverness Center Parkway
Birmingham, AL 35242

Gary Park, Chairman
BWRVIP Inspection Focus Group
Nuclear Management Co.
3313 DAEC Road
Palo, IA 52324-9646

John Wilson, Technical Chair
BWRVIP Mitigation Committee
AmerGen Energy Co.
Clinton Power Station, M/C T-31C
P.O. Box 678
Clinton, IL 61727

Vaughn Wagoner, Technical Chair
BWRVIP Integration Committee
Carolina Power & Light Company
One Hannover Square 9C1
P.O. Box 1551
Raleigh, NC 27612

Bruce McLeod, Technical Chair
BWRVIP Repair Focus Group
Southern Nuclear Operating Co.
Post Office Box 1295
40 Inverness Center Parkway
Birmingham, AL 35201

Tom Mulford, EPRI BWRVIP
Integration Manager
Raj Pathania, EPRI BWRVIP
Mitigation Manager
Ken Wolfe, EPRI BWRVIP Repair Manager
Larry Steinert, EPRI BWRVIP
Electric Power Research Institute
P. O. Box 10412 3412 Hillview Ave.
Palo Alto, CA 94303