



OG-02-004

NRC Project Number 686

Domestic Members

AmerenUE
Callaway
American Electric Power Co.
D.C. Cook 1 & 2
Carolina Power & Light Co.
H.B. Robinson 2
Shearon Harris
Consolidated Edison
Company of NY, Inc.
Indian Point 2
Duke Power Company
Catawba 1 & 2
McGuire 1 & 2
Entergy Nuclear Operations Inc.
Indian Point 3
Exelon
Braidwood 1 & 2
Byron 1 & 2
First Energy Nuclear
Operating Co.
Beaver Valley 1 & 2
Florida Power & Light Co.
Turkey Point 3 & 4
Northeast Utilities
Seabrook
Millstone 3
Nuclear Management Co.
Point Beach 1 & 2
Prairie Island 1 & 2
Kewaunee
Pacific Gas & Electric Co.
Diablo Canyon 1 & 2
PSEG - Nuclear
Salem 1 & 2
Rochester Gas & Electric Co.
R.E. Ginna
South Carolina Electric
& Gas Co.
V.C. Summer
STP Nuclear Operating Co.
South Texas Project 1 & 2
Southern Nuclear
Operating Co.
J.M. Farley 1 & 2
A.W. Vogtle 1 & 2
Tennessee Valley Authority
Sequoyah 1 & 2
Watts Bar 1
TXU Electric
Comanche Peak 1 & 2
Virginia Electric & Power Co.
(Dominion)
North Anna 1 & 2
Surry 1 & 2
Wolf Creek Nuclear
Operating Corp.
Wolf Creek

International Members

Electrabel
Doel 1, 2, 4
Tihange 1, 3
Kansai Electric Power Co.
Mihama 1
Takahama 1
Ohi 1 & 2
Korea Electric Power Co.
Kori 1 - 4
Yonggwang 1 & 2
Nuclear Electric plc
Sizewell B
Nuklearna Elektrarna Krsko
Krsko
Spanish Utilities
Asco 1 & 2
Vandellós 2
Almaraz 1 & 2
Vattenfall AB
Ringhals 2 - 4
Taiwan Power Co.
Maanshan 1 & 2

January 22, 2002

To: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Attention: S. K. Mitra, Project Manager
License Renewal and Standardization Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Subject: Westinghouse Owners Group
Request for Modification of NRC Safety Evaluation Report on WCAP-15338, "A Review of Cracking Associated with Weld Deposited Cladding in Operating PWR Plants," (MUHP6130)

- References: 1. OG-01-047, Revised Response to NRC Request for Additional Information on WCAP-15338, "A Review of Cracking Associated with Weld Deposited Cladding in Operating PWR Plants," July 31, 2001, to Document Control Desk, NRC
2. Safety Evaluation Of WCAP-15338, "A Review Of Cracking Associated With Weld Deposited Cladding In Operating PWR Plants," Grimes to Newton, October 15, 2001

Reference 1 transmitted the revised Westinghouse Owners Group responses to the NRC's Request for Additional Information on the WOG Report WCAP-15388, "A Review of Cracking Associated with Weld Deposited Cladding in Operating PWR Plants," March 2000. The responses were formatted as an appendix to the original WCAP to facilitate review.

Reference 2 transmitted the final safety evaluation for WCAP-15338, with the following conclusion:

"The staff has concluded that the topical report is acceptable for Westinghouse 3-loop RPVs because the underclad cracks satisfy the ASME Code flaw evaluation requirements for detected flaws. However, for renewal applicants for Westinghouse 2-loop and 4-loop RPVs who plan to reference this topical report, they need to address the plant-specific applicability of this topical report to their plants as described under Section 4.0, "Renewal Applicant Action Items," of the enclosed staff final safety evaluation report (FSER)."

Do 43


OG-02-004
January 22, 2002

Reference 2 also contains a request that WOG publish the accepted version of WCAP-15338 within 90-days.

This letter is intended to document the exception that WOG takes to the Reference 2 conclusion. The 3-loop RPV evaluation presented in the report is intended to be a bounding evaluation for all Westinghouse plant sizes, including both 2-loop and 4-loop RPVs. The acceptability of that evaluation in your SER should be extended to all sizes of WOG RPVs. Discussions have been initiated between the author of WCAP-15338 and the NRC reviewer(s) to resolve this issue, however because of personnel unavailability over the year-end holidays, a firm path for resolution has not been defined.

Publication of an accepted version of WCAP-15338 will be delayed beyond the 90-days, pending resolution of the WOG concern with the Reference 2 SER.

Very truly yours,



Robert H. Bryan, Chairman
Westinghouse Owners Group

cc: S.K. Mitra, Project Manager, USNRC License Renewal and Standardization Branch (1L)
C.I. Grimes, Director, USNRC License Renewal and Standardization Branch (1L)
Westinghouse Owners Group Primary Representatives (1L)
Westinghouse Owners Group LCM/LR Working Group (1L)
Westinghouse Owners Group Steering Committee (1L)
G.C. Bischoff, W ECE 5-16 (1L)
C.E. Meyer, W ECE 4-08 (1L)
W.H. Bamford, WECE 314C (1L)