

## INDEX

### DESIGN FEATURES

---

SECTION	PAGE
<u>5.1 SITE</u>	
5.1.1 SITE LOCATION .....	5-1
<u>5.2 CONTAINMENT</u>	
5.2.1 CONFIGURATION.....	5-1
5.2.2 DESIGN PRESSURE AND TEMPERATURE.....	5-1
<u>5.3 REACTOR CORE</u>	
5.3.1 FUEL ASSEMBLIES.....	5-4
5.3.2 CONTROL ROD ASSEMBLIES.....	5-4
<u>5.4 REACTOR COOLANT SYSTEM</u>	
5.4.1 DESIGN PRESSURE AND TEMPERATURE.....	5-4
5.4.2 VOLUME.....	5-4
<u>5.5 METEOROLOGICAL TOWER LOCATION</u> .....	5-4
<u>5.6 FUEL STORAGE</u>	
5.6.1 CRITICALITY.....	5-5
5.6.2 DRAINAGE.....	5-6
5.6.3 CAPACITY.....	5-6
<u>5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT</u> .....	5-6
TABLE 5.7-1 COMPONENT CYCLIC OR TRANSIENT LIMITS.....	5-7

## 5.0 DESIGN FEATURES

### 5.1 SITE

- 5.1.1 The site is approximately 25 miles south of Miami, 8 miles east of Florida City, and 9 miles southeast of Homestead, Florida

### 5.2 CONTAINMENT

#### CONFIGURATION

5.2.1 The containment building is a steel-lined, reinforced concrete building of cylindrical shape, with a dome roof and having the following design features:

- a. Nominal inside diameter = 116 feet.
- b. Nominal inside height = 170.6 feet.
- c. Minimum thickness of concrete walls = 3.75 feet.
- d. Minimum thickness of concrete roof = 3.25 feet.
- e. Minimum thickness of concrete floor pad = 10.5 feet.
- f. Nominal thickness of steel liner = 0.25 inches.
- g. Nominal net free volume = 1,550,000 cubic feet.

#### DESIGN PRESSURE AND TEMPERATURE

5.2.2 The containment building is designed and shall be maintained for a maximum internal pressure of 55 psig and a temperature of 283°F. The containment building is also structurally designed to withstand an internal vacuum of 2.5 psig.

[ THIS PAGE INTENTIONALLY LEFT BLANK ]

[ THIS PAGE INTENTIONALLY LEFT BLANK ]