



BALESTRACCI UNLIMITED  
29 Ridgewood Road  
Charlestown, Rhode Island 02813  
(401) 364-0652 Phone  
(401) 364-3238 Fax

MS 16

P-3

BU/02-001  
February 28, 2002

Kathy Dole Modes  
Health Physicist  
Nuclear Materials Safety Branch 2  
Division of Nuclear Materials Safety

Docket Nos. 03035908  
03034615

License Nos. 38-30708-01  
06-30423-01

Control Nos. 130771  
130772

Megarad, Inc., Request for Additional Information concerning Application for  
Amendment to License 06-30423-01.

To whom it may concern:

In response to your request for additional concerning the source storage location  
Address at the new license address, the following clarification and additional information  
is provided.


The storage area is located within the Quality Services Laboratories Plus, Inc. exposure  
cell. The cell is a 13'5" x 14' area (with walls 2" thick solid concrete) x 13' high, topped  
8" solid block to ceiling height of 22'. The floor is 8" thick poured concrete slab. The  
rear wall is a concrete block retaining wall 8' high 2' thick with additional 5' of poured  
concrete 2' thick, then topped with solid block to the ceiling. An earth embankment 8'  
high sloped up to the fence line 20' behind the building. The maze entrance is secured  
with a 5' tall fence, gate and key locked. It is posted with "Caution - Radioactive  
Materials" - "Do Not Enter" - "Authorized Personnel Only". Only radiographic personnel  
have authorized access. The gate is kept locked when not in use.

Currently no radioactive material is possessed under the Megarad, Inc By-Products  
Materials License 06-30423-010.

130771/130772

NMSS/RGNI MATERIALS-002

I apologize for the delay in responding to this request. Additional information needed to be obtained from QSL Plus and I have been away on travel. If any additional information is required please call me at (401) 364-0652. Thank you for your time and consideration.

A handwritten signature in cursive script, reading "Garry L. Balestracci".

Garry L. Balestracci  
Radiation Safety Officer