



**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

February 13, 2002

Docket No. 50-443

NYN-02014

United States Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555-0001


Seabrook Station
2001 Annual Report of Removable
Contamination from Sealed Source or Fission Detector

Seabrook Station Technical Specification 4.7.8.3 requires a report be prepared and submitted if sealed source or fission detector leakage tests reveal the presence of greater than or equal to 0.005 microCurie of removable contamination. In accordance with this requirement, North Atlantic Energy Service Corporation hereby reports that during 2001, there were no leaking sources.

Should you have any questions, please contact Mr. William T. Cash, Manager – Health Physics, at (603) 773-7315.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.


James M. Peschel
Manager – Regulatory Programs

cc: H. J. Miller, NRC Region I Administrator

G.F. Wunder, NRC Project Manager, Project Directorate I-2

G.T. Dentel, NRC Senior Resident Inspector

A001