

March 7, 2002

Mr. A Christopher Bakken III, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 2 - 30-DAY REPORT OF LOSS-OF-COOLANT ACCIDENT EVALUATION MODEL CHANGES (TAC NO. MB4038)

Dear Mr. Bakken:

By letter dated February 4, 2002, pursuant to 10 CFR 50.46, the Indiana Michigan Power Company (the licensee) submitted a 30-day report of loss-of-coolant accident (LOCA) model changes affecting the peak cladding temperature (PCT) for Donald C. Cook Nuclear Plant, Unit 2. The letter describes the current assessments against the large-break LOCA analysis of record and a demonstration that the PCT value remains below 2200 degrees Fahrenheit, as required by 10 CFR 50.46. The letter also reported updated assessments of analyses-of-record in addition to previously identified analysis errors and changes.

The Nuclear Regulatory Commission (NRC) staff has reviewed the letter and the licensee's actions. The NRC staff finds that each action described in the letter was performed in accordance with the requirements of 10 CFR 50.46(a)(3)(ii), and therefore is acceptable. The NRC staff also find, the licensee's proposed schedule for reanalysis of the large-break LOCA acceptable.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

cc: See next page

March 7, 2002

Mr. A Christopher Bakken III, Senior Vice President
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 2 - 30-DAY REPORT OF LOSS-OF-COOLANT ACCIDENT EVALUATION MODEL CHANGES (TAC NO. MB4038)

Dear Mr. Bakken:

By letter dated February 4, 2002, pursuant to 10 CFR 50.46, the Indiana Michigan Power Company (the licensee) submitted a 30-day report of loss-of-coolant accident (LOCA) model changes affecting the peak cladding temperature (PCT) for Donald C. Cook Nuclear Plant, Unit 2. The letter describes the current assessments against the large-break LOCA analysis of record and a demonstration that the PCT value remains below 2200 degrees Fahrenheit, as required by 10 CFR 50.46. The letter also reported updated assessments of analyses-of-record in addition to previously identified analysis errors and changes.

The Nuclear Regulatory Commission (NRC) staff has reviewed the letter and the licensee's actions. The NRC staff finds that each action described in the letter was performed in accordance with the requirements of 10 CFR 50.46(a)(3)(ii), and therefore is acceptable. The NRC staff also find, the licensee's proposed schedule for reanalysis of the large-break LOCA acceptable.

Sincerely,

/RA/

John F. Stang, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

cc: See next page

DISTRIBUTION

PUBLIC

PDIII-1 Reading

WReckley

JStang

THarris

OGC

ACRS

AVegel, RIII

*See previous concurrence

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC(A)	SRXB
NAME	JStang	THarris /RA/ by RBouling	WReckley	SE Input*
DATE	03/07/02	03/07/02	03/07/02	02/26/02

ADAMS Accession No. ML020650015

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Joseph E. Pollock
Plant Manager
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Michigan Department of Environmental
Quality
DWRPD/RPS
Nuclear Facilities Unit
Constitution Hall
P. O. Box 30630
Lansing, MI 48909-8130

Scot A. Greenlee
Director, Nuclear Technical Services
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Michael W. Rencheck, Vice President
Strategic Business Improvements
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107