

12/28/01
66 FIR 67335

(1)

COMMENTS ON DRAFT REGULATORY GUIDES DG-1091 AND DG-1112

This is an editorial comment.

Appendix B of DG-1091 lists Code Cases N-613 and N627 as being unacceptable and refers by "*" to DG-1112. Neither Code Case is addressed in DG-1112. However Code Case N-627 is listed in Table 1 of DG-1090 as acceptable. I cannot find any discussion of Code Case N-613 in neither DG-1090 nor DG-1112. The "*" after Code Case N-627 should be deleted. Code Case N-613 should be removed from Appendix B or addressed in DG-1090 or DG-1112.

Douglas Ramey
Energy Northwest
MS PE27
PO Box 968
Richland, WA 99338

RECEIVED
17 FEB 28 PM 12:06
Rules and Directives
Group
10073

Template = ADM-013

E-KIDS = ADM-03
Add = A. Beranek (AFB)
W. E. Norris (WEN)