

UNIVERSITY OF ILLINOIS
AT URBANA-CHAMPAIGN

Department of Nuclear, Plasma,
and Radiological Engineering

214 Nuclear Engineering Laboratory
103 South Goodwin Avenue
Urbana, IL 61801-2984



February 18, 2002
Docket No. 50-151

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Dear Sir,

SUBJECT: ANNUAL REPORT: Illinois Advanced TRIGA Reactor
License No. R-115 / Docket No. 50-151

The following is written to comply with the requirements of section 6.8.d of the Technical Specifications and the conditions of 10CFR50.59. The outline of the report follows the numbered sequence of section 6.8.d of the Technical Specifications.

Sincerely,

Richard L. Holm
Reactor Administrator

James F. Stubbins, Head
Department of Nuclear Engineering


c: Nuclear Reactor Committee
American Nuclear Insurers
File

A020

STATE OF ILLINOIS


COUNTY OF CHAMPAIGN

Richard L. Holm, being first duly sworn on oath, deposes and says that he has affixed his signature to the letter above in his official capacity as Reactor Administrator, University of Illinois Nuclear Reactor Laboratory; that in accordance with the provisions of Part 50, Chapter 1, Title 10 of the Code of Federal Regulations, he is attaching this affidavit; that the facts set forth in the within letter are true to his best information and belief.



Richard L. Holm
Reactor Administrator


Subscribed and sworn to before me, a Notary Public, in and for the County of Champaign, State of Illinois, this 27th day of February, A.D., 2002.



Notary Public of Illinois

8-19-04

My Commission Expires



ANNUAL REPORT
JANUARY 1, 2001-DECEMBER 31, 2001
ILLINOIS ADVANCED TRIGA
FACILITY LICENSE R-115

I. SUMMARY

The reactor was in a shutdown SAFSTOR status for all of 2001. Monitoring of the facility is through the use of weekly, monthly and quarterly surveillance checklists performed by the Reactor Administrator and Reactor Health Physicist. Additional surveillances are performed at other intervals where appropriate. The checklists created for SAFSTOR have proven to be more than adequate to ensure that the facility is monitored safely.

During 2001 there were two individuals with a Senior Reactor Operator License, one of which is the reactor health physicist.

II. UNSCHEDULED REACTOR SHUTDOWNS

Not applicable.

III. MAJOR PREVENTIVE AND CORRECTIVE MAINTENANCE HAVING SAFETY SIGNIFICANCE

No major maintenance was performed having safety significance.

IV. CONDITIONS UNDER SECTION 50.59 OF 10CFR50

No 50.59 reviews were performed in 2001.

V. RELEASE OF RADIOACTIVE MATERIAL

A. Gaseous Effluents

1) ^{41}Ar

No longer produced: reactor shutdown, defueled, and in SAFSTOR condition.

2) ^3H

The estimated total release of ^3H to the Reactor Building atmosphere (and consequently out the Exhaust Stack) from the evaporation of water in the Primary Tank (PT) and the Bulk Shielding Tank (BST) was 86 μCi . This is based on the measure of the activity of ^3H in the PT or BST (whichever had the highest concentration of ^3H), multiplied by the total volume of makeup water additions since the tanks were last sampled for ^3H (yearly). This is calculated as follows: highest

concentration of ^3H in the PT or BST ($3.1 \text{ E}^{-6} \mu\text{Ci/ml}$) multiplied by the evaporative loss volume ($2.78 \text{ E}^7 \text{ ml}$) equals $86 \mu\text{Ci}$.

The average concentration released via the Exhaust Stack was $5.75 \text{ E}^{-11} \mu\text{Ci/ml}$ calculated as follows: assume an average stack flow of $50 \text{ fpm}^1 * 2 \text{ ft}^2 = 100 \text{ ft}^3 / \text{min} * 2.83 \text{ E}^4 \text{ ml/ft}^3 = 2.83 \text{ E}^6 \text{ ml/min} * 5.256 \text{ E}^5 \text{ min/yr} = 1.5 \text{ E}^{12} \text{ ml/yr}$. Then, $86 \mu\text{Ci}$ (estimated total release) divided by $1.5 \text{ E}^{12} \text{ ml}$ (the total volume released) = $5.75 \text{ E}^{-11} \mu\text{Ci/ml}$ average concentration.

¹ Exhaust Stack Blower secured, flow reduced from 1200 fpm to 50 fpm.

3) Summary of Gaseous Effluents Released

A summary of all gaseous effluents for 2001 (Sections 1+2 above) is shown in the following table, which includes for each isotope: the total activity released; the average concentration; the 10 CFR 20, Appendix B, Table 2 limit; and the fraction of the limit released. The sum of the fractions for all isotopes released is listed at the end of the table.

Isotope	Total μCi	Ave Conc. ($\mu\text{Ci/ml}$)	App. B Table 2 limit	Ave. Conc. / limit
^{41}Ar	None	None	$2.0 \text{ E}^{-6} *$	0.000
^3H	86	5.75 E^{-11}	4.0 E^{-8}	0.001
			Sum of Fractions =	0.001 (< 1.0)

* Ar-41 concentration limit is specified by the Facility Technical Specifications.

B. Liquid Effluent

1) Waste Water discharged to the municipal sanitary sewer system

Waste Water is collected in the Reactor Building Retention Tank. When the Tank becomes full it is pumped over to a Holdup Tank. The water passes through a coarse and a fine filter assembly on route to the Holdup Tank where it is then sampled. The water is discharged from the Holdup Tank into the municipal sanitary sewer system when the soluble activity results are satisfactory and it is verified that no insoluble activity is present. If insoluble activity is detected before the discharge then the contents of the Holdup Tank can be recirculated through a 0.4 micron process filter until the insoluble activity has been removed and it is verified that no insoluble activity is present.

The average concentration of all soluble beta-gamma activity released in 2001 was $4.7 \text{ E}^{-8} \mu\text{Ci/ml}$. This is well below the 10 CFR 20, App. B, Table 3, "Releases to Sewers" limit of $9.0 \text{ E}^{-6} \mu\text{Ci/ml}$ for the most restrictive isotope not known to be absent, ^{134}Cs . The average concentration of ^3H released concurrently with the above was $3.6 \text{ E}^{-5} \mu\text{Ci/ml}$. This is well below the 10 CFR 20 "release to sewer" limit of $1.0 \text{ E}^{-2} \mu\text{Ci/ml}$ for ^3H .

VI. ENVIRONMENTAL SURVEYS

Continuous radiation monitoring utilizing Thermoluminescent Dosimeters (TLDs) supplied by a vendor (ICN Worldwide Dosimetry Service) was conducted at the Site Boundary and in the Surrounding Environs. The Lower Limit of Detection (LLD) for these TLDs = 10 mRem/Quarter).

A. Site Boundary

The site boundary is established at the Reactor Building Walls with extensions at the fence around the Cooling Towers and the perimeter of the roof over the Mechanical Equipment Room. This is also defined as the boundary between the Restricted and Unrestricted Areas. The average annual dose at this perimeter was 134 mRem with a range of 96 mRem to 268 mRem. However, pursuant to 10 CFR 20.1302 (b) (1) an Annual Site Boundary Dose Calculation for Members of the Public, based on Occupancy Time, was performed. The highest calculated dose at the site boundary for 2001 was 0.7 mRem for the Year. These calculations are maintained and updated in the files of the Reactor Health Physicist.

B. Surrounding Environs

A background TLD was deployed ~100 meters from the Reactor Building. The total annual dose recorded on this monitor was 80 mRem.

VII. PERSONNEL RADIATION EXPOSURE AND SURVEYS WITHIN THE FACILITY

A. Personnel Exposure

1) Whole Body

Two part-time employees (SROs) who maintained an office in the building for <10 hours/week were assigned dosimetry at the facility. One of these individuals received a measurable Whole Body exposure (LLD = 10 mRem/month). The dosimetry was provided by ICN Worldwide Dosimetry Service, a National Voluntary Laboratory Accreditation Program (NVLAP) accredited Dosimetry Vendor. The tables and explanations below outline the Whole Body exposure received by the 1 individual.

Whole Body Exposure (mRem)	Number of Individuals
10 to 100	1
> 100 to 250	0
> 250	0
Total	1

ManRem Total: 0.042

Summary: The highest individual Whole Body Exposure was 42 mRem. This exposure was received by the Reactor Health Physicist as a result of handling radioisotopes or performing required Operations and Health Physics Surveillances.

2) Extremity Exposure

Two part-time employees (SROs) who maintained an office in the building for <10 hours/week were assigned dosimetry at the facility and received a measurable Extremity Exposure (LLD = 10 mRem/month).

ManRem Total: 0.342

Summary: The highest individual Extremity Exposure was 342 mRem. This exposure was received by the Reactor Health Physicist as a result of handling radioisotopes or performing required Operations and Health Physics Surveillances.

3) Skin Dose

There were no significant deviations between the Shallow Dose and Deep Dose reported by the vendor for any personnel.

4) Internal Exposure

There were no incidents or events that required investigation or assessment of internal exposure. Contamination levels are acceptably low and areas few (see B. below). There were no evolutions performed or events that occurred which caused, or could have caused, the presence of Airborne Radioactivity.

5) Visitor Exposures

All recorded exposures for Visitors were 0 mRem by Electronic Pocket Dosimeter (EPD).

B. Contamination Surveys

Smear surveys from various locations around the laboratory were taken on a quarterly basis. The removable contamination was determined by counting the smears on an Eberline BC-4 or RM-14/HP-210T Beta Counter, and/or a SAC-4 Scintillation Alpha Counter.

Routine surveys for Alpha Contamination were all < 100 dpm/100 cm².

Routine surveys for beta contamination were all < 1000 dpm/100cm².

VIII. REACTOR COMMITTEE

Dr. David Miller (Illinois Power Company and Adjunct Assistant Professor of Nuclear Engineering) continued as Chairman of the Nuclear Reactor Committee for the 2001-2001 Academic Year. The following members remained on the Committee: Mr. Daniel Hang (Professor Emeritus of Nuclear Engineering), Dr. Brent Heuser (Assistant Professor of Nuclear Engineering), Mr. David Scherer (Campus Radiation Safety Officer), Mr. Rich Holm (Reactor Administrator), Mr. Mark Kaczor (Reactor Health Physicist), and Dr. Jonathan Nadler (Adjunct Assistant Professor of Nuclear Engineering and former licensed SRO on the facility).

The committee held 2 meetings during the calendar year. Major topics reviewed were: a) Reactor Operations and Health Physics Surveillances; b) NRC Annual Report; c) NRC Inspection Report; d) Post 9/11 Security; e) Reports on - Reactor Committee Audit of Operations, Annual Review of the Radiation Protection and ALARA Programs, the Emergency Plan Drill Critique, and Operations and Health Physics Quarterly Reports.