

March 5, 2002
5928-02-20036

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Three Mile Island, Unit 1 (TMI Unit 1)
Facility Operating License No. DPR-50
NRC Docket No. 50-289

Cycle 14 Refueling (T1R14) Inservice Inspection (ISI) Summary Report

Submittal of the Owner's Data Reports for Inservice Inspections is required by the American Society of Mechanical Engineers (ASME) Code, Section XI. Enclosure 1, "NIS-1 Owner's Data Report for Inservice Inspections," covers the 1R14 OTSG examinations and other ISI examinations conducted between December 21, 1999 and December 6, 2001. The report includes the Second Ten Year ISI Interval examinations performed in accordance with the 1986 Code Edition with no addenda, augmented examinations of the reactor vessel shell welds in accordance with the 1989 Code Edition and Third ISI Interval examinations in accordance with the ASME Code, Section XI, 1995 Edition with addenda through 1996.

Attachment 1 to Enclosure 1, Topical Report (TR) No. 151, "Report on the 2001 Outage 1R14 Eddy Current Examinations of the TMI-1 OTSG Tubing," provides the results from the OTSG tube inservice inspections (ISI) in accordance with Technical Specification 4.19.5.b.

Enclosure 2, "Form NIS-2 Owner's Report for Repairs or Replacements," includes the NIS-2 Forms covering repairs or replacements where documentation was completed between December 21, 1999 and March 6, 2002. NIS-2 Reports completed after March 6, 2002 will be included with our next submittal following the Cycle 15 Refueling Outage (T1R15).


Results from containment examinations performed in accordance with ASME Section XI, Subsection IWE are included in this submittal. No containment

A047

March 5, 2002
5928-02-20036
Page 2 of 2

examinations in accordance with Subsection IWL have been performed since our last submittal.

Respectfully,

A handwritten signature in cursive script, appearing to read "George B. Ronbld" followed by a small mark and the word "for".

Michael P. Gallagher
Director – Licensing and Regulatory Affairs

Enclosures

cc: H. J. Miller, USNRC, Regional Administrator, Region I
T. G. Colburn, USNRC, Senior Project Manager, TMI Unit 1
J. D. Orr, USNRC, Senior NRC Resident Inspector, TMI
Barry K. Bobo, Hartford Steam Boiler I&I Co. of CT
File No. 02032