

March 13, 2002

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: **Docket Nos. 50-361 and 50-362**
Annual RCS Specific Activity Report - 2001
San Onofre Nuclear Generating Station, Units 2 and 3

Gentlemen:

Technical Specification (TS) 5.7.1.1 for Units 2 and 3 requires Southern California Edison (SCE) to submit annually the results of specific activity analyses for instances where the primary coolant exceeded the limits of TS 3.4.16. This letter is provided to confirm there were no instances during 2001 in which the RCS specific activity of either unit exceeded these limits.

If you require any additional information, please so advise.

Sincerely,



cc: E. W. Merschhoff, Regional Administrator, NRC Region IV
L. Raghavan, NRC Project Manager, San Onofre Units 2, and 3
C. C. Osterholtz, NRC Senior Resident Inspector, San Onofre Units 2 & 3

A001