



**Duke Power**

526 South Church Street  
P.O. Box 1006  
Charlotte, NC 28201-1006

February 14, 2002

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Subject: Duke Energy Corporation  
Oconee Nuclear Station, Units 1, 2, and 3  
Docket Numbers 50-269, 50-270 and 50-287  
Monthly Performance and Operation Status-January, 2002

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of January, 2002 and REVISION 1 for unit 3 on the Unit Shutdowns page.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

Terry Dimmery, Manager  
Nuclear Business Support

Attachment

XC:

L. A. Reyes, Regional Administrator  
USNRC, Region II

Dave LaBarge, Project Manager  
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin  
Nuclear Assurance Corporation

Dottie Sherman, ANI Library  
American Nuclear Insurers

Oconee NRC Inspector

TE24

Document Control Desk  
U.S. NRC - Ocone

bxc:

L. E. Nicholson (ON03RC)  
RGC Site Licensing File  
ELL (EC050)

# Operating Data Report

Docket No. 50-269  
 Date February 14, 2002  
 Completed By Roger Williams  
 Telephone 704-382-5346

## Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: January 1, 2002 - January 31, 2002
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	744.0	250249.0
12. Number of Hours Reactor was Critical	744.0	744.0	196457.5
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	744.0	193015.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1895800	1895800	477214740
17. Gross Electrical Energy Generated (MWH)	673299	673299	165010071
18. Net Electrical Energy Generated (MWH)	645353	645353	156911942
19. Unit Service Factor	100.0	100.0	77.1
20. Unit Availability Factor	100.0	100.0	77.1
21. Unit Capacity Factor (Using MDC Net)	102.5	102.5	73.4
22. Unit Capacity Factor (Using DER Net)	97.9	97.9	70.8
23. Unit Forced Outage Rate	0.0	0.0	9.5
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: February 14, 2002COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: January, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

Summary:

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

### MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: March 2002
3. Scheduled restart following refueling: April 2002

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
  - (a) in the core: 177
  - (b) in the spent fuel pool: 998\*
  - (c) in the ISFSI: 1488\*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: February 14, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* On March 29, 1990, received a license for ISFSI which will store 2112 assemblies

\*\*\* We currently have 60 modules of which 49 modules are loaded.  
Additional modules will be built on an as-needed basis.

\*\*\*\* Represents the combined total for Units 1, 2, and 3

# Operating Data Report

Docket No. 50-270  
 Date February 14, 2002  
 Completed By Roger Williams  
 Telephone 704-382-5346

## Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: January 1, 2002 - January 31, 2002
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	744.0	240169.0
12. Number of Hours Reactor was Critical	744.0	744.0	194059.4
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	744.0	191506.8
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1911208	3807008	474551422
17. Gross Electrical Energy Generated (MWH)	669960	669960	162415085
18. Net Electrical Energy Generated (MWH)	643027	643027	154758231
19. Unit Service Factor	100.0	100.0	79.7
20. Unit Availability Factor	100.0	100.0	79.7
21. Unit Capacity Factor (Using MDC Net)	102.2	102.2	75.5
22. Unit Capacity Factor (Using DER Net)	97.5	97.5	72.7
23. Unit Forced Outage Rate	0.0	0.0	8.9
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-270UNIT NAME: Oconee 2DATE: February 14, 2002COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: January, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		
<b>Summary:</b>							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

### MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: October, 2002
3. Scheduled restart following refueling: November, 2002

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
  - (a) in the core: 177
  - (b) in the spent fuel pool: 998\*
  - (c) in the ISFSI: See unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: February 14, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* See footnote on Unit 1

\*\*\* We currently have 60 modules of which 49 modules are loaded.  
Additional modules will be built on an as needed basis.

\*\*\*\* See footnote on Unit 1

# Operating Data Report

Docket No. 50-287  
Date February 14, 2002  
Completed By Roger Williams  
Telephone 704-382-5346

## Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: January 1, 2002 - January 31, 2002
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	744.0	237816.0
12. Number of Hours Reactor was Critical	744.0	744.0	187101.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	744.0	184462.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909359	5716367	464726258
17. Gross Electrical Energy Generated (MWH)	672423	672423	159426334
18. Net Electrical Energy Generated (MWH)	645094	645094	152079218
19. Unit Service Factor	100.0	100.0	77.6
20. Unit Availability Factor	100.0	100.0	77.6
21. Unit Capacity Factor (Using MDC Net)	102.5	102.5	74.9
22. Unit Capacity Factor (Using DER Net)	97.9	97.9	72.2
23. Unit Forced Outage Rate	0.0	0.0	9.4
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: February 14, 2002COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: January, 2002

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		
<b>Summary:</b>							

**(1) Reason**

A - Equipment failure (Explain)  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction

E - Operator Training/License Examination  
 F - Administrative  
 G - Operator Error (Explain)  
 H - Other (Explain)

**(2) Method**

1 - Manual  
 2 - Manual Trip/Scram  
 3 - Automatic Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)

### MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April 2003
3. Scheduled restart following refueling: May 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies 

(a)	in the core: <u>177</u>
(b)	in the spent fuel pool: <u>536</u>
(c)	in the ISFSI: <u>See Unit 1 *****</u>
8. Present licensed fuel pool capacity: 825  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: February 14, 2002

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\*\* See footnote of Unit 1

\*\*\* We currently have 60 modules of which 49 modules are loaded.  
Additional modules will be built on an as needed basis.

\*\*\*\* See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

DECEMBER 2001

1. Personnel Exposure -

The total station liquid release for DECEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for DECEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

**\* REVISION 1****UNIT SHUTDOWNS****DOCKET NO.** 50-287**UNIT NAME:** Oconee 3**DATE:** January 15, 2002**COMPLETED BY:** Roger Williams**TELEPHONE:** 704-382-5346**REPORT MONTH:** December, 2001

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
3	12/01/01	S	193.25	C	4		END-OF-CYCLE 19 REFUELING OUTAGE
4	12/09/01	F	120.33	A	4		OUTAGE DELAY OF 5.01 DAYS DUE TO REACTOR VESSEL HEAD NOZZLE REPAIRS

**Summary:**

The unit began the month of December, 2001 in end-of-cycle 19 refueling outage. The refueling outage was delayed 5.01 days due to reactor vessel head nozzle repairs. The end-of-cycle 19 refueling outage spanned 34.01 days. The unit was placed on-line 12/14/01 at 0135 holding at approximately 17% power. The unit held at 28% power from 0253 to 0850 and at 57% power from 12/14/01 at 1301 to 1451 due to nuclear instrumentation calibration. The unit held at 71.4% power from 1736 to 1757 due to high main turbine vibration on bearing #1. On 12/14/01 from 1821 to 12/15/01 at 0407 the unit held at 73% power due to power escalation testing. The unit held at 90% power from 12/15/01 at 0731 to 12/15/01 at 1109 due to nuclear instrumentation calibration. The unit returned to 100% full power on 12/15/01 at 1429 and operated at or near 100% full power the remainder of the month.

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation