



## State of New Jersey

James E. McGreevey  
Governor

Department of Environmental Protection

Bradley M. Campbell  
Acting Commissioner

Division of Environmental Safety, Health  
Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, NJ 08625-0415  
Tel: (609) 984-7700 FAX (609) 984-7513

March 4, 2002

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Ladies and Gentlemen:

SUBJECT:SALEM Unit 2 Generating Station -- Docket No.  
50-311 -- Request for Change to Technical  
Specifications (TS) - "One Time Extension to  
Increase the Interval of the Integrated Leak Rate  
Test from Ten to Fifteen Years" -- LCR S02-01


On January 17, 2002, PSEG Nuclear LLC (PSEG) submitted to the U.S. Nuclear Regulatory Commission (NRC) the subject request for a one-time revision to Technical Specification (TS) 6.8.4.f "Primary Containment Leakage Rate Testing Program".

PSEG evaluated the proposed change and, based on Salem-2 previous successful leak rate tests, and NRC and industry studies, stated that the one-time change request extending the ten-year maximum test interval to up to twenty years would lead to an imperceptible increase in public health and safety risk. In addition, the NRC had approved similar requests for extensions from ten to fifteen years at other plants.

The New Jersey Department of Environmental Protection (NJ DEP) Bureau of Nuclear Engineering (BNE) staff has reviewed the subject change request, per requirements of 10 CFR 50.91(b), and has no comments.

If you have any questions, please contact Richard Pinney at (609) 984-7558.

Sincerely,

A handwritten signature in black ink, appearing to read "Kent Tosch", with a stylized flourish at the end.

Kent Tosch, Manager  
Bureau of Nuclear Engineering

c:

J. Lipoti, Ph.D., Assistant Director Radiation Protection  
Programs, NJDEP

R. Bores, Ph.D., State Liaison - Region 1, U.S. NRC

R. Fretz, Licensing Project Manager, U.S. NRC

G. Salamom, Licensing, PSEG

D. Zannoni, Supervisor, NJDEP/NES