

**CORR: 01-0057**

*Merrifield*  
**CORR: 01-0057**

## COMMISSION CORRESPONDENCE

### Correspondence Response Sheet

**Date:** *April 5, 2001*

I concur subject to attached edits.

**To:** *Chairman Meserve*  
*Commissioner Dicus*  
*Commissioner Diaz*  
*Commissioner McGaffigan*  
*Commissioner Merrifield —*

*[Signature]*  
Jeffrey S. Merrifield, 4/11/01

**From:** *Annette Vietti-Cook, Secretary*

**Subject:** *Letter to James Riccio, Public Citizen's Critical Mass  
Energy & Environmental Program, concerns Indian Point 2  
and NRC's conclusions in an inspection report pertaining  
to the Reactor Protection System*

**ACTION:** *Please comment/concur and respond to the Office of the  
Secretary by:*

**Time:** *3:30 p.m.*

**Day:** *Friday*

**Date:** *April 13, 2001*

**Comment:**

**Contact:** *Patrick Milano, EDO/NRR*  
*415-1457*

**Entered in STARS Tracking System** ☒ **Yes** ☐ **No**

*W/109*



CHAIRMAN

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

Mr. James Riccio  
Public Citizen's Critical Mass Energy  
& Environmental Program  
215 Pennsylvania Avenue SE  
Washington, D.C. 20003

Dear Mr. Riccio:

I am responding to your letter of March 5, 2001 in which you requested that I meet with you and Mr. David Lochbaum regarding the Indian Point Nuclear Generating Unit No. 2 (IP2). I met with you on March 7, 2001, and hope you found this meeting beneficial. Your letter, also raised concerns about conclusions in a recent U.S. Nuclear Regulatory Commission (NRC) inspection report pertaining to the Reactor Protection System (RPS), among other issues. In your letter, you state you have information that contradicts these conclusions and you question the inspector's review of RPS issues was limited to a few Consolidated Edison (Con Edison) condition reports. Finally, you questioned the adequacy of Con Edison's 1997 response to NRC's 10 CFR 50.54(f) letter regarding design basis documentation.

The inspection report to which you referred is a report documenting numerous reviews by NRC resident inspectors and regional specialists between November 19 and December 30, 2000. As this inspection report and a separate letter issued before plant restart indicate, our staff inspected many activities and issues in this period. In addition to performing baseline inspections, we examined activities associated with the modification, testing, and restoration of plant systems after the steam generator replacement. We undertook a variety of special

SHOULD  
BE  
MORE  
SPECIFIC

inspection initiatives to assess the readiness of plant systems and equipment. We devoted a significant effort to assess the issues which emerged during these reviews and plant restoration activities, ~~Numerous issues arose with respect to~~ *including those associated with* the plant design control process and vendor interface affecting such functions as residual heat removal system flow, containment pressure control, diesel generator starting sequence, and battery capacity.

As with all of these issues and consistent with our process, our review of problems reported on the RPS involved the sampling of issues or conditions which, in the judgment of inspectors, potentially affected the ability of equipment to perform intended safety functions. NRC has unfettered access to plant activities, reports and records. During the period before plant restart, in the normal screening of condition reports generated by Con Edison's corrective action process, our resident inspectors became aware of wiring and drawing discrepancies in the RPS. The resident inspectors *and regional specialists* selected for examination condition reports on cable separation problems which potentially affected system operability. ~~The resident inspectors obtained help from a specialist in the region.~~ We believe our inspection and assessment of these issues provided reasonable assurance that the discrepancies reported were not of a nature that would prevent this system from performing its intended safety function. We believe, contrary to your statements regarding "lack of a questioning attitude" by NRC staff, that our inspectors were appropriately thorough.

Our inspections and review of RPS issues continued past restart and the end of the inspection period covered in the January 30, 2001, inspection report. We are still inspecting RPS issues, examining, among other things, information contained in other condition reports some of which you described in your meeting with me. While we continue to identify issues

similar to those previously raised, we have found none that would render the system inoperable. Confidence about operability of the RPS is enhanced by the frequent testing conducted by Con Edison following detailed requirements in the technical specifications. If at any time Con Edison or the NRC were to determine there was a significant problem associated with the RPS, Con Edison would be required to take action in accordance with the condition of their license, up to and including plant shutdown for problems affecting operability. Results of inspections conducted from the beginning of the year are being documented in inspection reports.

*raised concerns with Con Edison*  
*For the past several years,* The NRC has ~~been concerned~~ about the general area of design control and engineering support at the IP2 plant, of which the RPS issues are a subset, ~~for the past several years.~~  
 Along with other performance issues, it was a consideration in designating IP2 as an "agency focus" facility warranting heightened oversight in May 2000. As described most recently by the NRC at the March 2, 2001, public exit ~~for~~ *associated with* the 95003 supplemental inspection, we have continued to identify weaknesses in this area. As we said at the exit meeting, we expect Con Edison to reassess their improvement efforts related to design control and inform us of changes they plan to make to address identified issues. This area will be a topic of discussion at a public meeting with the NRC staff following Con Edison's receipt of the 95003 inspection report.

We have taken numerous steps to keep the public accurately informed of our inspections, assessments, and findings at the IP2 plant. As you know, we instituted a special website and have held numerous public meetings over the past year. We believe, in all of this, that our communications on IP2 matters have been extensive and accurate.