



General Electric Company
Vallecitos Nuclear Center
6705 Vallecitos Road, Sunol, CA 94586

March 12, 2002

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Annual Report for 2001

Reference: License DR-10, Docket 50-183

Gentlemen:

Enclosed are three signed copies of Annual Report No. 34 for the deactivated ESADA-Vallecitos Experimental Superheat Reactor located at Vallecitos Nuclear Center in Sunol, California.

If there are any questions or additional information is required, please contact the undersigned at 925-862-4455.

Sincerely,

Chris Hamilton
Senior Licensing Engineer

Enclosures (3)

A020
A001



GE Nuclear Energy

*Vallecitos Nuclear Center
General Electric Company
Sunol, California*

**ESADA-VALLECITOS EXPERIMENTAL
SUPERHEAT REACTOR
(DEACTIVATED)**

**ANNUAL REPORT NO. 34
FOR THE YEAR 2001**

**LICENSE DR-10
DOCKET 50-183**

MARCH 2002

ESADA-Vallecitos Experimental Superheat Reactor (Deactivated)

Annual Report No. 34

General Electric Company has maintained the ESADA Vallecitos Experimental Superheat Reactor (EVESR) in a deactivated status under the authority of Amendment No. 3 to License DR-10, Docket 50-183, issued June 11, 1976. In this annual report, a summary of the status of the facility for the period of January 1, 2001 to December 31, 2001 is presented, as required by paragraph 3.E.2. of the license.

1.0 SUMMARY

The facility remains in essentially the same condition described in Annual Report No. 33. Entry into the containment building was made for routine radiation surveys, a general examination of conditions throughout the building, and a maintenance project. In accordance with written procedures, the Facility Manager controls access to the containment building.

Radiation levels remain essentially unchanged.

2.0 STATUS OF FACILITY

The facility continues to be in deactivated status. The plugs to the reactor vessel and head storage shield, the wooden cover over the fuel storage pool, and the locked covers for the personnel and equipment hatchways remain in-place except during maintenance or inspection activities.

3.0 RADIATION AND CONTAMINATION

Complete radiation and contamination surveys of the facility indicate that levels remain low. Results of the surveys are presented in Table 1. The radiation/contamination levels listed are representative but not necessarily maximum values.

4.0 ACTIVITIES

Routine inspections were conducted during this report period. There were no preventive or corrective maintenance activities performed having safety significance during the reporting

period.

5.0 ORGANIZATION

The management and operations organization for the EVESR is described in Technical Specification IX of License DR-10. Although the organizational structure remains the same, the General Manager has changed due to the retirement of G.L. Stimmell. The new General Manager is L.M. Quintana.

6.0 CONCLUSION

The General Electric Company concludes that the deactivated ESADA-Vallecitos Experimental Superheat Reactor is being maintained in a safe shutdown condition. The inspections, access control, and administratively controlled activities ensure maximum protection for the public health and safety. The procedures will be continued to maintain this high level of protection.

GENERAL ELECTRIC COMPANY
Vallecitos Operations



F.A. Arlt, Manager
Facilities Maintenance

Table 1
Radiation and Contamination Level Data
ESADA-Vallecitos Experimental Superheat Reactor (Deactivated)

Date of Measurement:	Contamination Levels					
	Radiation Levels (mR/h Gamma)		Surface Smears Beta-Gamma [*] (cpm/ft ² x 10 ³)		Airborne Beta-Gamma [†] (μ Ci/cc x 10 ⁻¹⁰)	
	12/00	12/01	12/00	12/01	12/00	12/01
Reactor Enclosure						
Top of spent fuel pool (main floor)	0.7	<1	--	--	--	--
549-ft level (main floor)	<1-1.5	<1	500	400	0.009	0.014
534-ft level	<1-4	<1-3	--	--	--	--
519-ft level	<1-4	<1	--	--	0.015	0.025
503-ft level (maximum pipe reading)	0.5	<0.5	--	--	--	--
487-ft level (basement)	<1	<1	--	--	0.002	0.004

Note:

Radiation levels, surface smears, and air samples may vary from survey to survey as they are taken in general areas rather than at specific locations.

^{*} For conversion to d/m, assume an instrument efficiency of 20%.

[†] 24-hour decayed values