

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
148100	Valve RC-427 2" Gate Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															
148300	CVC-02-LD-1001-19 Valve RC-427 to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Letdown from Loop B Cold Leg / Dwg. No. ISI-PRI-1147															
149000	CVC-02-LD-1001-20 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
149100	CVC-02-LD-1001-21 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
149200	CVC-02-LD-1001-22 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
149300	CVC-02-LD-1001-23 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
149400	44-23-PSSA Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
149600	44-23-PSSB Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
149900	44-23-PSSC Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
150100	CVC-02-LD-1001-25 Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
150200	CVC-02-LD-1001-26 Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
150300	44-23-PSSD Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
150500	CVC-02-LD-1001-27 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
150600	CVC-02-LD-1001-28 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
150700	44-28-PSSA Rigid Support	F-A F1.10B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
150800	44-28-PSSE Rigid Support	F-A F1.10B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
150900	CVC-02-LD-1001-29 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151000	CVC-02-LD-1001-30 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151200	CVC-02-LD-1001-31 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151300	CVC-02-LD-1001-31A Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
151500	CVC-02-LD-1001-32 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151600	CVC-02-LD-1001-32B Tee to Insert	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151700	CVC-02-LD-1001-32A Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
151800	44-32A-PSS Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
151900	CVC-02-LD-1001-33 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152000	CVC-02-LD-1001-34 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152100	CVC-02-LD-1001-35 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152200	CVC-02-LD-1001-36 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152300	CVC-02-LD-1001-37 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152400	CVC-02-LD-1001-38 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
152500	CVC-02-LD-1001-39 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152600	CVC-02-LD-1001-40 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152700	CVC-02-LD-1001-41 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152800	CVC-02-LD-1001-42 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
152900	CVC-02-LD-1001-43 Pipe to Nozzle	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop A Drain / Dwg. No. ISI-PRI-1148</u>															
154000	RC-02-DR-1002-01 Branch Connection to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
154100	RC-02-DR-1002-02 Pipe to Elbow	R-A R1.11	VOL	-	-	-	-	X	-	-	-	-	-	-	-
154200	RC-02-DR-1002-02A Elbow to Pipe	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
154300	RC-02-DR-1002-02B Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
154400	RC-02-DR-1002-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
154600	RC-02-DR-1002-03A Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
154700	RC-02-DR-1002-03B Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
155000	45-03-PR Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
155100	RC-02-DR-1002-04 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
155200	RC-02-DR-1002-05 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
155700	45-05-PRA Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
155900	45-05-PRB Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
156000	RC-02-DR-1002-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
156100	RC-02-DR-1002-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
156300	45-07-PR Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
156500	RC-02-DR-1002-07A Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
156600	RC-02-DR-1002-07B Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
156800	45-07-PSA Rigid Support	F-A F1.10B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
157100	45-07-PSB Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
157200	RC-02-DR-1002-08 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157300	RC-02-DR-1002-09 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157400	RC-02-DR-1002-10 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157500	RC-02-DR-1002-11 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157600	RC-02-DR-1002-11A Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157700	RC-02-DR-1002-11B Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
157800	RC-02-DR-1002-12 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
157900	RC-02-DR-1002-13 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
158000	RC-02-DR-1002-14R1 Pipe to Cap	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
158100	RC-02-DR-1002-17 Tee to Insert	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection to Loop B Cold Leg / Dwg. No. ISI-PRI-1149</u>															
159000	Valve SI-845B 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															
159100	SIS-02-SI-1002-04 Valve SI-845B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159200	SIS-02-SI-1002-05 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159300	SIS-02-SI-1002-06 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159400	SIS-02-SI-1002-07 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159500	SIS-02-SI-1002-08 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
159600	46-08-PR Rigid Support	F-A F1.10B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
159700	SIS-02-SI-1002-09 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159800	SIS-02-SI-1002-10 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
159900	SIS-02-SI-1002-10A Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160000	SIS-02-SI-1002-10B Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160100	SIS-02-SI-1002-11 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160200	SIS-02-SI-1002-12 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160300	46-12-PR Rigid Support	F-A F1.10B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
160400	SIS-02-SI-1002-13 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160500	SIS-02-SI-1002-14 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
160550	1-SI-878B-4 Rigid Support	F-A Fl.10A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
Examination to be performed during U1R27 to satisfy IWF-2210(b).															
160600	SIS-02-SI-1002-15 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160700	SIS-02-SI-1002-16 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
160800	1SI-878B-6 Component Support	F-A Fl.10A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
160900	1SI-878B-7 Component Support	F-A Fl.10A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
161000	1SI-878B-8 Component Support	F-A Fl.10A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
161100	1SI-878B-9 Spring Hanger	F-A Fl.10C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
161300	SIS-02-SI-1002-17 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
161400	SIS-02-SI-1002-18 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
161500	SIS-02-SI-1002-19 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
161600	SIS-02-SI-1002-20 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
161700	SIS-02-SI-1002-21 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
161800	SIS-02-SI-1002-22 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
161900	SIS-02-SI-1002-25 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
162000	SIS-02-SI-1002-26 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
162100	SIS-02-SI-1002-27 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
162200	SIS-02-SI-1002-32 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
162300	SIS-02-SI-1002-33 Pipe to Branch Connection	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
163000	SIS-02-SI-1005-01 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
163100	46-01-PR Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
163200	SIS-02-SI-1005-02 Pipe to Valve SI-845F	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
163300	Valve SI-845F 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															
<u>High Head Safety Injection to Loop A / Dwg. No. ISI-PRI-1150</u>															
164000	Valve SI-845E 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															
164100	SIS-02-SI-1004-04A Valve SI-845E to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164200	SIS-02-SI-1004-05A Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164300	SIS-02-SI-1004-06A Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164400	SIS-02-SI-1004-07A Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164500	SIS-02-SI-1004-09A Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164600	SIS-02-SI-1004-10A Valve SI-845A to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
164700	Valve SI-845A 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
164800	SIS-02-SI-1004-08A Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
164900	SIS-02-SI-1004-09 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
165000	SIS-02-SI-1004-10 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
165100	SIS-02-SI-1004-11 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
165200	SIS-02-SI-1004-12 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
165300	24-12-PRA Rigid Support	F-A F1.10C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-
165400	24-12-PRB Rigid Support	F-A F1.10C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-
165500	24-12-PRC Rigid Support	F-A F1.10C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-
165600	SIS-02-SI-1004-13 Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
165700	SIS-02-SI-1004-14 Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
165800	SIS-02-SI-1004-15 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
165900	SIS-02-SI-1004-16 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166000	SIS-02-SI-1004-17 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166100	SIS-02-SI-1004-18 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166200	SIS-02-SI-1004-18A Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166300	SIS-02-SI-1004-18B Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166400	SIS-02-SI-1004-18C Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166500	SIS-02-SI-1004-18D Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166600	SIS-02-SI-1004-19 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
166700	SIS-02-SI-1004-20 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
166800	24-20-PS Rigid Support			-	-	-	-	-	-	-	-	-	-	-	-
Plant ID is 1SI-878D-6. Support removed from service during U1R26 under WO 9929844.															
166900	SIS-02-SI-1004-21 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167000	SIS-02-SI-1004-22 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167100	SIS-02-SI-1004-23 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167200	SIS-02-SI-1004-24 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167300	SIS-02-SI-1004-25 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167400	SIS-02-SI-1004-26 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167500	SIS-02-SI-1004-27 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
167600	SIS-02-SI-1004-28 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

				PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
SUMMARY	EXAMINATION AREA	CATEGORY	NDE					O U T A G E							
NUMBER	IDENTIFICATION	ITEM NO	METH	1	2	3	4	1	2	3	4	1	2	3	4
<u>Accumulator A to Loop A / Dwg. No. ISI-PRI-1150</u>															
167700	SIS-02-SI-1004-29 Pipe to Branch Connection	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
.....															
<u>Auxiliary Charging / Dwg. No. ISI-PRI-1151</u>															
169000	Valve CV-1296 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required due to size.															
169100	CVC-02-ACH-1001-01 Valve CV-1296 to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169200	CVC-02-ACH-1001-02 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169300	CVC-02-ACH-1001-03 Tee to Reducing Insert	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169400	CVC-02-ACH-1001-04 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169500	CVC-02-ACH-1001-05 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169600	CVC-02-ACH-1001-06 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
169700	CVC-02-ACH-1001-07 Pipe to Valve CV-320C	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
169800	Valve CV-320C 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required due to size.														
169900	CVC-02-ACH-1001-08 Valve CV-320C to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170000	CVC-02-ACH-1001-09 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170100	CVC-02-ACH-1001-10 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170200	39-19-PS Rigid Support	F-A F1.10B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
170300	CVC-02-ACH-1001-11 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170400	CVC-02-ACH-1001-12 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170500	CVC-02-ACH-1001-13 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170600	CVC-02-ACH-1001-14 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
170700	39-14-PR Rigid Support	F-A F1.10B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 1 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS															
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD							
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3	4
<u>Steam Generator's HX-1A and HX-1B / Dwg. No. ISI-PRI-1201</u>																			
200000	SG-A-1 Tubesheet to Stub Barrel Cal Block: 41-PTB Serial number 92639, WRGT 4051, Spin No. WRS-RCPCSG-01	C-A Cl.30	VOL	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-
200100	SG A Stub Barrel Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.																			
200200	SG-A-2 Shell to Stub Barrel Weld Cal Block: 41-PTB	C-A Cl.10	VOL	-	-	-	-	-	-	-	-	-	-	-	-	X	-	-	-
200300	SG A Shell Section A Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.																			
200400	SG A Girth Seam No. 4 Shell A to Shell B			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not at a gross structural discontinuity.																			
200500	SG A Shell Section B Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.																			
200600	SG-A-3 Shell to Transition Cone Weld Cal Block: 41-PTB	C-A Cl.10	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
200700	SG A Cone Seam Weld No. 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.																			
200800	SG A Cone Seam Weld No. 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.																			
200900	SG-A-4 Transition Cone to Shell Weld Cal Block: 41-PTB	C-A Cl.10	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
201000	SG A Upper Barrel Lower Shell Seam 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
201100	SG A Upper Barrel Lower Shell Seam 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
201200	SG A Upper Shell Barrel Weld Lower Barrel to Upper Barrel			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not at a gross structural discontinuity.															
201300	SG A Upper Barrel Top Shell Seam 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
201400	SG A Upper Barrel Top Shell Seam 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
201500	SG-A-5 Shell to Head Circumferential Weld Cal Block: 41-PTB	C-A C1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
201600	SG-A-6 Feedwater Nozzle to Shell Cal Block: 41-PTB	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
201700	SG-A-6-IRS Feedwater Nozzle Inside Radius Section Cal Block: 42-PTB	C-B C2.22	VOL	-	-	-	-	-	-	-	-	-	-	-	-
201800	SG-A-7 Shell to Main Steam Nozzle Cal Block: 41-PTB	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
201900	SG-A-7-IRS Main Steam Nozzle Inside Radius Section Cal Block: 42-PTB	C-B C2.22	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
202000	HS-5 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Examination to be performed in conjunction with the snubber program.															
202100	HS-6 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Examination to be performed in conjunction with the snubber program.															
202200	HS-7 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Examination to be performed in conjunction with the snubber program.															
203000	SG-B-1 Tubesheet to Stub Barrel Cal Block: 41-PTB Serial number 93382, WRGT 4052, Spin No. WRS-RCPCSG-02	C-A C1.30	VOL	-	-	-	-	-	-	-	-	-	-	-	-
203100	SG B Stub Barrel Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
203200	SG-B-2 Shell to Stub Barrel Weld Cal Block: 41-PTB	C-A C1.10	VOL	-	-	-	-	-	-	-	-	-	-	-	-
203300	SG B Shell Section A Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
203400	SG B Girth Seam No. 4 Shell A to Shell B			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not at a gross structural discontinuity.															
203500	SG B Shell Section B Seam Weld Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
203600	SG-B-3 Shell to Transition Cone Weld Cal Block: 41-PTB	C-A C1.10	VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
203700	SG B Cone Seam Weld No. 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
203800	SG B Cone Seam Weld No. 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
203900	SG-B-4 Transition Cone to Shell Weld Cal Block: 41-PTB	C-A C1.10	VOL	-	-	-	-	X	-	-	-	-	-	-	-
204000	SG B Upper Barrel Lower Shell Seam 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
204100	SG B Upper Barrel Lower Shell Seam 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
204200	SG B Upper Shell Barrel Weld Lower Barrel to Upper Barrel			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not at a gross structural discontinuity.															
204300	SG B Upper Barrel Top Shell Seam 1 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
204400	SG B Upper Barrel Top Shell Seam 2 Seam Weld			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Weld is not addressed by Section XI.															
204500	SG-B-5 Shell to Head Circumferential Weld Cal Block: 41-PTB	C-A C1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
204600	SG-B-6 Feedwater Nozzle to Shell Cal Block: 41-PTB	C-B C2.21	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
206300	RHE-08 Shell to Head Cal Block: 17-PTB	C-A C1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
206400	RHE-11 Shell to Tube Sheet Cal Block: 17-PTB	C-A C1.30	VOL	-	-	-	-	-	-	-	-	-	-	-	-
206500	RHE-12 Shell to Head Cal Block: 17-PTB	C-A C1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
206600	RHE-N2 Shell to Nozzle Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
206700	RHE-N3 Nozzle to Shell Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
206800	RHE-N6 Shell to Nozzle Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
206900	RHE-N7 Nozzle to Shell Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
207000	RHE-N10 Shell to Nozzle Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
207100	RHE-N11 Nozzle to Shell Cal Block: 17-PTB No examination required. Nozzle is not greater than 4 NPS.	C-B C2.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
209000	RHR-B-1 Shell to Head Cal Block: 43-PTB	C-A C1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
209100	RHR-B-2 Shell to Flange Cal Block: 43-PTB	C-A C1.10	VOL	-	-	-	-	X	-	-	-	-	-	-	-
209200	RHR-B-N1 Nozzle to Shell	C-B C2.33	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Weld is located under a reinforcement plate and is inaccessible. Examine the telltale hole in the reinforcing plate during the system leakage test. If the inside surface becomes available, the weld will be examined at that time.															
209300	RHR-B-N2 Shell to Nozzle	C-B C2.33	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Weld is located under a reinforcement plate and is inaccessible. Examine the telltale hole in the reinforcing plate during the system leakage test. If the inside surface becomes available, the weld will be examined at that time.															
209400	RHR-B-N3 Inlet Nozzle Reinforcing Plate Welds	C-B C2.31	SUR	-	-	-	-	-	-	-	-	X	-	-	-
Examine the plate to nozzle and plate to shell welds.															
209500	RHR-B-N4 Outlet Nozzle Reinforcing Plate Welds	C-B C2.31	SUR	-	-	-	-	-	-	-	-	X	-	-	-
Examine the plate to nozzle and plate to shell welds.															
209600	RHR-B-LEG-1 thru 4 Component Support	F-A F1.40	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
209700	RHR-B-LEG-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RHR to Accumulator B line in PAB / Dwg. No. ISI-PRI-1220															
211000	AC-10-RHR-1001-01 Reducer to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211100	AC-10-RHR-1001-02 Reducer to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211300	AC-10-RHR-1001-03 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211500	AC-10-RHR-1001-04 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211600	AC-10-RHR-1001-05 Elbow to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211700	AC-10-RHR-1001-06 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211800	AC-10-RHR-1001-07 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
211900	AC-601R-6-H9 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
212000	AC-601R-6-H9-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
212100	AC-10-RHR-1001-08 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
212200	AC-10-RHR-1001-09 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
212300	AC-10-RHR-1001-10 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
212400	AC-601R-6-H10 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
212500	AC-601R-6-H10-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
212600	AC-10-RHR-1001-11 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
212700	AC-10-RHR-1001-12 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
212800	AC-601R-6-R331 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
212900	AC-10-RHR-1001-13 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
213000	AC-10-RHR-1001-14 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
213100	AC-10-RHR-1001-15 Pipe to Tee Cal Block: 33-PTB	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
213300	AC-10-RHR-1001-16 Tee to Pipe Cal Block: 33-PTB	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
213500	AC-10-RHR-1001-17 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
213550	AC-601R-6-R351 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
213600	AC-601R-6-H33 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
213700	AC-601R-6-H33-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	X	-	-	-	-	-	-	-
213800	AC-10-RHR-1001-18 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214000	AC-10-RHR-1001-19 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214100	AC-10-RHR-1001-20 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214300	AC-601R-6-H34 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
214400	AC-10-RHR-1001-21 Pipe to Flange Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
214500	AC-10-RHR-1001-22 Flange to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214600	AC-10-RHR-1001-23 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214700	AC-10-RHR-1001-24 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
214800	AC-10-RHR-1001-25 Pipe to Flued Head Cal Block: 33-PTB Weld is located inside penetration and is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR to Accumulator B Line in Containment / Dwg. No. ISI-PRI-1221</u>															
215900	AC-601R-6-A3 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
216000	AC-10-RHR-1001-26 Flued Head to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
216100	AC-10-RHR-1001-27 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
216300	AC-10-RHR-1001-28 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
216500	AC-10-RHR-1001-29 Elbow to Pipe Cal Block: 33-PTB Weld is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
216700	AC-10-RHR-1001-30 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
216800	AC-10-RHR-1001-31 Pipe to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
216900	AC-10-RHR-1001-36 Tee to Reducer Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
217000	AC-10-RHR-1001-32 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
217200	AC-10-RHR-1001-33 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
217300	AC-10-RHR-1001-34 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
217500	AC-601R-6-AC-1 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
217600	AC-10-RHR-1001-35 Pipe to Valve RH-720 Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Pump A Suction from Cont Sump & Loop A Hot Leg / Dwg. No. ISI-PRI-1222</u>															
218000	AC-08-RHR-1005-01 Reducer to Valve RH-718A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
218100	Valve 1RH-718A 8" Check Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
218200	AC-08-RHR-1005-02 Valve RH-718A to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
218300	AC-601R-2-H2 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
218400	AC-601R-2-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
218450	AC-601R-2-R352 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
218500	AC-08-RHR-1005-03 Pipe to Valve RH-704A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
218600	Valve 1RH-704A 8" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
218700	AC-08-RHR-1005-04 Valve RH-704A to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
218800	AC-08-RHR-1005-06 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
219000	AC-08-RHR-1005-07 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
219100	AC-601R-2-H6 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
219200	AC-601R-2-H6-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
219250	AC-601R-2-R351A Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
219300	AC-08-RHR-1005-08 Elbow to Pipe Cal Block: 31-PTB Inaccessible/support limitations.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
219500	AC-601R-2-R351-1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
219700	AC-08-RHR-1005-09 Pipe to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
220000	Valve RH-856A 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
220100	AC-10-RHR-1002-01 Valve SI-856A to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
220200	AC-601R-3-H-5A Spring Support	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
220300	AC-601R-3-H-5A-IWA Welded Attachment	C-C C3.20	SUR	X	-	-	-	-	-	-	-	-	-	-	-
220400	AC-10-RHR-1002-02 Pipe to Valve SI-854A Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
220500	Valve RH-854A 10" Check Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
220600	AC-10-RHR-1002-03 Valve SI-854A to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
220700	AC-601R-3-H5 Rigid Support	F-A F1.20A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
220800	AC-10-RHR-1002-04 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
220900	AC-10-RHR-1002-05 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221000	AC-10-RHR-1002-06 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221200	AC-601R-3-R348 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
221300	AC-10-RHR-1002-07 Pipe to Elbow Cal Block: 33-PTB WELD INACCESSIBLE DUE TO PENETRATION IN WALL.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221400	AC-10-RHR-1002-08 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221500	AC-601R-3-H4 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
221550	AC-601R-3-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
221600	AC-10-RHR-1002-08A Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221800	AC-10-RHR-1002-09 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
221900	AC-10-RHR-1002-10 Elbow to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222000	AC-10-RHR-1002-11 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222100	AC-10-RHR-1002-12 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222200	AC-10-RHR-1002-13 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222450	AC-601R-3-R345 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
222500	AC-10-RHR-1002-14 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222600	AC-10-RHR-1002-15 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
222700	AC-601R-3-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
222800	AC-601R-3-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
222900	AC-10-RHR-1002-16 Pipe to Flange Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
223000	RHR Pump P-10A RHR Pump No examination required			-	-	-	-	-	-	-	-	-	-	-	-
224000	Valve SI-850A 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
224100	Valve SI-850A-Welds Two Valve Body Welds Examine valve body welds after U1R26 on only one of two valves, SI-850A or SI-850B. Perform remaining examinations not completed during 1992 outage. Includes MT of CS welds and PT of actuator housing to valve body weld.	C-G C6.20	SUR	X	-	-	-	-	-	-	-	-	-	-	-
224200	SI-151R-X-H209 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
224300	SI-151R-X-H208 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
224400	AC-10-RHR-1003-04 Valve SI-850A to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
224500	AC-10-RHR-1003-04A Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
224600	AC-10-RHR-1003-05 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
224700	SI-151R-X-H203 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Support is embedded in wall.															
224800	AC-10-RHR-1003-06 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
224900	AC-601R-1-H4 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
225000	AC-601R-1-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
225100	AC-10-RHR-1003-07 Elbow to Valve SI-851A Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
225200	Valve SI-851A 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
225300	AC-10-RHR-1003-08 Valve SI-851A to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
225400	AC-10-RHR-1003-09 Pipe to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Pump B Suction from Cont Sump & Loop A Hot Leg / Dwg. No. ISI-PRI-1223</u>															
226000	AC-08-RHR-1006-01 Tee to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
226100	AC-08-RHR-1006-02 Elbow to Valve RH-718B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
226200	Valve RH-718B 8" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
226300	AC-08-RHR-1006-03 Valve RH-718B to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
226400	AC-601R-2-H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
226450	AC-601R-2-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
226500	AC-08-RHR-1006-04 Pipe to Valve RH-704B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
226600	Valve RH-704B 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
226700	AC-08-RHR-1006-05 Valve RH-704B to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
226800	AC-601R-2-R354 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
226900	AC-08-RHR-1006-06 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
227000	AC-08-RHR-1006-07 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
227050	AC-601R-2-R334-2 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
227200	AC-08-RHR-1006-08 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
227300	AC-08-RHR-1006-09 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
227400	AC-601R-3-H8 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
227600	AC-08-RHR-1006-10 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
227700	AC-601R-2-R351-2 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
227800	AC-08-RHR-1006-11 Pipe to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229000	Valve 1SI-856B 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
229100	AC-10-RHR-1004-01 Valve SI-856B to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229200	AC-601R-3-H7 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
229300	AC-10-RHR-1004-02 Pipe to Valve SI-854B Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229400	Valve SI-854B 10" Check Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
229500	AC-10-RHR-1004-03 Valve SI-854B to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229600	AC-10-RHR-1004-04 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229800	AC-10-RHR-1004-05 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
229900	AC-10-RHR-1004-06 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
230000	AC-601R-2-R357A Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
230200	AC-10-RHR-1004-07 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
230300	AC-601R-3-H1 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
230400	AC-601R-3-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
230500	AC-10-RHR-1004-08 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
230600	AC-10-RHR-1004-09 Pipe to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
230700	AC-10-RHR-1004-10 Tee to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
230800	AC-601R-3-H2A Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
230850	AC-601R-3-H2A-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
230900	AC-10-RHR-1004-11 Pipe to Flange Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
231000	RHR Pump P-10B RHR Pump No examination required			-	-	-	-	-	-	-	-	-	-	-	-
232000	Valve SI-850B 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
232100	Valve SI-850B-Welds Valve Body Welds	C-G C6.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Examine both valve body welds after UIR26 on only one of two valves, SI-850A or SI-850B. Perform remaining examinations not completed during 1992 outage. Includes MT of CS welds and PT of actuator housing to valve body weld.															
232200	SI-151R-X-H207 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
232300	SI-151R-X-H206 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
232400	AC-10-RHR-1005-04 Valve SI-850B to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
232500	AC-10-RHR-1005-04A Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
232600	AC-10-RHR-1005-05 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
232700	SI-151R-X-H205 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
232800	AC-601R-1-H3 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
232850	AC-601R-1-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
232900	AC-10-RHR-1005-06 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
233000	AC-10-RHR-1005-07 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
233100	AC-10-RHR-1005-08 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
233200	AC-601R-1-H201 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
233300	AC-10-RHR-1005-09 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
233400	AC-10-RHR-1005-10 Pipe to Valve SI-851B Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
233500	Valve SI-851B 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
233600	AC-10-RHR-1005-11 Valve SI-851B to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
233700	AC-601R-1-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
233800	AC-601R-1-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
233900	AC-10-RHR-1005-12 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
234000	AC-10-RHR-1005-13 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
234200	AC-10-RHR-1005-14 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
234300	AC-10-RHR-1005-15 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
234500	AC-601R-1-H1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
234550	AC-601R-1-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
234600	AC-10-RHR-1005-16 Pipe to Tee Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
234800	AC-601R-2-R354 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Pump Suction from Loop A Hot Leg in Cont. / Dwg. No. ISI-PRI-1224</u>															
236000	AC-10-RHR-1006-01 Valve RH-701 to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
236100	AC-601R-2-R145 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
236200	AC-10-RHR-1006-02 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
236300	AC-10-RHR-1006-03 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
236400	AC-10-RHR-1006-04 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
236600	AC-601R-2-R146 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
236700	AC-601R-2-R147 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
236750	AC-601R-2-R147-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
236800	AC-10-RHR-1006-04A Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
236900	AC-10-RHR-1006-04B Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237000	AC-601R-2-R148 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
237050	AC-601R-2-R148-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
237100	AC-10-RHR-1006-04C Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237200	AC-601R-2-R149 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
237250	AC-601R-2-R149-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
237300	AC-10-RHR-1006-04D Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237500	AC-601R-2-R151 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
237550	AC-601R-2-R151-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
237600	AC-10-RHR-1006-05 Pipe to Elbow Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237700	AC-10-RHR-1006-06 Elbow to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237800	AC-10-RHR-1006-07 Pipe to Flued Head Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
237810	AC-601R-2-A15 Anchor Penetration 7	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
237850	AC-601R-2-A15-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
237900	AC-10-RHR-1006-08 Flued Head to Pipe Cal Block: 33-PTB Weld is located inside of penetration and is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
238000	AC-10-RHR-1006-09 Pipe to Pipe Cal Block: 33-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS													
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	O	U	T	A	G	E	1	2	3	4
239600	AC-601R-6-H5 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	X	-	-	-
239650	AC-601R-6-H5-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	X	-	-	-
239700	AC-08-RHR-1001-06 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
239800	AC-08-RHR-1001-07 Elbow to Flange Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
239900	Valve RH-624 8" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-	-	-
240000	AC-08-RHR-1001-08 Flange to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
240100	AC-08-RHR-1001-09 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	X	-	-	-	-
240200	AC-08-RHR-1001-10 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-	-	-
240400	AC-08-RHR-1001-11 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
240500	AC-601R-6-H4 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	X	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
240550	AC-601R-6-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	X	-	-	-
240600	AC-08-RHR-1001-12 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
240700	AC-601R-6-R325 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
240800	AC-08-RHR-1001-13 Pipe to Valve RH-716A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
240900	Valve RH-716A 10" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
241000	AC-08-RHR-1001-14 Valve RH-716A to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Heat Exchanger HX-11B Outlet / Dwg. No. ISI-PRI-1226</u>															
242000	AC-08-RHR-1002-01 Nozzle to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
242100	AC-08-RHR-1002-02 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
242200	AC-08-RHR-1002-03 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
242400	AC-08-RHR-1002-04 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
242500	AC-08-RHR-1002-05 Elbow to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
242600	AC-08-RHR-1002-06 Tee to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
242700	AC-601R-6-H1 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
242750	AC-601R-6-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
242800	AC-08-RHR-1002-07 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
242900	AC-08-RHR-1002-08 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
243100	AC-08-RHR-1002-09 Pipe to Flange Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
243200	Valve RH-625 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
243300	AC-08-RHR-1002-10 Flange to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
243400	AC-08-RHR-1002-11 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
243500	AC-08-RHR-1002-12 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
243700	AC-08-RHR-1002-13 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
243800	AC-601R-6-H2 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
243850	AC-601R-6-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
243900	AC-08-RHR-1002-14 Elbow to Pipe Cal Block: 31-PTB The weld is inaccessible due to support 6H-02.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
244000	AC-601R-6-R323 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
244100	AC-08-RHR-1002-15 Pipe to Valve RH-716B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
244200	Valve RH-716B 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
244300	AC-08-RHR-1002-16 Valve RH-716B to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
244400	AC-08-RHR-1002-17 Tee to Valve RH-716C Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2. COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
244500	Valve RH-716C 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
244600	AC-08-RHR-1002-18 Valve RH-716C to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
244700	AC-601R-6-H3 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
244750	AC-601R-6-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
244800	AC-08-RHR-1002-19 Pipe to Valve RH-716D Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
244900	Valve RH-716D 10" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
245000	AC-08-RHR-1002-20 Valve RH-716D to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Pumps Discharge to HX-11A and Crosstie / Dwg. No. ISI-PRI-1227</u>															
246000	AC-08-RHR-1003-01 Flange to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246100	AC-08-RHR-1003-02 Reducer to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246200	AC-08-RHR-1003-03 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
246300	AC-08-RHR-1003-03A Pipe to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246400	AC-08-RHR-1003-04 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246500	AC-08-RHR-1003-05 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246600	AC-08-RHR-1003-06 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246700	AC-08-RHR-1003-07 Elbow to Valve RH-710A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
246800	Valve RH-710A 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
246900	AC-08-RHR-1003-08 Valve RH-710A to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247000	AC-601R-4-H6 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
247050	AC-601R-4-H6-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
247100	AC-08-RHR-1003-09 Pipe to Valve RH-709A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
247200	Valve RH-709A 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
247300	AC-08-RHR-1003-10 Valve RH-709A to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247400	AC-08-RHR-1003-11 Flange to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247500	AC-08-RHR-1003-12 Reducer to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247600	AC-08-RHR-1003-13 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247700	AC-08-RHR-1003-13A Pipe to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247800	AC-08-RHR-1003-14 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
247900	AC-08-RHR-1003-15 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
248000	AC-601R-4-H200 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
248100	AC-08-RHR-1003-16 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

						PLAN STATUS											
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	O U T A G E				1	2	3	4		
248200	AC-08-RHR-1003-17 Elbow to Valve RH-710B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	
248300	Valve RH-710B 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-	-	
248400	AC-08-RHR-1003-18 Valve RH-710B to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	
248500	AC-601R-4-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	
248550	AC-601R-4-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	
248600	AC-08-RHR-1003-19 Pipe to Valve RH-709B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	
248700	Valve RH-709B 8" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-	-	
248800	AC-08-RHR-1003-20 Valve RH-709B to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	
249000	AC-08-RHR-1003-21 Tee to Valve RH-713B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	
249100	Valve RH-713B 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-	-	

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

					PLAN STATUS											
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
249200	AC-08-RHR-1003-22 Valve RH-713B to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
249300	AC-08-RHR-1003-23 Pipe to Valve RH-713A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
249400	Valve RH-713A 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-	
249500	AC-08-RHR-1003-24 Valve RH-713A to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
249600	AC-08-RHR-1003-25 Tee to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
249700	AC-08-RHR-1003-26 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
249900	AC-08-RHR-1003-27 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	
250000	AC-601R-4-H9 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	
250050	AC-601R-4-H9-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	
250100	AC-08-RHR-1003-28 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
250200	AC-08-RHR-1003-29 Elbow to Pipe Cal Block: 31-PTB Inaccessible/support limitations.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
250300	AC-601R-4-R343 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
250400	AC-08-RHR-1003-30 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
250500	AC-08-RHR-1003-31 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
250700	AC-08-RHR-1003-32 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
250800	AC-08-RHR-1003-33 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
250900	AC-08-RHR-1003-34 Pipe to Tee Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
251000	AC-08-RHR-1003-35 Tee to Valve RH-715A Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
251100	Valve RH-715A 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
251200	AC-08-RHR-1003-36 Valve RH-715A to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
251300	AC-08-RHR-1003-37 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
251400	AC-08-RHR-1003-38 Pipe to Nozzle Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Heat Exchanger HX-11B Inlet / Dwg. No. ISI-PRI-1228</u>															
252000	AC-08-RHR-1004-01 Tee to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
252100	AC-08-RHR-1004-02 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
252200	AC-08-RHR-1004-03 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
252300	AC-601R-4-H3 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
252350	AC-601R-4-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
252400	AC-08-RHR-1004-04 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
252500	AC-08-RHR-1004-05 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
252700	AC-08-RHR-1004-06 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
252800	AC-08-RHR-1004-07 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253000	AC-08-RHR-1004-08 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253100	AC-08-RHR-1004-09 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253200	AC-601R-4-H4 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
253250	AC-601R-4-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
253300	AC-601R-4-H11 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
253350	AC-601R-4-H11-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
253400	AC-08-RHR-1004-10 Pipe to Valve RH-715B Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253500	Valve RH-715B 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
253600	AC-08-RHR-1004-11 Valve RH-715B to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
253700	AC-08-RHR-1004-12 Elbow to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253800	AC-08-RHR-1004-13 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
253900	AC-08-RHR-1004-14 Pipe to Nozzle Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Residual Heat Removal to RWST / Dwg. No. ISI-PRI-1229															
255000	AC-08-SI-1002-01 Tee to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
255100	AC-08-SI-1002-02 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
255200	AC-08-SI-1002-03 Elbow to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
255300	AC-06-SI-1004-01 Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
255400	AC-06-SI-1004-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
255500	AC-06-SI-1004-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
255600	AC-06-SI-1004-04 Pipe to Valve RH-706B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
255700	Valve RH-706B 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
256000	AC-08-SI-1001-01 Tee to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256100	AC-08-SI-1001-02 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256300	AC-08-SI-1001-03 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256400	AC-08-SI-1001-04 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256500	AC-601R-6-H7 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
256600	AC-601R-6-H7-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
256700	AC-08-SI-1001-05 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256800	AC-08-SI-1001-06 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
256850	AC-601R-6-R317 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
256900	AC-08-SI-1001-07 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
257000	AC-601R-6-H8 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
257100	AC-601R-6-H8-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
257200	AC-08-SI-1001-08 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
257300	AC-08-SI-1001-09 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
257400	AC-08-SI-1001-10 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
257600	AC-601R-6-H12 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
257700	AC-08-SI-1001-10A Pipe to Tee Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
257800	AC-08-SI-1001-11R Tee to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
257900	AC-08-SI-1001-12 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
258100	AC-08-SI-1001-13 Pipe to Elbow Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
258200	AC-08-SI-1001-14 Elbow to Pipe Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
258400	AC-601R-6-H13 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-
258500	AC-08-SI-1001-14A Elbow to Reducer Cal Block: 31-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Heat Exchanger HX-11A Bypass / Dwg. No. ISI-PRI-1230</u>																
259000	AC-06-RHR-1001-01 Tee to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
259100	AC-06-RHR-1001-02 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
259200	AC-06-RHR-1001-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
259300	AC-601R-5-H1 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
259400	AC-601R-5-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
259500	AC-06-RHR-1001-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
								O U T A G E							
				1	2	3	4	1	2	3	4	1	2	3	4
259600	AC-06-RHR-1001-05 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
259700	AC-06-RHR-1001-06 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
259800	AC-06-RHR-1001-07 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
259900	AC-06-RHR-1001-08 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260000	AC-06-RHR-1001-09 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260100	AC-06-RHR-1001-10 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
260200	AC-06-RHR-1001-11 Pipe to Valve RH-714B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260300	Valve RH-714B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
260400	AC-06-RHR-1001-12 Valve RH-714B to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260500	AC-601R-5-H2 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
260600	AC-06-RHR-1001-13 Pipe to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260700	Valve RH-626 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
260800	AC-06-RHR-1001-14 Flange to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
260900	AC-06-RHR-1001-15 Pipe to Valve RH-714A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
261000	Valve RH-714A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
261100	AC-06-RHR-1001-16 Valve RH-714A to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
261200	AC-06-RHR-1001-17 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
261300	AC-06-RHR-1001-18 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
261400	AC-06-RHR-1001-19 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
<u>RHR HX-11A Outlet to SI and CS Pumps / Dwg. No. ISI-PRI-1231</u>															
262000	AC-06-SI-1002-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
262100	AC-06-SI-1002-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
262200	AC-06-SI-1002-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
262400	AC-06-SI-1002-04 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
262500	AC-06-SI-1002-05 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
262600	AC-06-SI-1002-06 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
262700	AC-06-SI-1002-07 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
262750	AC-601R-6-R317 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
262800	AC-601R-6-H6 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
262900	AC-601R-6-H6-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
263000	AC-06-SI-1002-08 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263100	AC-06-SI-1002-09 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263200	AC-06-SI-1002-10 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263300	AC-06-SI-1002-11 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263500	AC-601R-6-H28 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
263700	AC-06-SI-1002-11A Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263800	AC-06-SI-1002-11B Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
263900	AC-06-SI-1002-11C Pipe to Valve RH-706A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
264000	Valve RH-706A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
264100	AC-06-SI-1002-12R Tee to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS												
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O	U	T	A	G	E	1	2	3
264200	AC-06-SI-1002-13 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
264400	AC-06-SI-1002-14 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
264500	AC-06-SI-1002-15 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
264600	AC-601R-6-H27 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
264700	AC-06-SI-1002-15A Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
264750	AC-601R-6-R313 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
264800	AC-601R-6-H26 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
264900	AC-601R-6-H25 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
264950	AC-601R-6-R309 Guide	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
265000	AC-06-SI-1002-16 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
265100	AC-06-SI-1002-17 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
265200	AC-06-SI-1002-18 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
265300	AC-06-SI-1002-19 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	X	-	-	-
265500	AC-601R-6-R307 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR HX-11B Outlet to SI and CS Pumps / Dwg. No. ISI-PRI-1232</u>																
266000	AC-06-SI-1003-01A Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
266050	AC-601R-6-H201 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
266100	AC-06-SI-1003-01B Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
266200	AC-06-SI-1003-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
266300	AC-06-SI-1003-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
266400	AC-06-SI-1003-04 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-

PAGE: 169

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
267500	AC-06-SI-1003-12 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
267700	AC-06-SI-1003-13 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
267800	AC-06-SI-1003-14 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
267900	AC-601R-6-H17 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
267950	AC-601R-6-R309 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
268000	AC-06-SI-1003-15 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
268100	AC-06-SI-1003-16 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
268200	AC-06-SI-1003-17 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
268300	AC-06-SI-1003-18 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
268500	AC-601R-6-H18 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	O U T A G E											
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Safety Injection Pump A Inlet and Outlet / Dwg. No. ISI-PRI-1235</u>															
270000	Valve SI-896A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
270100	SIS-06-SI-1005-01 Valve SI-896A to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
270200	SI-151R-2-S735 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-151R-2-S735. Examination will be performed at the same time for both supports.															
270300	SIS-06-SI-1005-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
270400	SIS-06-SI-1005-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
270500	SI-151R-2-H3 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
270550	SI-151R-2-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
270600	SIS-06-SI-1005-04 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
270700	Valve SI-857A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
270800	SIS-06-SI-1005-05 Valve SI-857A to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
270900	SIS-06-SI-1005-06 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271000	SIS-06-SI-1005-07 Elbow to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271100	SIS-06-SI-1005-08 Tee to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271200	SIS-06-SI-1005-09 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271300	SIS-06-SI-1005-10 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271400	Safety Injection Pump P-15A Safety Injection Pump No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
271500	SIS-04-SI-1001-11 Flange to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
271600	SI-1501R-1-H1 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
271700	SI-1501R-1-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
271800	SIS-04-SI-1001-12 Elbow to Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
271900	SIS-06-SI-1005-13 Reducer to Pipe Cal Block: 52-PTB Inaccessible/support limitations.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
272000	SIS-06-SI-1005-13-BC 2" Branch Connection	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
272100	SIS-06-SI-1005-14 Pipe to Valve SI-889A Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
272200	Valve SI-889A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
272300	SIS-06-SI-1005-15 Valve SI-889A to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
272400	SIS-06-SI-1005-16 Elbow to Pipe Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
272500	SI-1501R-1-S841 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
272600	SIS-06-SI-1005-17 Pipe to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
272700	SIS-06-SI-1005-18 Elbow to Valve SI-888A Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
272800	Valve SI-888A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
272900	SIS-06-SI-1005-19 Valve SI-888A to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
273000	SI-1501R-1-H2 Rigid Support	F-A F1.20A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
273100	SIS-06-SI-1005-20 Elbow to Tee Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
273200	SIS-06-SI-1005-21 Tee to Reducer Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
274000	SIS-04-SI-1003-01 Tee to Valve SI-829A Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
274100	Valve SI-829A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection Pump B Inlet and Outlet / Dwg. No. ISI-PRI-1236</u>															
275000	Valve SI-896B 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
275100	SIS-06-SI-1006-01 Valve SI-896B to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
275200	SI-151R-2-S735 Rigid Support Ganged with SI-151R-2-S735. Examination will be performed at the same time for both supports.	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
275300	SIS-06-SI-1006-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
275400	SIS-06-SI-1006-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
275500	SI-151R-2-H12 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
275600	SIS-06-SI-1006-04 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
275800	SIS-06-SI-1006-05M Tee to Valve 1SI-857B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
275900	SIS-06-SI-1006-05R1 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276000	Valve SI-857B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
276100	SIS-06-SI-1006-06 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276200	SIS-06-SI-1006-07 Pipe to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276300	Safety Injection Pump P-15B Safety Injection Pump			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
276400	SIS-04-SI-1002-08 Flange to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
276500	SIS-04-SI-1002-09 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276600	SIS-04-SI-1002-10 Elbow to Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276700	SIS-06-SI-1006-11 Reducer to Pipe Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
276900	SIS-06-SI-1006-11BC 2" Branch Connection	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
277000	SIS-06-SI-1006-12 Pipe to Valve SI-889B Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
277100	Valve SI-889B 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
277200	SIS-06-SI-1006-13 Valve SI-889B to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
277300	SIS-06-SI-1006-14 Elbow to Pipe Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
277400	SI-1501R-1-H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
277500	SI-1501R-1-S840 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
277600	SIS-06-SI-1006-15 Pipe to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
277700	SIS-06-SI-1006-16 Elbow to Valve SI-888B Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
277800	Valve SI-888B 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
277900	SIS-06-SI-1006-17 Valve SI-888B to Elbow Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
278000	SI-1501R-1-H4 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
278050	SI-1501R-1-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
278100	SIS-06-SI-1006-18 Elbow to Tee Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
278200	SIS-06-SI-1006-19 Tee to Reducer Cal Block: 52-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
279000	SIS-04-SI-1004-01 Tee to Valve SI-829B Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
279100	Valve SI-829B 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O	U	T	A	G	E	1	2
RHR Heat Exchanges to Reactor Pressure Vessel / Dwg. No. ISI-PRI-1237															
280000	SIS-06-SI-1007-01 Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280100	SIS-06-SI-1007-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280200	AC-601R-6-AC-2 Variable Spring	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
280250	AC-601R-6-AC2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
280300	SIS-06-SI-1007-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280500	SIS-06-SI-1007-04 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280600	SIS-06-SI-1007-05 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280700	SIS-06-SI-1007-06 Pipe to Valve SI-852A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
280800	Valve SI-852A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
280900	SIS-06-SI-1007-07 Valve SI-852A to Pipe Cal Block: LATER	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
281000	SI-2501R-4-R25 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
281050	Si-2501R-4-R25-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
281100	SIS-06-SI-1007-08 Pipe to Valve SI-853A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR to RPV Injection Line / Dwg. No. ISI-PRI-1238</u>															
282000	SIS-06-SI-1008-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282100	SIS-06-SI-1008-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282200	SIS-06-SI-1008-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282300	SIS-06-SI-1008-04 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282400	SIS-06-SI-1008-05 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282600	SIS-06-SI-1008-06 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
282700	SIS-06-SI-1008-07 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
282900	SI-601R-2-H200 Component Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
283000	SIS-06-SI-1008-08 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
283100	SIS-06-SI-1008-09 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
283300	SI-601R-2-H2 Spring Hanger	F-A Fl.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
283500	SIS-06-SI-1008-10 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
283600	SIS-06-SI-1008-11 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
283700	SI-601R-2-H3 Rigid Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
283800	SI-601R-2-H202 Rigid Support	F-A Fl.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
283900	SIS-06-SI-1008-12 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
284000	SIS-06-SI-1008-13 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS													
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	O	U	T	A	G	E	1	2	3	4
284100	SI-601R-2-H4 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-	-	-
284150	SI-601R-2-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284200	SIS-06-SI-1008-14 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284300	SIS-06-SI-1008-15 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284400	SI-601R-2-H7 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284600	SIS-06-SI-1008-16 Pipe to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284700	SIS-06-SI-1008-17 Flange to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284800	SI-601R-2-H6 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
284900	SIS-06-SI-1008-17A Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
285800	SIS-06-SI-1008-18 Pipe to Flued Head	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Weld is located inside the penetration and is inaccessible.

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Reactor Pressure Vessel Safety Injection Line / Dwg. No. ISI-PRI-1239															
285900	SI-601R-2-A23 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
286000	SI-601R-2-A23-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
286100	SIS-06-SI-1008-19 Penetration to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
286200	SIS-06-SI-1008-20 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
286300	SIS-06-SI-1008-21 Elbow to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
286400	SIS-06-SI-1008-22 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
286500	SI-601R-2-R198 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
286600	SI-601R-2-R198-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
286700	SIS-06-SI-1008-23 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
286800	SIS-06-SI-1008-24 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
286900	SIS-06-SI-1008-25 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
287000	SIS-06-SI-1008-26 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
287100	SI-601R-2-R195 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
287200	SI-601R-2-R195-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
287300	SIS-06-SI-1008-27 Pipe to Valve SI-852B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
287400	Valve SI-852B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
287500	SIS-06-SI-1008-28 Valve SI-852B to Pipe Cal Block: 4-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
287600	SI-2501R-5-R194 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
287700	SI-2501R-5-R194-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
287800	SIS-06-SI-1008-29 Pipe to Valve SI-853B Cal Block: 4-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Loop A Main Steam Inside Containment / Dwg. No. ISI-PRI-1240															
289090	MS-30-MS-1001-06LU Upstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
289100	MS-30-MS-1001-06 Pipe to Pipe Cal Block: 45-PTB, 46-PTB One longitudinal seam upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
289110	MS-30-MS-1001-06LD Downstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
289400	EB-1-MS-H5 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
289500	EB-1-MS-H5-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
289590	MS-30-MS-1001-06ALU Upstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
289600	MS-30-MS-1001-06A Pipe to Pipe Cal Block: 45-PTB, 46-PTB One longitudinal seam upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
289610	MS-30-MS-1001-06ALD Downstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
289900	EB-1-MS-H6 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
289990	MS-30-MS-1001-07LU Upstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
290000	MS-30-MS-1001-07 Pipe to Pipe Cal Block: 45-PTB, 46-PTB THERE IS A WALL THICKNESS CHANGE FROM 1.125 IN. TO 0.908 IN. One longitudinal seam upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290010	MS-30-MS-1001-07LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290100	MS-30-MS-1001-07-BC 6" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290290	MS-30-MS-1001-08LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290300	MS-30-MS-1001-08 Pipe to Elbow Cal Block: 46-PTB One longitudinal seam upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290310	MS-30-MS-1001-08LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290320	MS-30-MS-1001-08LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290380	MS-30-MS-1001-09LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290390	MS-30-MS-1001-09LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290400	MS-30-MS-1001-09 Elbow to Pipe Cal Block: 46-PTB Two longitudinal seam upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
290410	MS-30-MS-1001-09LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290690	MS-30-MS-1001-10LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290700	MS-30-MS-1001-10 Pipe to Elbow Cal Block: 46-PTB One longitudinal seam upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290710	MS-30-MS-1001-10LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290720	MS-30-MS-1001-10LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290780	MS-30-MS-1001-11LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290790	MS-30-MS-1001-11LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290800	MS-30-MS-1001-11 Elbow to Pipe Cal Block: 46-PTB Two longitudinal seams upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290810	MS-30-MS-1001-11LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
290890	MS-30-MS-1001-12LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
290900	MS-30-MS-1001-12 Pipe to Penetration Cal Block: 46-PTB One longitudinal seam upstream. Anchor cone configuration.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
290950	EB-1-MS-69-A2 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
292000	MS-06-MS-1001-01 Branch Connection to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
292100	MS-06-MS-1001-02 Pipe to Cap	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop B Main Steam Inside Containment / Dwg. No. ISI-PRI-1241</u>															
292990	MS-30-MS-1002-09ALU Upstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293000	MS-30-MS-1002-09A Pipe to Elbow Cal Block: 45-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
293010	MS-30-MS-1002-09ALD Downstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293200	EB-1-MS-H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
293290	MS-30-MS-1002-10LU Upstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293300	MS-30-MS-1002-10 Elbow to Elbow Cal Block: 46-PTB THERE IS A WALL THICKNESS CHANGE FROM 1.125 IN. TO 0.908 IN. Two longitudinal seam welds upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
293310	MS-30-MS-1002-10LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293320	MS-30-MS-1002-10LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293380	MS-30-MS-1002-11LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293390	MS-30-MS-1002-11LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293400	MS-30-MS-1002-11 Elbow to Pipe Cal Block: 46-PTB WELD INACCESSIBLE DUE TO GRATING AND DUCTWORK. Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
293410	MS-30-MS-1002-11LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293500	MS-30-MS-1002-11-BC 6" Branch Connection Asbestos insulation present with high contamination. Area has difficult access.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
293690	MS-30-MS-1002-12LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293700	MS-30-MS-1002-12 Pipe to Elbow Cal Block: 46-PTB One longitudinal seam weld upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
293710	MS-30-MS-1002-12LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
293720	MS-30-MS-1002-12LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293880	MS-30-MS-1002-13LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293890	MS-30-MS-1002-13LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293900	MS-30-MS-1002-13 Elbow to Elbow Cal Block: 46-PTB THERE IS A WALL THICKNESS CHANGE FROM 1.125 IN. TO 0.908 IN. Two longitudinal seam welds upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
293910	MS-30-MS-1002-13LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293920	MS-30-MS-1002-13LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293980	MS-30-MS-1002-14LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
293990	MS-30-MS-1002-14LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
294000	MS-30-MS-1002-14 Elbow to Pipe Cal Block: 46-PTB Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294010	MS-30-MS-1002-14LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS														
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3
294090	MS-30-MS-1002-15LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
294100	MS-30-MS-1002-15 Pipe to Penetration Cal Block: 46-PTB Anchor cone. One longitudinal seam weld upstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
294150	EB-1-MS-65-A1 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
295000	MS-06-MS-1002-01 Branch Connection to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
295100	MS-06-MS-1002-02 Pipe to Cap	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop A Main Steam Outside Containment / Dwg. No. ISI-PRI-1240</u>																		
295800	MS-30-MS-1001-13 Flued Head to Pipe Cal Block: 46-PTB Anchor cone. Weld is inside penetration and is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
295810	MS-30-MS-1001-13LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop A Main Steam Outside Containment / Dwg. No. ISI-PRI-1242</u>																		
295990	MS-30-MS-1001-14LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
296000	MS-30-MS-1001-14 Pipe to Tee Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
296010	MS-30-MS-1001-14LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296020	MS-30-MS-1001-14LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296080	MS-30-MS-1001-15LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296090	MS-30-MS-1001-15LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296100	MS-30-MS-1001-15 Tee to Valve MS-2018 Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
296200	Valve MS-2018 30" Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
296300	MS-30-MS-1001-16 Valve MS-2018 to Elbow Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
296310	MS-30-MS-1001-16LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296320	MS-30-MS-1001-16LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296580	MS-30-MS-1001-17LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
296590	MS-30-MS-1001-17LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296600	MS-30-MS-1001-17 Elbow to Pipe Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
296610	MS-30-MS-1001-17LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296700	EB-1-H8 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
296750	EB-1-H8-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
296790	MS-30-MS-1001-17ALU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296800	MS-30-MS-1001-17A Pipe to Pipe Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
296810	MS-30-MS-1001-17ALD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296890	MS-30-MS-1001-17BLU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296900	MS-30-MS-1001-17B Pipe to Pipe Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
296910	MS-30-MS-1001-17BLD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
296990	MS-30-MS-1001-17CLU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
297000	MS-30-MS-1001-17C Pipe to Pipe Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
297010	MS-30-MS-1001-17CLD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
297100	EB-1-R225 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
297980	MS-30-MSR-1001-01LUI First Upstream Long Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
297990	MS-30-MSR-1001-01LUO Second Upstream Long Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
298000	MS-30-MSR-1001-01 Tee to Pipe Cal Block: 47-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
298010	MS-30-MSR-1001-01LD Downstream Longitudinal Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
298100	MS-30-MSR-1001-02-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
298200	EB-1-H20 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
298300	MS-30-MSR-1001-03-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
298400	EB-1-H20A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
298500	MS-30-MSR-1001-04-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
298600	MS-30-MSR-1001-05-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
298700	EB-1-H21 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
298800	MS-30-MSR-1001-06-BC 6" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
298900	EB-1-A1001X Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
298990	MS-30-MSR-1001-07LU Upstream Longitudinal Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
299000	MS-30-MSR-1001-07 Pipe to Cap Cal Block: 47-PTB Inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
300000	MS-08-MSR-1001-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
300100	MS-08-MSR-1001-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														
300200	MS-08-MSR-1001-02 Flange to Valve MS-2010	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
300300	Valve MS-2010 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
301000	MS-08-MSR-1002-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
301100	MS-08-MSR-1002-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														
301200	MS-08-MSR-1002-02 Flange to Valve MS-2011	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
301300	Valve MS-2011 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
302000	MS-08-MSR-1003-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
302100	MS-08-MSR-1003-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
302200	MS-08-MSR-1003-02 Flange to Valve MS-2012	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
302300	Valve MS-2012 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
303000	MS-08-MSR-1004-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
303100	MS-08-MSR-1004-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														
303200	MS-08-MSR-1004-02 Flange to Valve MS-2013	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
303300	Valve MS-2013 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
304000	MS-06-MSR-1001-01 Branch Connection to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
304100	MS-06-MSR-1001-02 Pipe to Valve MS-227	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
304200	Valve MS-227 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
304300	MS-06-MSR-1001-03 Valve MS-227 to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
304400	MS-06-MSR-1001-04R Pipe to Valve MS-2016	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
304500	Valve MS-2016 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
Loop B Main Steam Outside Containment / Dwg. No. ISI-PRI-1243															
305800	MS-30-MS-1002-16 Flued Head to Pipe Cal Block: 46-PTB Anchor Cone. Weld access to be evaluated. One longitudinal seam weld downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
305810	MS-30-MS-1002-16LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
305990	MS-30-MS-1002-17LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306000	MS-30-MS-1002-17 Pipe to Tee Cal Block: 46-PTB One long seam on the upstream side and two on the downstream side of the weld.	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
306010	MS-30-MS-1002-17LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306020	MS-30-MS-1002-17LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306080	MS-30-MS-1002-18LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306090	MS-30-MS-1002-18LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
306100	MS-30-MS-1002-18 Tee to Valve MS-2017 Cal Block: 46-PTB Two long seams on the upstream side of the weld.	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
306200	Valve MS-2017 30" Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
306300	MS-30-MS-1002-19 Valve MS-2017 to Pipe Cal Block: 46-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
306310	MS-30-MS-1002-19LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306400	EB-1-H19 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
306600	EB-1-H7 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
306700	EB-1-H7-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
306980	MS-30-MSR-1002-01LUI First Upstream Long Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
306990	MS-30-MSR-1002-01LUO Second Upstream Long Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
307000	MS-30-MSR-1002-01 Tee to Pipe Cal Block: 47-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
307010	MS-30-MSR-1002-01LD Downstream Longitudinal Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
307100	MS-30-MSR-1002-02-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307200	EB-1-H9 Rigid Support	F-A F1.20A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
307300	MS-30-MSR-1002-03-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307400	EB-1-H9A Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
307500	MS-30-MSR-1002-04-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307600	MS-30-MSR-1002-05-BC 8" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307700	EB-1-H10 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
307800	MS-30-MSR-1002-06-BC 6" Branch Connection	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307900	EB-1-B1001X Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
307990	MS-30-MSR-1002-07LU Upstream Longitudinal Weld Cal Block: 47-PTB			-	-	-	-	-	-	-	-	-	-	-	-
308000	MS-30-MSR-1002-07 Pipe to Cap Cal Block: 47-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
309000	MS-08-MSR-1005-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
309100	MS-08-MSR-1005-01-FB Flange Bolting No examination required, bolting is 2" or less in size.			-	-	-	-	-	-	-	-	-	-	-	-
309200	MS-08-MSR-1005-02 Flange to Valve MS-2005	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
309300	Valve MS-2005 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
310000	MS-08-MSR-1006-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
310100	MS-08-MSR-1006-01-FB Flange Bolting No examination required, bolting is 2" or less in size.			-	-	-	-	-	-	-	-	-	-	-	-
310200	MS-08-MSR-1006-02 Flange to Valve MS-2006	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
310300	Valve MS-2006 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
311000	MS-08-MSR-1007-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
311100	MS-08-MSR-1007-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														
311200	MS-08-MSR-1007-02 Flange to Valve MS-2007	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
311300	Valve MS-2007 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
312000	MS-08-MSR-1008-01 Branch Connection to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
312100	MS-08-MSR-1008-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required, bolting is 2" or less in size.														
312200	MS-08-MSR-1008-02 Flange to Valve MS-2008	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
312300	Valve MS-2008 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
313000	MS-06-MSR-1002-01 Branch Connection to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
313100	MS-06-MSR-1002-02 Pipe to Valve MS-244	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
313200	Valve MS-244 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
313300	MS-06-MSR-1002-03 Valve MS-244 to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
313400	MS-06-MSR-1002-04R Pipe to Valve MS-2015	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
313500	Valve MS-2015 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
<u>Feedwater Loop A / Dwg. No. ISI-PRI-1244</u>															
314000	EB-9-H200 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
314100	FW-16-FW-1001-01A Pipe to Valve CS-466AA Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
314200	Valve FW-466AA 16" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
314300	FW-16-FW-1001-01 Valve CS-466AA to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
314400	EB-9-19 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
314500	FW-16-FW-1001-02 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
314600	FW-16-FW-1001-03 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
314700	FW-16-FW-1001-04 Pipe to Flued Head Cal Block: 34-PTB Weld is located inside of penetration and is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
314800	EB-9-A-M83A Anchor Penetration 4	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
314900	FW-16-FW-1001-05 Flued Head to Pipe Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
315000	FW-16-FW-1001-05A Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
315100	FW-16-FW-1001-06 Elbow to Pipe Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
315400	EB-9-FW-H9 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
315500	EB-9-FW-H9-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
315600	FW-16-FW-1001-07 Pipe to Elbow Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
315700	FW-16-FW-1001-08 Elbow to Pipe Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
315800	EB-9-FW-H8 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
315850	EB-9-FW-H8-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
315900	EB-9-FW-H7 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
315950	EB-9-FW-H7-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
316000	FW-16-FW-1001-09 Pipe to Elbow Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
316100	FW-16-FW-1001-10 Elbow to Pipe Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Feedwater Loop A Inside Containment / Dwg. No. ISI-PRI-1245</u>															
317100	FW-16-FW-1001-11 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
317200	FW-16-FW-1001-12 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
317300	EB-9-FW-H6 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
317350	EB-9-FW-H6-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
317400	FW-16-FW-1001-13 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
317500	FW-16-FW-1001-14 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
317600	EB-9-FW-H5 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
317650	EB-9-FW-H5-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
317700	EB-9-FW-H4 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
317800	EB-9-FW-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
317900	FW-16-FW-1001-15 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
318000	FW-16-FW-1001-16 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
318100	EB-9-FW-H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
318150	EB-9-FW-H3-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
318200	EB-9-HS-11 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Examination will be performed in conjunction with the Snubber Program.															
318300	EB-9-HS-11-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
318400	FW-16-FW-1001-17 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
318500	FW-16-FW-1001-18 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
318700	FW-16-FW-1001-19 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
318800	FW-16-FW-1001-20 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319100	FW-16-FW-1001-21 Pipe to Elbow Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319200	EB-9-FW-H2 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
319250	EB-9-FW-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
319300	FW-16-FW-1001-22 Elbow to Valve CS-466BB Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
319400	Valve FW-466BB 16" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
319500	FW-16-FW-1001-23 Valve CS-466BB to Elbow Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319600	EB-9-FW-H1 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
<u>Feedwater Loop A Inside Containment / Dwg. No.</u>															
319650	EB-9-FW-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Feedwater Loop A Inside Containment / Dwg. No. ISI-PRI-1245</u>															
319700	FW-16-FW-1001-24 Elbow to Pipe Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319750	FW-16-FW-1001-24BC 3" Branch Conneciton	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319800	FW-16-FW-1001-24A Pipe to Pipe Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
319900	FW-16-FW-1001-25 Pipe to Reducer Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	X	-	-	-
320000	FW-16-FW-1001-26 Reducer to Nozzle Extension Cal Block: 25-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH					O U T A G E							
				1	2	3	4	1	2	3	4	1	2	3	4
320100	FW-16-FW-1001-27 Nozzle Extension to Nozzle Cal Block: 48-PTB	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
<u>Feedwater Loop B Inside Containment / Dwg. No. ISI-PRI-1246</u>															
321000	EB-9-S922 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321100	FW-16-FW-1002-01A Pipe to Valve CS-476AA Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321200	Valve FW-476AA 16" Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321300	FW-16-FW-1002-01 Valve CS-476AA to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321400	EB-9-13 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321450	EB-9-13-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321500	FW-16-FW-1002-02 Pipe to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321600	FW-16-FW-1002-03 Pipe to Flued Head Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<hr/>															
321700	FW-16-FW-1002-04 Penetration to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
321800	EB-9-A-M83 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
321900	FW-16-FW-1002-05 Pipe to Elbow Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322000	FW-16-FW-1002-06 Elbow to Pipe Cal Block: 34-PTB	R-A R1.18	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322200	FW-16-FW-1002-07 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322300	FW-16-FW-1002-08 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322500	FW-16-FW-1002-09 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322600	FW-16-FW-1002-10 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
322700	EB-9-FW-H12 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
322800	EB-9-FW-H12-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
322900	FW-16-FW-1002-11 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
323000	FW-16-FW-1002-12 Elbow to Pipe Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
323300	FW-16-FW-1002-13 Pipe to Elbow Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
323400	EB-9-FW-H11 Constant Support	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
323450	FW-H11-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
323500	FW-16-FW-1002-14 Elbow to Valve CS-476BB Cal Block: 34-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
323600	Valve FW-476BB 16" Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
323700	FW-16-FW-1002-15 Valve CS-476BB to Elbow Cal Block: 34-PTB	R-A R1.11	VOL	X	-	-	-	-	-	-	-	-	-	-	-
323800	EB-9-FW-H10 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
323850	EB-9-FW-H10-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
323900	FW-16-FW-1002-15B Elbow to Pipe Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
323950	FW-16-FW-1002-15BC 3" Branch Connection	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
324000	FW-16-FW-1002-16 Pipe to Reducer Cal Block: 34-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
324100	FW-16-FW-1002-17 Reducer to Nozzle Extension Cal Block: 25-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	X	-	-	-	-	-	-	-
324200	FW-16-FW-1002-18 Nozzle Extension to Nozzle Cal Block: 48-PTB Item no. R1.18 also applies.	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR HX-11A Outlet to SI and CS Pumps / Dwg. No. ISI-PRI-1247</u>															
325000	Valve ISI-870A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
325100	SIS-06-CS-1001-01 Valve ISI-870A to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
325200	SIS-06-CS-1001-02 Pipe to Valve ISI-858A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
325300	Valve SI-858A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
325400	SIS-06-CS-1001-03 Valve SI-858A to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
325500	SI-151R-3-H2 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
325550	SI-151R-3-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	X	-	-	-
325600	SIS-06-CS-1001-04 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
325700	SIS-08-CS-1001-01 Reducer to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
325800	Containment Spray Pump P-14A Pump No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
326000	AC-06-SI-1002-20 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
326100	AC-06-SI-1002-21 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
326400	AC-06-SI-1002-21A Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
326500	AC-601R-6-H23 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
326700	AC-601R-6-R303 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-S843 and SI-1501R-3-S843. Examination will be performed at the same time for all supports.															
326750	AC-601R-6-R303-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
326800	AC-601R-6-H22 Spring Hanger	F-A Fl.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
326900	AC-06-SI-1002-22 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
327000	AC-06-SI-1002-23 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
327200	AC-06-SI-1002-24 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
327300	AC-06-SI-1002-25 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
327600	AC-601R-6-H21 Spring Hanger	F-A Fl.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with AC-601R-6-H21. Examination will be performed at the same time for both supports.															
327700	AC-06-SI-1002-26 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
327800	AC-06-SI-1002-27 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
328000	AC-06-SI-1002-28 Pipe to Valve SI-857A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
328200	AC-06-SI-1002-29 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RHR HX-11B Outlet to SI and CS Pumps / Dwg. No. ISI-PRI-1248															
330000	Valve 1SI-870B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
330100	SIS-06-CS-1002-01 Valve 1SI-870B to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
330200	SIS-06-CS-1002-02 Pipe to Valve 1SI-858B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
330300	Valve SI-858B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
330400	SIS-06-CS-1002-03 Valve SI-858B to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
330500	SI-151R-3-H1 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
330550	SI-151R-3-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
330600	SIS-06-CS-1002-04 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
330700	SIS-08-CS-1002-01 Reducer to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
330800	Containment Spray Pump P-14B Pump			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
331100	AC-06-SI-1003-19 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
331200	AC-06-SI-1003-20 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
331300	AC-601R-6-R304A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
331400	AC-601R-6-H19 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
331600	AC-601R-6-R303 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
331700	AC-06-SI-1003-21 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
331800	AC-06-SI-1003-22 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
332000	AC-601R-6-H31 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
332100	AC-06-SI-1003-23 Elbow to Pipe	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
332200	AC-601R-6-H20 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
332300	AC-06-SI-1003-24 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
332400	AC-06-SI-1003-25 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
332700	AC-601R-6-H21 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
Ganged with AC-601R-6-H21. Examination will be performed at the same time for both supports.															
332800	AC-06-SI-1003-26 Pipe to Elbow	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
332900	AC-06-SI-1003-27 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333100	AC-06-SI-1003-28R1 Pipe to Valve SI-857B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333300	AC-06-SI-1003-29 Tee to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333400	AC-06-SI-1003-30 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333500	AC-06-SI-1003-31 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333600	AC-06-SI-1003-32 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
333700	AC-06-SI-1003-33 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
333800	AC-601R-6-H30 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
333900	AC-601R-6-H30-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
334000	AC-06-SI-1003-34 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
334100	AC-06-SI-1003-35 Pipe to Valve SI-871B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
334200	Valve SI-871B 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
334300	AC-06-SI-1003-36 Valve SI-871B to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>SI Pump B Discharge to Loop B and RPV / Dwg. No. ISI-PRI-1249</u>															
335000	SIS-02-SI-1005-03 Valve SI-845F to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
335100	SIS-02-SI-1005-04 Pipe to Valve SI-878F	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
335200	Valve SI-878F 2" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
335300	SIS-02-SI-1005-05 Valve SI-878F to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
335400	SI-11 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
335500	SIS-02-SI-1005-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
335600	SIS-02-SI-1005-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
335700	SIS-02-SI-1005-08 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336000	SIS-02-SI-1006-02 Conc Swage Reducer to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336100	SIS-02-SI-1006-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336200	SIS-02-SI-1006-04 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336300	SIS-02-SI-1006-05 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336400	SIS-02-SI-1006-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
336500	SIS-02-SI-1006-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336600	SIS-02-SI-1006-08 Pipe to Valve SI-878C	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336700	Valve SI-878C 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
336800	SIS-02-SI-1006-09 Valve SI-878C to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
336900	SIS-02-SI-1006-10 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
337000	SIS-02-SI-1006-11 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
337100	SIS-02-SI-1006-12 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
337150	ISI-878C-2 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
	RRM 2000-0045 will be implemented.														
337200	SIS-02-SI-1006-13 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
337300	SIS-02-SI-1006-14 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS													
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	O U T A G E				1	2	3	4		
337400	SIS-02-SI-1006-15 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
337500	SIS-02-SI-1006-16 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
337600	SIS-02-SI-1006-17 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
337700	SIS-02-SI-1006-18 Pipe to Valve SI-845C	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
338000	SIS-04-SI-1006-42 Pipe to Tee Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
338100	SIS-04-SI-1006-43 Tee to Conc Swage Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
338200	SIS-04-SI-1006-45 Tee to Conc Swage Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SI Pump A Discharge to Loop A and RPV / Dwg. No. ISI-PRI-1250																	
339000	SIS-02-SI-1001-01 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
339100	SIS-02-SI-1001-02 Pipe to Valve SI-878A	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
339200	Valve SI-878A 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-	-	-

No examination required.

PAGE: 222

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
339300	878A-1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
339400	SIS-02-SI-1001-03 Valve SI-878A to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
339500	SIS-02-SI-1001-04 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
339600	SIS-02-SI-1001-05 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
339700	SIS-02-SI-1001-05A Pipe to Valve SI-845D	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340000	SIS-02-SI-1007-02 Conc Swage Reducer to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340100	SIS-02-SI-1007-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340200	SIS-02-SI-1007-04 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340300	SIS-02-SI-1007-05 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340400	SIS-02-SI-1007-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
340500	SIS-02-SI-1007-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340600	SI-86 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
340700	SIS-02-SI-1007-08 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340800	SIS-02-SI-1007-09 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
340900	SIS-02-SI-1007-10 Pipe to Valve SI-878E	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
341000	Valve SI-878E 2" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
341100	SIS-02-SI-1007-11 Valve SI-878E to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
341200	SIS-02-SI-1007-12 Pipe to Valve SI-845E	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>SI Pump A Discharge to Loop A and B Cold Leg / Dwg. No. ISI-PRI-1251</u>															
342000	SIS-02-SI-1008-02 Conc Swage Reducer to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342100	SIS-02-SI-1008-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
342200	SIS-02-SI-1008-04 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342300	SIS-02-SI-1008-05 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342400	SIS-02-SI-1008-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342500	SIS-02-SI-1008-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342600	SIS-02-SI-1008-08 Pipe to Valve SI-878B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342700	Valve SI-878B 2" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
342800	SIS-02-SI-1008-09 Valve SI-878B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
342900	SIS-02-SI-1008-10 Pipe to Valve SI-845B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
344000	SIS-02-SI-1009-02 Conc Swage Reducer to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
344100	SIS-02-SI-1009-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
346000	SIS-04-SI-1005-40 Pipe to Tee Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
346100	SIS-04-SI-1005-41 Tee to Conc Swage Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
346200	SIS-04-SI-1005-43 Tee to Conc Swage Reducer Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
346300	1SI-878B-4 Support RRM 2000-0045	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
346400	1SI-878B-5 Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
346500	1SI-878B-6 Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
346600	1SI-878B-7 Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
346700	1SI-878B-8 Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
346800	1SI-878D-6 Support RRM 2000-0045	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
349000	SI-1501R-3-H15A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
349100	SIS-04-SI-1005-29 Pipe to Valve SI-866A Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
349200	Valve SI-866A 4" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
349300	SIS-04-SI-1005-30 Valve SI-866A to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
349400	SI-1501R-3-H15 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
349450	SIS-04-SI-1005-30A Pipe to Flued Head Weld is located inside penetration P-13 and is inaccessible.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
349500	SI-1501R-3-A24 Anchor Penetration P-13.	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
349600	SIS-04-SI-1005-30B Flued Head to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
349700	SIS-04-SI-1005-31 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
349800	SIS-04-SI-1005-32 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
349900	SIS-04-SI-1005-33 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
350000	SIS-04-SI-1005-34 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
350100	SI-1501R-3-H4 Rigid Support Ganged with SI-1501R-2-H17. Examination will be performed at the same time for both supports	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
350200	SIS-04-SI-1005-35 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
350300	SI-1501R-3-H4A Rigid Support Ganged with SI-1501R-2-H17A. Examination will be performed at the same time for both supports	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
350400	SIS-04-SI-1005-35A Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
350500	SI-1501R-3-S246 Rigid Support Ganged with SI-1501R-2-S246. Examination will be performed at the same time for both supports	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
350600	SI-1501R-3-H5 Rigid Support Ganged with SI-1501R-2-H18. Examination will be done at the same for both supports.	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
350700	SI-1501R-3-H5A Rigid Support Ganged with SI-1501R-2-H18A. Examination will be performed at the same time for both supports	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
350800	SIS-04-SI-1005-36 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS														
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3
350900	SIS-04-SI-1005-37 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
351000	SI-1501R-3-H6 Guide	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
351100	SIS-04-SI-1005-38 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
351200	SIS-04-SI-1005-39 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection Pump P-15B Discharge / Dwg. No. ISI-PRI-1253</u>																		
352000	SIS-04-SI-1006-22 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
352100	SIS-04-SI-1006-23 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
352200	SIS-04-SI-1006-24 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
352300	SIS-04-SI-1006-25 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-
352400	SIS-04-SI-1006-25A Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
352500	SI-1501R-2-H13 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
352550	SI-1501R-2-H13-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
352600	SI-1501R-2-S848 Guide	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
352700	SIS-04-SI-1006-26 Pipe to Flange Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
352800	SIS-04-SI-1006-27 Flange to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
352900	SI-1501R-2-H16A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
352950	SI-1501R-2-H16A-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
353000	SIS-04-SI-1006-27A Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353100	SIS-04-SI-1006-28 Pipe to Valve SI-866B Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353200	Valve SI-866B 4" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
353300	SIS-04-SI-1006-29 Valve SI-866B to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
353400	SIS-04-SI-1006-30 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353500	SIS-04-SI-1006-31 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353600	SIS-04-SI-1006-32 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353700	SI-1501R-2-H16 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
353750	SI-1501R-2-H16-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
353800	SIS-04-SI-1006-32A Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353850	SIS-04-SI-1006-32B Pipe to Flued Head	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
353900	SI-1501R-2-A24 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
354050	SIS-04-SI-1006-32C Flued Head to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354100	SIS-04-SI-1006-33 Flued Head to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
354200	SIS-04-SI-1006-34 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354300	SIS-04-SI-1006-35 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354400	SIS-04-SI-1006-36 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354500	SI-1501R-2-H17 Rigid Support Ganged with SI-1501R-2-H17. Examination will be performed at the same time for both supports.	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
354600	SIS-04-SI-1006-37 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354700	SI-1501R-2-H17A Rigid Support Ganged with SI-1501R-3-H4A. Examination will be performed at the same time for both supports.	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
354800	SIS-04-SI-1006-37A Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
354900	SI-1501R-2-S246 Rigid Support Ganged with SI-1501R-3-S246. Examination with be performed at the same time for both of them.	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
355000	SI-1501R-2-H18 Rigid Support Ganged with SI-1501R-3-H5. Examination will be performed at the same time for both supports.	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
355100	SI-1501R-2-H18A Rigid Support Ganged with SI-1501R-3-H5A. Examination will be performed at the same time for both supports.	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS													
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	O U T A G E				1	2	3	4		
355200	SIS-04-SI-1006-38 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
355300	SIS-04-SI-1006-39 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
355400	SIS-04-SI-1006-40 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
355500	SIS-04-SI-1006-41 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection Pumps P-15A and P-15B Discharge / Dwg. No. ISI-PRI-1254</u>																	
357000	SIS-04-SI-1005-10 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
357100	SIS-04-SI-1005-11 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
357200	SIS-04-SI-1005-12 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
357300	SIS-04-SI-1005-13 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
357400	SI-1501R-3-H5 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Ganged with SI-1501R-2-H5. Total of 9 pipes are ganged, but only two are class 1,2, or 3.
Examination will be performed at the same time for both supports.

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
357500	SI-1501R-3-S844 Guide	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-S844. Examination will be performed at the same time for both supports.															
357600	SIS-04-SI-1005-14 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
357700	SI-1501R-3-H6 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-H6. Total of nine pipes ganged, but only 2 are class 1,2, or 3. Examination will be performed at the same time for both supports.															
357800	SIS-04-SI-1005-15 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
357900	SI-1501R-3-H7 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-H7. Examination will be performed at the same time for both supports.															
358000	SI-1501R-3-H8 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Ganged with SI-1501R-2-H8 and 3 other pipes. Examination will be performed at the same time for both supports.															
358100	SIS-04-SI-1005-16 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
358200	SIS-04-SI-1005-17 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
358300	SI-1501R-3-S845 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-S845. Examination will be performed at the same time for both supports.															
358400	SIS-04-SI-1005-18 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
358500	SIS-04-SI-1005-19 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
358600	SIS-04-SI-1005-20 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
358700	SIS-04-SI-1005-21 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
358750	SI-1501R-3-S846 Guide	F-A F.120A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
358800	SIS-04-SI-1005-22 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
358900	SIS-04-SI-1005-23 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
360000	SIS-04-SI-1006-10 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
360100	SIS-04-SI-1006-11 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
360200	SIS-04-SI-1006-12 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
360300	SIS-04-SI-1006-13 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
360400	SI-1501R-2-H5 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H5. Total of 9 pipes ganged, but only 2 are class 1,2, or 3. Examination will be performed at the same time for both supports.															
360500	SI-1501R-2-S844 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-S844. Examination will be performed at the same time for both supports.															
360600	SIS-04-SI-1006-14 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
360700	SI-1501R-2-H6 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H6. Total of 9 pipes ganged, but only 2 are class 1, 2, or 3. Examination will be performed at the same time for both supports.															
360800	SIS-04-SI-1006-15 Pipe to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
360900	SI-1501R-2-H7 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H7. Total of 9 pipes but only 2 are class 1, 2, or 3. Examination will be performed at the same time for both supports.															
361000	SI-1501R-2-H8 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H8 and 3 others. Examination will be performed at the same time for both supports.															
361100	SIS-04-SI-1006-16 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
361200	SIS-04-SI-1006-17 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
361300	SI-1501R-2-S845 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Ganged with SI-1501R-3-S845. Examination will be performed at the same time for both supports.															
361400	SIS-04-SI-1006-18 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
361500	SIS-04-SI-1006-19 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
361600	SI-1501R-2-H11 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H11. Examination will be performed at the same time for both supports.															
361700	SI-1501R-2-H12 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H12. Examination will be performed at the same time for both supports.															
361800	SIS-04-SI-1006-20 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
361900	SIS-04-SI-1006-21 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection Pumps P-15A and P-15B Discharge / Dwg. No. ISI-PRI-1255</u>															
363000	SIS-04-SI-1005-01 Reducer to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
363100	SI-1501R-3-H1 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
363200	SIS-04-SI-1005-02 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
363300	SIS-04-SI-1005-03 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
363400	SI-1501R-3-S842 Guide Ganged with SI-1501R-2-S842. Examination will be performed at the same time for both supports.	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
363500	SIS-04-SI-1005-04 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
363600	SIS-04-SI-1005-05 Elbow to Pipe Cal Block: 27-PTB Spring support SI-39 interferes with examination area.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
363700	SI-1501R-3-H2 Spring Support Ganged with SI-1501R-2-H3. Examination will be performed at the same time for both supports.	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
363800	SI-1501R-3-S843 Guide Ganged with SI-1501R-2-S843 and AC-601R-6-R303. Examination will be performed for all 3 supports at the same time.	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
363900	SIS-04-SI-1005-06 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
364000	SIS-04-SI-1005-07 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
364100	SIS-04-SI-1005-08 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
364200	SIS-04-SI-1005-09 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
364300	SI-1501R-3-H3 Guide	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-2-H4. Examination will be performed at the same time for both supports.															
365000	SIS-04-SI-1006-01 Reducer to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
365100	SI-1501R-2-H1 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
365150	SI-1501R-2-H201 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
365200	SIS-04-SI-1006-02 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
365300	SIS-04-SI-1006-03 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
365400	SI-1501R-2-S842 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-S842. Examination will be performed at the same time for both supports.															
365500	SI-1501R-2-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H2. Examination will be performed at the same time for both supports.															
365600	SIS-04-SI-1006-04 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	X	-	-	-
365700	SIS-04-SI-1006-05 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
365800	SI-1501R-2-S843 Guide	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Ganged with SI-1501R-3-S843 and AC-601R-6-R303. Examination will be performed at the same time for all supports.															
365900	SIS-04-SI-1006-06 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
366000	SIS-04-SI-1006-07 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
366100	SIS-04-SI-1006-08 Pipe to Elbow Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
366200	SIS-04-SI-1006-09 Elbow to Pipe Cal Block: 27-PTB	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
366300	SI-1501R-2-H4 Guide	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with SI-1501R-3-H3. Examination will be performed at the same time for both supports.															
<u>Safety Injection Pump P-15A Test Line / Dwg. No. ISI-PRI-1256</u>															
367000	SIS-02-SI-1010-01 Branch Connection to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
367100	SIS-02-SI-1010-02 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
367200	SIS-02-SI-1010-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS												
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O	U	T	A	G	E	1	2	3
368300	SIS-02-SI-1010-10 Pipe to Valve SI-891A	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
368400	Valve SI-891A 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.															
368500	SIS-02-SI-1010-11 Valve SI-891A to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
368600	SIS-02-SI-1010-12 Pipe to Valve SI-876A	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
368700	Valve SI-876A 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.															
368800	SIS-02-SI-1010-13 Valve SI-876A to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
368900	SIS-02-SI-1010-14 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
369000	SIS-02-SI-1010-15 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-
369100	SI-66 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
369200	SI-67 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
371200	SIS-02-SI-1011-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371300	SIS-02-SI-1011-04 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371400	SIS-02-SI-1011-05 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371500	SIS-02-SI-1011-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371600	SIS-02-SI-1011-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371700	SIS-02-SI-1011-08 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371800	SIS-02-SI-1011-09 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
371900	SIS-02-SI-1011-10 Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372000	SIS-02-SI-1011-10A Coupling to Orifice	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372100	SIS-02-SI-1011-10B Orifice to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
372200	SIS-02-SI-1011-11 Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372300	SIS-02-SI-1011-12 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372400	SIS-02-SI-1011-13 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372500	SIS-02-SI-1011-14 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372600	SIS-02-SI-1011-15 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372700	SIS-02-SI-1011-16 Pipe to Valve SI-891B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
372800	Valve SI-891B 2" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
372900	SIS-02-SI-1011-17 Valve SI-891B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
373000	SI-80 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
373100	SIS-02-SI-1011-18 Pipe to Valve SI-876B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
373200	Valve SI-876B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
373300	SIS-02-SI-1011-19 Valve SI-876B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
373400	SIS-02-SI-1011-20 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
373500	SIS-02-SI-1011-21 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
373600	SIS-02-SI-1011-22 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Safety Injection Pumps P-15A and P-15B Test Line / Dwg. No. ISI-PRI-1258															
375000	SIS-02-SI-1010-20 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
375100	SIS-02-SI-1010-21 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
375200	SI-73 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
375300	SIS-02-SI-1010-22 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
375400	SIS-02-SI-1010-23 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
375500	SIS-02-SI-1010-24 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
375600	SIS-02-SI-1010-25 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
375700	SI-74 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
375800	SI-75 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
375900	SIS-02-SI-1010-26 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376000	SIS-02-SI-1010-27 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376100	SIS-02-SI-1010-28 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376200	SIS-02-SI-1010-29 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376300	SIS-02-SI-1010-30 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376400	SIS-02-SI-1010-31 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
376500	SI-76 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
376600	SIS-02-SI-1010-31A Pipe to Coupling	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376700	SIS-02-SI-1010-31B Coupling to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376800	SIS-02-SI-1010-32 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
376900	SIS-02-SI-1010-33 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377000	SI-77 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
377100	SI-78 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
377200	SIS-02-SI-1010-34 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377300	SIS-02-SI-1010-35 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377400	SIS-02-SI-1010-36 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
377500	SIS-02-SI-1010-37 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377600	SI-79 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
377700	SIS-02-SI-1010-38 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377800	SIS-02-SI-1010-39 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
377900	SIS-02-SI-1010-40 Pipe to Valve SI-897B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
378000	Valve SI-897B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
378100	SIS-02-SI-1010-41 Tee to Reducing Insert	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Containment Spray Pumps P-14A and P-14B Test Line / Dwg. No. ISI-PRI-1259</u>															
379000	SIS-02-SI-1012-01 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
379100	SIS-02-SI-1012-02 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
379200	SIS-02-SI-1012-03 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
380900	SIS-02-SI-1013-08 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381000	SIS-02-SI-1013-09 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381100	SI-81 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
381200	SI-82 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
381300	SIS-02-SI-1013-10 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381400	Valve SI-859B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
381500	SIS-02-SI-1013-11 Valve SI-859B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381600	SI-83 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
381700	SIS-02-SI-1013-12 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381800	SIS-02-SI-1013-13 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
381900	SIS-02-SI-1013-14 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382000	SIS-02-SI-1013-15 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382100	SIS-02-SI-1013-16 Pipe to Valve SI-873B	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382200	Valve SI-873B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
382300	SIS-02-SI-1013-17 Valve SI-873B to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382400	SIS-02-SI-1013-18 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382500	SIS-02-SI-1013-19 Tee to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
382600	SIS-02-SI-1013-20 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383000	SIS-02-SI-1014-01 Reducer to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383100	SI-84 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
383200	SIS-02-SI-1014-02 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383300	SIS-02-SI-1014-03 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383400	SIS-02-SI-1014-04 Pipe to Flange	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383500	SIS-02-SI-1014-05 Flange to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383600	SI-87 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
383700	SIS-02-SI-1014-06 Pipe to Elbow	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383800	SIS-02-SI-1014-07 Elbow to Pipe	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
383900	SIS-02-SI-1014-08 Pipe to Tee	R-A R1.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Containment Spray Pumps P-14A and P-14B Test Line / Dwg. No. ISI-PRI-1260</u>															
385000	SIS-06-CS-1003-01 Reducer to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385100	SIS-06-CS-1003-02 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
385200	SIS-06-CS-1003-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385300	SIS-06-CS-1003-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385400	SIS-06-CS-1003-05 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385500	SIS-06-CS-1003-06 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385600	SI-301R-1-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
385700	SIS-06-CS-1003-07 Pipe to Valve SI-860B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
385800	Valve SI-860B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
385900	SIS-06-CS-1003-08 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
386000	SIS-06-CS-1003-09 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
386100	SIS-06-CS-1003-10 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
386200	SI-301R-1-S862 Guide	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
386300	SIS-06-CS-1003-11 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
386400	SIS-06-CS-1003-12 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
386500	SI-301R-1-H1 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
386600	SIS-06-CS-1003-13 Pipe to Valve SI-860A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
386700	Valve SI-860A 6" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
387000	SIS-06-CS-1004-01 Reducer to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387100	SIS-06-CS-1004-02 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387200	SIS-06-CS-1004-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387300	SIS-06-CS-1004-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

PAGE: 257

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
387400	SIS-06-CS-1004-05 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387500	SIS-06-CS-1004-06 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387600	SI-301R-1-H9 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
387700	SIS-06-CS-1004-07 Pipe to Valve SI-860D	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
387800	Valve SI-860D 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	no examination required.														
387900	SIS-06-CS-1004-08 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
388000	SIS-06-CS-1004-09 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
388100	SIS-06-CS-1004-10 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
388150	SI-301R-1-S865 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
388200	SIS-06-CS-1004-11 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
388400	SIS-06-CS-1004-12 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
388500	SI-301R-1-H8 Spring Support	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
388600	SIS-06-CS-1004-13 Pipe to Valve SI-860C	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
388700	Valve SI-860C 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
<u>Loop A Main Steam Inside Containment / Dwg. No. ISI-PRI-1261</u>															
390000	MS-31-MS-1001-01 Nozzle to Elbow Cal Block: 44-PTB Two longitudinal seam welds downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
390010	MS-31-MS-1001-01LDI Inside Downstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
390020	MS-31-MS-1001-01LDO Outside Downstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
390080	MS-31-MS-1001-02LUI Inside Upstream Longitudinal Weld Cal Block: 44-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390090	MS-31-MS-1001-02LUO Outside Upstream Longitudinal Weld Cal Block: 44-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390100	MS-31-MS-1001-02 Elbow to Pipe Cal Block: 44-PTB, 46-PTB Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
390110	MS-31-MS-1001-02LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390190	MS-30-MS-1001-02ALU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390200	MS-30-MS-1001-02A Pipe to Pipe Cal Block: 46-PTB One longitudinal seam weld upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
390210	MS-30-MS-1001-02ALD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390300	HS-1 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
390400	HS-2 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
390490	MS-30-MS-1001-03LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390500	MS-30-MS-1001-03 Pipe to Flow Element Cal Block: 46-PTB One longitudinal seam weld upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
390510	MS-30-MS-1001-03LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390590	MS-30-MS-1001-04LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
390600	MS-30-MS-1001-04 Flow Element to Elbow Cal Block: 46-PTB One longitudinal seam weld upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
390610	MS-30-MS-1001-04LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390620	MS-30-MS-1001-04LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390800	EB-1-MS-H4 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
390900	EB-1-MS-H4-IWA Welded Attachment	C-C C3.20	SUR	X	-	-	-	-	-	-	-	-	-	-	-
390980	MS-30-MS-1001-05LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
390990	MS-30-MS-1001-05LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
391000	MS-30-MS-1001-05 Elbow to Pipe Cal Block: 45-PTB, 46-PTB THERE IS A WALL THICKNESS CHANGE FROM 0.908 IN. TO 1.125 IN. Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
391010	MS-30-MS-1001-05LD Downstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-

[illegible]

PAGE: 262

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
392220	MS-31-MS-1002-03LDO Outside Downstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
392280	MS-30-MS-1002-04LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
392290	MS-30-MS-1002-04LUO Outside Upstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
392300	MS-30-MS-1002-04 Elbow to Pipe Cal Block: 46-PTB Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
392310	MS-30-MS-1002-04LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
392400	HS-3 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
392500	HS-4 Snubber	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
392590	MS-30-MS-1002-05LU Upstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
392600	MS-30-MS-1002-05 Pipe to Flow Element Cal Block: 46-PTB One longitudinal seam weld upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
392610	MS-30-MS-1002-05LD Downstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
392690	MS-30-MS-1002-06LU Upstream Longitudinal Weld			-	-	-	-	-	-	-	-	-	-	-	-
392700	MS-30-MS-1002-06 Flow Element to Elbow Cal Block: 46-PTB One longitudinal seam weld upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
392710	MS-30-MS-1002-06LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
392720	MS-30-MS-1002-06LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
392900	EB-1-MS-H2 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
393000	EB-1-MS-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
393080	MS-30-MS-1002-07LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393090	MS-30-MS-1002-07LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393100	MS-30-MS-1002-07 Elbow to Pipe Cal Block: 46-PTB Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
393110	MS-30-MS-1002-07LD Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
393190	MS-30-MS-1002-08LU Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393200	MS-30-MS-1002-08 Pipe to Elbow Cal Block: 46-PTB One longitudinal seam weld upstream and two downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
393210	MS-30-MS-1002-08LDI Inside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393220	MS-30-MS-1002-08LDO Outside Downstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393380	MS-30-MS-1002-09LUI Inside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393390	MS-30-MS-1002-09LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB			-	-	-	-	-	-	-	-	-	-	-	-
393400	MS-30-MS-1002-09 Elbow to Pipe Cal Block: 45-PTB, 46-PTB THERE IS A WALL THICKNESS CHANGE FROM 0.908 IN. TO 1.125 IN. Two longitudinal seam welds upstream and one downstream.	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
393410	MS-30-MS-1002-09LD Downstream Longitudinal Weld Cal Block: 45-PTB			-	-	-	-	-	-	-	-	-	-	-	-
<u>RWST to RHR, SI, and CS Pumps / Dwg. No. ISI-PRI-1263</u>															
396000	AC-16-SI-1001-01 Flange to Elbow	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
396100	AC-16-SI-1001-02 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
396200	AC-16-SI-1001-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
396300	AC-16-SI-1001-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
396400	SI-151R-2-S741 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
396500	SI-151R-2-S741A Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
396600	AC-16-SI-1001-05 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
396700	AC-16-SI-1001-06 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
396800	AC-16-SI-1001-07 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>RWST to RHR Pumps / Dwg. No. ISI-PRI-1264</u>															
398000	AC-10-RHR-1007-01 Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398100	AC-10-RHR-1007-02 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
398200	AC-10-RHR-1007-03 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398300	SI-151R-4-H11 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
398400	AC-10-RHR-1007-04 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398500	SI-151R-4-H200 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
398600	AC-10-RHR-1007-05 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398700	AC-10-RHR-1007-06 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398800	AC-10-RHR-1007-07 Pipe to Valve ISI-856A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
398900	Valve ISI-856A 10" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
399000	AC-10-RHR-1007-08 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
399100	AC-10-RHR-1007-09 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
399200	AC-10-RHR-1007-10 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
399300	AC-10-RHR-1007-11 Pipe to Valve ISI-856B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
399400	Valve ISI-856B 10" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
400000	AC-08-RHR-1007-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
400100	AC-08-RHR-1007-02 Pipe to Valve ISI-742	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
400200	Valve ISI-742 8" Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
RWST to CS and SI Pumps / Dwg. No. ISI-PRI-1265															
401000	AC-12-SI-1001-01 Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
401100	AC-12-SI-1001-02 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
401200	SI-151R-2-H9 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
401300	SI-151R-2-S740 Restraint	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
401400	AC-12-SI-1001-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
401500	AC-12-SI-1001-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
401600	SI-151R-2-S739 Restraint	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
401700	SI-151R-2-H8 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
401800	AC-12-SI-1001-05 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
401900	AC-12-SI-1001-06 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
402000	SI-151R-2-H6 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
402100	SI-151R-2-S738 Restraint	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
402200	AC-12-SI-1001-07 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
402300	AC-12-SI-1001-08 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
402400	SI-151R-2-H7 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
402500	AC-12-SI-1001-09 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
402600	SI-151R-2-H7A Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
402700	AC-12-SI-1001-10 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
402800	SI-151R-2-S737 Restraint	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
403000	AC-12-SI-1001-11 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403100	SI-151R-2-H7B Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
403200	AC-12-SI-1001-12 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403300	AC-12-SI-1001-13 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RWST to SI Pumps / Dwg. No. ISI-PRI-1266															
403400	AC-12-SI-1001-14 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403500	SI-151R-2-H5 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
403600	AC-12-SI-1001-15 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403700	AC-12-SI-1001-16 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403800	AC-12-SI-1001-17 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
403900	SI-151R-2-H4 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
404000	AC-12-SI-1001-18 Tee to Valve 1SI-825B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404100	Valve 1SI-825B 12" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
404200	AC-12-SI-1001-19 Valve 1SI-825B to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404300	AC-12-SI-1001-20 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
404400	AC-12-SI-1001-21 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404500	AC-12-SI-1001-22 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404600	AC-12-SI-1001-23 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404700	AC-12-SI-1001-24 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404800	AC-12-SI-1001-25 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
404900	AC-12-SI-1001-26 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405000	AC-12-SI-1001-27 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405100	AC-12-SI-1001-28 Pipe to Valve 1SI-825A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405200	Valve 1SI-825A 12" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
405300	AC-12-SI-1001-29 Valve 1SI-825A to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

PAGE: 272

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
405400	AC-12-SI-1001-30 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405500	AC-12-SI-1001-31 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405600	SI-151R-2-H202A Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
405650	SI-151R-2-H202 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
405700	AC-12-SI-1001-32 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
405800	SI-151R-2-S736 Restraint	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
405900	AC-12-SI-1001-33 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
406000	SI-151R-2-H2 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
406100	AC-12-SI-1001-34 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
406200	AC-12-SI-1001-35 Tee to Reducer	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
407000	AC-08-SI-1004-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
407200	AC-08-SI-1004-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
407300	AC-08-SI-1004-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
407400	AC-08-SI-1004-04 Pipe to Valve 1SI-826A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
407500	Valve 1SI-826A 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
<u>RWST to SI Pumps / Dwg. No. ISI-PRI-1267</u>															
408000	AC-06-SI-1007-01 Reducer to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
408100	AC-06-SI-1007-02 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
408200	AC-06-SI-1007-03 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
408300	AC-06-SI-1007-04 Pipe to Valve 1SI-896A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
409000	AC-06-SI-1008-01 Reducer to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
409100	AC-06-SI-1008-02 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
409200	AC-06-SI-1008-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
409300	AC-06-SI-1008-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
409400	AC-06-SI-1008-05 Pipe to Valve ISI-896B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
<u>RWST to CS Pumps / Dwg. No. ISI-PRI-1268</u>															
410000	AC-06-CS-1001-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
410100	AC-06-CS-1001-02 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
410200	AC-06-CS-1001-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
410300	AC-06-CS-1001-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
410400	AC-06-CS-1001-05 Pipe to Valve ISI-870A	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
411000	AC-06-CS-1002-01 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
411100	AC-06-CS-1002-02 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
Located beneath deck plating.															
411200	AC-06-CS-1002-03 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
411300	AC-06-CS-1002-04 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
411400	AC-06-CS-1002-05 Pipe to Valve ISI-870B	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-1269</u>															
412900	Valve 1AF-102 3" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
413000	AF-03-AFW-1001-1 Valve 1AF-102 to Pipe Cal Block: TBD	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
413100	AF-03-AFW-1001-2 Pipe to Valve 1AF-31 Cal Block: TBD	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
413150	Valve 1AF-31 3" Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
413200	AF-03-AFW-1001-3 Valve 1AF-31 to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
413300	AF-03-AFW-1001-4 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
413400	AF-03-AFW-1001-5 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
413500	AF-03-AFW-1001-6 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
413600	AF-03-AFW-1001-7 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
413700	AF-03-AFW-1001-8 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
413800	EB-10-H37 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
413900	AF-03-AFW-1001-9 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
414000	AF-03-AFW-1001-10 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
414100	AF-03-AFW-1001-11 Pipe to Tee Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
414150	Valve 1AF-106 Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
414200	AF-03-AFW-1001-12 Valve 1AF-106 to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
414300	AF-03-AFW-1001-13 Pipe to Valve 1AF-18 Cal Block: TBD	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
414350	Valve 1AF-18 Motor Operated Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
414400	AF-03-AFW-1001-14 Valve 1AF-18 to Pipe Cal Block: TBD	R-A R1.20	VOL	X	-	-	-	-	-	-	-	-	-	-	-
414500	DB-3-H1 Anchor	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
414600	DB-3-H1-IWA Welded Attachment	C-C C3.20	SUR	X	-	-	-	-	-	-	-	-	-	-	-
414700	AF-03-AFW-1001-15 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
414800	AF-03-AFW-1001-16 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
414900	EB-10-S882 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
415000	EB-10-S882-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
415100	EB-10-S884 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
415200	EB-10-S884-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
415300	AF-03-AFW-1001-17 Pipe to Tee Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
415400	AF-03-AFW-1001-18 Tee to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
415500	AF-03-AFW-1001-19 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
415600	AF-03-AFW-1001-20 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
415700	AF-03-AFW-1001-21 Pipe to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
415800	EB-10-S895 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
415900	EB-10-S895-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-1270</u>															
416000	AF-03-AFW-1001-22 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
416100	AF-03-AFW-1001-23 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
416200	AF-03-AFW-1001-24 Pipe to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
416300	EB-10-S897 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
416400	EB-10-S897-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
416500	AF-03-AFW-1001-25 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
416600	EB-10-H1 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
416700	EB-10-H1-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
416800	AF-03-AFW-1001-26 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
416900	AF-03-AFW-1001-27 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417000	AF-03-AFW-1001-28 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417100	EB-10-H2 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
417200	EB-10-H2-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
417300	EB-10-S898 Component Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
417400	EB-10-S898-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	X	-	-	-	-	-	-	-
417500	AF-03-AFW-1001-29 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417600	AF-03-AFW-1001-30 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417700	AF-03-AFW-1001-31 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417800	AF-03-AFW-1001-32 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
417900	AF-03-AFW-1001-33 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
418000	AF-03-AFW-1001-34 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-
418100	EB-10-H4 Component Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
418200	AF-03-AFW-1001-35 Pipe to Flange Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
418300	AF-03-AFW-1001-36 Flange to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
418400	EB-10-H5 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
418500	EB-10-H6 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
418600	AF-03-AFW-1001-37 Pipe to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
418700	EB-10-S899 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
418800	EB-10-S899-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
418900	AF-03-AFW-1001-38 Pipe to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
419000	EB-10-H7 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
419100	EB-10-H7-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
419200	AF-03-AFW-1001-39 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
419300	AF-03-AFW-1001-40 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
419400	EB-10-H8 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
419500	EB-10-H8-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
419600	EB-10-S900 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
419700	EB-10-S900-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
419800	AF-03-AFW-1001-41 Pipe to Elbow Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
419900	AF-03-AFW-1001-42 Elbow to Pipe Cal Block: TBD	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
420000	EB-10-S695 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
420100	EB-10-S695-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
420200	EB-10-H9 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
420300	AF-03-AFW-1001-43 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
420400	EB-10-H10 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
420500	EB-10-H11 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
420600	EB-10-S901 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
420700	EB-10-S901-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
420800	AF-03-AFW-1001-44 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
420900	AF-03-AFW-1001-45 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
421000	EB-10-S901 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
421100	AF-03-AFW-1001-46 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
421200	AF-03-AFW-1001-47 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
421300	EB-10-H32 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
421400	EB-10-H31 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
421500	AF-03-AFW-1001-48 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
421600	AF-03-AFW-1001-49 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
421700	EB-10-S902 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
421800	EB-10-S902-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
421900	AF-03-AFW-1001-50 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
422000	AF-03-AFW-1001-51 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
422100	EB-10-H30 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
423200	EB-10-A14-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
423300	AF-03-AFW-1001-60 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
423400	AF-03-AFW-1001-61 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
423500	AF-03-AFW-1001-62 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
423600	AF-03-AFW-1001-63 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
423700	EB-10-R140 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
423900	EB-10-R139 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
424100	EB-10-R138 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
424300	EB-10-R137 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
424400	AF-03-AFW-1001-64 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
425900	EB-10-R132 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
426100	AF-03-AFW-1001-69 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
426200	EB-10-R130 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
426400	AF-03-AFW-1001-70 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
426500	EB-10-R128 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
426700	AF-03-AFW-1001-71 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
426800	EB-10-R126 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
427000	EB-10-A12 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
427100	EB-10-A12-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
427200	AF-03-AFW-1001-72 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
427300	EB-10-R123 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
427500	AF-03-AFW-1001-73 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
427600	EB-10-R122 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
427800	EB-10-EB2 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
428000	EB-10-R121 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
428200	AF-03-AFW-1001-74 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
428300	AF-03-AFW-1001-75 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
428400	EB-10-R119 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
428600	EB-10-R118 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
428800	AF-03-AFW-1001-76 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
428900	EB-10-R116 Component Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
429100	AF-03-AFW-1001-77 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
429200	EB-10-R115 Component Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
429400	EB-10-R114 Component Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
429600	EB-10-EB1 Component Support	F-A Fl.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
429800	AF-03-AFW-1001-78 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
429900	AF-03-AFW-1001-79 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
430000	AF-03-AFW-1001-80 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
430100	AF-03-AFW-1001-81 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
430200	AF-03-AFW-1001-82 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
430300	AF-03-AFW-1001-83 Pipe to Valve 1AF-100	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
430350	Valve 1AF-100 Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
430400	AF-03-AFW-1001-84 Valve 1AF-100 to Pipe	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
430500	AF-03-AFW-1001-85 Pipe to Branch Connection	R-A R1.11	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-1272</u>															
433000	Valve 1AF-104 Check Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
433100	AF-03-AFW-1002-1 Valve 1AF-104 to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
433200	AF-03-AFW-1002-2 Pipe to Valve 1AF-44	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
433300	Valve 1AF-44 Motor Operated Valve No examination required.			-	-	-	-	-	-	-	-	-	-	-	-
433400	AF-03-AFW-1002-3 Valve 1AF-44 to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
433500	AF-03-AFW-1002-4 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
433600	EB-10-H40 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
433700	EB-10-H38 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
433800	AF-03-AFW-1002-5 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
433900	AF-03-AFW-1002-6 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434000	AF-03-AFW-1002-7 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434100	AF-03-AFW-1002-8 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434200	EB-10-H36 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
434300	AF-03-AFW-1002-9 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434400	AF-03-AFW-1002-10 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434500	AF-03-AFW-1002-11 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
434600	Valve 1AF-107 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
434700	AF-03-AFW-1002-12 Valve 1AF-107 to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434800	AF-03-AFW-1002-13 Pipe to Valve 1AF-19	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
434900	Valve 1AF-19 Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required.														
435000	AF-03-AFW-1002-14 Valve 1AF-19 to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
435100	DB-3-H4 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
435200	DB-3-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
435300	AF-03-AFW-1002-15 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
435400	AF-03-AFW-1002-16 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
435500	EB-10-S883 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
435600	EB-10-S883-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
435700	EB-10-S885 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
435800	EB-10-S885-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
435900	AF-03-AFW-1002-17 Pipe to Tee	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436000	AF-03-AFW-1002-18 Tee to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436100	AF-03-AFW-1002-19 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436200	AF-03-AFW-1002-20 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436300	AF-03-AFW-1002-21 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436400	EB-10-S895 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
436500	EB-10-S895-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
<u>Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-1273 sh. 1</u>															
436600	AF-03-AFW-1002-22 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436700	AF-03-AFW-1002-23 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
436800	EB-10-S896 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
436900	EB-10-S896-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
437000	AF-03-AFW-1002-24 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
437100	AF-03-AFW-1002-25 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
437200	EB-10-H12 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
437300	EB-10-H12-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
437400	AF-03-AFW-1002-26 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
437500	AF-03-AFW-1002-27 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
437600	AF-03-AFW-1002-28 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
437700	EB-10-H13 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
437800	EB-10-H13-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
437900	EB-10-S898 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
438000	EB-10-S898-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
438100	AF-03-AFW-1002-29 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
438200	AF-03-AFW-1002-30 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
438300	AF-03-AFW-1002-31 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
438400	AF-03-AFW-1002-32 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
438500	AF-03-AFW-1002-33 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS														
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3
438600	AF-03-AFW-1002-34 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
438700	EB-10-H4 Component Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
438800	EB-10-H4-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
438900	AF-03-AFW-1002-35 Pipe to Flange	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439000	AF-03-AFW-1002-36 Flange to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439100	EB-10-H5 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439200	EB-10-H6 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439300	EB-10-H6-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439400	AF-03-AFW-1002-37 Pipe to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
439450	EB-10-S899 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
439500	EB-10-H7 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
439600	EB-10-H7-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
439700	AF-03-AFW-1002-38 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
439800	AF-03-AFW-1002-39 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
439900	EB-10-H8 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
440000	EB-10-H8-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
440100	EB-10-S900 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
440200	EB-10-S900-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
440300	AF-03-AFW-1002-40 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
440400	AF-03-AFW-1002-41 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
440500	EB-10-S695 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
440600	EB-10-S695-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
<u>Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-1273 sh. 2</u>															
440700	EB-10-H9 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
440800	EB-10-H9-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
440900	EB-10-H10 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
441000	EB-10-H10-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
441100	EB-10-H11 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
441200	EB-10-H11-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
441300	EB-10-S901 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
441400	EB-10-S901-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
441500	AF-03-AFW-1002-42 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
441600	AF-03-AFW-1002-43 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
441700	AF-03-AFW-1002-44 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
441800	AF-03-AFW-1002-45 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
441900	EB-10-S901 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
442000	EB-10-S901-IWA Welded Attachment	C-C C3.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
442100	AF-03-AFW-1002-46 Pipe to Elbow	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
442200	AF-03-AFW-1002-47 Elbow to Pipe	R-A R1.20	VOL	-	-	-	-	-	-	-	-	-	-	-	-
442300	EB-10-H32 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
442400	EB-10-H31 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-