

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
258000	AC-06-SI-2002-34 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
258100	2H-19 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH 2H-19A (7/00)															
258300	AC-06-SI-2002-35 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
258400	AC-06-SI-2002-36 Elbow to Tee	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
258500	AC-06-SI-2002-37 Tee to Pipe	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
258700	AC-06-SI-2002-38 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
258800	2H-20A Rigid Support	F-A F1.20A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
259100	2H-21 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
259300	AC-06-SI-2002-39 Pipe to Elbow	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
259400	AC-06-SI-2002-40 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
259600	AC-06-SI-2002-41 Pipe to Valve SI-857A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
259700	Valve SI-857A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
259800	AC-06-SI-2002-42 Tee to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
259900	AC-06-SI-2002-43 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
260100	AC-06-SI-2002-44 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
260200	AC-06-SI-2002-45 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
260400	AC-06-SI-2002-46 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
260500	2H-29 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
260700	AC-06-SI-2002-47 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
260800	AC-06-SI-2002-48 Pipe to Valve SI-871A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
260900	Valve SI-871A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
261000	AC-06-SI-2002-49 Valve SI-871A to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>RHR to B Safety Injection Pump Suction / Dwg. No. ISI-PRI-2234</u>															
262000	22-2H-16B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH 2H-16B, SI-301R-1 2H14A, AND AN UNIDENTIFIED 2" PIPE (7/00)															
262200	22-2H-16A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH 2H-16A, SI-301R-1 2H13A AND AN UNKNOWN 2" PIPE (7/00)															
262400	AC-06-SI-2003-17 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
262500	AC-06-SI-2003-18 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
262800	2H-17A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH 2H-17A (7/00)															
262900	AC-06-SI-2003-18A Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
263200	2H-18A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
263500	AC-06-SI-2003-19 Pipe to Elbow	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
263600	AC-06-SI-2003-20 Elbow to Pipe	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
263700	2H-19A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH 2H-19 (7/00)															
263900	AC-06-SI-2003-21 Pipe to Elbow	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
264000	AC-06-SI-2003-22 Elbow to Pipe	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
264100	AC-06-SI-2003-23 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
264200	AC-06-SI-2003-24 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
264400	2H-20 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
264700	AC-06-SI-2003-25 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
264800	2H-22 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
265000	AC-06-SI-2003-26 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
265200	AC-06-SI-2003-27 Pipe to Valve SI-857B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
265300	Valve SI-857B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
265400	AC-06-SI-2003-28 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
265600	AC-06-SI-2003-29 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
265700	AC-06-SI-2003-30 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
265900	AC-06-SI-2003-31 Pipe to Elbow	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
266000	2H-30 Spring Support	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
266200	AC-06-SI-2003-32 Elbow to Pipe	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
266300	AC-06-SI-2003-33 Pipe to Valve SI-871B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
266400	Valve SI-871B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

Category and item number will be R-A and R1.20 for the 4th interval.

RHR to Safety Injection Pump Suction / Dwg. No. ISI-PRI-2235

267000	AC-06-SI-2003-01	C-F-1	- - - - -
	Reducer to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

RHR to B Safety Injection Pump Suction / Dwg. No. ISI-PRI-2235

267100	AC-06-SI-2003-02	C-F-1	- - - - -
	Pipe to Elbow	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

[illegible]

Category and item number will be R-A and R1.20 for the 4th interval.

[illegible]

Category and item number will be R-A and R1.20 for the 4th interval.

267600	AC-06-SI-2003-05	C-F-1	- - - - -
	Elbow to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

267700	AC-06-SI-2003-06	C-F-1	- - - - -
	Pipe to Elbow	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

267800	AC-06-SI-2003-07	C-F-1	- - - - -
	Elbow to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
267900	AC-06-SI-2003-07A Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268000	AC-06-SI-2003-08 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268200	AC-06-SI-2003-09 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268300	AC-06-SI-2003-10 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268400	AC-06-SI-2003-11 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268500	R-2376A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
268600	R-2375A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
268700	R-2315A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH SI-301R-1-R2315 AND R-2315A (7/00)															
268800	AC-06-SI-2003-12 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
268900	AC-06-SI-2003-13 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
269000	AC-06-SI-2003-14 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
269100	AC-06-SI-2003-15 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
269200	AC-06-SI-2003-16 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Safety Injection Pump A Inlet and Outlet / Dwg. No. ISI-PRI-2238</u>															
270000	SIS-06-SI-2005-01 Valve SI-896A to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
270100	S-742A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH S-742B															
270200	SIS-06-SI-2005-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
270300	SIS-06-SI-2005-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
270400	2-2H3 Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
270600	SIS-06-SI-2005-04 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
270700	SIS-06-SI-2005-05 Valve SI-857A to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
270800	SIS-06-SI-2005-06 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
270900	SIS-06-SI-2005-07 Elbow to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271000	SIS-06-SI-2005-08 Tee to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271100	SIS-06-SI-2005-09 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271200	SIS-06-SI-2005-10 Pipe to Flange	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271300	Safety Injection Pump P-15A Safety Injection Pump			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
271400	SIS-06-SI-2005-12 Flange to Elbow Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271500	SIS-06-SI-2005-13 Elbow to Reducer Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271600	SIS-06-SI-2005-14 Reducer to Pipe Cal Block: 52-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
271700	SIS-06-SI-2005-14-BC 2" Branch Connection	C-F-1 C5.41	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS														
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3
271800	SIS-06-SI-2005-15 Pipe to Valve SI-889A Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
271900	Valve SI-889A 6" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272000	SIS-06-SI-2005-16 Valve SI-889A to Elbow Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272100	SIS-06-SI-2005-17 Elbow to Pipe Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272200	S-250 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272300	SIS-06-SI-2005-18 Pipe to Elbow Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	X	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272400	SIS-06-SI-2005-19 Elbow to Valve SI-888A Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272500	Valve SI-888A 6" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272600	SIS-06-SI-2005-20 Valve SI-888A to Elbow Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
272700	1-2H2 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	X	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
272900	SIS-06-SI-2005-21 Elbow to Tee Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	X	-	-	-	-	-	-	-	-	-	-	-
273000	SIS-06-SI-2005-21A Tee to Valve SI-829A Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
273100	Valve SI-829A 6" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
273200	SIS-06-SI-2005-22 Tee to Reducer Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection Pump B Inlet and Outlet / Dwg. No. ISI-PRI-2239</u>															
274100	SIS-06-SI-2006-01 Valve SI-896B to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
274200	S-742B Rigid Support GANGED WITH S-742A	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
274300	SIS-06-SI-2006-02 Pipe to Elbow Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
274400	SIS-06-SI-2006-03 Elbow to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
274500	SIS-06-SI-2006-04 Pipe to Tee Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
274600	SIS-06-SI-2006-05 Tee to Valve SI-857B Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
274700	SIS-06-SI-2006-06 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
274800	SIS-06-SI-2006-07 Pipe to Flange	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
274900	Safety Injection Pump P-15B Safety Injection Pump			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
275000	SIS-06-SI-2006-08 Flange to Elbow Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
275100	SIS-06-SI-2006-09 Elbow to Reducer Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
275200	SIS-06-SI-2006-10 Reducer to Pipe Cal Block: 52-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
275300	SIS-06-SI-2006-10-BC 2" Branch Connection	C-F-1 C5.41	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
275500	SIS-06-SI-2006-11 Pipe to Valve SI-889B Cal Block: 52-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
275600	Valve SI-889B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
275700	SIS-06-SI-2006-12 Valve SI-889B to Elbow Cal Block: 52-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
275800	SIS-06-SI-2006-13 Elbow to Pipe Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
275900	1-2H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
276100	SIS-06-SI-2006-14 Pipe to Elbow Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
276200	SIS-06-SI-2006-15 Elbow to Valve SI-888B Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
276300	Valve SI-888B 6" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
276400	SIS-06-SI-2006-16 Valve SI-888B to Elbow Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
276500	1-2H4 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
276700	SIS-06-SI-2006-17 Elbow to Tee Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
276800	SIS-06-SI-2006-17A Tee to Pipe Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
276900	SIS-06-SI-2006-17B Pipe to Valve SI-829B Cal Block: 52-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
277000	Valve SI-829B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
277100	SIS-06-SI-2006-18 Tee to Reducer Cal Block: 52-PTB	C-F-1 C5.11	SUR VOL	X	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
<u>RHR to Reactor Pressure Vessel / Dwg. No. ISI-PRI-2240</u>															
278000	SIS-06-SI-2007-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
278100	SIS-06-SI-2007-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
278200	SIS-06-SI-2007-03 Elbow to Valve SI-852A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
278300	Valve SI-852A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
278400	SIS-06-SI-2007-04 Valve SI-852A to Pipe Cal Block: 4-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
278500	2R-24 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
278600	SIS-06-SI-2007-05 Pipe to Valve SI-853A Cal Block: 4-PTB	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RHR to RPV Injection / Dwg. No. ISI-PRI-2241															
279000	SIS-06-SI-2008-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279200	SIS-06-SI-2008-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279300	SIS-06-SI-2008-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279400	SIS-06-SI-2008-04 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279500	SIS-06-SI-2008-05 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279600	H201 Rigid Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
279800	SIS-06-SI-2008-06 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
279900	SI-601R-2-H5 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
280100	SIS-06-SI-2008-07 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
280200	H200 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
280400	SIS-06-SI-2008-08 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
280500	SIS-06-SI-2008-09 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
280600	SI-601R-2-H4 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
280800	R-2372 Component Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
280900	SIS-06-SI-2008-10 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
281000	SIS-06-SI-2008-11 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
281200	SI-601R-2-H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
281400	SIS-06-SI-2008-12 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
281500	SIS-06-SI-2008-13 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
281600	R-2334 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
283100	A-11/M82 Anchor	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 22															
283110	SIS-06-SI-2008-20 Penetration to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
283300	SIS-06-SI-2008-21 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
283400	R-96 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
NOTED ON WE-200072 AS A WHIP RESTRAINT															
283500	SIS-06-SI-2008-22 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
283600	SIS-06-SI-2008-23 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
283700	SIS-06-SI-2008-24 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
283800	R-94 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
283900	SIS-06-SI-2008-25 Pipe to Valve SI-852B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
284000	Valve SI-852B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
284100	SIS-06-SI-2008-26 Valve SI-852B to Pipe Cal Block: 4-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
284200	R-93 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
284300	SIS-06-SI-2008-27 Pipe to Valve SI-853B Cal Block: 4-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop A Main Steam Inside Containment / Dwg. No. ISI-PRI-2243</u>															
285000	MS-31-MS-2001-01A Nozzle to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285010	MS-31-MS-2001-01ALD Downstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285090	MS-31-MS-2001-01BLU Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285100	MS-31-MS-2001-01B Pipe to Elbow Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285110	MS-31-MS-2001-01LDI Inside Downstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285120	MS-31-MS-2001-01LDO Outside Downstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
285180	MS-31-MS-2001-02LUI Inside Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285190	MS-31-MS-2001-02LUO Outside Upstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285200	MS-31-MS-2001-02 Elbow to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
285210	MS-31-MS-2001-02LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285290	MS-30-MS-2001-02ELU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285300	MS-30-MS-2001-02E Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285310	MS-30-MS-2001-02ELD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285390	MS-30-MS-2001-02HLU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285400	MS-30-MS-2001-02H Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
285410	MS-30-MS-2001-02HLD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285500	HS-32 Snubber Ganged with HS-33	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
285600	HS-33 Snubber Ganged with HS-32	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
285690	MS-30-MS-2001-03LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285700	MS-30-MS-2001-03 Pipe to Flow Element Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285710	MS-30-MS-2001-03LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285790	MS-30-MS-2001-04LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285800	MS-30-MS-2001-04 Flow Element to Elbow Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285810	MS-30-MS-2001-04LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285820	MS-30-MS-2001-04LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
285880	MS-30-MS-2001-05LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285890	MS-30-MS-2001-05LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285900	MS-30-MS-2001-05 Elbow to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
285910	MS-30-MS-2001-05LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
286100	MS-2H3 Spring Hanger Ganged with R-10	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
286390	MS-30-MS-2001-06LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
286400	MS-30-MS-2001-06 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
286410	MS-30-MS-2001-06LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
286500	MS-2H4 Constant Support Ganged with R-13,	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
286990	MS-30-MS-2001-07LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
287000	MS-30-MS-2001-07 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
287010	MS-30-MS-2001-07LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
287090	MS-30-MS-2001-07ALU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
287100	MS-30-MS-2001-07A Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
287110	MS-30-MS-2001-07ALD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
287200	MS-2R16 Rigid Support Ganged with MD-2H5, MOD 96-026	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
287300	MS-2H5 Spring Hanger Ganged with R-16	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Loop A Main Steam Inside Containment / Dwg. No. ISI-PRI-2244															
287990	MS-30-MS-2001-08LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288000	MS-30-MS-2001-08 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS											
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
288010	MS-30-MS-2001-08LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288200	MS-2H6 Spring Hanger Ganged with R-19	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
288490	MS-30-MS-2001-09LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288500	MS-30-MS-2001-09 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288510	MS-30-MS-2001-09LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288790	MS-30-MS-2001-10LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288800	MS-30-MS-2001-10 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288810	MS-30-MS-2001-10LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
288900	MS-2H7 Spring Hanger Ganged with R-22	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
289090	MS-30-MS-2001-11LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
289100	MS-30-MS-2001-11 Pipe to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
289110	MS-30-MS-2001-11LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
289300	MS-30-MS-2001-11-BC 6" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
290000	MS-06-MS-2001-01 Branch Connection to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
290100	MS-06-MS-2001-02 Pipe to Cap Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
<u>Loop B Main Steam Inside Containment / Dwg. No. ISI-PRI-2245</u>															
291000	MS-31-MS-2002-01A Nozzle to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291010	MS-31-MS-2002-01ALD Downstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291090	MS-31-MS-2002-01BLU Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291100	MS-31-MS-2002-01B Pipe to Elbow Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
291110	MS-31-MS-2002-01LDI Inside Downstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291120	MS-31-MS-2002-01LDO Outside Downstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291180	MS-31-MS-2002-02LUI Inside Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291190	MS-31-MS-2002-02LUO Outside Upstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291200	MS-31-MS-2002-02 Elbow to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-	-
291210	MS-31-MS-2002-02LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291290	MS-31-MS-2002-02ELU Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291300	MS-31-MS-2002-02E Pipe to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-	-
291310	MS-31-MS-2002-02ELD Downstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
291390	MS-31-MS-2002-02HLU Upstream Long Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
291400	MS-31-MS-2002-02H Pipe to Pipe Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291410	MS-31-MS-2002-02HLD Downstream Longitudinal Weld Cal Block: 44-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291500	HS-34 Snubber Ganged with HS-35 and MS-2H1	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
291600	HS-35 Snubber Ganged with HS-34 and MS-2H1	F-A F1.20S	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
291800	MS-2H1 Spring Hanger Ganged with HS-34 and HS-35	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
291890	MS-31-MS-2002-03LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291900	MS-31-MS-2002-03 Pipe to Elbow Cal Block: 44-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291910	MS-31-MS-2002-03LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291920	MS-31-MS-2002-03LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
291980	MS-30-MS-2002-04LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
291990	MS-30-MS-2002-04LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292000	MS-30-MS-2002-04 Elbow to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292010	MS-30-MS-2002-04LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292190	MS-30-MS-2002-05LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292200	MS-30-MS-2002-05 Pipe to Flow Element Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
292210	MS-30-MS-2002-05LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292290	MS-30-MS-2002-06LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292300	MS-30-MS-2002-06 Flow Element to Elbow Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292310	MS-30-MS-2002-06LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
292320	MS-30-MS-2002-06LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292400	MS-2H2 Constant Support Ganged with EB-1-R3 and EB-1-R4	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
292500	MS-2H2-IWA Welded Attachment Category and item number will be R-A and R1.20 for the 4th interval.	C-C C3.20	SUR	-	-	-	-	X	-	-	-	-	-	-	-
292680	MS-30-MS-2002-07LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292690	MS-30-MS-2002-07LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292700	MS-30-MS-2002-07 Elbow to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292710	MS-30-MS-2002-07LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292890	MS-30-MS-2002-08LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292900	MS-30-MS-2002-08 Pipe to Elbow Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292910	MS-30-MS-2002-08LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
292920	MS-30-MS-2002-08LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292980	MS-30-MS-2002-09LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
292990	MS-30-MS-2002-09LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
293000	MS-30-MS-2002-09 Elbow to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
293010	MS-30-MS-2002-09LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Loop A Main Steam Outside Containment / Dwg. No. ISI-PRI-2246															
293990	MS-30-MS-2001-18LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
294000	MS-30-MS-2001-18 Pipe to Tee Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
294010	MS-30-MS-2001-18LDI Inside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
294020	MS-30-MS-2001-18LDO Outside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
294410	MS-30-MS-2001-21LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294500	2H-19B Rigid Support	F-A Fl.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A SPRING HANGER ON P-207, BASED ON P-407 SH18 IT IS A RIGID SUPPORT (8/00)															
294690	MS-30-MS-2001-22LU Upstream Long Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294700	MS-30-MS-2001-22 Pipe to Pipe Cal Block: 46-PTB One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294710	MS-30-MS-2001-22LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294790	MS-30-MS-2001-23LU Upstream Long Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294800	MS-30-MS-2001-23 Pipe to Pipe Cal Block: 46-PTB One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294810	MS-30-MS-2001-23LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294890	MS-30-MS-2001-24LU Upstream Long Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
294900	MS-30-MS-2001-24 Pipe to Pipe Cal Block: 46-PTB One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
294910	MS-30-MS-2001-24LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
295000	R-250 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
WE-200098 REFERENCED C-2390 AND C-396 (8/00)															
295980	MS-30-MSR-2001-01LUI Inside Upstream Long Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
295990	MS-30-MSR-2001-01LUO Outside Upstream Longitudinal Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
296000	MS-30-MSR-2001-01 Tee to Pipe Cal Block: 47-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
296010	MS-30-MSR-2001-01LD Downstream Longitudinal Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
296100	MS-30-MSR-2001-02-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
296200	2H-20B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
296300	MS-30-MSR-2001-03-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
296400	2H-20C Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
SHOWN AS A RESTRAINT ON P-207 (8/00)															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
296500	MS-30-MSR-2001-04-BC 8" Branch Connection	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
296600	MS-30-MSR-2001-05-BC 8" Branch Connection	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
296700	2H-21A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A RESTRAINT ON P-207 (8/00)															
296800	MS-30-MSR-2001-06-BC 6" Branch Connection	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
296900	2HC Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
SHOWN AS A RESTRAINT ON P-207 (8/00)															
296990	MS-30-MSR-2001-07LU Upstream Long Weld Cal Block: 47-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
297000	MS-30-MSR-2001-07 Pipe to Cap Cal Block: 47-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side.															
298000	MS-08-MSR-2001-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
298100	MS-08-MSR-2001-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting is less than 2" diameter.															
298200	MS-08-MSR-2001-02 Flange to Valve MS-2010	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
298300	Valve MS-2010 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
299000	MS-08-MSR-2002-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
299100	MS-08-MSR-2002-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting is less than 2" diameter.															
299200	MS-08-MSR-2002-02 Flange to Valve MS-2011	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.															
299300	Valve MS-2011 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
300000	MS-08-MSR-2003-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
300100	MS-08-MSR-2003-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting is less than 2" diameter.															
300200	MS-08-MSR-2003-02 Flange to Valve MS-2012	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.															
300300	Valve MS-2012 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
301000	MS-08-MSR-2004-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
301100	MS-08-MSR-2004-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required. Bolting is less than 2" diameter.														
301200	MS-08-MSR-2004-02 Flange to Valve MS-2013	C-F-2 C5.51	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attach to an 8" flange.														
301300	Valve MS-2013 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required. Bolting 2" or less in size.														
302000	MS-06-MSR-2001-01 Branch Connection to Pipe	C-F-2 C5.51A		-	-	-	-	X	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
302100	MS-06-MSR-2001-02 Pipe to Valve MS-227	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
302200	Valve MS-227 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required. Bolting 2" or less in size.														
302300	MS-06-MSR-2001-03 Valve MS-227 to Pipe	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
302400	MS-06-MSR-2001-04R1 Pipe to Valve MS-2016	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
302500	Valve MS-2016 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required. Bolting 2" or less in size.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
		FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	O U T A G E											
				1	2	3	4	1	2	3	4	1	2	3	4
<u>RHR to B Safety Injection Pump Suction / Dwg. No. ISI-PRI-2247</u>															
303200	AC-08-SI-2001-11A Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
303300	AC-08-SI-2001-11B Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
303400	AC-08-SI-2001-13 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
303500	AC-08-SI-2001-14 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
303600	AC-08-SI-2001-14A Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
303700	2H-13 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
304000	2H-13A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
304100	AC-08-SI-2001-15 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
304200	AC-08-SI-2001-16 Tee to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
304300	AC-08-SI-2001-17 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
304400	AC-08-SI-2001-17R Pipe to Cap	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
305000	AC-08-SI-2002-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
305100	AC-08-SI-2002-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
305200	AC-08-SI-2002-03 Elbow to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
306000	AC-06-SI-2006-01 Reducer to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
306100	AC-601R-7-H303 Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
306200	AC-06-SI-2006-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
306300	AC-06-SI-2006-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
306400	AC-06-SI-2006-04 Pipe to Valve 2RH-706B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
306500	Valve 2RH-706B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Loop B Main Steam Outside Containment / Dwg. No. ISI-PRI-2248															
306990	MS-30-MS-2002-17LU Upstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307000	MS-30-MS-2002-17 Pipe to Tee Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. One longitudinal seam weld on the upstream side and two on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307010	MS-30-MS-2002-17LDI Inside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307020	MS-30-MS-2002-17LDO Outside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307080	MS-30-MS-2002-18LUI Inside Upstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307090	MS-30-MS-2002-18LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307100	MS-30-MS-2002-18 Tee to Valve MS-2017 Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307200	Valve MS-2017 30" Valve No examination required. Bolting 2" or less in size.			-	-	-	-	-	-	-	-	-	-	-	-
307300	MS-30-MS-2002-19 Valve MS-2017 to Pipe Cal Block: 46-PTB One longitudinal seam weld on the downstream side.	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
307310	MS-30-MS-2002-19LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307400	EB-1-2H8 Spring Support DUAL SPRING SUPPORT	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
307600	EB-1-2H7 Rigid Support NOT SHOWN ON P-207 (8/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
307690	MS-30-MS-2002-20LU Upstream Long Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307700	MS-30-MS-2002-20 Pipe to Pipe Cal Block: 45-PTB One longitudinal seam weld on the upstream side and one on the downstream side.	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307710	MS-30-MS-2002-20LD Downstream Longitudinal Weld Cal Block: 46-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	-	-	-	-
307800	EB-1-2H6 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
307980	MS-30-MSR-2002-01LUI Inside Upstream Long Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
307990	MS-30-MSR-2002-01LUO Outside Upstream Longitudinal Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
308000	MS-30-MSR-2002-01 Tee to Pipe Cal Block: 47-PTB Category and item number will be R-A and R1.20 for the 4th interval. Two longitudinal seam welds on the upstream side and one on the downstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
308010	MS-30-MSR-2002-01LD Downstream Longitudinal Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
308100	MS-30-MSR-2002-02-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
308200	EB-1-2H9 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
308300	MS-30-MSR-2002-03-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
308400	EB-1-2H9A Rigid Support SHOWN AS A RESTRAINT ON P-207 (8/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
308500	MS-30-MSR-2002-04-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
308600	MS-30-MSR-2002-05-BC 8" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
308700	EB-1-2H10 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
308800	MS-30-MSR-2002-06-BC 6" Branch Connection Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
308900	EB-1-2HB Rigid Support SHOWN AS A RESTRAINT ON P-207 (8/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
308990	MS-30-MSR-2002-07LU Upstream Long Weld Cal Block: 47-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
309000	MS-30-MSR-2002-07 Pipe to Cap Cal Block: 47-PTB Category and item number will be R-A and R1.20 for the 4th interval. Cap is 0.908 thick. One longitudinal seam weld on the upstream side.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
310000	MS-08-MSR-2005-01 Branch Connection to Flange Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
310100	MS-08-MSR-2005-01-FB Flange Bolting No examination required. Bolting is less than 2" diameter.			-	-	-	-	-	-	-	-	-	-	-	-
310200	MS-08-MSR-2005-02 Flange to Valve MS-2005 Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
310300	Valve MS-2005 6" Valve No examination required. Bolting 2" or less in size.			-	-	-	-	-	-	-	-	-	-	-	-
311000	MS-08-MSR-2006-01 Branch Connection to Flange Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
311100	MS-08-MSR-2006-01-FB Flange Bolting No examination required. Bolting is less than 2" diameter.			-	-	-	-	-	-	-	-	-	-	-	-
311200	MS-08-MSR-2006-02 Flange to Valve MS-2006 Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
311300	Valve MS-2006 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
312000	MS-08-MSR-2007-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
312100	MS-08-MSR-2007-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting is less than 2" diameter.															
312200	MS-08-MSR-2007-02 Flange to Valve MS-2007	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.															
312300	Valve MS-2007 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
313000	MS-08-MSR-2008-01 Branch Connection to Flange	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This weld will have an F volumetric examination due to space limitations.															
313100	MS-08-MSR-2008-01-FB Flange Bolting			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting is less than 2" diameter.															
313200	MS-08-MSR-2008-02 Flange to Valve MS-2008	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval. This is a 6" valve attached to an 8" flange.															
313300	Valve MS-2008 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
314000	MS-06-MSR-2002-01M Pipe to Pipe	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
314100	MS-06-MSR-2002-02R1 Pipe to Valve MS-244	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
314200	Valve MS-224 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
314300	MS-06-MSR-2002-03R1 Valve MS-244 to Pipe	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
314400	MS-06-MSR-2002-04 Pipe to Valve CV-2015	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
314500	Valve MS-2015 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required. Bolting 2" or less in size.															
<u>Feedwater Loop A / Dwg. No. ISI-PRI-2249</u>															
315200	FW-16-FW-2001-01AR1 Pipe to Valve CS-466AA Cal Block: 34-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	X	-	-	-
315400	FW-16-FW-2001-01R1 Valve CS-466AA to Pipe Cal Block: 34-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
315500	2H-19C Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
315700	FW-16-FW-2001-02 Pipe to Elbow Cal Block: 34-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
315800	FW-16-FW-2001-03 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
315900	FW-16-FW-2001-04 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316000	FW-16-FW-2001-05 Pipe to Penetration Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval. WELD ACCESS TO BE EVALUATED.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316100	A-04/M83 Anchor PENETRATION 4	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
316110	FW-16-FW-2001-06 Penetration to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316200	FW-16-FW-2001-07 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval. COMPONENT IS INACCESSIBLE.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316300	FW-16-FW-2001-08 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316500	FW-16-FW-2001-09 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316600	R-13 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
316700	R-12 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
316800	FW-16-FW-2001-10 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
316900	FW-16-FW-2001-11 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Feedwater Loop A / Dwg. No. ISI-PRI-2250</u>															
318100	FW-16-FW-2001-12 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
318200	FW-16-FW-2001-13 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
318300	FW-2H6 Rigid Support SHOWN AS A DUAL RESTRAINT ON P-212 (8/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
318400	FW-16-FW-2001-14 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
318500	FW-2H5 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
318600	FW-16-FW-2001-15 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
318700	FW-16-FW-2001-16 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
318900	FW-16-FW-2001-17 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
319000	FW-16-FW-2001-18 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
319100	FW-2H4 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
319200	FW-16-FW-2001-19 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
319300	FW-16-FW-2001-20 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
319500	FW-2H3 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
319700	FW-16-FW-2001-21 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
319800	FW-16-FW-2001-22 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
320000	FW-16-FW-2001-23 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
320100	FW-16-FW-2001-24 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
320300	FW-16-FW-2001-24M Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
320500	FW-16-FW-2001-25 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
320600	FW-2H2 Constant Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
320800	FW-16-FW-2001-26 Elbow to Valve CS-466BB Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
320900	Valve CS-466BB 16" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
321000	FW-16-FW-2001-27 Valve CS-466BB to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.11 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
321100	FW-2H1 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
321300	FW-16-FW-2001-28 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.11 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
321350	FW-16-FW-2001-28BC 3" Branch Connection Category and item number will be R-A and R1.11 for the 4th interval.		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
321400	FW-16-FW-2001-28D Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.11 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
321500	FW-16-FW-2001-28G Pipe to Nozzle Cal Block: 34-PTB Category and item number will be R-A and R1.11/R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Feedwater Loop B / Dwg. No. ISI-PRI-2251</u>															
322100	FW-16-FW-2002-01AR1 Pipe to Valve CS-476AA Cal Block: 34-PTB	C-F-2A MEB 3-1	VOL	-	-	-	-	-	-	-	-	X	-	-	-
322300	FW-16-FW-2002-01R1 Valve CS-476AA to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
322400	2H-13B Dual Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
322600	FW-16-FW-2002-02 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
322700	FW-16-FW-2002-03 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
322800	FW-16-FW-2002-04 Pipe to Penetration Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval. FIELD ACCESS TO BE EVALUATED.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
322900	FW-16-FW-2002-05 Penetration to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
322910	A-03 Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
323000	FW-16-FW-2002-06 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
323100	FW-16-FW-2002-07 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
323300	FW-16-FW-2002-08 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
323400	FW-16-FW-2002-09 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
323600	FW-16-FW-2002-10 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
323700	FW-16-FW-2002-11 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval. Weld is inaccessible.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
323900	FW-2H9 Spring Hanger Piping and structural steel in the area limits access, support is difficult to reach due to height.	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
324200	FW-16-FW-2002-12 Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
324400	FW-16-FW-2002-13 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
324500	FW-16-FW-2002-14 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
324700	FW-16-FW-2002-14M Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
324800	FW-16-FW-2002-15 Pipe to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
325000	FW-2H8 Constant Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
325200	FW-16-FW-2002-16 Elbow to Valve CS-476BB Cal Block: 34-PTB Category and item number will be R-A and R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
325400	FW-16-FW-2002-17 Valve CS-476BB to Elbow Cal Block: 34-PTB Category and item number will be R-A and R1.11/R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
325600	FW-2H7 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
325700	FW-16-FW-2002-18 Elbow to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.11/R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
325750	FW-16-FW-2002-18BC 3" Branch Connection Category and item number will be R-A and R1.11 for the 4th interval.		SUR	-	-	-	-	-	-	-	-	-	-	-	-
325800	FW-16-FW-2002-18D Pipe to Pipe Cal Block: 34-PTB Category and item number will be R-A and R1.11/R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
325900	FW-16-FW-2002-18G Pipe to Nozzle Cal Block: 34-PTB Category and item number will be R-A and R1.11/R1.18 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
RHR Pump A Suction from Cont Sump & Loop A Hot Leg / Dwg. No. ISI-PRI-2252															
327100	Valve 2SI-850A 10" Valve	C-G C6.20	SUR	-	-	-	-	-	-	-	-	X	-	-	-
Group 5 Valve.															
327400	AC-10-RHR-2003-04 Valve 2SI-850A to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
327500	AC-10-RHR-2003-04A Pipe to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
327600	H-201 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
327700	AC-10-RHR-2003-05 Pipe to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
327800	AC-10-RHR-2003-06 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
327900	H-200A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
328000	AC-10-RHR-2003-07 Elbow to Valve SI-851A Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
328100	Valve SI-851A 10" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
328200	AC-10-RHR-2003-08 Valve SI-851A to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
328300	2H-04A Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
328500	AC-10-RHR-2003-09 Pipe to Tee Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
329000	AC-10-RHR-2002-05 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
329100	AC-10-RHR-2002-06 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
329300	AC-10-RHR-2002-07 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
329400	AC-10-RHR-2002-08 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
329500	2H-04 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
329700	AC-10-RHR-2002-09 Pipe to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330000	AC-10-RHR-2002-10 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330100	AC-10-RHR-2002-11 Elbow to Tee Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 - COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
330200	AC-10-RHR-2002-12 Tee to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330300	AC-10-RHR-2002-13 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330400	AC-10-RHR-2002-14 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330500	AC-10-RHR-2002-15 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330600	AC-10-RHR-2002-16 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
330700	2H-03 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
330900	AC-10-RHR-2002-17 Pipe to Flange Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
331000	RHR Pump P-10A Pump No examination required			-	-	-	-	-	-	-	-	-	-	-	-
<u>RHR Pump B Suction from Cont Sump & Loop B Hot Leg / Dwg. No. ISI-PRI-2253</u>															
332100	Valve SI-850B 10" Valve	C-G C6.20	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Examine valve body welds on only one of two valves, SI-850A or SI-850B..															
332400	AC-10-RHR-2005-04 Valve SI-850B to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
332500	AC-10-RHR-2005-04A Pipe to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
332600	AC-10-RHR-2005-05 Pipe to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
332700	H-205 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
332800	2H-03B Spring Hanger NOT SHOWN	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
333000	AC-10-RHR-2005-06 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333100	AC-10-RHR-2005-07 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333200	AC-10-RHR-2005-08 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333300	AC-10-RHR-2005-09 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333400	AC-10-RHR-2005-10 Pipe to Valve SI-851B Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333500	Valve SI-851B 10" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
333600	AC-10-RHR-2005-11 Valve SI-851B to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
333700	R-2347A Rigid Support MARKED AS A RESTRAINT ON P-232	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
333800	2H-02B Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
334100	AC-10-RHR-2005-12 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
334200	AC-10-RHR-2005-13 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
334400	AC-10-RHR-2005-14 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
334500	AC-10-RHR-2005-15 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
334700	AC-10-RHR-2005-16 Elbow to Tee Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335000	AC-10-RHR-2004-05 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335100	AC-10-RHR-2004-06 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
335200	AC-10-RHR-2004-07 Pipe to Elbow Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335300	2H-01 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
335500	AC-10-RHR-2004-08 Elbow to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335600	AC-10-RHR-2004-09 Pipe to Tee Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335700	AC-10-RHR-2004-10 Tee to Pipe Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335800	AC-10-RHR-2004-11 Pipe to Flange Cal Block: 33-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11B	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
335900	RHR Pump P-10B Pump No examination required			-	-	-	-	-	-	-	-	-	-	-	-
Safety Injection Pump P-15A and P-15B Test Line / Dwg. No. ISI-PRI-2254															
337000	SI-23 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
337100	SIS-02-SI-2008-24 Pipe to Elbow Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
337200	SIS-02-SI-2008-25 Elbow to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
337300	SIS-02-SI-2008-26 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337400	SIS-02-SI-2008-27 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337500	SIS-02-SI-2008-28 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337600	SIS-02-SI-2008-29 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337700	SIS-02-SI-2008-30 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337800	SIS-02-SI-2008-31 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
337900	SI-24 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
338000	SI-25 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
338100	SIS-02-SI-2008-32 Pipe to Coupling	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
338200	SIS-02-SI-2008-33 Coupling to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
339300	SIS-02-SI-2008-41 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
339400	SI-28 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
339500	SIS-02-SI-2008-42 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
339600	SIS-02-SI-2008-45 Tee to Reducing Insert	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
339700	SIS-02-SI-2008-43 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
339800	SI-29 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
339900	SIS-02-SI-2008-44 Pipe to Valve SI-897B	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
340000	Valve SI-897B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
<u>Safety Injection Pump P-15B Test Line / Dwg. No. ISI-PRI-2255</u>															
341000	SIS-02-SI-2008-01 Branch Connection to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341100	SIS-02-SI-2008-02 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
341200	SIS-02-SI-2008-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341300	SIS-02-SI-2008-04 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341400	SIS-02-SI-2008-05 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341500	SIS-02-SI-2008-06 Pipe to Coupling	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341600	SIS-02-SI-2008-07 Coupling to Orifice	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341700	SIS-02-SI-2008-08 Orifice to Coupling	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341800	SIS-02-SI-2008-09 Coupling to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
341900	SI-15 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342000	SIS-02-SI-2008-10 Pipe to Valve SI-891B	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342100	Valve SI-891B 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
342200	SIS-02-SI-2008-11 Valve SI-891B to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342300	SIS-02-SI-2008-12 Pipe to Valve SI-876B	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342400	Valve SI-876B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
342500	SIS-02-SI-2008-13 Valve SI-876B to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342600	SI-16 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
342700	SIS-02-SI-2008-14 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342800	SIS-02-SI-2008-15 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
342900	SIS-02-SI-2008-16 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
343000	SIS-02-SI-2008-17 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
343100	SIS-02-SI-2008-18 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
344200	SI-22 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Safety Injection Pump P-15A Test Line / Dwg. No. ISI-PRI-2256															
345000	SIS-02-SI-2007-01 Branch Connection to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345100	SIS-02-SI-2007-02 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345200	SIS-02-SI-2007-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345300	SIS-02-SI-2007-04 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345400	SIS-02-SI-2007-05 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345500	SI-34 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
345600	SIS-02-SI-2007-06 Pipe to Coupling	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345700	SIS-02-SI-2007-07 Coupling to Orifice	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
345800	SIS-02-SI-2007-08 Orifice to Coupling	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
345900	SIS-02-SI-2007-09 Coupling to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346000	SI-05 Rigid Support	F-A F1.20A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
346100	SIS-02-SI-2007-10 Pipe to Valve SI-891A	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346200	Valve SI-891A 2" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
346300	SIS-02-SI-2007-11 Valve SI-891A to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346400	SIS-02-SI-2007-12 Pipe to Valve SI-876A	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346500	Valve SI-876A 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
346600	SIS-02-SI-2007-13 Valve SI-876A to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346700	SIS-02-SI-2007-14 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
346800	SIS-02-SI-2007-15 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
346900	SIS-02-SI-2007-16 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
347000	SIS-02-SI-2007-17 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
347100	SI-10 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
347200	SI-14 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
347300	SIS-02-SI-2007-18 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Containment Spray Pumps P-14A and P-15A Test Line / Dwg. No. ISI-PRI-2257</u>															
348100	SIS-02-SI-2009-01 Valve SI-859B to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
348200	SIS-02-SI-2009-02 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
348300	SIS-02-SI-2009-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
348400	SI-33A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
348500	SIS-02-SI-2009-04 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
348600	SIS-02-SI-2009-05 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
348700	SIS-02-SI-2009-06 Pipe to Valve SI-873B	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
348900	SIS-02-SI-2009-07 Valve SI-873B to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
349000	SIS-02-SI-2009-08 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
349100	SIS-02-SI-2009-09 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
349200	SIS-02-SI-2009-10 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350100	SIS-02-SI-2009-11 Valve SI-859A to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350200	SIS-02-SI-2009-12 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350300	SIS-02-SI-2009-13 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350400	SIS-02-SI-2009-14 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
350500	SIS-02-SI-2009-15 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350600	SIS-02-SI-2009-16 Pipe to Valve SI-873A	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350800	SIS-02-SI-2009-17 Valve SI-873A to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
350900	SIS-02-SI-2009-18 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
351000	SIS-02-SI-2009-19 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
351200	SIS-02-SI-2009-20 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352000	SIS-02-SI-2010-01 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352100	SIS-02-SI-2010-02 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352200	SIS-02-SI-2010-03 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352300	SIS-02-SI-2010-04 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
352400	SIS-02-SI-2010-05 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352500	SIS-02-SI-2010-06 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352600	SIS-02-SI-2010-07 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
352700	SI-32 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
352800	SI-33 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
352900	SIS-02-SI-2010-08 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
353000	SIS-02-SI-2010-09 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
353100	SIS-02-SI-2010-10 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354000	SIS-02-SI-2011-02 Reducing Insert to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354100	SIS-02-SI-2011-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
354200	SIS-02-SI-2011-04 Pipe to Flange	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354500	SIS-02-SI-2011-05 Flange to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354600	SI-30 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
354700	SIS-02-SI-2011-06 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354800	SIS-02-SI-2011-07 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
354900	SI-31 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
355000	SIS-02-SI-2011-08 Pipe to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2258</u>															
356000	SIS-04-SI-2001-01 Reducer to Pipe Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
356100	2H-01D Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH 2H-01E (7/00)															
356300	SIS-04-SI-2001-02 Pipe to Elbow Cal Block: 27-PTB	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
356400	SIS-04-SI-2001-03 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
356500	SIS-04-SI-2001-04 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
356600	SIS-04-SI-2001-05 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
356700	SIS-04-SI-2001-06 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
356800	SIS-04-SI-2001-07 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
357000	SIS-04-SI-2002-01 Reducer to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
357100	2H-01E Spring Hanger GANGED WITH 2H-01D (7/00)	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
357300	SIS-04-SI-2002-02 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
357400	SIS-04-SI-2002-03 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
357500	SIS-04-SI-2002-04 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
357600	SIS-04-SI-2002-05 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
357700	2H-02C Rigid Support GANGED WITH 1-2H2	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
357800	SIS-04-SI-2002-06 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
357900	SIS-04-SI-2002-07 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2259</u>															
359000	SIS-04-SI-2001-08 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
359100	SIS-04-SI-2001-09 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
359200	H-202A Rigid Support GANGED WITH H-202B (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
359400	2H-03C Anchor GANGED WITH 2H-03D (7/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
359500	SIS-04-SI-2001-10 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
359600	SIS-04-SI-2001-11 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
359700	H-207A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-207B (7/00)															
359800	H-206A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-206B (7/00)															
359900	SIS-04-SI-2001-12 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
360000	H-205A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-205B (7/00)															
360100	H-204A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-204B (7/00)															
360200	SIS-04-SI-2001-13 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
360300	H-203A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-203B (7/00)															
360400	S-852A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH S-852B (7/00)															
360500	SIS-04-SI-2001-14 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
360600	SIS-04-SI-2001-15 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
360700	SIS-04-SI-2001-16 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
360800	SIS-04-SI-2001-17 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
361000	SIS-04-SI-2002-08 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
361100	SIS-04-SI-2002-09 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
361200	H-202B Rigid Support GANGED WITH H-202A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
361300	2H-03D Anchor GANGED WITH 2H-03C (7/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
361500	SIS-04-SI-2002-10 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
361600	SIS-04-SI-2002-11 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
361700	H-207B Rigid Support GANGED WITH H-207A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
361800	H-206B Rigid Support GANGED WITH H-206A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
361900	H-205B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-205A (7/00)															
362000	SIS-04-SI-2002-12 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
362100	H-204B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-204A (7/00)															
362200	SIS-04-SI-2002-13 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
362300	H-203B Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-203A (7/00)															
362400	S-852B Rigid Support	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH S-852A (7/00)															
362500	SIS-04-SI-2002-14 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
362600	SIS-04-SI-2002-15 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
362700	SIS-04-SI-2002-16 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
362800	SIS-04-SI-2002-17 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2260															
363000	SIS-04-SI-2001-18 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363100	SIS-04-SI-2001-19 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363200	SIS-04-SI-2001-20 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363300	SIS-04-SI-2001-21 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363400	S-853A Rigid Support GANGED WITH S-853B (7/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
363500	SIS-04-SI-2001-22 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363600	SIS-04-SI-2001-23 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
363700	SIS-04-SI-2001-24 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
363800	SIS-04-SI-2001-25 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
363900	SIS-04-SI-2001-26 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
364000	H-208A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-208B (7/00)															
364100	SIS-04-SI-2001-27 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
364200	S-854A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH S-854B (7/00)															
364300	SIS-04-SI-2001-28 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
364400	SIS-04-SI-2001-29 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
364500	SIS-04-SI-2001-30 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
364600	SIS-04-SI-2001-31 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
365000	SIS-04-SI-2002-18 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
365100	SIS-04-SI-2002-19 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
365200	SIS-04-SI-2002-20 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
365300	SIS-04-SI-2002-21 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
365400	S-853B Rigid Support GANGED WITH S-853A (7/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
365500	SIS-04-SI-2002-22 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
365600	SIS-04-SI-2002-23 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
365700	SIS-04-SI-2002-24 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	X	-	-	-
365800	H-208B Rigid Support GANGED WITH H-208A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
365900	SIS-04-SI-2002-25 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
366000	S-854B Rigid Support GANGED WITH S-854A (7/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
366100	SIS-04-SI-2002-26 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
366200	SIS-04-SI-2002-27 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
366300	SIS-04-SI-2002-28 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
366400	SIS-04-SI-2002-29 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2261</u>															
367000	H-209A Rigid Support GANGED WITH H-209B (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
367100	SIS-04-SI-2001-32 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
367200	S-855A Rigid Support SHOWN AS A RESTRAINT ON P-219 (8/00), GANGED WITH S-855B	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
367300	H-210A Rigid Support GANGED WITH H-210B AND TWO UNIDENTIFIED PIPES (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
367400	H-211A Rigid Support GANGED WITH H-211B AND TWO UNIDENTIFIED PIPES (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
367500	SIS-04-SI-2001-33 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
367600	SIS-04-SI-2001-34 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
367700	SIS-04-SI-2001-35 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
367800	SIS-04-SI-2001-36 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
367900	SIS-04-SI-2001-37 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
368000	SIS-04-SI-2001-38 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
368100	H-08A Rigid Support GANGED WITH H-08B (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
369000	H-209B Rigid Support GANGED WITH H-209A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
369100	SIS-04-SI-2002-30 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
369200	S-855B Rigid Support SHOWN AS A RESTRAINT ON P-220 (8/00), GANGED WITH S-855A	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
369300	H-210B Guide GANGED WITH H-210A AND TWO UNIDENTIFIED PIPES (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
369400	H-211B Rigid Support GANGED WITH H-211A AND TWO UNIDENTIFIED PIPES (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
369500	SIS-04-SI-2002-31 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
369600	SIS-04-SI-2002-32 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
369700	SIS-04-SI-2002-33 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
369800	SIS-04-SI-2002-34 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
369900	SIS-04-SI-2002-35 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
370000	SIS-04-SI-2002-36 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-
370100	H-08B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH H-08A (7/00)															
Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2262															
371000	H-09A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH H-09B (7/00)															
371100	SIS-04-SI-2001-39 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
371200	S-856A Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
GANGED WITH S-856B (7/00)															
371300	SIS-04-SI-2001-40 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
371400	SIS-04-SI-2001-41 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
371500	H-11 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
371600	H-11A Rigid Support ADDED PER MOD 96-026 (8/00)	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
371700	H-12 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
371800	SIS-04-SI-2001-42 Pipe to Flange Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
371900	SIS-04-SI-2001-43 Flange to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372000	SIS-04-SI-2001-44 Pipe to Valve SI-866A Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372100	Valve SI-866A 2" Valve No examination required			-	-	-	-	-	-	-	-	-	-	-	-
372200	SIS-04-SI-2001-45 Valve SI-866A to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372300	S-857A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
372400	SIS-04-SI-2001-46 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372500	SIS-04-SI-2001-47 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372600	SIS-04-SI-2001-48 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372700	SIS-04-SI-2001-49 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
372800	SIS-04-SI-2001-49A Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373000	H-09B Rigid Support GANGED WITH H-09A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
373100	SIS-04-SI-2002-37 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373200	SIS-04-SI-2002-38 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373300	SIS-04-SI-2002-39 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373400	SIS-04-SI-2002-40 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
373500	SIS-04-SI-2002-41 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373600	S-856B Rigid Support GANGED WITH S-856A (7/00)	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
373700	SIS-04-SI-2002-42 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373800	SIS-04-SI-2002-43 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
373900	H-21 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
374000	SIS-04-SI-2002-44 Pipe to Flange Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374100	SIS-04-SI-2002-45 Flange to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374200	H-22B Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
374300	SIS-04-SI-2002-46 Pipe to Valve SI-866B Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374400	Valve SI-866B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-

No examination required

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
374500	SIS-04-SI-2002-47 Valve SI-866B to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374600	SIS-04-SI-2002-48 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374700	S-857B Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
374800	SIS-04-SI-2002-49 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
374900	SIS-04-SI-2002-50 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
375000	H-23 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
375100	SIS-04-SI-2002-51 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
375200	SIS-04-SI-2002-52 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Core Deluge and Cold Leg Injection Header / Dwg. No. ISI-PRI-2263															
376000	M-82A Anchor	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 13 (7/00)															
376200	SIS-04-SI-2001-50 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
376300	SIS-04-SI-2001-51 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376400	SIS-04-SI-2001-52 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376500	SIS-04-SI-2001-53 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376600	SIS-04-SI-2001-54 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376700	SIS-04-SI-2001-55 Elbow to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376800	SIS-04-SI-2001-56 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
376900	SIS-04-SI-2001-57 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377000	SIS-04-SI-2001-58 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377100	SIS-04-SI-2001-59 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377200	SIS-04-SI-2001-60 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
377300	SIS-04-SI-2001-61 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377400	SIS-04-SI-2001-62 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377500	SIS-04-SI-2001-63 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377600	SIS-04-SI-2001-64 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
377800	H-200 SECTION C-C Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
FORMERLY H-200 (7/00), SHOWN AS A GANG HANGER ON P-419, IT IS TWO SEPARATE SUPPORTS															
<u>Core Deluge Header / Dwg. No. ISI-PRI-2264</u>															
379000	M-82B Anchor	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 27 (8/00)															
379200	SIS-04-SI-2002-53 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
379300	SIS-04-SI-2002-54 Pipe to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
379400	SIS-04-SI-2002-55 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
379500	SIS-04-SI-2002-56 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
379600	SIS-04-SI-2002-57 Pipe to Elbow Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
379700	SIS-04-SI-2002-58 Elbow to Pipe Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
380000	SIS-04-SI-2002-59 Pipe to Tee Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
380100	SIS-04-SI-2002-60 Tee to Conc Swage Reducer Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
380200	SIS-04-SI-2002-61 Tee to Conc Swage Reducer Cal Block: 27-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.21	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Core Deluge Header / Dwg. No. ISI-PRI-2265															
381000	SIS-02-SI-2012-01 Conc Swage Reducer to Tee Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381100	SIS-02-SI-2012-02 Tee to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381200	SIS-02-SI-2012-03 Pipe to Elbow Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381300	SIS-02-SI-2012-04 Elbow to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
381400	SIS-02-SI-2012-05 Pipe to Valve SI-878A Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
381600	SI-878-A1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
381650	SI-878-A2 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
A GANG HANGER WITH SI-878C-2?															
381700	SIS-02-SI-2012-06 Valve SI-878A to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
381800	SIS-02-SI-2012-07 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
381900	SIS-02-SI-2012-08 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382000	SIS-02-SI-2012-09 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382100	SIS-02-SI-2012-10 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382200	SIS-02-SI-2012-11 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382300	SIS-02-SI-2012-12 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382400	SIS-02-SI-2012-13 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
382500	SIS-02-SI-2012-14 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
382600	SIS-02-SI-2012-15 Pipe to Valve SI-845D	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
383000	SIS-02-SI-2013-01 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
383100	SIS-02-SI-2013-02 Pipe to Valve SI-878E	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
383200	Valve SI-878E 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
383300	SIS-02-SI-2013-03 Valve SI-878E to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
383400	SIS-02-SI-2013-04 Pipe to Valve SI-845E	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
383500	Valve SI-878A 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
Core Deluge Header / Dwg. No. ISI-PRI-2266															
384000	SIS-02-SI-2014-01 Conc Swage Reducer to Tee	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
384100	SIS-02-SI-2014-02 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
384200	SIS-02-SI-2014-03 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
384300	SIS-02-SI-2014-04 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
384400	SIS-02-SI-2014-05 Pipe to Valve SI-878C	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
384500	Valve SI-878C 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
384600	SI-878-C1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
384700	SI-878-C2 Rigid Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
A GANG HANGER WITH SI-878A-2?															
384800	SIS-02-SI-2014-06 Valve SI-878C to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
384900	SIS-02-SI-2014-07 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
385000	SIS-02-SI-2014-08 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
385100	SIS-02-SI-2014-09 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
385200	SIS-02-SI-2014-10 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
385300	SIS-02-SI-2014-11 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
385400	SIS-02-SI-2014-12 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
385500	SIS-02-SI-2014-13 Pipe to Valve SI-845C	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386000	SIS-02-SI-2015-01 Tee to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386100	SIS-02-SI-2015-02 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386200	SIS-02-SI-2015-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386300	SIS-02-SI-2015-04 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386400	SIS-02-SI-2015-05 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386500	SIS-02-SI-2015-06 Pipe to ValveE SI-878F	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
386600	Valve SI-878F 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
386700	SIS-02-SI-2015-07 Valve SI-878F to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
386800	SIS-02-SI-2015-08 Pipe to Valve SI-845F	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Containment Spray Pump P-14A and P-14B Discharge / Dwg. No. ISI-PRI-2267</u>															
387000	SIS-06-SI-2003-01 Reducer to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
387100	SIS-06-SI-2003-02 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
387200	SIS-06-SI-2003-03 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
387300	SIS-06-SI-2003-04 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
387400	S-870 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
387500	SIS-06-SI-2003-05 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
387600	SIS-06-SI-2003-06 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
387700	H-01 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
387900	SIS-06-SI-2003-07 Pipe to Valve SI-860A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388000	Valve SI-860A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
388100	SIS-06-SI-2003-08 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388200	SIS-06-SI-2003-09 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388300	SIS-06-SI-2003-10 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388400	SIS-06-SI-2003-11 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388500	SIS-06-SI-2003-12 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
388600	H-02 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
388800	SIS-06-SI-2003-13 Pipe to Valve SI-860B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
388900	Valve SI-860B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
389000	SIS-06-SI-2004-01 Reducer to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389100	SIS-06-SI-2004-02 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389200	SIS-06-SI-2004-03 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389300	SIS-06-SI-2004-04 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389400	S-873 Rigid Support	F-A F1.20B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS DUAL RESTRAINT															
389500	SIS-06-SI-2004-05 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389600	SIS-06-SI-2004-06 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
389700	H-08 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
389900	SIS-06-SI-2004-07 Pipe to Valve SI-860C	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
390000	Valve SI-860C 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
390100	SIS-06-SI-2004-08 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390200	SIS-06-SI-2004-09 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390300	SIS-06-SI-2004-10 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390400	SIS-06-SI-2004-11 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390500	SIS-06-SI-2004-12 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390600	H-09 Spring Hanger	F-A F1.20C	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
390800	SIS-06-SI-2004-13 Pipe to Valve SI-860D	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
390900	Valve SI-860D 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
393500	Valve SI-878B 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
393600	SI-878-B1 Rigid Support	F-A Fl.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
393700	SIS-02-SI-2016-07 Valve SI-878B to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
393800	SIS-02-SI-2016-08 Pipe to Valve SI-845B	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394000	SIS-02-SI-2017-01 Conc Swage Reducer to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394100	SIS-02-SI-2017-03 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394200	SIS-02-SI-2017-04 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394300	SIS-02-SI-2017-05 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394400	SIS-02-SI-2017-06 Pipe to Valve SI-878D	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
394500	Valve SI-878D 2" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS															
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
394600	SI-878-D1 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-

394700	SIS-02-SI-2017-07 Valve SI-878D to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

394800	SIS-02-SI-2017-08 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

394900	SIS-02-SI-2017-09 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

395000	SIS-02-SI-2017-10 Pipe to Elbow	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

395100	SIS-02-SI-2017-11 Elbow to Pipe	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

395200	SIS-02-SI-2017-12 Pipe to Valve SI-845A	C-F-1 C5.30	SUR	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

<u>RHR to Safety Injection Pump Suction / Dwg. No. ISI-PRI-2269</u>																	
396000	AC-06-SI-2002-11A Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

396100	AC-06-SI-2002-11B Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

396200	AC-06-SI-2002-11C Pipe to Valve 2RH-706A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																	

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
396300	Valve 2RH-706A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
	No examination required														
396400	AC-06-SI-2002-11D Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
396500	AC-06-SI-2002-12 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
396600	AC-06-SI-2002-13 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
396800	AC-06-SI-2002-14 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
396900	AC-06-SI-2002-15 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
397000	2H-24 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
397300	2H-24A Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
397500	AC-06-SI-2002-16 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
	Category and item number will be R-A and R1.20 for the 4th interval.														
397600	2H-23 Spring Hanger	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
397800	AC-06-SI-2002-17 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
397900	AC-06-SI-2002-18 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398000	AC-06-SI-2002-19 Elbow to Pipe	C-F-1 C5.11A		X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398100	AC-06-SI-2002-20 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398200	AC-06-SI-2002-21 Elbow to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398300	AC-06-SI-2002-22 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398400	AC-06-SI-2002-23 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398500	AC-06-SI-2002-24 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
398600	R-2376 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
398700	R-2375 Rigid Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
398800	R-2315 Rigid Support	F-A F1.20C	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH SI-301R-1-R2315 AND R-2315A (7/00)															
398900	AC-06-SI-2002-25 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Containment Spray Pumps P-14A and P-14B Suction / Dwg. No. ISI-PRI-2270</u>															
400100	SIS-06-CS-2001-01 Valve SI-870A to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
400200	SIS-06-CS-2001-02 Pipe to Valve SI-858A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
400300	Valve SI-858A 6" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
400400	SIS-06-CS-2001-03 Valve SI-858A to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
400500	3H-01A Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
400700	SIS-06-CS-2001-04 Tee to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
400800	SIS-08-CS-2001-01 Reducer to Flange	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
400900	Containment Spray Pump P-14A Pump			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
402100	SIS-06-CS-2002-01 Valve SI-870B to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
402200	SIS-06-CS-2002-02 Pipe to Valve SI-858B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
402300	Valve SI-858B 6" Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
402400	SIS-06-CS-2002-03 Valve SI-858B to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
402500	3H-01B Spring Support	F-A F1.20C	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
402700	SIS-06-CS-2002-04 Tee to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
402800	SIS-08-CS-2002-01 Reducer to Flange	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
402900	Containment Spray Pump P-14B Pump			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
<u>Loop A Main Steam Inside Containment / Dwg. No. ISI-PRI-2271</u>															
402990	MS-30-MS-2001-12LU Upstream Long Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
403000	MS-30-MS-2001-12 Pipe to Elbow Cal Block: 45-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
403010	MS-30-MS-2001-12LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403080	MS-30-MS-2001-13LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403090	MS-30-MS-2001-13LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403100	MS-30-MS-2001-13 Elbow to Pipe Cal Block: 45-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403110	MS-30-MS-2001-13LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403290	MS-30-MS-2001-14LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403300	MS-30-MS-2001-14 Pipe to Elbow Cal Block: 45-PTB, 46-PTB Category and item number will be R-A and R1.20 for the 4th interval. Thickness change at this weld. Upstream uses block 45-PTB and downstream uses 46-PTB.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403310	MS-30-MS-2001-14LDI Inside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403320	MS-30-MS-2001-14LDO Outside Downstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
403380	MS-30-MS-2001-15LUI Inside Upstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

				PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD					
				1	2	3	4	1	2	3	4	1	2	3	4		
403390	MS-30-MS-2001-15LUO Outside Upstream Longitudinal Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403400	MS-30-MS-2001-15 Elbow to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403410	MS-30-MS-2001-15LD Downstream Longitudinal Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403490	MS-30-MS-2001-16LU Upstream Long Weld Cal Block: 46-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403500	MS-30-MS-2001-16 Pipe to Penetration Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403510	MS-69/A-2 Anchor PENETRATION 1	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403520	MS-30-MS-2001-16LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403590	MS-30-MS-2001-17LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403600	MS-30-MS-2001-17 Penetration to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-
403610	MS-30-MS-2001-17LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Loop B Main Steam Inside Containment / Dwg. No. ISI-PRI-2272															
405000	MS-06-MS-2002-01 Branch Connection to Pipe	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
405100	MS-06-MS-2002-02 Pipe to Cap	C-F-2 C5.51A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
406100	MS-30-MS-2002-09-BC 6" Branch Connection	C-F-2 C5.81	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
406190	MS-30-MS-2002-10LU Upstream Long Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
406200	MS-30-MS-2002-10 Pipe to Elbow Cal Block: 46-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
406210	MS-30-MS-2002-10LDI Inside Downstream Long Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
406220	MS-30-MS-2002-10LDO Outside Downstream Long Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
406280	MS-30-MS-2002-11LUI Inside Upstream Long Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
406290	MS-30-MS-2002-11LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Component will be deleted from the fourth interval ISI Program.															
406300	MS-30-MS-2002-11 Elbow to Pipe Cal Block: 46-PTB	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
406310	MS-30-MS-2002-11LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406490	MS-30-MS-2002-12LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406500	MS-30-MS-2002-12 Pipe to Elbow Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406510	MS-30-MS-2002-12LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406520	MS-30-MS-2002-12LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406680	MS-30-MS-2002-13LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406690	MS-30-MS-2002-13LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406700	MS-30-MS-2002-13 Elbow to Elbow Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406710	MS-30-MS-2002-13LDI Inside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406720	MS-30-MS-2002-13LDO Outside Downstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
406780	MS-30-MS-2002-14LUI Inside Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406790	MS-30-MS-2002-14LUO Outside Upstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406800	MS-30-MS-2002-14 Elbow to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406810	MS-30-MS-2002-14LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406890	MS-30-MS-2002-15LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406900	MS-30-MS-2002-15 Pipe to Penetration Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406910	MS-65/A-1 Anchor PENETRATION 2	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
406920	MS-30-MS-2002-15LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
406990	MS-30-MS-2002-16LU Upstream Long Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
407000	MS-30-MS-2002-16 Penetration to Pipe Cal Block: 46-PTB Category and item number will be R-A and R1.20 for the 4th interval.	C-F-2 C5.51	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
407010	MS-30-MS-2002-16LD Downstream Longitudinal Weld Cal Block: 45-PTB Component will be deleted from the fourth interval ISI Program.	C-F-2 C5.52	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
RWST to RHR, SI, and Containment Spray Pumps / Dwg. No. ISI-PRI-2273															
408000	AC-16-SI-2001-FB Flange Bolting No examination required due to bolting is 2" or less in diameter.			-	-	-	-	-	-	-	-	-	-	-	-
408100	AC-16-SI-2001-01 Flange to Elbow Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
408200	AC-16-SI-2001-02 Elbow to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
408300	AC-16-SI-2001-03 Pipe to Elbow Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
408400	AC-16-SI-2001-04 Elbow to Pipe Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
408500	S-734 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
408600	SI-151R-2H10 Component Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
408700	AC-16-SI-2001-05 Pipe to Tee Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
408800	AC-16-SI-2001-06 Tee to Reducer Category and item number will be R-A and R1.20 for the 4th interval.	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

[illegible]

Category and item number will be R-A and R1.20 for the 4th interval.

RWST to RHR Pumps / Dwg. No. ISI-PRI-2274

410000	AC-10-RHR-2007-01	C-F-1	- - - - -
	Reducer to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

410100	AC-10-RHR-2007-02	C-F-1	- - - - -
	Pipe to Tee	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

[illegible]

Category and item number will be R-A and R1.20 for the 4th interval.

410300	AC-10-RHR-2007-04	C-F-1	- - - - -
	Pipe to Tee	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

410400	AC-10-RHR-2007-05	C-F-1	- - - - -
	Tee to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

[illegible]

410600	AC-10-RHR-2007-06	C-F-1	- - - - -
	Pipe to Valve 2SI-856A	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

410700	Valve 2SI-856A	- - - - -
	8" Motor Operated Valve	-

No examination required

410800	AC-10-RHR-2007-07	C-F-1	- - - - -
	Tee to Pipe	C5.11A	

Category and item number will be R-A and R1.20 for the 4th interval.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
410900	AC-10-RHR-2007-08 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
411000	AC-10-RHR-2007-09 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
411100	AC-10-RHR-2007-10 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
411200	AC-10-RHR-2007-11 Pipe to Valve 2SI-856B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
411300	Valve 2SI-856B 8" Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
412000	AC-08-RHR-2007-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
412100	AC-08-RHR-2007-02 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
412200	AC-08-RHR-2007-03 Pipe to Valve 2SI-742	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>RWST to Safety Injection & Containment Spray Pumps / Dwg. No. ISI-PRI-2275</u>															
413000	AC-12-SI-2001-01 Reducer to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
413100	AC-12-SI-2001-02 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
413200	SI-151R-2H9 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
413300	AC-12-SI-2001-03 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
413400	SI-151R-2H8 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
413500	AC-12-SI-2001-04 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
413600	S-733 Pipe Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
413700	AC-12-SI-2001-05 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
413800	AC-12-SI-2001-06 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
413900	0101 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
414000	S-739 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
414100	AC-12-SI-2001-07 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
414200	AC-12-SI-2001-08 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
414300	SI-151R-2H7 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates outside safety injection pump room.															
414400	SI-151R-2H6A Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
414500	S-738 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
414600	AC-12-SI-2001-09 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
414700	AC-12-SI-2001-10 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
414800	S-737 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
414900	SI-151R-2H6 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
415000	AC-12-SI-2001-11 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RWST to Safety Injection & Containment Spray Pumps / Dwg. No. ISI-PRI-2276															
415100	AC-12-SI-2001-12 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415200	SI-151R-2H5 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
415300	AC-12-SI-2001-13 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415400	AC-12-SI-2001-14 Tee to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415500	AC-12-SI-2001-15 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415600	AC-12-SI-2001-16 Pipe to Valve 2SI-825A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415700	Valve 2SI-825A 12" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
415800	AC-12-SI-2001-17 Valve 2SI-825A to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
415900	AC-12-SI-2001-18 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416000	AC-12-SI-2001-19 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
416100	AC-12-SI-2001-20 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416200	AC-12-SI-2001-21 Pipe to Valve 2SI-825B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416300	Valve 2SI-825B 12" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
416400	AC-12-SI-2001-22 Valve 2SI-825B to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416500	2H1A Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
416600	AC-12-SI-2001-23 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416700	AC-12-SI-2001-24 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416800	AC-12-SI-2001-25 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
416900	AC-12-SI-2001-26 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
417000	AC-12-SI-2001-27 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
417100	AC-12-SI-2001-28 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
417200	AC-12-SI-2001-29 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
417300	AC-12-SI-2001-30 Pipe to Tee	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
417400	AC-12-SI-2001-31 Tee to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
417500	AC-12-SI-2001-32 Tee to Reducer	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
418000	AC-08-SI-2003-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
418100	AC-08-SI-2003-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
418200	AC-08-SI-2003-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
418300	AC-08-SI-2003-04 Pipe to Valve 2SI-826A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
418400	Valve 2SI-826A 8" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
RWST to Safety Injection Pumps / Dwg. No. ISI-PRI-2277															
419000	AC-06-SI-2004-01 Reducer to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
419100	S-743 Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room.															
419200	AC-06-SI-2004-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
419300	AC-06-SI-2004-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
419400	AC-06-SI-2004-04 Pipe to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
419500	AC-06-SI-2004-05 Pipe to Valve 2SI-896A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
419600	Valve 2SI-896A 6" Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
420000	AC-06-SI-2005-01 Reducer to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
420100	AC-06-SI-2005-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
420200	AC-06-SI-2005-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
420300	S-743 part B Pipe Support	F-A F1.20B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Located under floor plates inside safety injection pump room. Will be examined as part of S-74 on line AC-06-SI-2004.															
420400	AC-06-SI-2005-04 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
420500	AC-06-SI-2005-05 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
420600	AC-06-SI-2005-06 Pipe to Valve 2SI-896B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
420700	Valve 2SI-896B 6" Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
<u>RWST to Containment Spray Pumps / Dwg. No. ISI-PRI-2278</u>															
421000	AC-06-CS-2001-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
421100	AC-06-CS-2001-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
421200	SI-151R-3-2H1A Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
421300	SI-151R-3-2H1A-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS													
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
421400	AC-06-CS-2001-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
421500	AC-06-CS-2001-04 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
421600	AC-06-CS-2001-05 Elbow to Valve 2SI-870A	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
421700	Valve SI-870A 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
422000	AC-06-CS-2002-01 Tee to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
422100	AC-06-CS-2002-02 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
422200	SI-151R-3-2H2A Support	F-A F1.20A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
422300	SI-151R-3-2H2A-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
422400	AC-06-CS-2002-03 Elbow to Pipe	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
422500	AC-06-CS-2002-04 Pipe to Elbow	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
422600	AC-06-CS-2002-05 Elbow to Valve 2SI-870B	C-F-1 C5.11A		-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
422700	Valve SI-870B 6" Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required															
<u>Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-2279</u>															
425000	Valve 2AF-103 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
425100	AF-03-AFW-2001-1 Valve 2AF-103 to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
425200	AF-03-AFW-2001-2 Pipe to Valve 2AF-32		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
425300	Valve 2AF-32 Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
425400	AF-03-AFW-2001-3 Valve 2AF-32 to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
425500	AF-03-AFW-2001-4 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
425600	AF-03-AFW-2001-5 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
425700	EB-10-H201 Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
425800	EB-10-2H3 Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
425900	AF-03-AFW-2001-6 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426000	AF-03-AFW-2001-7 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426100	AF-03-AFW-2001-8 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426200	AF-03-AFW-2001-9 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426250	EB-10-H203 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
426300	EB-10-S893 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
426400	EB-10-S893-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
426500	AF-03-AFW-2001-10 Pipe to Tee		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426600	Valve 2AF-106 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
426700	AF-03-AFW-2001-11 Valve 2AF-106 to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
426800	DB-3-2H2 Component Support		VT-3	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
426900	DB-3-2H2-IWA Welded Attachment		VT-1	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
427000	AF-03-AFW-2001-12 Pipe to Valve 2AF-56		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
427100	Valve 2AF-56 Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
427200	AF-03-AFW-2001-13 Valve 2AF-56 to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
427300	AF-03-AFW-2001-14 Pipe to Elbow		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
427400	EB-10-HYY Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
427500	EB-10-HYY-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
427600	AF-03-AFW-2001-15 Elbow to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
427700	EB-10-S892 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and Fl.20A for the 4th interval.															
427800	AF-03-AFW-2001-16 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
427900	AF-03-AFW-2001-17 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
428000	AF-03-AFW-2001-18 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
428100	AF-03-AFW-2001-19 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
428200	AF-03-AFW-2001-20 Pipe to Tee		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
428300	AF-03-AFW-2001-21 Tee to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and Rl.20 for the 4th interval.															
428400	EB-10-S894 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and Fl.20A for the 4th interval.															
428500	EB-10-S894-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-2280															
428600	AF-03-AFW-2001-22 Pipe to Elbow		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
428700	AF-03-AFW-2001-23 Elbow to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
428800	AF-03-AFW-2001-24 Pipe to Flange		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
428900	AF-03-AFW-2001-25 Flange to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
429000	EB-10-H27 Spring Support		VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
429100	EB-10-H27-IWA Welded Attachment		VT-1	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
429200	AF-03-AFW-2001-26 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
429300	AF-03-AFW-2001-27 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
429400	EB-10-WEPCO-399 Spring Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
429500	EB-10-WEPCO-399-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
429600	EB-10-S903 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
429700	EB-10-S903-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
429800	AF-03-AFW-2001-28 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
429900	AF-03-AFW-2001-29 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
430000	EB-10-H15 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
430100	EB-10-H15-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
430200	AF-03-AFW-2001-30 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
430300	EB-10-H202 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
430400	EB-10-H16 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
430500	EB-10-H17 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
430600	EB-10-S904 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
430700	EB-10-S904-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
430800	AF-03-AFW-2001-31 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
430900	EB-10-H18 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
431000	EB-10-H19 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
431100	EB-10-S776 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
431200	EB-10-S776-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
431300	AF-03-AFW-2001-32 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
431400	AF-03-AFW-2001-33 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
431500	EB-10-S905 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
431600	EB-10-H20 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
431700	EB-10-H20-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
431800	AF-03-AFW-2001-34 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
431900	AF-03-AFW-2001-35 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
432000	EB-10-H21 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
432100	EB-10-H22 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
432200	EB-10-S906 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
432300	EB-10-S906-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
432400	AF-03-AFW-2001-36 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
432500	AF-03-AFW-2001-37 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
432600	EB-10-S777 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
432700	EB-10-S777-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
432800	EB-10-H23 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
433000	AF-03-AFW-2001-38 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433100	AF-03-AFW-2001-39 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433200	AF-03-AFW-2001-40 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433300	AF-03-AFW-2001-41 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433400	AF-03-AFW-2001-42 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433500	AF-03-AFW-2001-43 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433600	EB-10-H24 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
433700	AF-03-AFW-2001-44 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
433800	EB-10-H25 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
433900	EB-10-H26 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
434000	EB-10-S907 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
434100	EB-10-S907-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
434200	AF-03-AFW-2001-45 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
434300	AF-03-AFW-2001-46 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
434400	AF-03-AFW-2001-47 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
434500	AF-03-AFW-2001-48 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
434600	EB-10-H32 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
434700	EB-10-2H31 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
434800	AF-03-AFW-2001-49 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
434900	AF-03-AFW-2001-50 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435000	EB-10-S908 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
435100	EB-10-S908-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
435200	AF-03-AFW-2001-51 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435300	AF-03-AFW-2001-52 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435400	EB-10-H30 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
435500	AF-03-AFW-2001-53 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435600	AF-03-AFW-2001-54 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
435700	AF-03-AFW-2001-55 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435800	AF-03-AFW-2001-56 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
435900	AF-03-AFW-2001-57 Pipe to Elbow		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
436000	AF-03-AFW-2001-58 Elbow to Pipe		VOL	X	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
436100	EB-10-2H29 Component Support		VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
436200	AF-03-AFW-2001-59 Pipe to Flued Head		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
<u>Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-2281 sh. 1</u>															
436900	EB-10-A12 Anchor		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
<u>Auxiliary Feedwater to Steam Generator A / Dwg. No. ISI-PRI-2281</u>															
437000	AF-03-AFW-2001-60 Flued Head to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
437100	AF-03-AFW-2001-61 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
438600	AF-03-AFW-2001-68 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
438700	EB-10-2R129-S39 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
438900	AF-03-AFW-2001-69 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
439000	AF-03-AFW-2001-70 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
439100	EB-10-H203 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
439300	EB-10-2R120-S39 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
439500	AF-03-AFW-2001-71 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
439600	AF-03-AFW-2001-72 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
439700	EB-10-H202 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
439900	AF-03-AFW-2001-73 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
440000	EB-10-2R118-S39 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
440200	EB-10-2R117-S39 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
440400	AF-03-AFW-2001-74 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
440500	AF-03-AFW-2001-75 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
440600	AF-03-AFW-2001-76 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
440700	AF-03-AFW-2001-77 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
440800	EB-10-H201 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
441000	AF-03-AFW-2001-78 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
441100	AF-03-AFW-2001-79 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
441200	AF-03-AFW-2001-80 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
441300	AF-03-AFW-2001-81 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
441400	EB-10-H200 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
441600	AF-03-AFW-2001-82 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
441700	AF-03-AFW-2001-83 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
441800	EB-10-2R113-16 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
442000	AF-03-AFW-2001-84 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
442100	EB-10-2R110-16 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
442300	2-EB-2-7045 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
442500	AF-03-AFW-2001-85 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
442600	EB-10-2R107-16 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
442800	AF-03-AFW-2001-86 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
442900	AF-03-AFW-2001-87 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443000	AF-03-AFW-2001-88 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443100	AF-03-AFW-2001-89 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443200	EB-10-2R104-S38 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
443400	AF-03-AFW-2001-90 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443500	AF-03-AFW-2001-91 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443600	AF-03-AFW-2001-92 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443700	AF-03-AFW-2001-93 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
443800	AF-03-AFW-2001-94 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
443900	AF-03-AFW-2001-95 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
444000	2-EB-1-7044 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
444100	EB-10-2R99-S38 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
444300	AF-03-AFW-2001-96 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
444400	AF-03-AFW-2001-97 Pipe to Valve 2AF-218		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
444500	Valve 2AF-218 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
444600	AF-03-AFW-2001-98 Valve 2AF-218 to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															
444700	AF-03-AFW-2001-99 Pipe to Branch Connection		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															
<u>Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-2282</u>															
447000	Valve 2AF-105 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
447100	AF-03-AFW-2002-1 Valve 2AF-105 to Pipe		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
447200	AF-03-AFW-2002-2 Pipe to Valve 2AF-45		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447300	Valve 2AF-45 Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
447400	AF-03-AFW-2002-3 Valve 2AF-45 to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447500	AF-03-AFW-2002-4 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447600	AF-03-AFW-2002-5 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447700	AF-03-AFW-2002-6 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447800	AF-03-AFW-2002-7 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
447900	AF-03-AFW-2002-8 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448000	EB-10-H200 Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
448100	EB-10-H200-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															

DATE: 03/11/02

PAGE: 279

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
448150	EB-10-S893 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
448170	EB-10-S893-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
448200	AF-03-AFW-2002-9 Pipe to Tee		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448300	Valve 2AF-107 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
448400	AF-03-AFW-2002-10 Valve 2AF-107 to Pipe		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448500	AF-03-AFW-2002-11 Pipe to Valve 2AF-57		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448600	Valve 2AF-57 Motor Operated Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examination required.															
448700	AF-03-AFW-2002-12 Valve 2AF-57 to Pipe		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448800	AF-03-AFW-2002-13 Pipe to Elbow		VOL	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
448900	EB-10-HAA Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

		PLAN STATUS														
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O	U	T	A	G	E	1	2	3
450000	AF-03-AFW-2002-22 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
450100	AF-03-AFW-2002-23 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
450200	EB-10-S894 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.																
450300	EB-10-S894-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.																
<u>Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-2283</u>																
451000	AF-03-AFW-2002-24 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
451100	AF-03-AFW-2002-25 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
451200	AF-03-AFW-2002-26 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
451300	AF-03-AFW-2002-27 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
451400	AF-03-AFW-2002-28 Pipe to Flange		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																
451500	AF-03-AFW-2002-29 Flange to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
451600	EB-10-H14 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
451700	AF-03-AFW-2002-30 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
451800	AF-03-AFW-2002-31 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
451900	AF-03-AFW-2002-32 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
452000	AF-03-AFW-2002-33 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
452100	EB-10-WEPCO-399 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
452200	EB-10-WEPCO-399-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
452300	EB-10-S903 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
452400	EB-10-S903-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
452500	AF-03-AFW-2002-34 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
452600	AF-03-AFW-2002-35 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
452700	EB-10-H16 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
452800	EB-10-H16-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
452900	EB-10-S904 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
453000	EB-10-S904-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
453100	AF-03-AFW-2002-36 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
453200	EB-10-H18 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
453300	EB-10-H19 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
453400	EB-10-H19-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
453500	AF-03-AFW-2002-37 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
453600	EB-10-S776 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
453700	EB-10-S776-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
453800	AF-03-AFW-2002-38 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
453900	AF-03-AFW-2002-39 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
454000	EB-10-S905 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
454100	EB-10-S905-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
454200	EB-10-H20 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
454300	AF-03-AFW-2002-40 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
454400	AF-03-AFW-2002-41 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
454500	EB-10-H21 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
454600	EB-10-H21-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
454700	EB-10-H22 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
454800	EB-10-H22-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
454900	EB-10-S906 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
455000	EB-10-S906-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
455100	AF-03-AFW-2002-42 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
455200	AF-03-AFW-2002-43 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
455300	EB-10-S777 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
455400	EB-10-S777-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
455500	EB-10-H23 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
455600	EB-10-H23-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
455700	AF-03-AFW-2002-44 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
455800	AF-03-AFW-2002-45 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
455900	AF-03-AFW-2002-46 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
456000	AF-03-AFW-2002-47 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
456100	AF-03-AFW-2002-48 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
456200	AF-03-AFW-2002-49 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
456300	EB-10-H24 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
456400	EB-10-H24-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
456500	AF-03-AFW-2002-50 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
456600	EB-10-H25 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
456700	EB-10-H25-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
456800	EB-10-H26 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
456900	EB-10-H26-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
457000	EB-10-S907 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
457100	EB-10-S907-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
457200	AF-03-AFW-2002-51 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
457300	AF-03-AFW-2002-52 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
457400	AF-03-AFW-2002-53 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
457500	AF-03-AFW-2002-54 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
457600	AF-03-AFW-2002-55 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
457700	AF-03-AFW-2002-56 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
457800	EB-10-2H32 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
457900	EB-10-2H31 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
458000	AF-03-AFW-2002-57 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
458100	AF-03-AFW-2002-58 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
458200	EB-10-S908 Component Support		VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
458300	EB-10-S908-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.															
458400	AF-03-AFW-2002-59 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
458500	AF-03-AFW-2002-60 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS														
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD						
				1	2	3	4	O U T A G E				1	2	3	4	1	2	3
458600	EB-10-2H30 Component Support		VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.																		
458700	AF-03-AFW-2002-61 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
458800	AF-03-AFW-2002-62 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
458900	AF-03-AFW-2002-63 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
459000	AF-03-AFW-2002-64 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
459100	AF-03-AFW-2002-65 Pipe to Elbow		VOL	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
459200	AF-03-AFW-2002-66 Elbow to Pipe		VOL	-	-	-	-	X	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
459300	AF-03-AFW-2002-67 Pipe to Flued Head		VOL	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.																		
460000	EB-10-A13 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.																		
460100	EB-10-A13-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be C-C and C3.20 for the 4th interval.																		

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Auxiliary Feedwater to Steam Generator B / Dwg. No. ISI-PRI-2284															
460200	AF-03-AFW-2002-68 Flued Head to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
460300	AF-03-AFW-2002-69 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
460400	AF-03-AFW-2002-70 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
460500	EB-10-2R140 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
460700	AF-03-AFW-2002-71 Pipe to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
460800	EB-10-2EB-5 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
461000	EB-10-2R137 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
461200	AF-03-AFW-2002-72 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
461300	AF-03-AFW-2002-73 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
461400	AF-03-AFW-2002-74 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
461500	AF-03-AFW-2002-75 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
461600	AF-03-AFW-2002-76 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
461700	AF-03-AFW-2002-77 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
461800	EB-10-2EB-4 Component Support		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
462000	AF-03-AFW-2002-78 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
462100	AF-03-AFW-2002-79 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
462200	EB-10-2EB-3 Component Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be F-A and F1.20A for the 4th interval.															
462400	AF-03-AFW-2002-80 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
462500	AF-03-AFW-2002-81 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															
462600	AF-03-AFW-2002-82 Pipe to Valve 2AF-218		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.20 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
462700	Valve 2AF-218 Check Valve			-	-	-	-	-	-	-	-	-	-	-	-
No examinations required.															
462800	AF-03-AFW-2002-83 Valve 2AF-218 to Pipe		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															
462900	AF-03-AFW-2002-84 Pipe to Elbow		VOL	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															
463000	AF-03-AFW-2002-85 Elbow to Pipe		VOL	-	-	-	-	-	-	-	-	X	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															
463100	AF-03-AFW-2002-86 Pipe to Branch Connection		VOL	-	-	-	-	-	-	-	-	-	-	-	-
Category and item number will be R-A and R1.11 for the 4th interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
<u>Service Water Supply to Aux FW Pump P-29 / Dwg. No. ISI-PRI-2325</u>															
500000	HB-19-H43 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
500100	HB-19-H200 Component Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
500200	HB-19-H44 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
500300	HB-19-S600 Component Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
500400	JG-4-H37 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
500500	JG-4-H37-IWA Welded Attachment		VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Examination category and item number will become D-A and D1.20 during fourth interval.															
500600	JG-4-S520 Component Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<u>Service Water Supply to HX-15D / Dwg. No. ISI-PRI-2329</u>															
501000	H-118 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A RESTRAINT ON P-215 SH1 (8/00)															
501200	H-117 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
501300	A-25 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 40															
501400	A-25-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 40. Examination category and item number will become D-A and D1.20 during fourth interval.															
501600	HB-19 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with H200, ISI drawing # should be changed (8/00)															
501700	R-219 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R219															
501800	R-218 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R218															
501900	R-217 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R217															
<u>Service Water Supply to HX-15D / Dwg. No. ISI-PRI-2330</u>															
502000	R-216 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R216															
502200	R-214 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R214 IN A WALL															
502300	R-213 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R213 IN A WALL															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS												
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	1	2	3	4	1	2	3	4	
502400	A-01D Anchor	F-A F1.30B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A-04																
502500	A-01D-IWA Welded Attachment			X	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A-04. Examination category and item number will become D-A and D1.20 during fourth interval.																
502600	HB-21 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
Service Water Supply to HX-15A / Dwg. No. ISI-PRI-2331																
503000	2H-122 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A GUIDE ON P-216 SH2, BASED ON P-314 SH12 IT IS A SUPPORT (8/00)																
503100	2H-92 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
503200	A-19/M82 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	X	-	-	-
PENETRATION 35																
503300	A-19/M82-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 35. Examination category and item number will become D-A and D1.20 during fourth interval.																
503400	R-192 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R192																

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Service Water Supply to HX-15A / Dwg. No. ISI-PRI-2332</u>															
503500	HB-19-R191 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R191															
503700	HB-19-R188 Restraint	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R188 IN A FLOOR															
503800	HB-19-R187 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R187															
503900	HB-19-R186 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R186, BEST SUPPORT DRAWING IN WALKDOWN WE-200089															
504000	HB-19-R185 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R185															
504200	HB-19-R181 Restraint	F-A F1.30B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R181 IN A FLOOR															
504400	HB-19-A2 Anchor	F-A F1.30B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
This anchor is listed as HB-19-A2 on plant controlled drawings, gang hanger with A2															
504500	HB-19-A2-IWA Welded Attachment			-	-	-	-	X	-	-	-	-	-	-	-
This anchor is listed as HB-19-A2 on plant controlled drawings, gang hanger with A2. Examination category and item number will become D-A and D1.20 during fourth interval.															
504700	HB-19-SA-1 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Service Water Supply to HX-15A / Dwg. No. ISI-PRI-2332</u>															
504800	HB-19-SA-2 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<u>Service Water Supply to HX-15C / Dwg. No. ISI-PRI-2333</u>															
506000	2H-116 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
506300	2H-115 Rigid Support	F-A F1.30A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
506350	2H-115-IWA Welded Attachment			X	-	-	-	-	-	-	-	-	-	-	-
Examination category and item number will become D-A and D1.20 during fourth interval.															
506400	A-24/M82 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 36															
506500	A-24/M82-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 36. Examination category and item number will become D-A and D1.20 during fourth interval.															
<u>Service Water Supply to HX-15C / Dwg. No. ISI-PRI-2334</u>															
507000	R-210 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R210															
507100	R-209 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R209															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
507200	R-208 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R208															
507300	R-207 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R207															
507400	R-206 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R206															
507500	R-205 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R205															
507600	A-03C Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A3															
507700	A-03C-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A3, Examination category and item number will become D-A and D1.20 during fourth interval.															
507800	HB-16 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Service Water Supply to HX-15B / Dwg. No. ISI-PRI-2335															
508000	HB-19-R197 Rigid Support	F-A F1.30B	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R197															
508100	HB-19-R196 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R196															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
508400	HB-19-A2 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with HB-19-A1.															
508500	HB-19-A2-IWA Welded Attachment	D-B D2.20	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
508700	HB-19-SB-1 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
508800	HB-19-SB-2 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
<u>Service Water Supply to HX-15B / Dwg. No. ISI-PRI-2336</u>															
509000	H-50 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
NOT VERIFIED THAT IT EXISTS (DOES NOT SHOW ON P-215 SH1) (8/00)															
509100	A-21 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 39															
509200	A-210-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 39, Category and item number will be D-A and D1.20.															
509300	R-200 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R200															
509400	R-199 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R199															
509500	R-198 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R198															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Service Water Supply to HX-15B / Dwg. No. ISI-PRI-2337</u>															
510000	H-109 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
510100	H-125 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
510200	H-124 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A GUIDE ON P-215 SH1 (8/00)															
<u>Discharge from Aux FW Pump 2P-29 / Dwg. No. ISI-PRI-2338</u>															
511000	H19 Pipe Hanger	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
511100	2H5 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
511150	2H5-IWA Welded Attachment			-	-	-	-	X	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
511200	H18 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
511300	2H4A Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
511400	2H1 Rigid Support	F-A F1.30A	VT-3	X	-	-	-	-	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
511500	2H2 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Component will be exempt for the fourth interval.															
<u>Service Water Return from HX-15A / Dwg. No. ISI-PRI-2344</u>															
512000	HB-19-SA-4 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
512100	HB-19-SA-3 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
512200	HB-19-SA-5 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
512300	HB-19-A2 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Gang hanger with A-02A and A-02B															
512400	HB-19-A2-IWA Welded Attachment	D-B D2.20	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Gang hanger with A-02A and A-02B															
512500	HB-19-R181 Restraint	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R181 IN A FLOOR															
512600	HB-19-R185 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R185															
512700	HB-19-R186 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R186, BEST SUPPORT DRAWING IN WALKDOWN WE-200089															
512800	HB-19-R187 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R187															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

				PLAN STATUS												
SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	FIRST PERIOD				SECOND PERIOD				THIRD PERIOD				
				1	2	3	4	O U T A G E				1	2	3	4	
512900	HB-19-R188 Restraint	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R188 IN A FLOOR																
513000	HB-19-R191 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R191																
513100	HB-19-R192 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R192																
513200	HB-19-A20 Anchor	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
Penetration 43, Flued Head																
<u>Service Water Return from HX-15A / Dwg. No. ISI-PRI-2345</u>																
514200	HB-19-2H121 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-	-
514300	HB-19-S573 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
P-213 SHOWS H127 FLIPPED WITH S573, 79-14 WALKDOWN CORRECTED THIS BUT THE DRAWING HAS NOT BEEN REVISED YET (8/00)																
514400	HB-19-H127 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
514500	HB-19-H119 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with H119A and H119B																
514600	HB-19-H120 Rigid Support	F-A Fl.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with H120A and H120B																

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
514700	HB-19-H102 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Gang support with ISI-PRI-2347, H102A. They are scheduled together.															
514800	HB-19-S547 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Gang support with ISI-PRI-2347, S547A and ISI-PRI-2351, S547B. They are scheduled together.															
514900	HB-19-S547-IWA Welded Attachment		VT-1	-	-	-	-	-	-	-	-	X	-	-	-
Examination category and item number will become D-A and D1.20 during fourth interval.															
<u>Service Water Return from HX-15B / Dwg. No. ISI-PRI-2346</u>															
516020	HB-19-SB-6 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
516040	HB-19-SB-3 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
516060	HB-19-SB-5 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
516080	HB-19-SB-4 Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
516100	HB-19-A1 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
This anchor is listed as HB-19-A-1 on plant controlled drawings, gang hanger with A-02B															
516200	HB-19-A1-IWA Welded Attachment	D-B D2.20	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
This anchor is listed as HB-19-A-1 on plant controlled drawings, gang hanger with A-02B															
516300	HB-19-R196 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R136															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
516400	HB-19-R197 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R197															
516500	HB-19-R198 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R198															
516600	HB-19-R199 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R199															
516700	HB-19-R200 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R200															
516800	HB-19-R202 Restraint	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R201 IN A FLOOR															
518000	HB-19-A22 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
PENETRATION 47															
<u>Service Water Return from HX-15B / Dwg. No. ISI-PRI-2347</u>															
518200	HB-19-2H119 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with H119 and H119B															
518300	HB-19-H120 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Ganged with H120 and H120B															
518400	HB-19-H102 Pipe Hanger	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Gang support with ISI-PRI-2345, H102. They are scheduled together.															
518500	HB-19-S547 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	X	-	-	-
Gang support with ISI-PRI-2345, S547 and ISI-PRI-2351, S547B. They are scheduled together.															

PAGE: 305

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
Service Water Return from HX-15B / Dwg. No.															
518550	HB-19-S547-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
Examination category and item number will become D-A and D1.20 during fourth interval.															
Service Water Return from HX-15B / Dwg. No. ISI-PRI-2347															
518600	HB-19 A Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
ADDED AFTER REVIEWING THE 79-14 WALKDOWN 7/00															
Service Water Return from HX-15C / Dwg. No. ISI-PRI-2348															
519000	HB-15 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
519100	A3 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A-03C															
519200	A3-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A-03C. Examination category and item number will become D-A and D1.20 during fourth interval.															
519300	R205 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R205															
519400	R206 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R206															
519500	R207 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R207															
519600	R208 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R208															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
519700	R209 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R209															
519800	R210 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R210															
519900	A32 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN ON P-213 AS A-27 (A DCN HAS BEEN WRITTEN) (7/00)															
520000	A32-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
SHOWN ON P-213 AS A-27 (A DCN HAS BEEN WRITTEN) (7/00)															
520100	H201 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
520200	HB-19-H201-IWA Welded Attachment		MT	-	-	-	-	-	-	-	-	-	-	-	-
Examination category and item number will become D-A and D1.20 during fourth interval.															
<u>Service Water Return from HX-15C / Dwg. No. ISI-PRI-2349</u>															
521000	H112 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	X	-	-	-	-	-	-	-
GANGED WITH ONE PIPE															
521100	H113 Rigid Support	F-A F1.30A	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
521200	S569 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A RESTRAINT ON P-213 (7/00)															
521300	S570 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A RESTRAINT ON P-213 (7/00), GANGED WITH OTHER PIPES															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
521400	H107 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
521500	S546 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
SHOWN AS A RESTRAINT ON P-213 (7/00)															
<u>Service Water Return from HX-15D / Dwg. No. ISI-PRI-2350</u>															
522000	HB20 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
522100	A4 Anchor	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH A-01D															
522200	A4-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
Ganged with A-01D. Examination category and item number will become D-A and D1.20 during fourth interval.															
522300	R213 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R213 IN A WALL															
522400	R214 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R214 IN A WALL															
522500	R216 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R216															
522600	R217 Rigid Support	F-A F1.30B	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
GANGED WITH R217															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

[illegible]

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 3 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	O U T A G E				1	2	3	4
523900	S547B Rigid Support		VT-3	-	-	-	-	-	-	-	-	X	-	-	-

Gang support with ISI-PRI-2345, S547 and ISI-PRI-2347, S547A. They are scheduled together.

Service Water Return from HX-15D / Dwg. No.

524000	HB-19-S547-IWA Welded Attachment			-	-	-	-	-	-	-	-	-	-	-	-
--------	-------------------------------------	--	--	---	---	---	---	---	---	---	---	---	---	---	---

Examination category and item number will become D-A and D1.20 during fourth interval.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS P COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Pressure Test / Dwg. No.</u>															
700100	2-PT-AF-1 Auxiliary Feedwater	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup AFW-2PT-1 (still needs to be generated). General area is from the outboard isolations through penetrations 5 and 6, to steam generators 2HX-1A and 2HX-1B.															
700200	2-PT-AF-2 Auxiliary Feedwater	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup AFW-2PT-2. General area is from 2P-29 TDAFWP to Outboard Isolation valves 106 and 107. Examination to be performed during the week of February 4, 2002. Need insulation removed from valve.															
700300	2-PT-CS-1 Containment Spray	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup CS-2PT-1. General area is from the C1 break at the whip restraint, through Penetrations 3 and 4, out to the Inboard isolation check and bypass.															
700400	2-PT-CC-1 Component Cooling	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup CC-2PT-1. General area is from Tank 2T-12 through P-11A/B, heat exchangers, through penetrations, to heat exchangers.															
701000	2-PT-MS-1 Main Steam Outside Containment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup MS-2PT-1. General area is from C1 break to penetrations 1 and 2 and MS-2019 and MS-2020.															
701100	2-PT-MS-2 Main Steam Inside Containment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup MS-2PT-2. General area is penetrations 1 and 2 to steam generators 2HX-1A and 2HX-1B.															
701500	2-PT-RH-1 Residual Heat Removal Inside/Outside Con	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup RH-2PT-1. General area is from P10A/B through heat exchangers to the inboard isolation valves.															
701700	2-PT-SI-1 Safety Injection Outside Containment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-1. General area is around pumps P-14A and P-14B.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS P COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
701800	2-PT-SI-2 Safety Injection Outside Containmentment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-2. General area is the safety injection eductor piping.															
701900	2-PT-SI-3 Safety Injection Outside Containmentment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-3. General area is RWST to boundary valves.															
702000	2-PT-SI-4 Safety Injection A Train Outside Contain	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-4. General area is safety injection A train outside containment and recirculation															
702100	2-PT-SI-5 Safety Injection B Train Outside Contain	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-5. General area is safety injection B train outside containment and recirculation															
702200	2-PT-SI-6 Safety Injection A/B Inside/Outside Cont	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-6. General area is near the Accumulators inside containment.															
702300	2-PT-SI-7 Safety Injection Spray Additive Tank	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-7. General area is the NaOH tank.															
702400	2-PT-SI-8 Safety Injection Event V RCS Check Valve	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SI-2PT-1.															
703000	2-PT-SW-1 Service Water Inside Containmentment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup SW-2PT-1.															
703100	2-PT-CV-1 CVCS Inside/Outside Containmentment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup CV-2PT-1.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS P COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
703200	2-PT-CV-2 CVCS Outside Containment	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup CV-2PT-2.															
705100	IT-536 Containment Sump	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-
Callup O-IT-536, performed every 18 months. General area is from valves 2SI-850A/B to valves 2SI-851A/B.															
705200	SEM 7.11.6 RCS System Leakage Test	P	VT-2	X	-	-	-	X	-	-	-	X	-	-	-

To be performed during startup at the end of the outage in conjunction with IT-235.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
/ Dwg. No.															
710000	2TS-36 Penetration Pressure Test	P	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup RH-2PT-2. General area is penetrations V-1 and V-2.															
710100	2TS-38 Containment Spray Pressure Test	P	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
No Callup: General area is the containment spray headers inside containment. This is a flow test to determine the system is open.															
720000	2ORT-25 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-25. General area is penetration P-9.															
720100	2ORT-30 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-30. General area is penetration P-12C.															
720200	2ORT-31 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-31. General area is penetration P-14A.															
720300	2ORT-33 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-633. General area is P-42C.															
720400	2ORT-42 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-42. General area is penetration P-30C.															
720500	2ORT-43 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-43. General area is P-31B.															
720600	2ORT-44 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-44. General area is P-31C.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
720700	2ORT-47 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-47. General area is penetration P-33A.														
720800	2ORT-48 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-48. General area is penetration P-33B.														
720900	2ORT-49 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-49. General area is penetration P-33C.														
721000	2ORT-50 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-50. General area is penetration P-34A.														
721100	2ORT-53 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-53. General area is Penetration P-34D.														
721200	2ORT-61 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-61. General area is penetration P-71.														
721300	2ORT-64 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-64. General area is penetration X-1.														
721400	2ORT-65 Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-65. General area is penetration X-1.														
721500	2ORT-66A Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-66A. General area is penetration P-31A.														
721600	2ORT-66B Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
	Callup O-RT-66B. General area is penetration P-14B.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
721700	20RT-66C Penetration Pressure Test	J	VT-2	-	-	-	-	-	-	-	-	-	-	-	-
Callup O-RT-66C. General area is penetration P-32A.															
725000	Containment Walkdown Information Only		VT	X	X	-	-	X	X	-	-	X	X	-	-

Information walkdown of the containment as the outage is beginning to look for leakage on components where work orders have not been written. This is an augmented examination performed at the request of the plant. Callup 2-RC-LT-INFO.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Pressurizer Safety and Relief Valve Discharge / Dwg. No. 0870 005-002 sh. 1</u>															
800000	HS-29 Snubber	AUG		-	-	-	-	-	-	-	-	-	-	-	-
800100	HS-30 Snubber	AUG		-	-	-	-	-	-	-	-	-	-	-	-
800200	HS-601R-37 Snubber	AUG		-	-	-	-	-	-	-	-	-	-	-	-
	Listed on drawing as RC-601R-2-HS37.														
800300	HS-601R-93 Snubber	AUG		-	-	-	-	-	-	-	-	-	-	-	-
	Listed on drawing as RC-601R-2-HS93.														
800400	HS-601R-95B Snubber	AUG		-	-	-	-	-	-	-	-	-	-	-	-
	Listed on drawing as RC-601R-2-HS95B.														
<u>RPV Head Lift Rig / Dwg. No. ISI-PRI-2401</u>															
801000	RPV-HLR-01 Clevis Plate to Leg Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801100	RPV-HLR-02 Clevis Plate to Leg Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801200	RPV-HLR-03 Clevis Plate to Leg Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801300	RPV-HLR-04 Ring Gird-Support Lug Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
801400	RPV-HLR-05 Ring Gird-Support Lug Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801500	RPV-HLR-06 Ring Gird-Support Lug Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801600	RPV-HLR-07 Side Lug-Sling Assy Link Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801700	RPV-HLR-08 Side Lug-Sling Assy Link Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
801800	RPV-HLR-09 Side Lug-Sling Assy Link Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
<u>RPV Internals Lift Rig / Dwg. No. ISI-PRI-2402</u>															
802000	RPV-ILR-01 Leg Assembly to Adapter Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
802100	RPV-ILR-02 Leg Assembly to Adapter Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
802200	RPV-ILR-03 Leg Assembly to Adapter Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
802300	RPV-ILR-04 Leg Assembly to Adapter Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
802400	RPV-ILR-05 Leg Assembly to Adapter Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
802500	RPV-ILR-06 Leg Assembly to Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
802600	RPV-ILR-07 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
802700	RPV-ILR-08 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
802800	RPV-ILR-09 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
802900	RPV-ILR-10 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
803000	RPV-ILR-11 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
803100	RPV-ILR-12 Sling Leg-Adapter Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
803200	RPV-ILR-13 Spreader Assembly Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
803300	RPV-ILR-14 Spreader Assembly Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
803400	RPV-ILR-15 Spreader Assembly Weld Not an ASME Section XI item.	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
803500	RPV-ILR-16 Sling Lug-Block Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
803600	RPV-ILR-17 Sling Lug-Block Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
803700	RPV-ILR-18 Sling Lug-Block Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
803800	RPV-ILR-19 Top Lug-Sling Block Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
803900	RPV-ILR-20 Top Lug-Sling Block Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	Not an ASME Section XI item.														
<u>RC Pump Motor Lift Rig / Dwg. No. ISI-PRI-2403</u>															
805000	RCP-LR-01 Lift Rig Spreader Assembly Weld	AUG		-	-	-	-	-	-	-	-	-	-	-	-
	NOT AN ASME SECTION XI EXAM.														
805100	RCP-LR-02 Lift Rig Spreader Assembly Weld	AUG		-	-	-	-	-	-	-	-	-	-	-	-
	NOT AN ASME SECTION XI EXAM.														
805200	RCP-LR-03 Lift Rig Spreader Assembly Weld	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	NOT AN ASME SECTION XI EXAM.														
<u>Reactor Pressure Vessel Closure Head Bolting/CRD / Dwg. No. ISI-PRI-2103</u>															
805300	RPV-HLUG-01 RPV Head Lifting Lug	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
	LUG IS NOT UNDER CONSTANT LOAD. ADDED TO PROGRAM AS AUGMENTED EXAM.														

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Reactor Pressure Vessel Closure Head / Dwg. No. ISI-PRI-2103</u>															
805400	RPV-HLUG-02 RPV Head Lifting Lug	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
Lug is not under constant load.															
805500	RPV-HLUG-03 RPV Head Lifting Lug	AUG	SUR	-	-	-	-	-	-	-	-	-	-	-	-
LUG IS NOT UNDER CONSTANT LOAD. ADDED TO PROGRAM AS AUGMENTED EXAM.															
<u>RC Pump Motor Flywheel / Dwg. No. ISI-PRI-2404</u>															
806100	RCP A Flywheel RC Pump Flywheel	RG1.14	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
NOT AN ASME SECTION XI EXAM.															
806300	RCP B Flywheel RC Pump Flywheel	RG1.14	SUR VOL	-	-	-	-	-	-	-	-	-	-	-	-
NOT AN ASME SECTION XI EXAM.															
<u>Main Steam Bypass Energy Absorbers / Dwg. No. ISI-PRI-2405</u>															
807000	EA-EB-2-1 Energy Absorber	AUG	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Not a Section XI examination. To be examined for cracking. Scratch plates will be examined to determine if any unanticipated loadings may have occurred.															
807100	EA-EB-2-3 Energy Absorber	AUG	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Not a Section XI examination. To be examined for cracking. Scratch plates will be examined to determine if any unanticipated loadings may have occurred.															
807200	EA-EB-2-4 Energy Absorber	AUG	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Not a Section XI examination. To be examined for cracking. Scratch plates will be examined to determine if any unanticipated loadings may have occurred.															
807300	EA-EB-2-5 Energy Absorber	AUG	VT-3	-	-	-	-	-	-	-	-	-	-	-	-
Not a Section XI examination. To be examined for cracking. Scratch plates will be examined to determine if any unanticipated loadings may have occurred.															

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS N COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
807400	EA-EB-2-6 Energy Absorber	AUG	VT-3	-	-	-	-	-	-	-	-	-	-	-	-

Not a Section XI examination. To be examined for cracking. Scratch plates will be examined to determine if any unanticipated loadings may have occurred.

POINT BEACH NUCLEAR PLANT - UNIT 2
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 COMPONENTS

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	CATEGORY ITEM NO	NDE METH	PLAN STATUS											
				FIRST PERIOD				SECOND PERIOD				THIRD PERIOD			
				1	2	3	4	1	2	3	4	1	2	3	4
<u>Safety Injection A Accumulator Nozzles / Dwg. No. N/A</u>															
810000	SI-832A-NOZ SI Accumulator A Nozzle Cal Block: 23-PTB Callup ISI-2P34A. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810100	SI-832B-NOZ SI Accumulator A Nozzle Cal Block: 23-PTB Callup ISI-2P34A. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810200	SI-832C-NOZ SI Accumulator A Nozzle Cal Block: 23-PTB Callup ISI-2P34A. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810300	SI-832D-NOZ SI Accumulator A Nozzle Cal Block: 23-PTB Callup ISI-2P34A. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
<u>Safety Injection B Accumulator Nozzles / Dwg. No. N/A</u>															
810400	SI-833A-NOZ SI Accumulator B Nozzle Cal Block: 23-PTB Callup ISI-2P34B. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810500	SI-833B-NOZ SI Accumulator B Nozzle Cal Block: 23-PTB Callup ISI-2P34B. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810600	SI-833C-NOZ SI Accumulator B Nozzle Cal Block: 23-PTB Callup ISI-2P34B. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-
810700	SI-833D-NOZ SI Accumulator B Nozzle Cal Block: 23-PTB Callup ISI-2P34B. Component to be examined once per interval in accordance with Information Notice 91-05.	IN91-05 NOZ	VOL	-	-	-	-	-	-	-	-	-	-	-	-