

April 4, 2002

ORGANIZATION: NUCLEAR ENERGY INSTITUTE

SUBJECT: SUMMARY OF MEETING WITH THE NUCLEAR ENERGY INSTITUTE (NEI) ON THE PROPOSED REVISION OF CHAPTERS II AND III OF GENERIC AGING LESSONS LEARNED (GALL) REPORT ON AGING MANAGEMENT OF CONCRETE ELEMENTS

On February 14, 2002, the Nuclear Regulatory Commission (NRC) staff met with NEI and other industry representatives to discuss the staff's proposed revision of Chapters II (Containment) and III (Structures) of the GALL report, which was issued for comment on November 23, 2001. The revision was to clarify applicable aging management programs (AMPs) for concrete elements identified during the lessons learned meeting on the license renewal demonstration project held on October 11, 2001. Attached are the agenda (Attachment 1), two NEI handouts provided during the meeting (Attachments 2 and 3), and the list of meeting attendees (Attachment 4).

The meeting began with an NEI representative making opening remarks that any resolution of technical issues (e.g., station blackout, and fire protection) or any changes to the license renewal process should be addressed through a series of meetings between the NRC staff and NEI. Following the opening remarks, an industry representative provided an overview (Attachment 2) of how to identify systems, structure, and components that should be in the scope of the license renewal, structures and components that are subjected to aging management review, and the industry's view on the use of the GALL report for license renewal. Next, an industry representative made a presentation on aging of concrete (Attachment 3) and relevant industry-wide operating experience over the years.

Immediately following these presentations, a general discussion ensued during which industry representatives presented the following views:

- Concrete fabricated according to its original design and not subjected to extreme environments will not age significantly or result in the loss of intended function of the concrete components.
- Aging management reviews of concrete structures and components have determined that not all of these structures and components require aging management for license renewal.

- The current version of the GALL report does not require an AMP for all accessible concrete components.
- The NRC staff's position that all accessible concrete components require aging management for license renewal, regardless of the applicants's aging management review of these components, is not justifiable.

In contrast to the above views presented by industry, the NRC staff made the following points:

- The GALL report describes an AMP for all accessible concrete components. The last column in the GALL report table concludes further evaluation beyond an AMP for concrete components that do not meet the environmental conditions presented in the AMP column of the GALL report table.
- The GALL report adopted the Structures Monitoring Program as an existing program developed under the Maintenance Rule to address (1) recommendations from NUREG-1557, "Summary of Technical Information and Agreements from Nuclear Management and Resources Council Industry Reports Addressing License Renewal", (2) actual industry experience from Generic Letters, or Information Notices and (3) comments from NEI, industry, and public through a series of public meetings during development of the GALL report.
- The staff's position requiring an AMP for all accessible concrete components for license renewal is consistent with and has not changed since the publication of the GALL report. Current proposed revisions to the GALL report are only intended to clarify and not change the staff's position.
- Aging management reviews of concrete components, performed by license renewal applicants, can be used to show that inspection frequencies may be varied based on the results of the applicant's aging management review.
- In order for the NRC staff to make a reasonable assurance finding that all concrete structures and components will maintain their structural integrity and intended function(s), the staff requires inspections of concrete components during the period of extended operation.
- The staff disagrees with industry's interpretation of the term "Non-significant" in NUREG-1557 to imply that no aging management is required for concrete structures at nuclear power plants.

As a result of the discussion, both the NRC staff and NEI achieved a better understanding of their respective positions regarding the aging management of concrete elements for license renewal. NEI will provide any written comments pertinent to the staff's proposed revision of GALL Chapters II and III at a later date. After the industry comments are received, the NRC staff will schedule another public meeting to discuss the resolution of this issue.

/RA/

Peter J. Kang, Reactor Systems Engineer
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 690

Attachments: As stated

cc w/atts: See next page

As a result of the discussion, both the NRC staff and NEI achieved a better understanding of their respective positions regarding the aging management of concrete elements for license renewal. NEI will provide any written comments pertinent to the staff's proposed revision of GALL Chapters II and III at a later date. After the industry comments are received, the NRC staff will schedule another public meeting to discuss the resolution of this issue.

/RA/

Peter J. Kang, Reactor Systems Engineer
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 690

Attachments: As stated

cc w/atts: See next page

Distribution:
See next page

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML020940319.wpd

See previous concurrence

OFFICE	LA:DRIP	NSE:RLEP	SC:RLEP	BC:EMEB	PD:RLEP
NAME	SLittle*	PKang*	PTKuo*	Elmbro*	CIGrimes
DATE	3/06/02	3/05/02	3/21/02	3/ 27/02	4/ 4 /02

OFFICIAL RECORD COPY

DISTRIBUTION: **ML020940312**

HARD COPY

RLEP RF

E. Hylton

E-MAIL:

PUBLIC

J. Johnson

W. Borchardt

D. Matthews

F. Gillespie

C. Grimes

J. Strosnider (RidsNrrDe)

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

C. Holden

P. Shemanski

H. Nieh

G. Holahan

S. Black

B. Boger

D. Thatcher

G. Galletti

B. Thomas

R. Architzel

J. Moore

R. Weisman

M. Mayfield

A. Murphy

W. McDowell

S. Droggitis

N. Dudley

RLEP Staff

A. Thadani

R. Zimmerman

C. Julian

R. Gardner

M. Farber

M. Modes

J. Vora

NRC Meeting Attendance List
Aging Management of Concrete Elements
February 14, 2002

<u>Name</u>	<u>Organization</u>	<u>Telephone #</u>
Peter J. Kang	NRC/NRR/DRIP/RLEP	301-415-2779
P.T. Kuo	NRC/NRR/DRIP/RLEP	301-415-3147
Hans Ashar	NRC/NRR/DE	301-415-2851
Cliff Munson	NRC/NRR/DE	301-415-2529
Chris Grimes	NRC/NRR/DRIP/RLEP	301-415-1183
Alan Nelson	NEI	202-739-8110
Debra Keiser	Duke Energy	704-382-3920
Fred Polaski	Exelon	610-765-5935
Bob Whorton	SC Elec & Gas	803-345-4725
Charlie Sorrell	Dominion-VA Power	804-273-3114
Shoji Takeyama	NRC/RLEP	301-415-3873
Bob Prato	NRC/RLEP	301-415-7147
Michael Henig	Dominion-VA Power	804-273-2237
Goutam Bagchi	NRC/NRR/DE	301-415-3298
John Hilbish	Parsons	610-855-2547
W. Robert Jackson	GE Nuclear Energy	615-826-7542
Hai-Boh Wang	NRC/NRR/DRIP/RLEP	301-415-2958
David C. Jeng	NRC/NRR/DE/EMEB	301-415-2727
Herman L. Graves	NRC/RES/DET/ERAB	301-415-5880
Tsun-Yung Chang	NRC/RES/DET/ERAB	301-415-6450
Jan E. Fridrichsen	Southern Nuclear	205-992-5688
Winston Liu	NRC/NRR/DRIP/RELP	301-415-3148
Raj Auluck	NRC/NRR/DRIP/RLEP	301-415-1025
Deann Raleigh	US/Scientech	301-258-2551
Nancy Chapman	Serch/Bechtel	301-228-6025
Noel Dudley	NRC/NRR/DRIP/RLEP	301-415-6888
Omid Tabatabai	NRC/NRR/DRIP/RLEP	301-415-3738
Garry Young	Entergy	501-858-4303
Alan Cox	Entergy	479-858-3173
William Burton	NRC/NRR/DRIP/RLEP	301-415-2853
Mark AcKerman	FENOC	724-682-7994
Carey W. Fleming	Winston & Strawn	202-371-5839
Joe Gasper	Omaha Public Power	402-533-7233
John Rycyna	CNS	410-793-3418
Jim E Knorr	NMC	920-755-6863
A.M. Omaou	Exelon	610-765-5937
Steve Hale	FPL	305-246-6090
Greg Robison	Duke Energy	704-382-8685
Bob Nickoll	EPRI consultant	858-485-9024
Pei-Ying Chen	NRC/NRR/DE	301-415-2789

NUCLEAR ENERGY INSTITUTE

Project No. 690

cc:

Mr. Joe Bartell
U.S. Department of Energy
NE-42
Washington, DC 20585

Mr. Richard P. Sedano, Commissioner
State Liaison Officer
Department of Public Service
112 State Street
Drawer 20
Montpelier, Vermont 05620-2601

Mr. Alan P. Nelson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708
APN@NEI.ORG

Mr. Stephen T. Hale
Florida Power & Light Company
9760 S.W. 344 Street
Florida City, Florida 33035

Mr. William Corbin
Virginia Electric & Power Company
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, Virginia 23060

Mr. Frederick W. Polaski
Manager License Renewal
Exelon Corporation
200 Exelon Way
Kennett Square, PA 19348

Mr. Robert Gill
Duke Energy Corporation
Mail Stop EC-12R
P.O. Box 1006
Charlotte, NC 28201-1006

Mr. Charles R. Pierce
Southern Nuclear Operating Co.
40 Inverness Center Parkway
BIN B064
Birmingham, AL 35242

Mr. David Lochbaum
Union of Concerned Scientists
1707 H Street, NW
Suite 600
Washington, DC 20006-3919

Mr. Paul Gunter
Director of the Reactor Watchdog Project
Nuclear Information & Resource Service
1424 16th Street, NW, Suite 404
Washington, DC 20036

Mr. Hugh Jackson
Public Citizen's Critical Mass Energy &
Environment Program
215 Pennsylvania Ave. SE
Washington DC 20003

Ms. Mary Olson
Nuclear Information & Resource Service
P. O. Box 7586
Asheville, North Carolina 28802