

April 22, 2002

Mr. John T. Conway  
Site Vice President  
Nine Mile Point Nuclear Station, LLC  
P.O. Box 63  
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - REQUEST FOR  
ADDITIONAL INFORMATION - AMENDMENT APPLICATION RE: INSERVICE  
TESTING AND INSPECTION REQUIREMENTS (TAC NO. MB3208)

Dear Mr. Conway:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing the subject proposed amendment, requested by your letter dated November 26, 2001. On April 10, 2002, we held a telephone discussion with Mr. A. Abbasi, et al., of your staff. The NRC staff decided to formalize its comments in a request for additional information.

The NRC staff holds the position that inservice testing of Quality Group A, B, and C pumps and valves be performed in accordance with requirements for American Society of Mechanical Engineers (ASME) Code Class 1, 2, and 3 components specified in Section XI of the applicable ASME Boiler and Pressure Vessel Code and Addenda. Your application is lacking such wording. Alternatively, you may consider adopting the proposed requirements described by Section 5.5.7.a of NUREG-1433, "Standard Technical Specifications for General Electric Nuclear Plants, BWR/4 and BWR/6."

Please respond within 45 days of receipt of this letter. If more time is needed, or if you need clarification, please call me at 301-415-1451.

Sincerely,

**/RA/**

Peter S. Tam, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

Mr. John T. Conway  
Site Vice President  
Nine Mile Point Nuclear Station, LLC  
P.O. Box 63  
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - REQUEST FOR  
ADDITIONAL INFORMATION - AMENDMENT APPLICATION RE: INSERVICE  
TESTING AND INSPECTION REQUIREMENTS (TAC NO. MB3208)

Dear Mr. Conway:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing the subject proposed amendment, requested by your letter dated November 26, 2001. On April 10, 2002, we held a telephone discussion with Mr. A. Abbasi, et al., of your staff. The NRC staff decided to formalize its comments in a request for additional information.

The NRC staff holds the position that inservice testing of Quality Group A, B, and C pumps and valves be performed in accordance with requirements for American Society of Mechanical Engineers (ASME) Code Class 1, 2, and 3 components specified in Section XI of the applicable ASME Boiler and Pressure Vessel Code and Addenda. Your application is lacking such wording. Alternatively, you may consider adopting the proposed requirements described by Section 5.5.7.a of NUREG-1433, "Standard Technical Specifications for General Electric Nuclear Plants, BWR/4 and BWR/6."

Please respond within 45 days of receipt of this letter. If more time is needed, or if you need clarification, please call me at 301-415-1451.

Sincerely,

*/RA/*

Peter S. Tam, Senior Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

DISTRIBUTION:

PUBLIC	PDI-1 R/F	RLaufer	PTam
OGC	YSHuang	SLittle	PHearn
ACRS	BPlatchek		

Accession Number: **ML021120379**

OFFICE	PDI-1/PM	PDI-1/LA	RORP	RORP/SC	PDI-1/SC
NAME	PTam	SLittle	PHearn	RDennig	RLaufer
DATE	4/18/02	4/18/02	4/19/02	4/19/02	4/22/02

OFFICIAL RECORD COPY

Nine Mile Point Nuclear Station  
Unit No. 1

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 126  
Lycoming, NY 13093

Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Mr. Paul D. Eddy  
Electric Division  
NYS Department of Public Service  
Agency Building 3  
Empire State Plaza  
Albany, NY 12223

Mr. William M. Flynn, President  
New York State Energy, Research,  
and Development Authority  
Corporate Plaza West  
286 Washington Avenue Extension  
Albany, NY 12203-6399

Mark J. Wetterhahn, Esquire  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

Supervisor  
Town of Scriba  
Route 8, Box 382  
Oswego, NY 13126

Mr. Robert E. Denton  
President  
Nine Mile Point Nuclear Station, LLC  
1997 Annapolis Exchange Parkway  
Suite 500  
Annapolis, MD 21401

Mr. Raymond L. Wenderlich  
Senior Constellation Nuclear Officer  
Responsible for Nine Mile Point  
Nine Mile Point Nuclear Station, LLC  
P.O. Box 63  
Lycoming, NY 13093

Mr. James M. Petro, Jr., Esquire  
Counsel  
Constellation Power Source, Inc.  
111 Market Place  
Suite 500  
Baltimore, MD 21202