

2.0 **LIMITING CONDITIONS FOR OPERATION**

2.3 **Emergency Core Cooling System (Continued)**

(2) **Modification of Minimum Requirements**

During power operation, the Minimum Requirements may be modified to allow one of the following conditions to be true at any one time. If the system is not restored to meet the minimum requirements within the time period specified below, the reactor shall be placed in a hot shutdown condition within 12 hours. If the minimum requirements are not met within an additional 48 hours the reactor shall be placed in a cold shutdown condition within 24 hours.

- a. One low-pressure safety injection pump may be inoperable provided the pump is restored to operable status within 24 hours.
- b. One high-pressure safety injection pump may be inoperable provided the pump is restored to operable status within 24 hours.
- c. One shutdown heat exchanger may be inoperable for a period of no more than 24 hours.
- d. Any valves, interlocks or piping directly associated with one of the above components and required to function during accident conditions shall be deemed to be part of that component and shall meet the same requirements as listed for that component.
- e. Any valve, interlock or piping associated with the safety injection and shutdown cooling system which is not covered under d. above but which is required to function during accident conditions may be inoperable for a period of no more than 24 hours.
- f. One safety injection tank may be inoperable for reasons other than g. or h. below for a period of no more than 24 hours.
- g. Level and/or pressure instrumentation on one safety injection tank may be inoperable for a period of 72 hours.
- h. One safety injection tank may be inoperable due to boron concentration not within limits for a period of no more than 72 hours.
- i. Components in excess of those allowed by Conditions a, b, d, and e may be inoperable provided they are returned to operable status within 1 hour when performing the quarterly recirculation actuation logic channel functional test (Table 3-2 item 20) under administrative controls. This allowance applies only to the remaining portion of Cycle 20 and all of Cycle 21.

2.0 LIMITING CONDITIONS FOR OPERATION

2.3 Emergency Core Cooling System (Continued)

Components in excess of those allowed by Conditions a, b, d, and e may be inoperable provided they are returned to operable status within 1 hour when performing the quarterly recirculation actuation logic channel functional test (Table 3-2 item 20) under administrative controls. This allowance applies only to the remaining portion of Cycle 20 and all of Cycle 21. This prevents violating Technical Specifications or necessitating a unit shutdown due to inability to perform the quarterly recirculation actuation logic channel functional test. These administrative controls consist of stationing three dedicated operators at the Engineered Safeguards Features (ESF) panel controls in the control room. In this way, the following conditions are maintained and actions can be rapidly performed should a valid ESF actuation occur.

- the appropriate Safety Injection Refueling Water Tank (SIRWT) to Safety Injection (SI) and Containment Spray (CS) pumps suction valve control switch is maintained in the OPEN position (spring-return switch),
- the appropriate SI and CS pumps to SIRWT recirculation minimum flow valve control switch is maintained in the OPEN position (spring return switch),
- the appropriate Recirculation Actuation Signal (RAS) lockout relays and initiating signal can be rapidly reset,
- the appropriate SI and CS pumps to SIRWT recirculation minimum flow valve control switch can be rapidly returned to the AUTO position,
- the appropriate SIRWT to SI and CS pumps suction valve control switch can be rapidly returned to the AUTO position, and
- the appropriate Containment Sump to SI and CS pumps suction valve control switch can be rapidly returned to the AUTO position.

The appropriate SI and CS pumps to SIRWT recirculation minimum flow valve control switch and the appropriate SIRWT to SI and CS pumps suction valve control switch are held in the OPEN position during the test to enhance the reliability of the appropriate SI and CS pumps by maintaining the associated valves open.

References

- (1) USAR, Section 14.15.1
- (2) USAR, Section 6.2.3.1
- (3) USAR, Section 14.15.3
- (4) USAR, Appendix K
- (5) Omaha Public Power District's Submittal, December 1, 1976
- (6) Technical Specification 2.1.2, Figure 2-1B
- (7) USAR, Section 4.4.3