

**INITIAL SUBMITTAL OF ADMINISTRATIVE JPMS**

**FOR THE DRESDEN INITIAL EXAMINATION - JUNE 2002**

## Nuclear Generation Group

### Job Performance Measure


Determine if Jet Pump Flow Meets Requirements

JPM Number: A.1.a-RO

Revision Number: 00

Date: 03/15/02

Developed By:




Facility Author

3/15/02

Date

Approved By:



Facility Representative

3-15-02

Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM is new and was developed for the Dresden ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Clean copy of DOS 0202-02
2. Copy of DOS 0202-02, Data Sheet 1, with jet pump flows filled in.
3. OPERATOR AID #18, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $\geq 80\%$
4. OPERATOR AID #19, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $\geq 60\%$  and  $< 80\%$
5. OPERATOR AID #20, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $< 60\%$
6. Calculator

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. A unit startup is in progress for Unit 2.
2. Reactor power is about 52% and has been steady for 2 hours.
3. Recirculation pump speeds are 55% for pump 2A and 56% for pump 2B.
4. The POWERPLEX computer is NOT operable.
5. You are the Unit 2 Assistant NSO.
6. The Unit 2 NLO has just obtained jet pump data from the Auxiliary Electrical Equipment Room.

**INITIATING CUE**

You have been directed by the Unit 2 Supervisor to perform the individual jet pump flow surveillance in accordance with DOS 0202-02.

Inform the Unit 2 Supervisor when the task is completed.

**Job Performance Measure (JPM)**

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....  
**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
<div style="border: 1px solid black; padding: 5px;">           Note: Provide examinee with clean copy of DOS 0202-02 and marked up copy of Data Sheet 1 from DOS 0202-02.         </div>					
1.	Determines that surveillance is to be performed in accordance with DOS 0202-02, step I.2.	Examinee determines that surveillance is performed in accordance with DOS 0202-02, step I.2.	—	—	—
2.	Record loop A and loop B RECIRC pump speeds (percent) under Speed A or Speed B.	Examinee records 55% under SA and 56% under SB on Data Sheet 1.	—	—	—
*3.	Add the readings for the jet pumps in each loop and divide by the number of operable jet pump indications for the loop to obtain loop average jet pump AND record this loop average flow value.	Examinee records 4.48 under "LOOP A AVG" and 4.48 under "LOOP B AVG."	—	—	—
<div style="border: 1px solid black; padding: 5px;">           Note: See attached KEY for normalized jet pump flow values.         </div>					
*4.	Normalize jet pump flows by dividing each individual jet pump flow by the loop average AND record normalized value on Line 2.	Examinee divides each individual jet pump flow by the loop average and records value on Line 2.	—	—	—
<div style="border: 1px solid black; padding: 5px;">           Note: When the examinee locates the Operator Aids to be used for this surveillance provide them with copies of Operator Aids 18, 19, and 20.         </div>					

**Job Performance Measure (JPM)**

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
5.	Compare the normalized jet pump readings to the appropriate characteristic graph.	Examinee compares normalized jet pump readings to characteristic graph for “Unit 2 Jet Pump Baseline Data, RECIRC Pump Speeds less than 60 percent.” [Operator Aid 20]	_____	_____	_____
*6.	Record on Line 3 whether each jet pump falls within the allowable range.	Examinee records YES on Line 3 for all jet pumps except #5 and #19.	_____	_____	_____
*7.	IF any jet pump is outside the allowable range, THEN:  1. Notify Unit Supervisor  2. Notify QNE to evaluate data.	Examinee notifies Unit 2 Supervisor and QNE that jet pumps #5 and #19 failed the surveillance.	_____	_____	_____

Note: The critical part of Step 7 is notifying the Unit Supervisor.

CUE: Acknowledge reports.

The JPM is considered complete at this time.

JPM Stop Time: \_\_\_\_\_

.....



**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☒ SRO ☐JPM Title: Determine if Jet Pump Flow Meets RequirementsJPM Number: A.1.a-RO Revision Number: 00

Task Number and Title: 202L014, Perform a jet pump operability and degradation surveillance when POWERPLEX computer is NOT available.

K/A Number and Importance: 2.1.25; RO IMPORTANCE - 2.8Suggested Testing Environment: SimulatorActual Testing Environment: ☐ Simulator ☐ Plant  
☐ Control RoomTesting Method: ☐ Simulate  
☒ Perform Alternate Path: ☐ Yes ☒ NoTime Critical: ☐ Yes ☒ No

Estimated Time to Complete: 22 minutes Actual Time Used: \_\_\_\_\_ minutes

**References:**

1. DOS 0202-02, Jet Pump Operability and Degradation, Rev. 23
2. OPERATOR AID #20, Rev. 2

[illegible]

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. A unit startup is in progress for Unit 2.
2. Reactor power is about 52% and has been steady for 2 hours.
3. Recirculation pump speeds are 55% for pump 2A and 56% for pump 2B.
4. The POWERPLEX computer is NOT operable.
5. You are the Unit 2 Assistant NSO.
6. The Unit 2 NLO has just obtained jet pump data from the Auxiliary Electrical Equipment Room.

**INITIATING CUE**

You have been directed by the Unit 2 Supervisor to perform the individual jet pump flow surveillance in accordance with DOS 0202-02.

Inform the Unit 2 Supervisor when the task is completed.

## CATEGORY 1

KEY

UNIT 2  
DOS 0202-02  
REVISION 23DATA SHEET 1  
INDIVIDUAL JET PUMP FLOW SURVEILLANCEUnit 2 Week: From \_\_\_\_\_ To \_\_\_\_\_

LOOP A

LOOP A		"JP option"	1	2	3	4	5	6	7	8	9	10	SA	LOOP A AVG	
MON	1		4.1	4.4	4.3	4.8	4.9	4.4	4.5	4.9	4.3	4.2			Calculations performed by _____ Sign/Date _____
	2		0.92	0.98	0.96	1.07	1.09	0.98	1.00	1.09	0.96	0.94	55	4.48	Independently verified by _____ Sign/Date _____
	(AC) 3		YES	YES	YES	YES	NO	YES	YES	YES	YES	YES			
TUE	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														
WED	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														
THU	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														
FRI	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														
SAT	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														
SUN	1														Calculations performed by _____ Sign/Date _____
	2														Independently verified by _____ Sign/Date _____
	(AC) 3														

## CATEGORY 1

KEY

UNIT 2  
DOS 0202-02  
REVISION 23DATA SHEET 1 (Continued)  
INDIVIDUAL JET PUMP FLOW SURVEILLANCEUnit 2

Week: From \_\_\_\_\_ To \_\_\_\_\_

LOOP B

	"JP option"	11	12	13	14	15	16	17	18	19	20	SB	LOOP B AVG	
MON	1	4.4	4.1	4.3	5.0	4.4	4.3	4.3	4.8	4.9	4.3			Calculations performed by _____ Sign/Date _____
	2	0.98	0.92	0.96	1.12	0.98	0.96	0.96	1.07	1.07	0.96	56	4.48	Independently verified by _____ Sign/Date _____
	(AC) 3	YES	YES	YES	YES	YES	YES	YES	YES	NO	YES			
TUE	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													
WED	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													
THU	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													
FRI	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													
SAT	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													
SUN	1													Calculations performed by _____ Sign/Date _____
	2													Independently verified by _____ Sign/Date _____
	(AC) 3													

KEY FOR ADMIN JPM - DOS 0202-02, DATA SHEET 1											
LOOP A											
	1	2	3	4	5	6	7	8	9	10	AVG
1	4.1	4.4	4.3	4.8	4.9	4.4	4.5	4.9	4.3	4.2	4.48
2	0.92	0.98	0.96	1.07	1.094	0.98	1.00	1.09	0.96	0.94	
HI	1.038	1.089	1.093	1.118	1.058	1.108	1.119	1.151	1.112	1.102	
LO	0.840	0.891	0.895	0.920	0.860	0.910	0.921	0.953	0.914	0.904	
AVG	0.94	0.99	0.99	1.02	0.96	1.01	1.02	1.05	1.01	1.00	
3											
LOOP B											
	11	12	13	14	15	16	17	18	19	20	AVG
1	4.4	4.1	4.3	5.0	4.4	4.3	4.3	4.8	4.9	4.3	4.48
2	0.98	0.92	0.96	1.12	0.98	0.96	0.96	1.07	1.094	0.96	
HI	1.129	1.090	1.106	1.161	1.090	1.058	1.068	1.121	1.074	1.092	
LO	0.931	0.892	0.908	0.963	0.892	0.860	0.870	0.923	0.876	0.894	
AVG	1.03	0.99	1.01	1.06	0.99	0.96	0.97	1.02	0.98	0.99	
3											

**Nuclear Generation Group**

**Job Performance Measure**

Verify Off-Site Power Sources Available

JPM Number: A.1.b-RO

Revision Number: 00


Date: 03/16/02

Developed By:

  
Facility Author

3/16/02  
Date

Approved By:

  
Facility Representative

3-18-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM was taken directly from the Dresden facility testing materials bank for use during the ILT Class 01-1 NRC Exam.



**Job Performance Measure (JPM)**

**MATERIALS**

1. Clean copy of Appendix X.
2. Copy of Attachment 3 of Appendix X with data filled in for Unit 3.

**SIMULATOR SET UP**

Have the simulator in IC 12 or any other setup with a normal electric plant line-up.

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. Unit 2 and 3 are at near rated conditions.
2. The U2 EDG was declared inoperable 10 minutes ago following a failed surveillance.
3. You are the Unit 2 Assistant NSO.

**INITIATING CUE**

The Unit 2 Supervisor has just directed you to verify offsite power availability with the U2 EDG inoperable, in accordance with Appendix X, Attachment 3 as required by Technical Specifications 3.8.1, Action Condition B.1.

The Unit 3 Assistant NSO has already collected the data for Unit 3.

Inform the Unit 2 Supervisor when the surveillance is complete.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....  
**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
<div style="border: 1px solid black; padding: 5px;"> <p>Note: The examinee is to be given a clean copy of Appendix X and a copy of Attachment 3 with the data for Unit 3 complete.</p> </div>					
*1.	Record actual breaker positions and bus voltages.	Examinee records actual breaker positions and bus voltages, and initials Attachment 3.	_____	_____	_____
*2.	Indicate Acceptance Criteria met.	Examinee circles "YES" for Acceptance Criteria met.	_____	_____	_____
*3.	Enter Signature, Date, and Time, for "Performed by."	Examinee enters signature, date, and time for "Performed by." This must be completed within 50 minutes of start of JPM.	_____	_____	_____
4.	Notify Unit 2 Supervisor that the surveillance is complete.	Examinee notifies Unit 2 Supervisor that the surveillance is complete.	_____	_____	_____
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: Acknowledge report.</p> <p>The JPM is considered complete at this time.</p> </div>					

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☒ SRO ☐JPM Title: Verify Off-Site Power Sources AvailableJPM Number: A.1.b-RO Revision Number: 00

Task Number and Title: 299L044, Perform administrative duties for a malfunction of a piece of safety related equipment.

K/A Number and Importance: 2.1.31: RO IMPORTANCE - 4.2**Suggested Testing Environment:** Simulator**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room**Testing Method:** ☐ Simulate  
☒ Perform **Alternate Path:** ☐ Yes ☒ No**Time Critical:** ☐ Yes ☒ No**Estimated Time to Complete:** 20 minutes **Actual Time Used:** \_\_\_\_\_ minutes**References:**

1. Appendix X

2. ITS 3.8.1



**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. Unit 2 and 3 are at near rated conditions.
2. The U2 EDG was declared inoperable 10 minutes ago following a failed surveillance.
3. You are the Unit 2 Assistant NSO.

**INITIATING CUE**

The Unit 2 Supervisor has just directed you to verify offsite power availability with the U2 EDG inoperable, in accordance with Appendix X, Attachment 3 as required by Technical Specifications 3.8.1, Action Condition B.1.

The Unit 3 Assistant NSO has already collected the data for Unit 3.

Inform the Unit 2 Supervisor when the surveillance is complete.

**Nuclear Generation Group**

**Job Performance Measure**


Perform NSO Actions for a Short Duration Time Clock

JPM Number: A.2-RO

Revision Number: 00

Date: 03/16/02

Developed By:

  
Facility Author

3/16/02  
Date

Approved By:

  
Facility Representative

3-28-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM was taken directly from the Dresden facility testing materials bank for use during the ILT Class 01-1 NRC Exam.



**Job Performance Measure (JPM)**

**MATERIALS**

1. Copy of current revision of OP-AA-108-104, Technical Specification Compliance
2. Copy of OP-AA-108-104, Attachment 1, partially filled out.

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. Reactor power is approximately 88%.
2. IMD will be performing DIS 0500-05, Unit 2 Scram Discharge Volume Sensor Calibration and Functional Tests, for Unit 2 scram discharge volume level switch LS 2-0302-82A. No other testing is in progress
3. You are the Unit 2 NSO.
4. You have been provided Attachment 1, Short Duration Time Clock, which has been partially filled in.

**INITIATING CUE**

IMD will perform DIS 0500-05, the Unit 2 Supervisor has directed you to log and monitor the performance of this surveillance.

Inform the Unit 2 Supervisor when the testing for LS 2-0302-82A is complete.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....  
**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
	<p>Note: Provide the examinee with OP-AA-108-104 and the partially filled in Attachment 1 form OP-AA-108-104.</p> <p>The RO will be performing the actions of section 4.6 through 4.7.1 of OP-AA-108-104</p>	o			
	CUE: It is 0720 and the IMD "B" man in the control room has just informed you that testing is commencing.				
	Note: Steps 1, 2, and 3 may be performed in any order.				
1.	Enter Tech Spec on the Short Duration Time Clock Log.	Examinee records 3.3.1.1			
2.	Starts an electronic clock.	Examinee starts an electronic clock to alarm after a time of 5.5 hours	_____	_____	_____
*3.	Enter Time Clock Start Time on the Short Duration Time Clock Log.	Examinee records "0720" on the Short Duration Time Clock Log.	_____	_____	_____
	Note: Time compression will be used in this JPM.				
	CUE: 5.5 hours have just elapsed and the electronic clock alarm has just alarmed.				

**Job Performance Measure (JPM)**

<u><b>STEP</b></u>	<u><b>ELEMENT</b></u> °	<u><b>STANDARD</b></u>	<u><b>SAT</b></u>	<u><b>UNSAT</b></u>	<u><b>Comment Number</b></u>
*4.	Contact the IMD "B" man in the control room to determine the surveillance status.	Examinee contacts IMD "B" man to determine if testing can be completed within the 6 hour time frame.	—	—	—
CUE: The IMD "B" man in the control room informs you that the testing will be completed in 10 minutes.					
CUE: It is 1300 and the IMD "B" man has just reported that the testing is complete.					
*5.	Complete the Short Duration Time Clock Log.	Examinee lists the time clock is stopped and initials log as complete.	—	—	—
6.	Notify Unit 2 Supervisor that testing is complete.	Examinee notifies Unit 2 Supervisor that testing for LS 2-0302-82A is complete.	—	—	—
CUE: Acknowledge report.					
The JPM is considered complete at this time.					

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☒ SRO ☐

JPM Title: Perform NSO Actions for a Short Duration Time Clock

JPM Number: A.2-RO Revision Number: 00

Task Number and Title: 299L145, Perform the administrative duties associated with short duration time clocks.

K/A Number and Importance: 2.2.23; RO IMPORTANCE - 2.6

**Suggested Testing Environment:** Simulator

**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room

**Testing Method:** ☐ Simulate  
☒ Perform **Alternate Path:** ☐ Yes ☒ No

**Time Critical:** ☐ Yes ☒ No

**Estimated Time to Complete:** 11 minutes **Actual Time Used:** \_\_\_\_\_ minutes

**References:**

1. OP-AA-108-104, Technical Specification Compliance, Rev. 0



**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. Reactor power is approximately 88%.
2. IMD will be performing DIS 0500-05, Unit 2 Scram Discharge Volume Sensor Calibration and Functional Tests, for Unit 2 scram discharge volume level switch LS 2-0302-82A. No other testing is in progress
3. You are the Unit 2 NSO.
4. You have been provided Attachment 1, Short Duration Time Clock, which has been partially filled in.

**INITIATING CUE**

IMD will perform DIS 0500-05, the Unit 2 Supervisor has directed you to log and monitor the performance of this surveillance.

Inform the Unit 2 Supervisor when the testing for LS 2-0302-82A is complete.





**Nuclear Generation Group**

**Job Performance Measure**

Locate Valve and Determine Requirements for Entering RCA

JPM Number: A.3-RO

Revision Number: 00


Date: 03/17/02

Developed By:

  
Facility Author

3/17/02  
Date

Approved By:

  
Facility Representative

3-18-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,** This JPM was created for use during the ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Copy of RP-AA-460.
2. Copy of Survey Map for Unit 2 Reactor Building, El. 570' General Area.
3. Copy of Survey Map for Unit 2 Reactor Building, El. 560' RWCU Pipeway.
4. Copy of Unit 2 RWCU System Maintenance. RWP# 10000967.
5. Copy of general operations RWP# 10000910.

**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. Following maintenance, it was reported that valve 2-0205-22 appeared to have packing leakage.
2. The Shift Manager is unable to obtain any more information regarding the packing leakage.
3. The logs do NOT indicate the location of the valve.
4. You are the Unit 2 Assistant NSO.

**INITIATING CUE**

The Shift Manager has informed you that you and the Shift Manager will be going to investigate the leakage.

He directs you to:

1. Find the location of valve 2-0205-22.
2. Determine the protective clothing requirements enter the area of valve 2-0205-22.
3. Determine what type of briefing is required to enter the area of valve 2-0205-22.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

**Job Performance Measure (JPM)**

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
	<div style="border: 1px solid black; padding: 5px;"> <p>Note: Valve location can be determined from a number of sources, such as PASSPORT or DOP 0220-M1/E1 page 2 of 4.</p> </div>				
*1.	Determine location of valve 2-0205-22.	Examinee determines that valve 2-0205-22 is in the RWCU Demin Pipeway.	___	___	___
	<div style="border: 1px solid black; padding: 5px;"> <p>Note: WHEN the examinee asks RP for the survey map of the area, THEN provide the map attached to this JPM.</p> <p>WHEN the examinee asks RP for the RWPs for the job THEN provide RWPs #10000910 and #10000967 attached to this JPM.</p> <p>If the student asks for the procedure for Control of High and Very High Radiation Areas, RP-AA-460, provide them with a copy.</p> </div>				
2.	Proceeds to RP Office and reviews survey data for the applicable area and determines the RCA type.	Examinee obtains latest survey map and determines that U2 RWCU Demin Pipeway is a Locked High Rad Area (LHRA) <b>and</b> a Contamination Area.	___	___	___

**Nuclear Generation Group**

**Job Performance Measure**

Estimating the Post Accident Noble Gas Activity

JPM Number: A.4-RO

Revision Number: 00


Date: 03/16/02

Developed By:

  
Facility Author

3/16/02  
Date

Approved By:

  
Facility Representative

3-28-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,** This JPM was taken directly from the Dresden facility testing materials bank for use during the ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Current copy of DOP 1700-10, Estimating the Post Accident Noble Gas Activity Release With/Without the Eberline SPING-4 Monitor Available.



**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. A transient has occurred, resulting in entry into DEOP 300-2.
2. The Eberline SPING-4 System is operable.
3. Annunciator 923-7 A-3, U2/3 Chimney Noble Gas HI-HI is in alarm.
4. Core damage is NOT suspected.
5. U2/3 Main Chimney Sping Recorder 2/3 1740-202 is reading approximately 12,000 on the low range.
6. You are the Unit 2 Assistant NSO.

**INITIATING CUE**

You have been directed by the Unit 2 Supervisor to calculate the 2/3 Chimney release rate per DOP 1700-10, for DEOP and GSEP classification of the release.

Inform the Unit 2 Supervisor when you have determined the 2/3 Chimney release rate.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.  
 .....:

**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.  
 .....

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
Note: Provide examinee with a clean copy of DOP 1700-10, Rev. 07.					
Note: The SPING is currently not working in the simulator. The portion of this JPM involving the SPING will be simulated. A CUE will be provided at the appropriate step to inform the examinee.					
1.	GO TO Step G.4.	Examinee proceeds to procedure step G.4.	_____	_____	_____
2.	Complete the following on Data Sheet 1 (Section):				
	a. Date and time. (1.a)	Examinee enters current data and time on Data Sheet 1, step 1.a.	_____	_____	_____
	b. Reason for calculation. (1.b)	Examinee checks "DEOP" and "EPIP" on Data Sheet 1, step 1.b.	_____	_____	_____
	c. SPING Monitor used. (1.c)	Examinee checks "2/3 Chimney" on Data Sheet 1, step 1.c.	_____	_____	_____
	d. SPING-4 detector channel used. (1.d)	Examinee checks "Low Range" on Data Sheet 1, step 1.d.	_____	_____	_____
3.	Verify the SPING-4 is receiving proper flow data as follows:				
	a. Obtain the desired flow rate value from the process computer.	Examinee obtains 2/3 chimney flow rate using OD-50, Option 1, Point F-281.	_____	_____	_____
CUE: The flow rate is 341 kefm.					

Job Performance Measure (JPM)

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
	b. Multiply (flow rate value) by 1000 to obtain cfm.	Examinee multiplies 341 kefm by 1000 to obtain 341,000 cfm.	—	—	—
	* c. Record (data from previous 2 steps) on Data Sheet 1, 2.a.	Examinee records "341" for computer flow rate and "341,000" for cfm in Data Sheet 1, step 2.a.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: The SPING is currently not working in the simulator. This portion of the JPM will be simulated. Describe in detail any action you would be performing.</p> </div>					
4.	Obtain the U-2/3 Chimney flow rate (cfm) from the CT and record as follows:				
	a. Verify the COMMAND ENABLE key is in the ENABLE position.	Examinee verifies COMMAND ENABLE key in the ENABLE position.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: The COMMAND ENABLE key is in the ENABLE position</p> </div>					
	b. Press: [DATA] [field unit number] [-] [10] [ENTER] [PRINT] [FILE] [ENTER].	Examinee simulates pressing [DATA] [5] [-] [10] [ENTER] [PRINT] [FILE] [ENTER] on the control terminal.			
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: The printer prints out the following.</p> <p>Hand the examinee Sheet = 1</p> </div>					
	* c. Record the value from the printer on Data Sheet 1, 2.b.	Examinee records "340,000" on Data Sheet 1, step 2.b.			

**Job Performance Measure (JPM)**

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
5.	Calculate the difference between the computer point flowrate and CT flowrate on lines 2c and 2d of Data Sheet 1.				
	a. Subtract the smaller from the larger: (Step 2.c)	Examinee subtracts "340,000" from "341,000" and obtains "1,000" on Data Sheet 1, step 2.c.	—	—	—
*	b. Divide the result of Step 2.c above by the larger of the two numbers AND multiply by 100:	Examinee divides "1,000" by "341,000" and multiplies by 100 to obtain .29%.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>Note: Since the flow rates are within 10%, the examinee should then proceed with the release rate calculation step G.6.</p> </div>					
6.	To obtain the Release Rate from the Eberline Control Terminal:				
	a. Press: [Hist 10 Min] [field unit number] [-] [channel number] [ENTER]	Examinee presses [Hist 10 Min] [5] [-] [5] [ENTER].	—	—	—
	b. Press the [-] key once, the release rate prompt will appear on the LCD.	Examinee presses [-] key once to display the release rate prompt.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: The release rate prompt appears</p> </div>					
	c. Press [ENTER].	Examinee presses [ENTER].	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: (If asked) The LCD does NOT request exhaust flow</p> </div>					

**Job Performance Measure (JPM)**

<u><b>STEP</b></u>	<u><b>ELEMENT</b></u>	<u><b>STANDARD</b></u>	<u><b>SAT</b></u>	<u><b>UNSAT</b></u>	<u><b>Comment Number</b></u>
	d. Press: [PRINT] [FILE] [ENTER]	Examinee presses [PRINT] [FILE] [ENTER]	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: The printer prints out the following. Hand the examinee Sheet # 2</p> </div>					
	* e. Record the latest value on Data Sheet 1, 3.a.	Examinee records "1.29 E6" on Data Sheet 1, step 3.a			
	* f. Divide value in 3.a. by 60 and record on Data Sheet 1, 3.b.	Examinee divides "1.29 E6" by 60 and records "2.15 E4" on Data Sheet 1, step 3.b. Answer must be less than 8.5 E5 and greater than 1.7 E5	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>Note: Answer acceptance criteria is based on providing the correct number to the Unit Supervisor to ensure the correct GSEP classification is made.</p> </div>					
	7. Signs and dates Data Sheet 1.	Examinee signs and dates Data Sheet 1 on the "Calculated by" line.			
	8. Report the 2/3 Chimney release rate to the Unit 2 Supervisor.	Examinee reports 2/3 Chimney release rate (results of step 6.e) to Unit 2 Supervisor.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: Report acknowledged.</p> <p>The JPM is considered complete at this time.</p> </div>					

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☒ SRO ☐JPM Title: Estimating the Post Accident Noble Gas ActivityJPM Number: A.4-RO Revision Number: 00

Task Number and Title: 272L008, Estimate post accident noble gas activity release rate with the Eberline SPING 4 monitor available.

K/A Number and Importance: 2.4.3; RO IMPORTANCE - 3.5**Suggested Testing Environment:** Simulator**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room**Testing Method:** ☐ Simulate  
☐ Perform **Alternate Path:** ☐ Yes ☒ No**Time Critical:** ☐ Yes ☒ No**Estimated Time to Complete:** 20 minutes **Actual Time Used:** \_\_\_\_\_ minutes**References:**

1. DOP 1700-10, Estimating the Post Accident Noble Gas Activity Release With/Without the Eberline SPING-4 Monitor Available, Rev. 07



**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. A transient has occurred, resulting in entry into DEOP 300-2.
2. The Eberline SPING-4 System is operable.
3. Annunciator 923-7 A-3, U2/3 Chimney Noble Gas HI-HI is in alarm.
4. Core damage is NOT suspected.
5. U2/3 Main Chimney Sping Recorder 2/3 1740-202 is reading approximately 12,000 on the low range.
6. You are the Unit 2 Assistant NSO.

**INITIATING CUE**

You have been directed by the Unit 2 Supervisor to calculate the 2/3 Chimney release rate per DOP 1700-10, for DEOP and GSEP classification of the release.

Inform the Unit 2 Supervisor when you have determined the 2/3 Chimney release rate.



3.4 135 cfm.

**Sheet #1**

1.29 E6  $\mu$ Ci/min

**Sheet #2**

# KEY

 UNIT 2(3)  
 DOP 1700-10  
 REVISION 07

## DATA SHEET 1

## GASEOUS RELEASE RATE CALCULATION SHEET

1. a. Date: Today Time: Now
- b. Reason for Calculation:  
 Routine ☒ (✓) DEOP: ☒ (✓) EPIP: ☒ (✓)
- c. SPING Monitor used:  
 2/3 Chimney ☒ (✓) 1.00E+10 cc/min.  
 U-1 Chimney ☒ (✓) 1.76E+09 cc/min.  
 2/3 RBX Vent ☒ (✓) 6.23E+09 cc/min.
- d. Detector:  
 Low Range: ☒ (✓) Mid Range: ☐ (✓) High Range: ☐ (✓)

## CONTROL TERMINAL OPERABLE:

2. Flow Comparison: (U-2/3 chimney and Reactor Building Vent only)
  - a. Computer Flow Rate (in KCFM) 341 x 1000 = 341,000 cfm  
 (Chimney Point F281 (F381), RBX Vent F293 (F393))
  - b. Control Terminal Flow Rate: 340,000 cfm
  - c. Subtract the smaller from the larger:  
341,000 - 340,000 = 1,000 cfm
  - d. Divide the result of Step 2.c above by the larger of the two numbers AND multiply by 100:  
1000 / 341,000 x 100 = .29 %
  - e. IF the result of Step 2.d is greater than 10%, THEN inform Health Physics Supervision and continue at Step 4.

## 3. Release Rate Determination:

- a. Record the latest printed value of release rate: 1.29E6  $\mu$ Ci/min
- b. Divide the value in Step 3.a above by 60:  
1.29E6  $\mu$ Ci/min / 60 = 21,500  $\mu$ Ci/sec

IF core damage has occurred, THEN GO TO Step 5.

Must be between  
 8.5E5 and  
 1.7E5

**Nuclear Generation Group**

**Job Performance Measure**

Review Faulted Jet Pump Operability Surveillance

JPM Number: A.1.a-SRO

Revision Number: 00


Date: 03/17/02

Developed By: \_\_\_\_\_

  
Facility Author

3/17/02  
Date

Approved By: \_\_\_\_\_

  
Facility Representative

3-18-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM is new and was developed for the Dresden ILT Class  
01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Clean copy of DOS 0202-02
2. Copy of DOS 0202-02, Data Sheet 1, filled in for Monday "Calculations performed by" signed.
3. OPERATOR AID #18, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $\geq 80\%$
4. OPERATOR AID #19, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $\geq 60\%$  and  $< 80\%$
5. OPERATOR AID #20, Jet Pump Baseline Data (Two Pump Operation) Pump Speeds  $< 60\%$
6. Calculator

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. A unit startup is in progress for Unit 2.
2. Reactor power is about 52% and has been steady for about 2 hours.
3. Recirculation pump speeds are 55% for pump 2A and 56% for pump 2B.
4. The POWERPLEX computer is NOT operable.
5. You are the WEC Supervisor.
6. The Unit 2 NSO has just completed Data Sheet 1 of DOS 0202-02, Jet Pump Operability and Degradation.

**INITIATING CUE**

You have been directed by the Shift Manager to independently verify the individual jet pump flow surveillance.

Inform the Unit 2 Supervisor when the task is completed.

**Job Performance Measure (JPM)**

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

Step	Time	Comments
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		
44		
45		
46		
47		
48		
49		
50		
51		
52		
53		
54		
55		
56		
57		
58		
59		
60		
61		
62		
63		
64		
65		
66		
67		
68		
69		
70		
71		
72		
73		
74		
75		
76		
77		
78		
79		
80		
81		
82		
83		
84		
85		
86		
87		
88		
89		
90		
91		
92		
93		
94		
95		
96		
97		
98		
99		
100		



**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b><u>SAT</u></b>	<b><u>UNSAT</u></b>	<b><u>Comment Number</u></b>
<div>Note: Provide examinee with a clean copy of DOS 0202-02 and a marked up copy of Data Sheet 1 from DOS 0202-02.</div>					
*1.	Verify loop A and loop B RECIRC pump speeds (percent) recorded under Speed A or Speed B.	Examinee verifies that 55% was entered under SA and 56% was entered under SB on Data Sheet 1.	—	—	—
*2.	Add the readings for the jet pumps in each loop and divide by the number of operable jet pump indications for the loop to obtain loop average jet pump AND verify this was recorded as loop average flow value.	Examinee verifies that 4.48 was recorded under "LOOP A AVG" and that 4.48 was recorded under "LOOP B AVG."	—	—	—
*3.	Normalize jet pump flows by dividing each individual jet pump flow by the loop average AND verify these normalized values were recorded Line 2.	Examinee divides each individual jet pump flow by the loop average and verifies agreement with all values recorded on Line 2 EXCEPT for jet pumps #5 and #19.	—	—	—
		Examinee determines normalized value of 1.09 for jet pumps #5 and #19.	—	—	—
<div>CUE: IF examinee reports errors, then acknowledge report and direct examinee to continue with the verification. -</div>					
<div>Note: Provide examinee with copies of Operator Aids 18, 19, and 20.</div>					

**Job Performance Measure (JPM)**

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b><u>SAT</u></b>	<b><u>UNSAT</u></b>	<b><u>Comment Number</u></b>
4.	Compare the normalized jet pump readings to the appropriate characteristic graph.	Examinee compares normalized jet pump readings to characteristic graph for "Unit 2 Jet Pump Baseline Data, RECIRC Pump Speeds less than 60 percent." [Operator Aid #20]	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>Note: Line 3 has been marked YES for all jet pumps but the jet pumps #5 and #19 DO NOT meet the acceptance criteria.</p> </div>					
*5.	Verify that it was recorded on Line 3 whether each jet pump falls within the allowable range.	Examinee verifies agreement with YES on Line 3 for all jet pumps EXCEPT #5 and #19.	—	—	—
*6.	IF any jet pump is outside the allowable range, THEN:	Examinee notifies Unit 2 Supervisor and QNE that jet pumps #5 and #19 failed the surveillance.	—	—	—
	1. Notify Unit Supervisor				
	2. Notify QNE to evaluate data.				
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: Acknowledge reports.</p> <p>The JPM is considered complete at this time.</p> </div>					

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☐ SRO ☒JPM Title: Review Faulted Jet Pump Operability SurveillanceJPM Number: A.1.a-SRO Revision Number: 00

Task Number and Title: 202L014, Perform a jet pump operability and degradation surveillance when POWERPLEX computer is NOT available.

K/A Number and Importance: 2.1.25; SRO IMPORTANCE - 3.1**Suggested Testing Environment:** Simulator**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room**Testing Method:** ☐ Simulate  
☒ Perform **Alternate Path:** ☐ Yes ☒ No**Time Critical:** ☐ Yes ☒ No**Estimated Time to Complete:** 22 minutes **Actual Time Used:** \_\_\_\_\_ minutes**References:**

1. DOS 0202-02, Jet Pump Operability and Degradation, Rev. 23
2. OPERATOR AID #20, Rev. 2



**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

**CONDITIONS**

1. A unit startup is in progress for Unit 2.
2. Reactor power is about 52% and has been steady for about 2 hours.
3. Recirculation pump speeds are 55% for pump 2A and 56% for pump 2B.
4. The POWERPLEX computer is NOT operable.
5. You are the WEC Supervisor.
6. The Unit 2 NSO has just completed Data Sheet 1 of DOS 0202-02, Jet Pump Operability and Degradation.

**INITIATING CUE**

You have been directed by the Shift Manager to independently verify the individual jet pump flow surveillance.

Inform the Unit 2 Supervisor when the task is completed.

**Nuclear Generation Group****Job Performance Measure**

Evaluate Overtime of Operators and Complete Required Documentation for  
Exceeding Allowable Limits

JPM Number: A.1.b-SRO

Revision Number: 00


Date: 03/17/02

Developed By:

  
Facility Author

3/17/02  
Date

Approved By:

  
Facility Representative

3-28-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM was taken directly from the Dresden facility testing materials bank for use during the ILT Class 01-1 NRC Exam.

•

**Job Performance Measure (JPM)**

**MATERIALS**

- 1. Copy of LS-AA-119.
- 2. Copy of LS-AA-119, Attachment 1, Overtime Guideline Deviation Authorization.

11/1/10	11/1/10	11/1/10	11/1/10
11/1/10	11/1/10	11/1/10	11/1/10
11/1/10	11/1/10	11/1/10	11/1/10
11/1/10	11/1/10	11/1/10	11/1/10
11/1/10	11/1/10	11/1/10	11/1/10
11/1/10	11/1/10	11/1/10	11/1/10



**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. Unit 2 is at near rated conditions.
2. You are the Unit 2 Shift Supervisor.
3. Personnel have been working extensive overtime to cover absences due to a severe flu epidemic.
4. It is 1530 on Saturday and several NSOs have called in sick for Sunday dayshift.
5. The Duty Shift Manager is in the Main Control Room.

**INITIATING CUE**

Two (2) NSOs must be called in to work eight (8) for Sunday dayshift to provide for minimum staffing.

The Shift Manager has directed you to determine which operators should be contacted, notify the WEC to contact the operators, and to obtain approval for any overtime guideline deviations, if required per LS-AA-119 "Overtime Controls"

Notify the Shift Manager when coverage has been arranged for Sunday dayshift.

The following work hour data has been obtained from Passport:

<b>List of NSOs Available for Sunday Dayshift</b>						
<ol style="list-style-type: none"> <li>1. NSOs are listed in order of overtime hours, from lowest to highest.</li> <li>2. All hours worked started at 0700.</li> <li>3. All hours worked were as panel operators, unless indicated by * for training.</li> <li>4. Hours listed are actual hours worked with turnover time already subtracted.</li> </ol>						
Operator	MON	TUE	WED	THU	FRI	SAT
Joe	8*	10	12	12	12	12
Bill	8	12	12	12	12	12
Dave	8	12	12	12	8	8
John	8	10	12	12	12	8
Bob	8*	12	12	12	12	16

**Job Performance Measure (JPM)**

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

Step	Time	Comments
1. Acknowledge Initiating Cue		
2. Review Situation		
3. Notify Control Room		
4. Perform Procedure		
5. Verify Completion		
6. Report to Control Room		
7. Standby for Next Step		

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b>SAT</b>	<b>UNSAT</b>	<b>Comment Number</b>
	Note: Give examinee a copy of LS-AA-119, "Overtime Controls"				
*1.	Ask individual to work with lowest number of overtime hours who will not exceed the overtime guidelines.	Examinee notifies WEC to contact Dave for overtime.	—	—	—
	CUE: Acknowledges that Dave should be contacted for overtime.				
	CUE: Report that Dave has volunteered for Sunday dayshift overtime.				
*2.	Ask next individual to work with lowest number of overtime hours who will not exceed the overtime guidelines.	Examinee notifies WEC to contact John for overtime.	—	—	—
	CUE: Acknowledges that John should be contacted for overtime.				
	CUE: Report that John is out of state and his return flight is tomorrow afternoon .				
*3.	Ask individual with the lowest number of overtime hours to work.	Examinee notifies WEC to contact Joe for overtime.	—	—	—
	CUE: Acknowledges that Joe should be contacted for overtime.				
	CUE: Report that Joe has volunteered for Sunday dayshift overtime.				

**Job Performance Measure (JPM)**

<b><u>STEP</u></b>	<b><u>ELEMENT</u></b>	<b><u>STANDARD</u></b>	<b><u>SAT</u></b>	<b><u>UNSAT</u></b>	<b><u>Comment Number</u></b>
*4.	Fill out Overtime Guideline Deviation Authorization form for individual exceeding GL 82-12 guidelines.	<p>Examinee fills out Overtime Guideline Deviation Authorization form for Joe:</p> <ul style="list-style-type: none"> <li>• *Name: Joe</li> <li>• Department: Operations</li> <li>• *GL 82-12 Guideline Exceeded: D</li> <li>• Time and Date Overtime Limit will be Exceeded: 1300 / SUN</li> <li>• *Description of safety-related work: Panel operation</li> <li>• Justification: flu epidemic</li> </ul>	—	—	—
5.	Obtain review of Overtime Guideline Deviation Authorization form.	Examinee obtains review from Shift Manager.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: When asked, state that Shift Manager has signed Overtime Guideline Deviation Authorization form for review.</p> </div>					
6.	Obtain approval of Overtime Guideline Deviation Authorization form.	Examinee obtains approval from the Duty Station Manager.	—	—	—
<div style="border: 1px solid black; padding: 5px;"> <p>CUE: When asked, state that Duty Station Manager has signed Overtime Guideline Deviation Authorization form for approval.</p> </div>					

Job Performance Measure (JPM)

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
7.	Notify Shift Manager that arrangements have been completed for Sunday dayshift overtime.	Examinee notifies Shift Manager that operators have volunteered and approval obtained from the Duty Station Manager.	—	—	—
<div>CUE: Acknowledge report.</div> <div>CUE: It is now 0730 on Sunday morning. Joe and Dave are working dayshift as panel operators. Both operators appear to be alert.</div>					
*8.	Complete the information in columns 6 – 10 of the Overtime Guideline Deviation Authorization form.	<p>Examinee completes columns 6 – 10 of the Overtime Guideline Deviation Authorization form:</p> <ul style="list-style-type: none"> <li>• Initials</li> <li>• Time: 0730</li> <li>• Date: SUN</li> <li>• Checks S for satisfactory condition of individual.</li> </ul>	—	—	—
<div>CUE: The JPM is considered complete at this time.</div>					

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☐ SRO ☒

JPM Title: Evaluate Overtime of Operators and Complete Required Documentation for Exceeding Allowable Limits

JPM Number: A.1.b-SRO Revision Number: 00

Task Number and Title: 299L057, Perform administrative duties to ensure overtime restrictions are not exceeded.

K/A Number and Importance: 2.1.5; SRO IMPORTANCE – 3.4

**Suggested Testing Environment:** Simulator

**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room

**Testing Method:** ☒ Simulate  
☐ Perform **Alternate Path:** ☐ Yes ☒ No

**Time Critical:** ☐ Yes ☒ No

**Estimated Time to Complete:** 17 minutes **Actual Time Used:** \_\_\_\_\_ minutes

**References:**

1. LS-AA-119, Overtime Controls, Rev. 0



**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. Unit 2 is at near rated conditions.
2. You are the Unit 2 Shift Supervisor.
3. Personnel have been working extensive overtime to cover absences due to a severe flu epidemic.
4. It is 1530 on Saturday and several NSOs have called in sick for Sunday dayshift.
5. The Duty Shift Manager is in the Main Control Room.

**INITIATING CUE**

Two (2) NSOs must be called in to work eight (8) for Sunday dayshift to provide for minimum staffing.

The Shift Manager has directed you to determine which operators should be contacted, notify the WEC to contact the operators, and to obtain approval for any overtime guideline deviations, if required.

Notify the Shift Manager when coverage has been arranged for Sunday dayshift.

The following work hour data has been obtained from Passport:

<b>List of NSOs Available for Sunday Dayshift</b>						
<ol style="list-style-type: none"> <li>1. NSOs are listed in order of overtime hours, from lowest to highest.</li> <li>2. All hours worked started at 0700.</li> <li>3. All hours worked were as panel operators, unless indicated by * for training.</li> <li>4. Hours listed are actual hours worked with turnover time already subtracted.</li> </ol>						
Operator	MON	TUE	WED	THU	FRI	SAT
Joe	8*	10	12	12	12	12
Bill	8	12	12	12	12	12
Dave	8	12	12	12	8	8
John	8	10	12	12	12	8
Bob	8*	12	12	12	12	16



**Job Performance Measure (JPM)**Comment  
↓**INITIAL CONDITIONS**

1. Unit 2 is at near rated conditions.
2. You are the Unit 2 Shift Supervisor.
3. Personnel have been working extensive overtime to cover absences due to a severe flu epidemic.
4. It is 1530 on Saturday and several NSOs have called in sick for Sunday dayshift. *May 25*
5. The Duty Shift Manager is in the Main Control Room.

**INITIATING CUE**

Two (2) NSOs must be called in to work eight (8) for Sunday dayshift to provide for minimum staffing.

The Shift Manager has directed you to determine which operators should be contacted, notify the WEC to contact the operators, and to obtain approval for any overtime guideline deviations, if required per LS-AA-119 "Overtime Controls"

Notify the Shift Manager when coverage has been arranged for Sunday dayshift.

The following work hour data has been obtained from Passport:

<b>List of NSOs Available for Sunday Dayshift</b>						
<ol style="list-style-type: none"> <li>1. NSOs are listed in order of overtime hours, from lowest to highest.</li> <li>2. All hours worked started at 0700.</li> <li>3. All hours worked were as panel operators, unless indicated by * for training.</li> <li>4. Hours listed are actual hours worked with turnover time already subtracted.</li> </ol>						
Operator	MON	TUE	WED	THU	FRI	SAT
Joe	8*	10	12	12	12	12
Bill	8	12	12	12	12	12
Dave	8	12	12	12	8	8
John	8	10	12	12	12	8
Bob	8*	12	12	12	12	<del>12</del>

12

Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

COMMENT



<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
	Note: Give examinee a copy of LS-AA-119, "Overtime Controls"				
*1.	Ask individual to work with lowest number of overtime hours who will not exceed the overtime guidelines.	Examinee notifies WEC to contact Dave for overtime.			
	CUE: Acknowledges that Dave should be contacted for overtime.				
	CUE: Report that Dave has volunteered for Sunday dayshift overtime.				
*2.	Ask next individual to work with lowest number of overtime hours who will not exceed the overtime guidelines.	Examinee notifies WEC to contact John for overtime.			
	CUE: Acknowledges that John should be contacted for overtime.				
	CUE: Report that John is out of state and his return flight is tomorrow afternoon.				
*3.	Ask individual with the lowest number of overtime hours to work.	Examinee notifies WEC to contact Joe for overtime.			
	CUE: Acknowledges that Joe should be contacted for overtime.				
	CUE: Report that Joe has volunteered for Sunday dayshift overtime.				

NOTE: IF asked by examinee, this is the asking order

Job Performance Measure (JPM)

DELETE Step 7/8

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment</u> <u>Number</u>
7.	Notify Shift Manager that arrangements have been completed for Sunday dayshift overtime.	Examinee notifies Shift Manager that operators have volunteered and approval obtained from the Duty Station Manager.	—	—	—

CUE: Acknowledge report.

CUE: It is now 0730 on Sunday morning. Joe and Dave are working dayshift as panel operators. Both operators appear to be alert.

- \*8. Complete the information in columns 6 – 10 of the Overtime Guideline Deviation Authorization form.

Examinee completes columns 6 – 10 of the Overtime Guideline Deviation Authorization form:

- Initials
- Time: 0730
- Date: SUN
- Checks S for satisfactory condition of individual.

CUE: The JPM is considered complete at this time.

JPM Stop Time: \_\_\_\_\_

**Nuclear Generation Group**

**Job Performance Measure**

Review and Approve a Temporary Modification

JPM Number: A.2

Revision Number: 00

Date: 03/20/02

Developed By:



Facility Author

3/20/02

Date

Approved By:



Facility Representative

3-20-02

Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,** This JPM is new and was developed for the Dresden ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Marked up Temporary Modification package.
2. Copy of CC-AA-112.
3. Copy of CC-MW-112-1001.

**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. Unit 3 is operating at near rated conditions.
2. You are the Unit 3 Supervisor.
3. PASSPORT is unavailable.
4. Temporary Modification 9900711 is ready for installation.

**INITIATING CUE**

The Shift Manager has directed you to review Temporary Modification 9900711 and authorize it for installation.

Inform the Shift Manager after you have authorized installation.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

**Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

**Job Performance Measure (JPM)**

JPM Start Time: \_\_\_\_\_

<u><b>STEP</b></u>	<u><b>ELEMENT</b></u>	<u><b>STANDARD</b></u>	<u><b>SAT</b></u>	<u><b>UNSAT</b></u>	<u><b>Comment Number</b></u>
	<p>Note: The examinee should review the Temporary Modification and then authorize it for installation by checking items 1 - 4 under OPERATIONS APPROVAL for PERFORMING TCCP INSTALLATION on Attachment 3 of CC-MW-112-1001.</p> <p>Provide examinee with TCCP package.</p> <p>If examinee requests copies of CC-AA-112 and/or CC-MW-112-1001 provide them with copies.</p>				
*1.	Verify that Administrative Controls are in place.	Examinee checks box labeled "Yes" since Administrative Controls are listed on Attachment 4 of CC-MW-112-1001.	_____	_____	_____
*2.	Verify whether there are any electrical circuits energized during TCCP installation.	Examinee checks box labeled "YES" since 125 vdc circuit will be energized during TCCP installation per Attachment 4.	_____	_____	_____
*3.	Verify that TCC Tag List has been completed.	Examinee checks box labeled "YES" after verifying TCC Tag List (Attachment 8) has been properly filled out.	_____	_____	_____
*4.	Verify that Temporary Change Tracking Log has been completed.	Examinee checks box labeled "YES" after filling out Block 6 of Temporary Change Tracking Log sheet. (Attachment 5)	_____	_____	_____



**Job Performance Measure (JPM)**

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
*5.	Print name/Signs and dates authorizing TCCP installation	Examinee prints and signs name and fills in date authorizing TCCP installation.	—	—	—

Note: The critical portion of step 5 is that their name and the date is recorded on the form. It is not critical that they print **and** sign their name.

6.	Notify Shift Manager that Temporary Modification 9900711 has been authorized for installation.	Notifies Shift Manager that Temporary Modification 9900711 has been authorized for installation.	—	—	—
----	--	--	---	---	---

CUE: Acknowledge report.

The JPM is considered complete at this time.

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☐ SRO ☒JPM Title: Review and Approve a Temporary ModificationJPM Number: A.2 Revision Number: 00

Task Number and Title: 299L127, Perform Unit Supervisor duties for Temporary Modification.

K/A Number and Importance: 2.2.11; SRO IMPORTANCE 3.4**Suggested Testing Environment:** Simulator**Actual Testing Environment:** ☐ Simulator ☐ Plant  
☐ Control Room**Testing Method:** ☐ Simulate  
☒ Perform **Alternate Path:** ☐ Yes ☒ No**Time Critical:** ☐ Yes ☒ No**Estimated Time to Complete:** 13 minutes **Actual Time Used:** \_\_\_\_\_ minutes**References:**

1. CC-AA-112, Rev. 5
2. CC-MW-112-1001, Rev. 2

[illegible]

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

COMMENT

STEP   ELEMENTSTANDARD

SAT

UNSAT

Comment  
Number

Note: The examinee should review the Temporary Modification and then authorize it for installation by checking items 1 - 4 under OPERATIONS APPROVAL for PERFORMING TCCP INSTALLATION on Attachment 3 of CC-MW-112-1001.

Provide examinee with TCCP package.

If examinee requests copies of CC-AA-112 and/or CC-MW-112-1001 provide them with copies.

1. Verify that Administrative Controls are in place.

*Yes or No*  
Examinee checks box labeled ~~"Yes"~~ since Administrative Controls are listed on Attachment 4 of CC-MW-112-1001. *1/2*

- \*2. Verify whether there are any electrical circuits energized during TCCP installation.

Examinee checks box labeled ~~"YES"~~ since 125 vdc circuit will be energized during TCCP installation per Attachment 4. *20*

- \*3. Verify that TCC Tag List has been completed.

Examinee checks box labeled "YES" after verifying TCC Tag List (Attachment 8) has been properly filled out.

- \*4. Verify that Temporary Change Tracking Log has been completed.

Examinee checks box labeled "YES" after filling out Block 6 of Temporary Change Tracking Log sheet. (Attachment 5)

**Nuclear Generation Group**

**Job Performance Measure**

Review Liquid Radwaste Discharge Permit


JPM Number: A.3-SRO

Revision Number: 00

Date: 03/17/02

Developed By:   
Facility Author

3/17/02  
Date

Approved By:   
Facility Representative

3-18-02  
Date

**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,** This JPM is new and was developed for the Dresden ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Copy of DOP 2000-110, Waste Surge Tank Radwaste Discharge to River with the Off Stream Liquid Effluent Monitor Operable
2. Marked up copy of Waste Surge Tank Radioactive Waste Discharge to River Card

**Job Performance Measure (JPM)****INITIAL CONDITIONS**

1. Radwaste is preparing to discharge the waste surge tank to the river.
2. The liquid effluent discharge monitor is operable.
3. You are the Unit 2 Supervisor.

**INITIATING CUE**

You have been directed by the Shift Manager to review the Waste Surge Tank Radioactive Waste Discharge to River Card for a discharge of the waste surge tank.

Data from the Chemistry River Discharge Card is as follows:

Total Gamma MPC Fraction	0.671
Total MPC/ECL Fraction	7.90
Total Isotopic Activity	6.04E+3

The River Discharge Monitor calibration constant is 0.455.

Inform the Shift Manager when your review is complete.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....



**Job Performance Measure (JPM)****Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
	<div style="border: 1px solid black; padding: 5px;">           Note: Provide examinee with the marked up Waste Surge Tank Radioactive Waste Discharge to River Card and a copy of DOP 2000-110.         </div>				
*1.	Divide dilution flow by Total MPC/ECL fraction multiplied by ten to obtain Authorized Discharge Rate.	Examinee divides dilution flow by Total MPC/ECL fraction multiplied by ten and obtains Authorized Discharge Rate of 506 gpm, NOT 560 gpm as listed on card.	—	—	—
	<div style="border: 1px solid black; padding: 5px;">           Note: The examinee may state that they would stop at this point. Direct them to check remainder of the Card.         </div>				
*2.	Calculate the expected 09-01 CPM by multiplying the Total Isotopic Activity by the Calibration Constant.	Examinee verifies expected 09-01 CPM is correct by multiplying the Total Isotopic Activity by the Calibration Constant.	—	—	—
*3.	Calculate the Alarm Setpoint by multiplying the expected 09-01 CPM by calculated Dilution Factor, divided by the total Gamma MPC fraction.	Examinee verifies Alarm Setpoint is correct by multiplying the expected 09-01 CPM by calculated Dilution Factor, divided by the total Gamma MPC fraction.	—	—	—
*4.	IF the calculated High Alarm Setpoint is less than $5.0E+5$ , THEN calculate the Alert Setpoint by multiplying the High Alarm setpoint by 0.5. Otherwise, use $2.5E+05$ .	Examinee determines that Alert Setpoint of $3.3E+05$ is incorrect and that correct setpoint is $2.5E+05$ .	—	—	—

Job Performance Measure (JPM)

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
5.	Notify Shift Manager of errors following review.	Examinee notifies Shift Manager that the Authorized Calculated Discharge Rate should be 506 gpm, NOT 560 gpm, AND that the Alert Setpoint should be 2.5E+05, NOT 3.3E+05.	—	—	—

CUE: Acknowledge report.

The JPM is considered complete at this time.

JPM Stop Time: \_\_\_\_\_

.....

**Job Performance Measure (JPM)**

Examinee's Name: \_\_\_\_\_

Job Title: RO ☐ SRO ☒JPM Title: Review Liquid Radwaste Discharge PermitJPM Number: A.3-SRO Revision Number: 00

Task Number and Title: 268L001, Perform calculations for a radioactive waste discharge to river with the offstream liquid effluent monitor operable.

K/A Number and Importance: 2.3.6; SRO IMPORTANCE – 3.1Suggested Testing Environment: SimulatorActual Testing Environment: ☐ Simulator ☐ Plant  
☐ Control RoomTesting Method: ☐ Simulate  
☒ Perform Alternate Path: ☐ Yes ☒ NoTime Critical: ☐ Yes ☒ No

Estimated Time to Complete: 14 minutes Actual Time Used: \_\_\_\_\_ minutes

**References:**

1. DOP 2000-110, Waste Surge Tank Radwaste Discharge to River with the Off Stream Liquid Effluent Monitor Operable, Rev. 21

Were all the Critical Elements performed satisfactorily? ☐ Yes ☐ No

The examinee's performance was evaluated against the standards contained in this JPM, and has been determined to be: ☒ Satisfactory ☐ Unsatisfactory

Comments:

Evaluator's Name: \_\_\_\_\_ (Print)

Evaluator's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. Radwaste is preparing to discharge the waste surge tank to the river.
2. The liquid effluent discharge monitor is operable.
3. You are the Unit 2 Supervisor.

**INITIATING CUE**

You have been directed by the Shift Manager to review the Waste Surge Tank Radioactive Waste Discharge to River Card for a discharge of the waste surge tank.

Data from the Chemistry River Discharge Card is as follows:

Total Gamma MPC Fraction	0.671
Total MPC/ECL Fraction	7.90
Total Isotopic Activity	6.04E+3

The River Discharge Monitor calibration constant is 0.455.

Inform the Shift Manager when your review is complete.

**KEY**

## ATTACHMENT 1

## WASTE SURGE TANK RADIOACTIVE WASTE DISCHARGE TO RIVER CARD

Page 1 of 1

BATCH NUMBER \_\_\_\_\_

## ROUTING:

1. RADWASTE COORDINATOR
2. HEALTH PHYSICIST

	BY OPERATOR		INITIAL
	DATE OF DISCHARGE		
	TANK LEVEL AT START	%	
	DILUTION FLOW	GPM	
	TIME OF PUMP START		
© River Discharge Secured Early Due to: _____ _____ If required, verify Automatic Grab Sample Obtained <u>AND</u> Reset 45 Second Timer. Date: _____ Time: _____ Initial: _____ ©(W-1)	LEVEL CHECK TIME		
	TANK LEVEL	%	
	DISCHARGE RATE	GPM	
	DATE DISCH COMPLETE		
	TIME DISCH COMPLETE		
	TANK LEVEL COMPLETION		

1. Calculate Discharge Rate below: (Minimum Allowed Calculated Discharge Rate 250 gpm)

Dilution Flow / [Total MPC/ECL Fraction x 10] = Calculated Allowable Discharge Rate

$$\underline{40,000 \text{ gpm}} / [\underline{7.90} \times 10] = \underline{560} \text{ gpm}$$

Wrong  
↑ should be 506

2. This River Discharge has an Authorized Calculated Discharge Rate of 560 gpm.
3. Calculate High Alarm Setpoint below:

- a. Total Isotopic Activity x Calibration Constant = 09-01 Expected CPM

$$\underline{6.04E+3} \times \underline{0.455} = \underline{2748}$$

- b. [Expected CPM x Dilution Factor] / Total Gamma MPC Fraction = High Alarm

$$[\underline{2748} \times \underline{161}] / \underline{0.671} = \underline{6.59E+5}$$

4. IF calculated High Alarm Setpoint is greater than 5.0E+05, THEN use 5.0E+05 as the High Alarm Setpoint.
5. IF the calculated High Alarm Setpoint is less than 5.0E+05, THEN calculate the Alert Setpoint by multiplying the High Alarm Setpoint by 0.5. Otherwise, use 2.5E+05.

Alert Setpoint: \_\_\_\_\_

3.3E+05

Wrong should be  
2.5E+05

CALCULATED BY \_\_\_\_\_

VERIFIED BY \_\_\_\_\_

Shift Manager, or designee

## Nuclear Generation Group

### Job Performance Measure


Prepare a NARS Form for Transmittal Including Determination of PARS

JPM Number: A.4

Revision Number: 00


Date: 03/17/02

Developed By:

  
Facility Author

3/17/02  
Date

Approved By:

  
Facility Representative

3-18-02  
Date



**Job Performance Measure (JPM)**

**Revision Record (Summary)**

1. **Revision 00,**      This JPM is new and was developed for the Dresden ILT Class 01-1 NRC Exam.

**Job Performance Measure (JPM)**

**MATERIALS**

1. Clean copy of EP-AA-114-100, ATTACHMENT 1, Nuclear Accident Reporting System (NARS)

**Job Performance Measure (JPM)**

**INITIAL CONDITIONS**

1. The unit is shutdown.
2. Core damage HAS occurred.
3. An off-site release is in progress.
4. Drywell pressure is 18 psig and steady.
5. The SPING Mid-Range High is in alarm.
6. The "A" and "B" models are NOT available.
7. Containment radiation levels are 1,800 Rem/Hr.
8. DOP 1700-10 calculated release rate is  $2.62 \times 10^6$  uCi/Second.
9. Field teams are being assembled and are expected to provide field data in about 30 minutes.
10. Wind speed and direction are 9 miles/hour from 203 degrees.

**INITIATING CUE**

1. The Shift Manager has determined that a GSEP condition exists.
2. The Shift Manager has directed you to prepare an initial notification NARS form for his/her approval, including your determination of the GSEP classification and PARS recommendations, and notify the Shift Manager when the NARS form is ready for final approval.