

Exelon Generation Company, LLC
Quad Cities Nuclear Power Station
22710 206th Avenue North
Cordova, IL 61242-9740

www.exeloncorp.com

January 15, 2003

SVP-03-009

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Quad Cities Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-29 and DPR-30
NRC Docket Nos. 50-254 and 50-265


Subject: Monthly Operating Report for December 2002

In accordance with Technical Specifications, Section 5.6.4, "Monthly Operating Reports," we are submitting this Monthly Operating Report for Quad Cities Nuclear Power Station (QCNPS), Units 1 and 2.

Additionally, QCNPS has implemented the relaxation designated in NRC Generic Letter 97-02, "Revised Contents of the Monthly Operating Report," which allowed a reduction in information that was being submitted in the Monthly Operating Report. These changes are and will be reflected in this and future reports.

Should you have any questions concerning this letter, please contact Mr. Wally Beck at (309) 227-2800.

Respectfully,



Timothy J. Tulon
Site Vice President
Quad Cities Nuclear Power Station

Attachment

cc: Regional Administrator — NRC Region III
NRC Senior Resident Inspector — Quad Cities Nuclear Power Station

IE24

ATTACHMENT

QUAD CITIES NUCLEAR POWER STATION UNITS 1 AND 2

MONTHLY OPERATING REPORT

FOR DECEMBER 2002

EXELON NUCLEAR

AND

MIDAMERICAN ENERGY COMPANY

FACILITY OPERATING LICENSE NOS. DPR-29 AND DPR-30

NRC DOCKET NOS. 50-254 AND 50-265

TABLE OF CONTENTS

- I. Introduction
- II. Summary of Operating Experience
 - A. Unit One
 - B. Unit Two
- III. Operating Data Statistics
 - A. Operating Data Report - Quad Cities Unit One
 - B. Operating Data Report - Quad Cities Unit Two
- IV. Unit Shutdowns
 - A. Unit One Shutdowns
 - B. Unit Two Shutdowns
- V. Challenges to Safety and Relief Valves

I. INTRODUCTION

Quad Cities Nuclear Power Station is composed of two Boiling Water Reactors and Steam Turbine/Generators located in Cordova, Illinois. Unit One has a Maximum Dependable Capacity of 855 MWe Net, and Unit Two has a Maximum Dependable Capacity of 855 MWe Net. The Station is jointly owned by Exelon Nuclear and MidAmerican Energy Company. The Nuclear Steam Supply Systems are General Electric Company Boiling Water Reactors. The Architect/ Engineer was Sargent & Lundy, Incorporated, and the primary construction contractor was United Engineers & Constructors. The Mississippi River is the condenser cooling water source. The plant is subject to license numbers DPR-29 and DPR-30, issued October 1, 1971, and March 21, 1972, respectively, pursuant to Docket Numbers 50-254 and 50-265. The dates of initial Reactor criticality for Units One and Two were October 18, 1971, and April 26, 1972, respectively. Commercial generation of power began on February 18, 1973, for Unit One and March 10, 1973, for Unit Two.

II. SUMMARY OF OPERATING EXPERIENCE

A. Unit One

Unit One entered the month of December at approximately 775 MWe due to power ascension after refuel outage Q1R17. This was the first startup following implementation of Extended Power Uprate (EPU). The power ascension continued to approximately 865 MWe on December 5, when a load drop to approximately 775 MWe was taken to address a problem with the 1B reactor feedwater pump. On December 6, power was increased to approximately 900 MWe. On December 6, the 1B reactor recirculation Motor-Generator (MG) Set tripped, causing a load drop to approximately 250 MWe. On December 7, power ascension was initiated. On December 8, a load drop was taken from approximately 755 MWe to approximately 535 MWe to add capacitance to the 1B MG Set and to perform MG Set tuning. Power was then increased from approximately 535 MWe on December 8 to approximately 900 MWe on December 10. On December 10 a load drop was taken to approximately 820 MWe to address an oil leak on the 1A reactor recirculation MG Set. The unit returned to approximately full power on December 10.

B. Unit Two

Unit Two operated the month of December at full power with the exception of a planned load drop to approximately 800 MWe on December 6 for planned turbine testing.

III. OPERATING DATA STATISTICS

A. Quad Cities Unit One Operating Data Report for December 2002

DOCKET NO.: 50-254
DATE: January 15, 2003
COMPLETED BY: Tony Fuhs
TELEPHONE: (309) 227-2813

OPERATING STATUS

REPORTING PERIOD: December 2002
GROSS HOURS IN REPORTING PERIOD: 744
CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2957

1. DESIGN ELECTRICAL RATING (MWe-Net): 867
2. MAX. DEPEND. CAPACITY (MWe-Net): 855

UNIT 1 OPERATING STATUS

	PARAMETER	THIS MONTH	YTD	CUMULATIVE
3.	NUMBER OF HOURS THE REACTOR WAS CRITICAL	744.00	7637.40	209670.20
4.	HOURS GENERATOR ON-LINE	744.00	7564.00	204320.60
5.	UNIT RESERVE SHUTDOWN HOURS	0.00	677.00	1655.20
6.	NET ELECTRICAL ENERGY GENERATED (MWH)	623205.00	5709520.00	134223909.00

III. OPERATING DATA STATISTICS

B. Quad Cities Unit Two Operating Data Report for December 2002

DOCKET NO.: 50-265
DATE: January 15, 2003
COMPLETED BY: Tony Fuhs
TELEPHONE: (309) 227-2813

OPERATING STATUS

REPORTING PERIOD: December 2002
GROSS HOURS IN REPORTING PERIOD: 744
CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2957

1. DESIGN ELECTRICAL RATING (MWe-Net): 867
2. MAX. DEPEND. CAPACITY (MWe-Net): 855

UNIT 2 OPERATING STATUS

	PARAMETER	THIS MONTH	YTD	CUMULATIVE
3.	NUMBER OF HOURS THE REACTOR WAS CRITICAL	744.00	7950.80	202495.10
4.	HOURS GENERATOR ON-LINE	744.00	7852.00	197671.15
5.	UNIT RESERVE SHUTDOWN HOURS	0.00	908.00	2312.90
6.	NET ELECTRICAL ENERGY GENERATED (MWH)	659940.00	6556830.00	135415000.00

IV. UNIT SHUTDOWNS

A. Unit ONE Shutdowns for December 2002

NO.	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN (3)	CORRECTIVE ACTIONS/COMMENTS
		None				

B. Unit TWO Shutdowns for December 2002

NO. FOR YEAR	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN (3)	CORRECTIVE ACTIONS/COMMENTS
		None				

Legend

(1) TYPE	(2) REASON	(3) METHOD
F – Forced S – Scheduled	A. Equipment Failure (Explain) B. Maintenance or Test C. Refueling D. Regulatory Restriction E. Operator Training/License Examination F. Administrative G. Operational Error (Explain) H. Other (Explain)	1. Manual 2. Manual Trip/Scram 3. Automatic Trip/Scram 4. Continuation 5. Other (Explain)

V. CHALLENGES TO SAFETY AND RELIEF VALVES

December 2002

Unit 1	None
Unit 2	None