

EXAMINATION MISSED QUESTION - ANALYSIS

Question	System	Comments
20	SDC	Thought discharge valve was open not closed.
36	MT	Misread question.
37	EOP 5.2.1	Felt that no action was needed until EOP entry condition was exceeded.
42	SO	Thought auto-stop oil was lost and thus BPVs not available. Did change right answer to wrong answer.
45	RRC	Misread distractor – mixed up drive flow and jet pump flow.
56	RHR	Felt that the bodies of water were connected and would then increase in temp together.
59	RCIC	Thought keepfill tapped in at discharge to system.
74	MS	Thought the drains went to a steam line.
76	UPS	Drew system on exam correctly – then thought MC-7A was maintenance bypass source.
82	RB HVAC	Answered as if fan dP went to zero.
92	SRV	Forgot about the swell associated with SRV opening.
98	Rad Prot.	Thought smear result was definition for contaminated area.

The justification for the key change to Question 98 is:

The 63 mr/hr requires a Radiation Area posting. The 752 dpm/1000cm² does not require any special posting. A is correct.