

NRC 2003-0032

GL 97-02

April 7, 2003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

DOCKETS 50-266 AND 50-301
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2
MONTHLY OPERATING REPORTS

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of March 2003.

Sincerely,

A. J. Cayia
Site Vice President

KML

Attachment

cc: J. D. Loock, PSCW
NRC Regional Administrator
NRC Resident Inspector
NRC Project Manager

JE 24

UNIT SHUTDOWNS

DOCKET NO. 50-266
 UNIT NAME: Point Beach, Unit 1
 DATE: 4/02/2003
 COMPLETED BY: Kim M. Locke
 TELEPHONE: 755-6420

REPORTING PERIOD: March 2003
 (Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination F. Administrative
- G. Operational Error (Explain) H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

SUMMARY:

Unit 1 average daily power for the month of March was 5511.2 MWe.
 There were no Licensee Event Reports (LERs) submitted to the NRC in March:

OPERATING DATA REPORT

DOCKET NO. 50-266
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1
DATE 04/02/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD March - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET)	522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	516.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	2,160.0	233,759.4
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	2,160.0	230,218.5
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	380,351.5	1,098,774.5	106,650,083.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

UNIT SHUTDOWNS

DOCKET NO. 50-301
UNIT NAME: Point Beach, Unit 2
DATE: 4/02/2003
COMPLETED BY: Kim M. Locke
TELEPHONE: 755-6420

REPORTING PERIOD: March 2003
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	

(1) Reason

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4. Continuation
- 5. Other (Explain)

SUMMARY:

Unit 2 average daily power for the month of March was 517.4 MWe.
There were no Licensee Event Reports (LERs) submitted to the NRC in March:

OPERATING DATA REPORT

DOCKET NO. 50-301
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2
DATE 04/02/03
COMPLETED BY Kim M. Locke
TELEPHONE 920-755-6420

REPORTING PERIOD March - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET)	522.0
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET)	518.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	2,160.0	227,913.1
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	744.0	2,160.0	224,925.7
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	384,955.5	1,109,964.5	105,897,768.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997